



Application Type  
Facility Type  
Major / Minor

Renewal  
Stormwater  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. **PA0065587**  
APS ID **844120**  
Authorization ID **1504346**

**Applicant and Facility Information**

Applicant Name	<b>JFR Real Estate LLC – JFR Salvage</b>	Facility Name	<b>JFR Salvage</b>
Applicant Address	6500 Sullivan Trail	Facility Address	6500 Sullivan Trail
Applicant Contact	Wind Gap, PA 18091	Facility Contact	Wind Gap, PA 18091
Applicant Phone	<b>(610) 863-6071</b>	Facility Phone	<b>(610) 863-6071</b>
Client ID	<b>143835</b>	Site ID	<b>535417</b>
SIC Code	<b>5093</b>	Municipality	<b>Plainfield Township</b>
SIC Description	Wholesale Trade - Scrap and Waste Materials	County	<b>Northampton</b>
Date Application Received	<b>October 23, 2024</b>	EPA Waived?	<b>Yes</b>
Date Application Accepted	<b>October 29, 2024</b>	If No, Reason	<b>-</b>
Purpose of Application	Renewal of NPDES permit to discharge industrial stormwater.		

**Summary of Review**

The applicant is requesting renewal of an existing NPDES permit to discharge stormwater associated with industrial activity to an Unnamed Tributary to Little Bushkill Creek, a HQ-CWF, MF (High Quality-Cold Water Fishes, Migratory Fishes) designated receiving stream in state water plan basin 1-F (Jacoby – Bushkill Creeks). As per the Department's current existing use list, the receiving stream segment does not have an existing use classification that is more protective than its designated use. The stream is impaired for Siltation due to Urban Runoff/ Storm Sewers.

The facility is a scrap processing and recycling center of ferrous and non-ferrous metals. Scrap metal is brought to the facility, weighed at the scale, moved/segregated by type, and ultimately transported offsite to approved facilities. Most of the stormwater from the site discharges to a ditch along the northern side of the property (Outfall 001). Two sumps in the basement of the office building and runoff from the scale are directed to a ditch in the front of the building along the western side of the property (Outfall 002). The drainage area for Outfall 001 is representative of Outfall 002. Stormwater in the remaining eastern portion of the facility flows overland to the eastern side of the property with no direct point source discharge.

No non-stormwater discharges are anticipated during the 5 years following coverage or approval.

The facility is categorized by SIC code 5093 (Wholesale Trade - Scrap and Waste Materials) and falls under Appendix P monitoring requirements of the PAG-03 General Permit. The Department renewed the NPDES General Permit for Stormwater Discharges Associated with Industrial Activity (PAG-03) and it became effective on March 24, 2023. Therefore, the new monitoring requirements for Appendix P will be utilized in this permit renewal. Semi-annual monitoring and reporting for Total Nitrogen, Total Phosphorus, Total Suspended Solids (TSS), Oil & Grease, Chemical Oxygen Demand (COD), Total Aluminum, Total Copper, Total Lead, and Total Zinc are required under this permit.

Approve	Deny	Signatures	Date
X		/s/ Allison Seyfried Zukosky / Project Manager	September 4, 2025
X		/s/ Edward Dudick, P.E. / Engineer Manager	September 5, 2025

### Summary of Review

Benchmark values exist for TSS, Oil & Grease, and Chemical Oxygen Demand (COD). A benchmark value is the concentration of a pollutant in stormwater discharges that serves as a threshold for the determination of whether existing site BMPs are effective in controlling stormwater pollution. The benchmark values can be found in Part C. III. F. of the permit. A corrective action plan must be submitted to DEP if the discharge concentration for the parameters exceeds the benchmark values for two or more consecutive monitoring periods.

PPC Plan implementation and completion of an annual inspection and compliance evaluation are required under the permit.

The previous NPDES permit listed the client's name as JFR Slavage, Inc. The renewal application lists the client's name as JFR Real Estate LLC – JFR Slavage. The EIN appears to have remained the same. The name change has been incorporated into the renewal.

The existing permit expired on April 30, 2025 and the application for renewal was received on time.

A Water Management System Inspection query indicated that on October 31, 2022 a Routine/Partial Inspection was performed.

There are currently no open violations for this client that warrant withholding issuance of the permit.

### Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

