

Application Type Amendment,  
Major  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0080039 A-1  
APS ID 15345  
Authorization ID 1362935

**Applicant and Facility Information**

Applicant Name	<u>Carroll Valley Sewer &amp; Water Authority</u>	Facility Name	<u>Carroll Valley STP</u>
Applicant Address	<u>5685 Fairfield Road</u> <u>Fairfield, PA 17320-9611</u>	Facility Address	<u>Sanders Road</u> <u>Carroll Valley, PA 17320-9611</u>
Applicant Contact	<u>David Hazlett</u>	Facility Contact	<u>Jed Fetter</u>
Applicant Phone	<u>(717) 642-8269</u>	Facility Phone	<u>(717) 642-5571</u>
Client ID	<u>73610</u>	Site ID	<u>252221</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Carroll Valley Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Adams</u>
Date Application Received	<u>July 23, 2021</u>	EPA Waived?	<u>no</u>
Date Application Accepted	<u>July 30, 2021</u>	If No, Reason	<u>Chesapeake Bay TMDL-existing discharge proposing to expand</u>
Purpose of Application	<u>Expand WWTF: increasing annual average flow and hydraulic design capacity to 0.25 MGD and replacing the chlorine disinfection to UV system disinfection</u>		

**Summary of Review**

WM. F. Hill & Assoc., Inc., on behalf of Carroll Valley Sewer & Water Authority, has applied to the Pennsylvania Department of Environmental Protection (DEP) for NPDES PA0080039 (which last reissuance was on February 24, 2020, became effective on March 1, 2020, and will expire on February 28, 2025) major amendment requests to construct and expand WWTF, to increase annual average design flow and hydraulic design capacity from 0.14 MGD to 0.25 MGD, and to replace the chlorine monitor & report requirement with UV light intensity (mW/cm<sup>2</sup>) disinfection. The organic design capacity changed from 337 lbs BOD<sub>5</sub>/day to 626 lbs BOD<sub>5</sub>/day.

There are no open violations against the facility or permittee.

Planning for the proposed project was not required.

At the request of DEP, WQM No. 0121403 a permit amendment application also submitted by WM. F. Hill & Assoc., Inc. thru OnBase on July 23, 2021. Then, DEP has decided to review both NPDES & WQM amendment permits application simultaneously.

Expansion to existing facilities discharge to waters within the Chesapeake Bay watershed trigger nutrient cap loads in order to achieve the nutrient reduction required by the Chesapeake Bay Total Maximum Daily Load (TMDL).

Because construction cannot commence until a WQM permit is issued, this amended NPDES permit will carry forward the existing permit limits for an interim period, will include final permit limits based on the new design flow, and will include a compliance schedule in Part C. During the comment period, the permittee can request changes to the compliance schedule.

Based on the review, it is recommended that the NPDES permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days since this is a major amendment.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	October 29, 2021
X		<i>Maria D. Bebenek for Daniel W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	November 18, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.14 MGD inter</u> <u>0.25 MGD Final</u>
Latitude	<u>39° 45' 35.79"</u>	Longitude	<u>-77° 22' 57.15"</u>
Quad Name	<u>Iron Springs</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Toms Creek (CWF)</u>	Stream Code	<u>58685</u>
NHD Com ID	<u>53321454</u>	RMI	<u>3.11 miles (PA border)</u>
Drainage Area	<u>12.4 mi.<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.086</u>
Q <sub>7-10</sub> Flow (cfs)	<u>1.07</u>	Q <sub>7-10</sub> Basis	<u></u>
Elevation (ft)	<u>544</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>13-D</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>PATHOGENS,</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	<u>Name</u>		
Nearest Downstream Public Water Supply Intake	<u>City of Frederick, MD</u>		
PWS Waters	<u>Monocacy River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>Approximate 35 miles</u>

Changes Since Last Permit Issuance:

Other Comments:

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Carroll Valley - Main STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
0121403		Pending		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Chlorination to Ultraviolet	0.14 to 0.25
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.14 to 0.25	337 to 626	Not Overloaded	Aerobic Digestion	Other WWTP

The WWTP train before construction is as follows:

Bar Screen (1) ⇒ EQ Tanks (6) ⇒ Aeration Tanks (14) ⇒ Clarifiers (2) ⇒ Chlorine Contact Tanks (2) ⇒ Post Aeration Lagoon (1) ⇒ Discharge

The facility incorporates the chemical addition of liquid sodium hypochlorite (for disinfection). Sludge holding tanks are on-site.

The WWTP train after construction will be as follows:

Mechanical Screen (1) ⇒ SBRs (2) ⇒ Sludge Digester/Holding (1) ⇒ Post Equalization Basin (1) ⇒ UV disinfection ⇒ Discharge

The facility incorporates the chemical addition of alum for precipitation of phosphorus.

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.25 final</u>
<b>Latitude</b> <u>39° 45' 35.98"</u>	<b>Longitude</b> <u>-77° 22' 57.32"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

***Ammonia (NH<sub>3</sub>-N):***

NH<sub>3</sub>-N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached WQM 7.0 computer model of the stream:

- Discharge pH = 7.0 (Default)
- Discharge Temperature = 25°C (Default)
- Stream pH = 7.0 (Default)
- Stream Temperature = 20°C (Default)
- Background NH<sub>3</sub>-N = 0 mg/L (Default)

The model input data and results are attached. The printout of the WQM 7.0 (ver. 1.1) output indicates that at a discharge of 0.25 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 8.4 mg/L NH<sub>3</sub>-N as a monthly average and 16.8 mg/L NH<sub>3</sub>-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects. These limits are slightly more stringent than before complete of construction and will be in the amendment permit. Mass limits are calculated as follows:

$$\text{Summer average monthly mass limit: } 8.4 \text{ mg/L} \times 0.25 \text{ MGD} \times 8.34 = 17.5 \text{ lbs/day}$$

The winter effluent limit will be set at three-times the summer limits; therefore, the average monthly winter limit for NH<sub>3</sub>-N will be 25.0 mg/L. For the same reason, the instantaneous maximum limit for the winter season will be 50.0 mg/L. Recent DMRs and inspection reports indicate that these limits are being attained easily.

$$\text{Winter average monthly mass limit: } 17.5 \text{ lbs/day} \times 3 = 52.5 \text{ lbs/day}$$

***Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>):***

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. This limit is consistent with the before upgrade permit. Therefore, the limits of 25.0 mg/L monthly average (AML), 40.0 mg/l average weekly limit (AWL), and 50.0 mg/L instantaneous maximum will remain in the amendment permit. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 25.0 \text{ mg/L} \times 0.25 \text{ MGD} \times 8.34 = 52.13 \text{ (52.0) lbs/day} \\ \text{Average weekly mass limit: } & 40.0 \text{ mg/L} \times 0.25 \text{ MGD} \times 8.34 = 83.4 \text{ (83.0) lbs/day} \end{aligned}$$

**Total Suspended Solids (TSS):**

The existing technology-based limits of 30.0 mg/L average monthly, 45.0 mg/L average weekly, and 60.0 mg/L instantaneous maximum will remain in the amendment permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Mass limits are calculated as follows:

Average monthly mass limit:  $30.0 \text{ mg/L} \times 0.25 \text{ MGD} \times 8.34 = 62.55 \text{ (63.0) lbs/day}$

Average weekly mass limit:  $45.0 \text{ mg/L} \times 0.25 \text{ MGD} \times 8.34 = 93.83 \text{ (94.0) lbs/day}$

**Dissolved Oxygen (D.O.):**

The existing permit contains a limit of 5.0 mg/l for Dissolved Oxygen (D.O.). DEP's Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001, 10/97) suggests that either the adopted minimum stream D.O. criteria for the receiving stream or the effluent level determined through water quality modeling be used for the limit. Since the WQM 7.0 model was run using a minimum D.O. of 5.0 mg/l, this limit will be continued in the amendment permit with a daily monitoring requirement per DEP guidance.

**pH:**

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa Code § 95.2(1).

**Fecal Coliform:**

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

**UV:**

The UV system daily monitor and report the UV intensity (mW/cm<sup>2</sup>) after update to replace chlorine disinfection to UV disinfection system will be in the amendment permit.

**Chesapeake Bay Strategy:**

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases I, II, and III) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6.0 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase IV (0.2 - 0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase V (below 0.2 MGD) will monitor during current permit renewal once a year. However, any facility in Phases IV and V that undergoes expansion is subjected to cap load right away.

After finished construction, this plant is classified as a phase IV. For Phase IV sewage facilities (average annual design flow on August 29, 2005 ≥ 0.2 MGD and < 0.4 MGD), renewed or amended permits that include an increase in design flow will contain Cap Loads based on the lesser of a) existing TN and TP concentrations at current design average annual flow or b) 7,306 lbs./yr. TN and 974 lbs./yr. TP.

According to DMR reported as screen shot below which indicated the existing 2020's 19.91 mg/L TN & 3.8 mg/L TP concentrations at current design average annual flow 0.14 MGD; and calculated the mass limits as follows.

9/18/2018 Submittec No	1 Yes	Final Efflu	600 Total Nitrogen			mg/L		< 19.5	Monitor a Annual Average		1/year	Calculatio	WRIGLESV SCRO	Adams	Carroll Valley
10/7/2019 Submittec No	1 Yes	Final Efflu	600 Total Nitrogen			mg/L		< 29.9	Monitor a Annual Average		1/year	Calculatio	WRIGLESV SCRO	Adams	Carroll Valley
8/4/2020 Submittec No	1 Yes	Final Efflu	600 Total Nitrogen			mg/L		< 19.91	Monitor a Annual Average		1/year	Calculatio	WRIGLESV SCRO	Adams	Carroll Valley
9/18/2018 Submittec No	1 Yes	Final Efflu	51445 Total Nitrogen (T lbs		4452	Monitor a Total Annual					1/year	Calculatio	WRIGLESV SCRO	Adams	Carroll Valley
10/7/2019 Submittec No	1 Yes	Final Efflu	51445 Total Nitrogen (T lbs		7646.75	Monitor a Total Annual					1/year	Calculatio	WRIGLESV SCRO	Adams	Carroll Valley
8/4/2020 Submittec No	1 Yes	Final Efflu	51445 Total Nitrogen (T lbs		4922.7	Monitor a Total Annual					1/year	Calculatio	WRIGLESV SCRO	Adams	Carroll Valley
9/18/2018 Submittec No	1 Yes	Final Efflu	665 Total Phosphorus			mg/L		4.1	Monitor a Annual Average		1/year	8-Hr Comj	WRIGLESV SCRO	Adams	Carroll Valley
10/7/2019 Submittec No	1 Yes	Final Efflu	665 Total Phosphorus			mg/L		4.3	Monitor a Annual Average		1/year	8-Hr Comj	WRIGLESV SCRO	Adams	Carroll Valley
8/4/2020 Submittec No	1 Yes	Final Efflu	665 Total Phosphorus			mg/L		3.8	Monitor a Annual Average		1/year	8-Hr Comj	WRIGLESV SCRO	Adams	Carroll Valley
9/18/2018 Submittec No	1 Yes	Final Efflu	51451 Total Phosphoru:lbs		936.06	Monitor a Total Annual					1/year	Calculatio	WRIGLESV SCRO	Adams	Carroll Valley
10/7/2019 Submittec No	1 Yes	Final Efflu	51451 Total Phosphoru:lbs		1098.65	Monitor a Total Annual					1/year	Calculatio	WRIGLESV SCRO	Adams	Carroll Valley
8/4/2020 Submittec No	1 Yes	Final Efflu	51451 Total Phosphoru:lbs		939.54	Monitor a Total Annual					1/year	Calculatio	WRIGLESV SCRO	Adams	Carroll Valley

TN:  $19.91 \text{ mg/L} \times 8.34 \times 0.14 \text{ MGD} \times 365 \text{ days/year} = 8,485.12 \text{ lbs/year}$

TP:  $3.8 \text{ mg/L} \times 8.34 \times 0.14 \text{ MGD} \times 365 \text{ days/year} = 1,619.46 \text{ lbs/year}$

Since 7,306 lbs/yr TN and 974 lbs/yr TP are less than existing load, then these numbers will be placed in the amendment permit.

**Influent BOD<sub>5</sub> and TSS Monitoring:**

The amendment permit will continue influent BOD<sub>5</sub> and TSS weekly monitoring at the same frequency as is done for effluent in order to implement Chapter 94.12 and assess percent removal requirements, per DEP policy.

**Additional Considerations**

*Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the amendment permit per 40 CFR § 122.44(i)(1)(ii).

*Monitoring Frequency and Sample Type*

The after-upgrade facility will collect weekly 8-hr composite effluent samples for CBOD<sub>5</sub>, TSS, Fecal Coliform, Ammonia, and influent of TSS & BOD<sub>5</sub>.

**WQM 7.0**

Two nodes were incorporated in the modeling effort.

Node 1: Outfall 001 on Tom's Creek (58685)

Elevation: 544 ft (USGS National Map Viewer)  
 Drainage Area: 12.4 mi.<sup>2</sup> (USGS PA StreamStats)  
 River Mile Index: 3.11 (PA DEP eMapPA)  
 Low Flow Yield: 0.086 cfs/mi.<sup>2</sup>  
 Discharge Flow: 0.250 MGD (NPDES Application)

Node 2: Just before confluence with UNT 58767

Elevation: 498 ft (USGS National Map Viewer)  
 Drainage Area: 13.0 mi.<sup>2</sup> (USGS PA StreamStats)  
 River Mile Index: 2.29 (PA DEP eMapPA)  
 Low Flow Yield: 0.086 cfs/mi.<sup>2</sup>  
 Discharge Flow: 0.000 MGD

The screenshot displays the StreamStats web application interface. On the left is a navigation sidebar with options for state selection (Pennsylvania), study area identification, and report building. The main content area is divided into three sections:

- Basin Characteristics:** A table listing parameters such as Drainage Area (12.4 square miles), Mean Annual Precipitation (43 inches), Stream Density (1.67 miles per square mile), Depth to rock (5 feet), and Percentage of area of carbonate rock (0 percent).
- Low-Flow Statistics Parameters [Low Flow Region 2]:** A table showing parameter values, units, and limits for Drainage Area, Mean Annual Precipitation, Stream Density, Depth to Rock, and Percent Carbonate.
- Low-Flow Statistics Flow Report [Low Flow Region 2]:** A table providing flow statistics for various return periods (7, 30, 90 days) and low flow types (2 Year, 10 Year), including values, units, and standard errors.

On the right side of the screenshot, a map view shows the study area with a yellow-shaded basin boundary and various street names like N Miller St and Franklin St.

StreamStats

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the 'Build Report' button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Continue

POWERED BY WIM

USGS Home Contact USGS Search USGS  
Accessibility FOIA Privacy Policy & Notices

Zoom Level  
Map Scale:  
Lat: 39.7771

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	13	square miles
PRECIP	Mean Annual Precipitation	43	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	1.7	miles per square mile
ROCKDEP	Depth to rock	5	feet
CARBON	Percentage of area of carbonate rock	0	percent

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	13	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	43	inches	35	50.4
STRDEN	Stream Density	1.7	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	5	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	2.07	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	2.66	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	1.11	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	1.39	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	2.01	ft <sup>3</sup> /s	36	36

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
3.11	Carroll Valley	PA0080039	0.2500

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	8.38	16.76	
Dissolved Oxygen			5

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

rptEffLimits

### WQM 7.0 Effluent Limits

SWP Basin		Stream Code		Stream Name			
13D	6886	TOM 1 CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
3.110	Carroll Valley	PA0080039	0.250	CBOD5	25		
				NH3-N	8.38	16.76	
				Dissolved Oxygen			5

Wednesday, October 20, 2021      Version 1.1      Page 1 of 1

rpt\_WLA

### WQM 7.0 Wasteload Allocations

SWP Basin		Stream Code		Stream Name			
13D	6886	TOM 1 CREEK					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.110	Carroll Valley	14.43	39.89	14.43	39.89	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.110	Carroll Valley	1.76	8.38	1.76	8.38	1	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
3.110	Carroll Valley	25	25	8.38	8.38	5	5
						Critical Reach	Percent Reduction
						0	0

Wednesday, October 20, 2021      Version 1.1      Page 1 of 1



rptDOSim

### WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name
13D	68866	TOM'S CREEK

RM	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
3.110	0.290	21.381	7.000

Reach Width (ft)	Reach Depth (ft)	Reach WDRatio	Reach Velocity (fps)
16.766	0.547	30.602	0.158

Reach CBOD5 (mg/L)	Reach Kc (1/days)	Reach NH3-N (mg/L)	Reach Kp (1/days)
8.12	1.107	2.29	0.775

Reach DO (mg/L)	Reach Kt (1/days)	Kt Equation	Reach DO Goal (mg/L)
7.380	95.510	Tskopou	6

Reach Travel Time (days)	Subreach Results			
0.316	Trav Time (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.082	7.81	2.18	7.46
	0.083	7.51	2.12	7.52
	0.085	7.22	2.07	7.58
	0.126	6.94	2.02	7.63
	0.158	6.68	1.97	7.67
	0.190	6.42	1.92	7.72
	0.221	6.17	1.88	7.76
	0.253	5.93	1.83	7.80
	0.285	5.71	1.79	7.84
	0.316	5.49	1.74	7.87

Wednesday, October 20, 2021      Version 1.1      Page 1 of 1

Page: 1 | No Filter

rptModelSpecs

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows
WLA Method	EMPR	Use Inputted W/D Ratio <input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times <input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kt <input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology <input checked="" type="checkbox"/>
D.O. Goal	6	

Wednesday, October 20, 2021      Version 1.1      Page 1 of 1

Page: 1 | No Filter

rptHydro

### WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code		Stream Name								
110		6686		TOM'S CREEK								
RM	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Flow (cfs)	Reach Scope (ft)	Depth (ft)	Width (ft)	WD Ratio	Velocity (ft/s)	Reach Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
3.110	1.07	0.00	1.07	3868	0.01062	.547	16.77	30.65	0.16	0.316	21.33	7.00
<b>Q1-10 Flow</b>												
3.110	0.68	0.00	0.68	3868	0.01062	NA	NA	NA	0.13	0.376	21.81	7.00
<b>Q30-10 Flow</b>												
3.110	1.45	0.00	1.45	3868	0.01062	NA	NA	NA	0.18	0.277	21.05	7.00

Wednesday, October 20, 2021      Version 1.1      Page 1 of 1

Page: 1 of 1      No Filter

rptGeneral

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RM	Elevation (ft)	Drainage Area (sqm)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply PC
110	6686	TOM'S CREEK	3.110	544.00	12.40	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfs)	Tib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (ft/s)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tran. Temp (°C)	Stream Temp (°C)	pH
Q7-10	0.065	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10	0.00	0.00	0.000	0.000							
Q30-10	0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Carroll Valley	PA0080039	0.2500	0.2500	0.2500	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Tib Conc (mg/L)	Stream Conc (mg/L)	Fals Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Wednesday, October 20, 2021      Version 1.1      Page 1 of 2

Page: 1 of 1      No Filter

rptGeneral
— □ ×

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sqm)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
13D	8886	TOM'S CREEK	2.280	468.00	13.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (ofm)	Trib Flow (cfs)	Stream Flow (cfs)	Roh Trsv Time (day)	Roh Velocity (ft/s)	WD Ratio	Roh Width (ft)	Roh Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.068	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q50-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Diso Flow (mgd)	Permitted Diso Flow (mgd)	Design Diso Flow (mgd)	Recurve Factor	Diso Temp (°C)	Diso pH
Carroll Valley	PA0080039	0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Diso Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.34	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Wednesday, October 20, 2021
Version 1.1
Page 2 of 2

Page: 14 2 No Filter

**Proposed Effluent Limitations and Monitoring Requirements**

Flow design before completion of construction: 0.14 MGD

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: March 1, 2020 through Completion of Construction.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD <sub>5</sub>	29.0	46.0 Wkly Avg	XXX	25.0	40.0	50.0	2/month	8-Hr Composite
TSS	35.0	52.0 Wkly Avg	XXX	30.0	45.0	60.0	2/month	8-Hr Composite
BOD <sub>5</sub> Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Ammonia May 1 - Oct 31	9.9	XXX	XXX	8.5	XXX	17.0	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	29.7	XXX	XXX	25.5	XXX	51.0	2/month	8-Hr Composite
Nitrate-Nitrite as N (lbs/year)	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Kjeldahl Nitrogen (lbs/year)	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Phosphorus (lbs/year)	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Nitrogen (lbs/year)	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation

**Proposed Effluent Limitations and Monitoring Requirements**

After completion of construction Final flow design: 0.25 MGD

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Completion of Construction through February 28, 2025.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
CBOD <sub>5</sub>	52.0	83.0 Wkly Avg	XXX	25.0	40.0	50.0	1/week	8-Hr Composite
TSS	63.0	94.0 Wkly Avg	XXX	30.0	45.0	60.0	1/week	8-Hr Composite
BOD <sub>5</sub> Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Ammonia May 1 - Oct 31	17.5	XXX	XXX	8.4	XXX	16.8	1/week	8-Hr Composite
Ammonia Nov 1 - Apr 30	52.5	XXX	XXX	25.0	XXX	50.0	1/week	8-Hr Composite

Compliance Sampling Location:     

Other Comments:

<b>Proposed Effluent Limitations and Monitoring Requirements</b>
--

Chesapeake Bay After completion of construction final flow design: 0.25 MGD

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Completion of Construction through February 28, 2025.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Net Total Nitrogen	Report	7,306	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	974	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location:

Other Comments: