

Application Type Renewal  
Facility Type Non-Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0080055  
APS ID 274913  
Authorization ID 1208486

**Applicant and Facility Information**

Applicant Name	<u>Conewago Industrial Park Water &amp; Sewer Company.</u>	Facility Name	<u>Conewago Industrial Park</u>
Applicant Address	<u>PO Box 332</u> <u>Lemoyne, PA 17043-0332</u>	Facility Address	<u>10 Creek Court</u> <u>Elizabethtown, PA 17022</u>
Applicant Contact	<u>Martin Murray</u>	Facility Contact	<u>Roy Junk</u>
Applicant Phone	<u>(717) 766-3000</u>	Facility Phone	<u>(717) 201-3109</u>
Client ID	<u>32774</u>	Site ID	<u>451841</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>West Donegal Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lancaster</u>
Date Application Received	<u>November 29, 2017</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 9, 2018</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Renewal.</u>		

**Summary of Review**

Conewago Industrial Park Water & Sewer Company has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The permit was issued on May 24, 2013, and became effective on June 1, 2013. The permit authorized discharge of treated sewage from the existing wastewater treatment plant (WWTP) located in West Donegal Township, Lancaster County into Conewago Creek. The existing permit expiration date was May 31, 2016, and the permit has been administratively extended since that time.

Per the previous fact sheet, Conewago Industrial Park operates a private STP. Customers change from year to year, resulting in changing influent characteristics and many operating problems, resulting in past enforcement action. 1999 violations resulted in a Consent Order and Agreement (COA), which included extensive repairs to the STP. It was noted that the stream was about 20' wide and at least 1' deep. The outfall discharges to the end of a long pool less than 100' to riffle areas which would allow for higher reaeration rates.

Changes to permit renewal: An Ammonia wintertime limit has been added. TN monitoring has been added.

Sludge use and disposal description and location(s): Offsite location

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*,

Approve	Deny	Signatures	Date
X		<i>Benjamin Lockwood</i> Benjamin R. Lockwood / Environmental Engineering Specialist	January 29, 2021
		Daniel W. Martin, P.E. / Environmental Engineer Manager	
		Maria D. Bebenek, P.E. / Program Manager	

**Summary of Review**

DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Supplemental information is located at the end of this fact sheet.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.15</u>
Latitude	<u>40° 9' 48.3"</u>	Longitude	<u>76° 39' 42.8"</u>
Quad Name	<u>Middletown</u>	Quad Code	<u>1732</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Conewago Creek (TSF, MF)</u>	Stream Code	<u>09217</u>
NHD Com ID	<u>56405273</u>	RMI	<u>7.0</u>
Drainage Area	<u>44.2 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0416</u>
Q <sub>7-10</sub> Flow (cfs)	<u>1.84</u>	Q <sub>7-10</sub> Basis	<u>USGS PA StreamStats</u>
Elevation (ft)	<u>364</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>7-G</u>	Chapter 93 Class.	<u>TSF, MF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>N/A</u>	Exceptions to Criteria	<u>N/A</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Nutrients, Total Suspended Solids</u>		
Source(s) of Impairment	<u>Agriculture, Agriculture</u>		
TMDL Status	<u>Final</u>	Name	<u>Conewago Creek Watershed</u>
Nearest Downstream Public Water Supply Intake	<u>Columbia Borough</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>22</u>

Changes Since Last Permit Issuance: USGS PA StreamStats provided a drainage area of 44.2 mi<sup>2</sup> and a Q<sub>7-10</sub> flow of 1.84 cfs at the point of discharge. A WQM Permit was issued on July 14, 2014 which approved the installation of a 48,000 gallon pre-equalization tank, 54,000 gallon post-equalization tank, 1 SBR Unit, 1 Sludge Digester.

Other Comments: None

Treatment Facility Summary				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	SBR	Hypochlorite	0.15
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.15	364	Not Overloaded	Sludge Holding	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The treatment process is as follows: Comminutor – Pre-Equalization Tank – 1 SBR Basin – Post-Equalization Tank – Microscreen Tank – Chlorine Contact Tank – Aerobic Digester – Outfall 001 to Conewago Creek.

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	A summary of the past 12-month DMR effluent data is presented on the next page of this fact sheet
<b>Summary of Inspections:</b>	<p>11/4/2014: A routine inspection was conducted by Bob Haines, DEP Water Quality Specialist. The effluent was clear, and field readings were within the permitted range. There were activated sludge deposits present in the receiving stream at the outfall and 10-12' below the outfall. The operator was asked to have the sludge cleaned out from the stream. All treatment units were online, consisting of a comminutor, aeration tank, 2 clarifiers, 2 sludge holding tanks, chlorine addition, 2 chlorine contact tanks, and post-aeration. The supernatant in the clarifiers had a lot of suspended floc that was not settling well. There was also some popping sludge clumps on the surface of both clarifiers. The RAS airlift pump was causing a lot of water movement, disturbing the settling sludge. Sludge carried over from the clarifiers and settled in a combined effluent box and in the metering pit. The operator reported that the chlorine contact tanks recently had accumulated sludge pumped out, and reported that the contact tanks act as additional settling when the sludge carries over from the clarifiers.</p> <p>11/6/2014: A follow up inspection was conducted by Bob Haines. The sludge had been cleaned from the stream. Very muddy water was observed discharging to Conewago Creek from a stormwater outfall which receives run-off from the WWTP. A construction worker was observed hosing down the mud covered asphalt driveway to a stormwater catch basin. The worker was asked to stop, and indicated that he would put a filter bag in the area he was hosing off, and would stop hosing altogether.</p> <p>8/16/2016: A routine inspection was conducted by Sheena Ripple, DEP Water Quality Specialist. The SBR was not discharging during the inspection and was in react/fill mode. The outfall was free of debris and solids. No other issues were observed.</p>

Other Comments: There are currently no open violations associated with the permittee or the facility.

Compliance History

DMR Data for Outfall 001 (from December 1, 2019 to November 30, 2020)

Parameter	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20	DEC-19
Flow (MGD) Average Monthly	0.043	0.041	0.035	0.044	0.050	0.049	0.039	0.048	0.049	0.049	0.057	0.042
Flow (MGD) Daily Maximum	0.068	0.079	0.067	0.081	0.051	0.107	0.107	0.081	0.079	0.089	0.087	0.075
pH (S.U.) Minimum	7.45	7.68	7.85	7.53	7.65	8.17	7.51	7.23	7.36	7.09	7.28	7.02
pH (S.U.) Maximum	8.12	8.22	8.54	8.49	8.35	8.87	8.87	8.14	8.14	8.12	7.91	8.14
DO (mg/L) Minimum	8.73	8.26	7.39	6.56	6.17	8.55	8.54	8.88	10.32	9.66	8.77	9.48
TRC (mg/L) Average Monthly	0.31	0.27	0.32	0.30	0.19	0.16	0.25	0.20	0.30	0.23	0.17	0.22
TRC (mg/L) Instantaneous Maximum	0.70	0.43	1.06	0.58	0.54	0.48	0.48	0.43	0.53	0.50	0.39	0.47
CBOD5 (mg/L) Average Monthly	2.18	2.22	3.05	3.46	2.52	2.76	3.3	3.1	3.28	2.75	3.35	6.16
TSS (mg/L) Average Monthly	3.4	5.75	5	6.4	5	5	5.25	5	4.4	6	6.75	4.2
Fecal Coliform (CFU/100 ml) Geometric Mean	171.16	38.83	2.6	25.61	12.43	38.68	8.85	3.48	1.37	20.11	5.73	68.74
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	6300	2200	23	19700	230	360	280	37	5	107	60	1060
Ammonia (mg/L) Average Monthly		0.230	0.100	0.168	0.552	0.105	0.111					
Total Phosphorus (lbs/day) Average Monthly	0.40	0.31	0.32	0.35	0.13	0.33	0.19	0.29	0.237	0.34	0.40	0.481
Total Phosphorus (mg/L) Average Monthly	0.89	0.86	0.93	0.88	0.38	0.91	0.52	0.68	0.55	0.59	0.71	1.134
Total Phosphorus (lbs) Total Monthly	12.12	9.84	9.6	10.97	4.26	9.9	5.96	8.85	7.35	10.07	12.4	14.911
Total Phosphorus (lbs) Total Annual			131									

**Compliance History**

**Effluent Violations for Outfall 001, from: January 1, 2020 To: November 30, 2020**

<b>Parameter</b>	<b>Date</b>	<b>SBC</b>	<b>DMR Value</b>	<b>Units</b>	<b>Limit Value</b>	<b>Units</b>
Fecal Coliform	08/31/20	IMAX	19700	CFU/100 ml	1000	CFU/100 ml

**Existing Effluent Limitations and Monitoring Requirements**

The table below summarizes the effluent limits and monitoring requirements implemented in the existing NPDES permit.

**Outfall 001**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	1/week	24-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	12	XXX	24	1/week	24-Hr Composite
Total Phosphorus	Report	XXX	XXX	2.0	XXX	4.0	1/week	24-Hr Composite
Total Phosphorus	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	XXX	913 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

Compliance Sampling Location: Outfall 001

Other Comments: None



**Development of Effluent Limitations**

Outfall No. 001  
 Latitude 40° 9' 48.30"  
 Wastewater Description: Sewage Effluent

Design Flow (MGD) .15  
 Longitude 76° 39' 42.80"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

CBOD<sub>5</sub>, NH<sub>3</sub>-N

Pursuant to 40 CFR § 122.44(d)(1)(i), more stringent requirements should be considered when pollutants are discharged at the levels which have the reasonable potential to cause or contribute to excursions above water quality standards.

WQM 7.0 ver. 1.0b is a water quality model designed to assist DEP in determining appropriate water quality based effluent limits (WQBELs) for carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), NH<sub>3</sub>-N and dissolved oxygen (D.O.). DEP's Technical Guidance No. 391-2000-007 provides the technical methods contained in WQM 7.0 for determining wasteload allocations and for determining recommended NPDES effluent limits for point source discharges. The model was utilized for this permit renewal, and the model output indicated a CBOD<sub>5</sub> average monthly limit of 25 mg/l, an NH<sub>3</sub>-N average monthly limit of 21.91 mg/l, and a D.O. minimum limit of 5.0 mg/l were protective of water quality.

The flow data used to run the model was acquired from USGS PA StreamStats, and is included at the end of this fact sheet. The existing CBOD<sub>5</sub> and NH<sub>3</sub>-N limits are more stringent than this more recent model output; therefore, the existing limits will remain in the permit. DEP's SOP No. BCW-PMT-033 recommends that for ammonia-nitrogen, "a seasonal multiplier of 3 times the summertime average monthly limit should be established for the winter period." As a result, a wintertime limit has been established for this permit.

Toxics

Effluent sample results for toxic pollutants reported on the renewal application were entered into DEP's Toxics Management Spreadsheet Ver. 1.1 to develop appropriate permit requirements for toxic pollutants of concern. Based on effluent sample results reported on the application, there are no necessary effluent limits or monitoring required for these parameters based on water quality. Reasonable potential to exceed water quality criteria was not determined, and the discharge concentrations were less than the thresholds for monitoring, or the pollutants were not detected and a sufficiently sensitive analytical method was used.

Best Professional Judgement (BPJ) Limitations

*Dissolved Oxygen*

A minimum D.O. limit of 5.0 mg/L is a D.O. water quality criterion found in 25 Pa. Code § 93.7(a). This limit is included in the existing NPDES permit based BPJ. It is still recommended to include this limit in the draft permit to ensure that the facility continues to achieve compliance with DEP water quality standards.

*Total Phosphorus*

For Total Phosphorus (TP), the current NPDES permit requires the permittee to comply with average monthly and IMAX limits of 2.0 mg/L and 4.0 mg/L, respectively. DEP's Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams (Guidance No. 391-2000-018) was used during the past renewal to evaluate if phosphorus limitations were necessary. According to the guidance, phosphorus limits would be needed if the contributions from this facility exceeded 0.25% of the total phosphorus load of all discharges in the Lower Susquehanna River Basin. The calculated 7.7 lbs/day was 0.20% of the loading after delivery ratios to the lower Susquehanna River were applied; however, there is a Conewago Creek TMDL which establishes a TP permit limit of 2.0 mg/l, described below. The TP average monthly limit of 2.0 mg/l and instantaneous maximum of 4.0 mg/l will remain in the permit.

**Additional Considerations**

Chesapeake Bay Total Maximum Daily Load (TMDL)

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the *Pennsylvania Chesapeake Watershed Implementation Plan* (WIP), dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a *Phase 2 Watershed Implementation Plan Wastewater Supplement* (Phase 2 Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. A new update to the WIP was published as the Phase 3 WIP in August 2019. As part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on December 17, 2019, and is the basis for the development of any Chesapeake Bay related permit parameters. Sewage discharges have been prioritized based on their design flow to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual Cap Loads based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. For Phase 4 and 5 facilities, Cap Loads are not currently being implemented for renewed or amended permits for facilities that do not increase design flow.

This facility is considered a Phase 5 non-significant discharger with a design flow less than 0.2 MGD but greater than 0.002 MGD. According to DEP's latest-revised Phase 3 Supplement, issuance of permits with monitoring and reporting for TN and TP is recommended for any Phase 5 non-significant sewage facilities. Furthermore, DEP's SOP No. BCW-PMT-033 states that in general, at a minimum, monitoring for TN and TP should be included in new and reissued permits for sewage discharges with design flows > 2,000 gpd. The existing permit already contains TP limits, so TN monitoring will be included in the renewed permit. Table 6-3 of DEP's Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001) recommends a measurement frequency of 1/week for NH<sub>3</sub>-N and phosphorus, which will be used in the permit.

Conewago Creek TMDL

A TMDL exists for Conewago Creek for phosphorus and sediment. The TMDL was completed and approved on March 2, 2001 and was revised on June 27, 2006. The TMDL established TP permit limits for this facility of 913 lbs/year and 2.0 mg/l. These limits will remain in the permit.

Fecal Coliform

PA Code § 92a.47.(a)(4) requires a monthly average limit of 200/100 mL as a geometric mean and an instantaneous maximum limit not greater than 1,000/100 mL from May through September for fecal coliform. PA Code § 92a.47.(a)(5) requires a monthly average limit of 2,000/100 mL as a geometric mean and an instantaneous maximum limit not greater than 10,000/100 mL from October through April for fecal coliform. These limits will remain in the permit.

Total Residual Chlorine

The attached computer printout utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID No. 391-2000-015) for developing chlorine limitations. The Guidance references Chapter 92, Section 92.2d (3) which establishes a standard BAT limit of 0.5 mg/l unless a facility-specific BAT has been developed. The attached printout indicates that a water quality limit of 0.5 mg/l would be needed to prevent toxicity concerns. This is consistent with the existing limits; therefore, a TRC limit of 0.5 mg/l monthly average and 1.5 mg/l instantaneous maximum will be included in the permit.

Sampling Frequency & Sample Type

The monitoring requirements were established based on BPJ and/or Table 6-3 of DEP's Technical Guidance No. 362-0400-001.

Flow Monitoring

Flow monitoring is recommended by DEP's technical guidance and is also required by 25 PA Code §§ 92a.61.

Mass Loading Limitation

All mass loading effluent limitations recommended in the draft permit are concentration-based, calculated using a formula: design flow (MGD) x concentration limit (mg/l) x conversion factor of 8.34.

Anti-Degradation

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303(d) Listed Streams

The discharge is located on a stream segment that is designated on the 303(d) list as impaired. There is an aquatic life impairment due to nutrients and total suspended solids from agriculture. The proposed effluent limits include limits for TSS and TP, as well as monitoring for TN.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit unless any exceptions addressed by DEP in this fact sheet.

**Proposed Effluent Limitations and Monitoring Requirements**


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	1/week	24-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	12	XXX	24	1/week	24-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	36	XXX	72	1/week	24-Hr Composite
Total Phosphorus	Report Total Mo	XXX	XXX	2.0	XXX	4.0	1/week	24-Hr Composite
Total Phosphorus	XXX	913 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Kjeldahl Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Nitrate-Nitrite as N	XXX	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: No. BCW-PMT-002, No. BCW-PMT-033
<input type="checkbox"/>	Other: [redacted]



Copyright: © 2013 National Geographic Society, I-cubed

Enter report title:


Conewago Industrial Park PA0080055 Outfall 001

Enter comments:

Some comments here

## Conewago Industrial Park PA0080055 Outfall 001

Region ID: PA  
Workspace ID: PA20210127223429190000  
Clicked Point (Latitude, Longitude): 40.16346, -76.66225  
Time: 2021-01-27 17:34:49 -0500



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	44.2	square miles
PRECIP	Mean Annual Precipitation	41	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	2.19	miles per square mile
ROCKDEP	Depth to rock	4.3	feet
CARBON	Percentage of area of carbonate rock	0	percent

Low-Flow Statistics Parameters (100 Percent (44.1 square miles) Low-Flow Region 2)

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	44.2	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	2.19	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.3	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Flow Report (100 Percent (44.1 square miles) Low-Flow Region 2)

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	3.99	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	5.48	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	1.84	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	2.54	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	4.03	ft <sup>3</sup> /s	36	36

Low-Flow Statistics Citations

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.4.0





Enter report title:

Conewago Industrial Park PA0080055 Downstream Point

Enter comments:

Some comments here

## Conewago Industrial Park PA0080055 Downstream Point

Region ID:

PA

Workspace ID:


PA20210127223827976000

Clicked Point (Latitude, Longitude):

40.15786, -76.67258

Time:

2021-01-27 17:38:47 -0500



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	44.6	square miles
PRECIP	Mean Annual Precipitation	41	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	2.19	miles per square mile
ROCKDEP	Depth to rock	4.3	feet
CARBON	Percentage of area of carbonate rock	0	percent

Low-Flow Statistics Parameters: 100 Percent (44.6 square miles) Low-Flow Region 2					
Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	44.6	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	2.19	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.3	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Flow Report: 100 Percent (44.6 square miles) Low-Flow Region 2					
PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)					
Statistic	Value	Unit	SE	SEp	
7 Day 2 Year Low Flow	4.03	ft <sup>3</sup> /s	38	38	
30 Day 2 Year Low Flow	5.54	ft <sup>3</sup> /s	33	33	
7 Day 10 Year Low Flow	1.86	ft <sup>3</sup> /s	51	51	
30 Day 10 Year Low Flow	2.57	ft <sup>3</sup> /s	46	46	
90 Day 10 Year Low Flow	4.07	ft <sup>3</sup> /s	36	36	

*Low-Flow Statistics Citations*

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

**USGS Data Disclaimer:** Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

**USGS Software Disclaimer:** This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

**USGS Product Names Disclaimer:** Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.4.0



	A	B	C	D	E	F	G	H	I
1	1A	B	C	D	E	F	G		
2	2	<b>TRC EVALUATION</b>							
3	3	Input appropriate values in B4:B8 and E4:E7							
4	4	1.84	= Q stream (cfs)		0.5	= CV Daily			
5	5	0.15	= Q discharge (MGD)		0.5	= CV Hourly			
6	6	30	= no. samples		1	= AFC_Partial Mix Factor			
7	7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor			
8	8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)			
9	9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)			
10	10	0	= % Factor of Safety (FOS)			=Decay Coefficient (K)			
11	10	Source	Reference	AFC Calculations		Reference	CFC Calculations		
12	11	TRC	1.3.2.iii	WLA_afc = 2.548		1.3.2.iii	WLA_cfc = 2.477		
13	12	PENTOXSD TRC	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581		
14	13	PENTOXSD TRC	5.1b	LTA_afc = 0.950		5.1d	LTA_cfc = 1.440		
15	14								
16	15	Source	Effluent Limit Calculations						
17	16	PENTOXSD TRC	5.1f	AML MULT = 1.231					
18	17	PENTOXSD TRC	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ			
19	18			INST MAX LIMIT (mg/l) = 1.635					
20	19								
21	20								
22	21								
23	22	WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots$						
24	23		$\dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$						
25	24	LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$						
26	25	LTA_afc	$wla\_afc \cdot LTAMULT\_afc$						
27	26								
28	27	WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots$						
29	28		$\dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$						
30	29	LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$						
31	30	LTA_cfc	$wla\_cfc \cdot LTAMULT\_cfc$						
32	31								
33	32	AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$						
34	33	AVG_MON_LIMIT	$MIN(BAT\_BPJ, MIN(LTA\_afc, LTA\_cfc) \cdot AML\_MULT)$						
35	34	INST_MAX_LIMIT	$1.5 \cdot ((av\_mon\_limit / AML\_MULT) / LTAMULT\_afc)$						
36	35								
37	36								

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07G	9217	CONEWAGO CREEK	7.000	384.00	44.20	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	1.84	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Conewago Ind	PA0080055	0.1500	0.1500	0.1500	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07G	9217	CONEWAGO CREEK	6.200	322.00	44.60	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	1.86	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
07G		9217				CONEWAGO CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
7.000	1.84	0.00	1.84	.2321	0.00994	.613	23.26	37.96	0.15	0.336	20.56	7.00
<b>Q1-10 Flow</b>												
7.000	1.18	0.00	1.18	.2321	0.00994	NA	NA	NA	0.12	0.417	20.82	7.00
<b>Q30-10 Flow</b>												
7.000	2.50	0.00	2.50	.2321	0.00994	NA	NA	NA	0.17	0.288	20.42	7.00

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
07G	9217	CONEWAGO CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.000	Conewago Ind	9.11	50	9.11	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.000	Conewago Ind	1.86	21.91	1.86	21.91	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
7.00	Conewago Ind	25	25	21.91	21.91	5	5	0	0



**WQM 7.0 D.O. Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07G	9217	CONEWAGO CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
7.000	0.150	20.560	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
23.263	0.613	37.959	0.145	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
4.58	0.823	2.45	0.731	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.880	13.915	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.336	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.034	4.45	2.39	7.95
	0.067	4.32	2.34	8.01
	0.101	4.20	2.28	8.05
	0.135	4.08	2.22	8.09
	0.168	3.97	2.17	8.12
	0.202	3.86	2.12	8.15
	0.235	3.75	2.07	8.16
	0.269	3.65	2.02	8.16
	0.303	3.54	1.97	8.16
	0.336	3.44	1.92	8.16

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
07G		9217		CONEWAGO CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
7.000	Conewago Ind	PA0080055	0.150	CBOD5	25		
				NH3-N	21.91	43.82	
				Dissolved Oxygen			5



## Discharge Information

Instructions Discharge Stream

Facility: **Conewago Industrial Park** NPDES Permit No.: **PA0080055** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Sewage Effluent**

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
0.15	100	8.99						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
<b>Group 1</b>											
Total Dissolved Solids (PWS)	mg/L										
Chloride (PWS)	mg/L										
Bromide	mg/L										
Sulfate (PWS)	mg/L										
Fluoride (PWS)	mg/L										
<b>Group 2</b>											
Total Aluminum	µg/L										
Total Antimony	µg/L										
Total Arsenic	µg/L										
Total Barium	µg/L										
Total Beryllium	µg/L										
Total Boron	µg/L										
Total Cadmium	µg/L										
Total Chromium (III)	µg/L										
Hexavalent Chromium	µg/L										
Total Cobalt	mg/L	0.015									
Total Copper	µg/L										
Free Cyanide	µg/L										
Total Cyanide	µg/L										
Dissolved Iron	µg/L										
Total Iron	mg/L	< 0.0022									
Total Lead	µg/L										
Total Manganese	µg/L										
Total Mercury	µg/L										
Total Nickel	µg/L										
Total Phenols (Phenolics) (PWS)	µg/L										
Total Selenium	µg/L										
Total Silver	µg/L										
Total Thallium	µg/L										
Total Zinc	mg/L	0.1									
Total Molybdenum	µg/L										
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									







## Stream / Surface Water Information

Conewago Industrial Park, NPDES Permit No. PA0080055, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: \_\_\_\_\_ No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	009217	7	364	44.2			Yes
End of Reach 1	009217	6.2	322	44.6			Yes

### Q<sub>7-10</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	7	0.1										100	7		
End of Reach 1	6.2	0.1													

### Q<sub>h</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	7														
End of Reach 1	6.2														



## Model Results

Conewago Industrial Park, NPDES Permit No. PA0080055, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Cobalt	0	0		0	95	95.0	1,660	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	117.180	120	2,094	Chem Translator of 0.978 applied

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Cobalt	0	0		0	19	19.0	381	
Total Iron	0	0		0	1,500	1,500	30,071	WQC = 30 day average; PMF = 1
Total Zinc	0	0		0	118.139	120	2,402	Chem Translator of 0.986 applied

THH

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Cobalt	0	0		0	N/A	N/A	N/A	

Total Iron	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

**Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Cobalt	0.38	mg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	N/A	N/A	Discharge Conc < TQL
Total Zinc	1.34	mg/L	Discharge Conc ≤ 10% WQBEL