



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0080616

APS ID

1005223

Authorization ID

1497192

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Applicant and Facility Information

Applicant Name	<u>Mountain View MHP Management LLC</u>	Facility Name	<u>Mountain View MHP</u>
Applicant Address	<u>2846 Main Street, Box 12A</u>	Facility Address	<u>203 Rife Road</u>
	<u>Morgantown, PA 19543-9490</u>		<u>East Berlin, PA 17316</u>
Applicant Contact	<u>James Perano</u>	Facility Contact	<u>James Perano</u>
Applicant Phone	<u>(610) 286-0490</u>	Facility Phone	<u>(610) 286-0490</u>
Client ID	<u>353440</u>	Site ID	<u>249933</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Reading Township</u>
Connection Status		County	<u>Adams</u>
Date Application Received	<u>August 27, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 30, 2024</u>	If No, Reason	
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

Mountain View MHP Management, LLC (Authority/Permittee), applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The permit was reissued on February 24, 2020, and became effective on March 1, 2020. The permit expires on February 28, 2025.

The design discharge flow from the facility is 0.011 MGD. The permit authorized discharge of treated sewage from the existing wastewater treatment plant (WWTP) located in Reading Township, Adams County to Conewago Creek.

WQM No. 0185402 was issued on 2/7/1986. 0185402 T-1 ownership transfer was issued on 2/24/2020.

Sludge use and disposal description and location(s): N/A because sludge is hauling by Smith's Septic contractor.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	January 10, 2025
X		<i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	January 27, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.011
Latitude	39° 56' 39.14"	Longitude	-76° 59' 3.37"
Quad Name	Abbottstown	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Conewago Creek (WWF)	Stream Code	08303
NHD Com ID	57470175	RMI	38.82 miles
Drainage Area	219 mi. ²	Yield (cfs/mi ²)	0.067
Q ₇₋₁₀ Flow (cfs)	14.7	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	386	Slope (ft/ft)	
Watershed No.	7-F	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Wrightsville Borough Municipal Authority, York County		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	28.51 miles	Distance from Outfall (mi)	Approximate 51.5 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Conewago Creek at RMI 38.82 miles. A drainage area upstream of the discharge is estimated to be 219 sq.mi, according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

According to StreamStats, the discharge point on Conewago Creek has a Q₇₋₁₀ of 14.7 cfs and a drainage area of 219 mi², which results in a Q₇₋₁₀ low flow yield of 0.067 cfs/mi². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 14.7 \text{ cfs} \\
 \text{Low Flow Yield} &= 14.7 \text{ cfs} / 219 \text{ mi}^2 \approx 0.067 \text{ cfs/mi}^2 \\
 Q_{30-10} &= 1.36 * 14.7 \text{ cfs} \approx 19.99 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 14.7 \text{ cfs} \approx 9.4 \text{ cfs}
 \end{aligned}$$

Public Water Supply

The nearest downstream public water supply intake is the Wrightsville Borough Municipal Authority on the Susquehanna River in York County, approximately 51.5 miles downstream of this discharge. Considering distance and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Mountainview MHP				
WQM Permit No.	Issuance Date			
0185402	2/7/1986			
0185402 T-1	2/24/2020			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration With Solids Removal	Hypochlorite	0.011
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.011		Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance:

Other Comments:

The WWTP train is as follows:

Bar Screen (1) ⇒ Aeration Tanks (2) ⇒ Settling Tanks (2) ⇒ Dosing Tank (1) ⇒ Sand Filters (2) ⇒ Chlorine Contact Tank (1) ⇒ Discharge (outfall)

The system incorporates chemical additions of alum & soda ash to control pH, and sodium hypochlorite for disinfection.

A sludge holding tank is used for solids storage.

Compliance History	
Summary of DMRs:	A summary of past 12-month DMR data is presented on the next page.
Summary of Inspections:	1/10/2023: Mr. Hoy, DEP WQS, conducted a compliance evaluation inspection. Field results tested within permit limits. There were no violations identified during inspection. Recommendations were 1. Repairing or replacing the effluent troughs to ensure the plant operates properly. 2. Keeping daily logs available to review on site. 3. Conducting an evaluation of the structural integrity of the metering pit walls.
Other Comments:	There are no violations against or associated to the facility or permittee.

Other Comments: 

Compliance History

DMR Data for Outfall 001 (from December 1, 2023 to November 30, 2024)

Parameter	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23
Flow (MGD) Average Monthly	0.0063	0.0069	0.0072	0.0056	0.0056	0.0055	0.0051	0.00515	0.0054	0.0054	0.0087	0.0054
Flow (MGD) Daily Maximum	0.0083	0.0112	0.0135	0.008	0.0101	0.0098	0.0078	0.008	0.009	0.0087	0.0355	0.0092
pH (S.U.) Daily Minimum	6.8	7.2	7.1	6.7	6.9	6.7	6.7	6.6	6.7	6.7	6.7	6.6
pH (S.U.) Instantaneous Maximum	7.3	7.8	8.0	7.8	7.5	7.3	7.4	7.3	7.3	7.3	7.5	7.3
DO (mg/L) Daily Minimum	9.4	6.2	8.0	7.2	7.7	8.0	8.1	8.2	8.9	9.6	7.8	7.3
TRC (mg/L) Average Monthly	0.33	0.32	0.33	0.32	0.31	0.3	0.31	0.27	0.28	0.31	0.26	0.24
TRC (mg/L) Instantaneous Maximum	0.56	0.52	0.52	0.48	0.57	0.53	0.51	0.42	0.43	0.57	0.49	0.38
CBOD5 (mg/L) Average Monthly	< 2.6	< 2.4	6.0	2.4	< 2.4	< 2.6	< 2.5	< 2.4	< 2.4	< 2.4	3.3	< 2.4
TSS (mg/L) Average Monthly	2	2	2	2	1	1	2	1	2	1	1	1
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 1	< 2	< 1	< 2	< 1	< 14	< 8
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	1	< 1	1	< 1	< 1	3	1	5	1	185	69
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	0.58	0.42	0.82	< 0.52	< 0.1	< 0.1	0.53	< 0.14
Total Phosphorus (mg/L) Average Monthly	0.29	0.32	0.75	0.59	1.11	0.7	0.63	0.18	0.18	0.29	0.31	0.4

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.63	1/day	Grab
CBOD ₅	XXX	XXX	XXX	25	XXX	50	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	10	XXX	20	2/month	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4.0	2/month	24-Hr Composite

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 56' 39.14"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.011
Longitude -76° 59' 3.37"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: [redacted]

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

- * Discharge pH = 7.0 (Default)
- * Discharge Temperature = 25°C (Default)
- * Stream pH = 7.0 (Default)
- * Stream Temperature = 20°C (Default)
- * Background NH₃-N = 0 mg/L (Default)

Analysis Results WQM 7.0

Hydrodynamics		NH ₃ -N Allocations		D.O. Allocations		D.O. Simulation		Effluent Limitations																	
RMI	Discharge Name	Permit Number Disc Flow (mgd)																							
38.82	Mountain View	PA0080616 0.0110																							
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Effluent Limit 30 Day Average (mg/L)</th> <th>Effluent Limit Maximum (mg/L)</th> <th>Effluent Limit Minimum (mg/L)</th> </tr> </thead> <tbody> <tr> <td>CBOD₅</td> <td>25</td> <td></td> <td></td> </tr> <tr> <td>NH₃-N</td> <td>25</td> <td>50</td> <td></td> </tr> <tr> <td>Dissolved Oxygen</td> <td></td> <td></td> <td>5</td> </tr> </tbody> </table>										Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)	CBOD ₅	25			NH ₃ -N	25	50		Dissolved Oxygen			5
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)																						
CBOD ₅	25																								
NH ₃ -N	25	50																							
Dissolved Oxygen			5																						
Record: 1 of 1 < Back No Filter Search																									
Print		Next >		Archive		Cancel																			

Mountain View MHP

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 25.0 mg/L as a monthly average and 50.0 mg/L instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects at the point of discharge. However, the existing summer limits of 10.0 mg/L monthly average & 20.0 mg/L IMAX are more stringent and will remain in the proposed permit. The existing winter monitoring and reporting will remain in place. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Minimum monitoring frequency will be 2/month and sampling type will be 8-hr composite.

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing permit 25.0 mg/L as AML will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has typically been achieving concentrations below this limit. The minimum monitoring frequency will remain the same as 2/month.

Dissolved Oxygen (D.O.):

The minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BCW-PMT-033, version 2.0 revised February 5, 2024, and has been applied to other point source dischargers throughout the state.

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

Total Suspended Solids (TSS):

The existing technology-based limits of 30.0 mg/L average monthly, and 60.0 mg/L IMAX will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Chesapeake Bay Strategy:

According to DEP's Chesapeake Bay Phase II Watershed Implementation Plan (WIP) Wastewater Supplement, this facility is considered a phase 5 non-significant sewage discharger with design flow less than 0.2 MGD but greater than 0.002 MGD. In general, DEP will issue permits for all phase 5 facilities with monitoring and reporting for Total Nitrogen (TN) and Total Phosphorus (TP) throughout the permit term at a frequency no less than annually. Furthermore, DEP's SOP No. BPNPSM-PMT-033 states that in general, at a minimum, monitoring for TN and TP should be included in new and reissued permits for sewage discharges with design flows > 2,000 gpd. At this time, the Department is not requiring a total maximum annual nitrogen or phosphorus loading cap. TN and TP monitoring is already included in the existing permit and will remain in the renewal.

Total Residual Chlorine (TRC):

Based on the attached TRC Excel spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), the facility's discharge must meet a monthly average limit of 0.5 mg/L and an instantaneous maximum limit of 1.63 mg/L. These limits are the same as in existing permit and will be carried over. The minimum monitoring frequency is 1/day.

TRC EVALUATION							
Input appropriate values in A3:A9 and D3:D9							
14.7	= Q stream (cfs)		0.5	= CV Daily			
0.011	= Q discharge (MGD)		0.5	= CV Hourly			
30	= no. samples		1	= AFC_Partial Mix Factor			
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor			
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)			
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)			
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)			
Source	Reference	AFC Calculations		Reference	CFC Calculations		
TRC	1.3.2.iii		WLA_afc = 275.585	1.3.2.iii			
PENTOXSD TRG	5.1a		LTAMULT_afc = 0.373	5.1c			
PENTOXSD TRG	5.1b		LTA_afc = 102.689	5.1d			
Source	Effluent Limit Calculations						
PENTOXSD TRG	5.1f		AML MULT = 1.231				
PENTOXSD TRG	5.1g		AVG MON LIMIT (mg/l) = 0.500				BAT/BPJ
			INST MAX LIMIT (mg/l) = 1.635				
WLA_afc			(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_afc			EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)				
LTA_afc			wla_afc*LTAMULT_afc				
WLA_cfc			(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_cfc			EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)				
LTA_cfc			wla_cfc*LTAMULT_cfc				
AML MULT			EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))				
AVG MON LIMIT			MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST MAX LIMIT			1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)				

Best Professional Judgment (BPJ) Limitations

Total Phosphorus

This approach is consistent with DEP's SOP No. BPNPSM-PMT-033 as well as the State regulation found in 25 Pa. Code § 96.5(c) which states the following: *"When it is determined that the discharge of phosphorus, alone or in combination with the discharge of other pollutants, contributes or threatens to impair existing or designated uses in a free-flowing surface water, phosphorus discharges from point source discharges shall be limited to an average monthly concentration of 2 mg/l. More stringent controls on point source discharges may be imposed, or may be otherwise adjusted as a result of a TMDL which has been developed."*

Phosphorus limits are included in the existing permit and phosphorus removal equipment is in place. Therefore, the existing limits of 2.0 mg/L average monthly and 4.0 mg/L instantaneous maximum will remain in place in accordance with 40 CFR §122.44(l)(1).

Additional Consideration

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Monitoring Frequency and Sample Type

The facility currently is required to collect daily effluent grab samples for DO, TRC, and pH; bi-monthly effluent 24-hr composite samples of CBOD₅, TSS, ammonia-nitrogen, and TP; bi-monthly effluent grab samples of fecal coliform. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the renewal permit monitoring frequencies will remain the same as those specified in the existing permit.

303d Listed Streams

This discharge is not located on a 303d listed stream segment.

Mountain View MHP

Antidegradation (93.4)

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as existing permit requirements in accordance with 40 CFR §122.44(l)(1).

WQM 7.0:

MODEL INPUTS


- Discharge pH = 7.0 (Default)
- Discharge Temperature = 25°C (Default)
- Stream pH = 7.0 (Default)
- Stream Temperature = 20°C (Default)
- Background NH₃-N = 0 (Default)

Node 1: Outfall 001 (08303)

Elevation: 386 ft (USGS National Map Viewer)
 Drainage Area: 219 mi² (USGS PA StreamStats)
 River Mile Index: 38.82 (PA DEP eMapPA)
 Low Flow Yield: 0.067 cfs/mi²
 Discharge Flow: 0.011 mgd (NPDES PA0080616 Application)

Node 2: Just before confluence of Conewago Creek with Beaver Creek

Elevation: 384.7 ft (USGS National Map Viewer)
 Drainage Area: 237 mi² (USGS PA StreamStats)
 River Mile Index: 37.97 (PA DEP eMapPA)
 Low Flow Yield: 0.067 cfs/mi²
 Discharge Flow: 0.000 mgd



NPDES Permit Fact Sheet

Mountain View MHP

NPDES Permit No. PA0080616

USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button.

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.4076	degrees
DRNAREA	Area that drains to a point on a stream	219	square miles
ROCKDEP	Depth to rock	4.7	feet
URBAN	Percentage of basin with urban development	3.4179	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]


Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	219	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	3.4076	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.7	feet	4.13	5.21
URBAN	Percent Urban	3.4179	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	30.6	ft ³ /s	46	46
30 Day 2 Year Low Flow	41.7	ft ³ /s	38	38
7 Day 10 Year Low Flow	14.7	ft ³ /s	51	51
30 Day 10 Year Low Flow	20.1	ft ³ /s	46	46
90 Day 10 Year Low Flow	34.4	ft ³ /s	41	41

Low-Flow Statistics Citations



USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button.

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.4321	degrees
DRNAREA	Area that drains to a point on a stream	237	square miles
ROCKDEP	Depth to rock	4.7	feet
URBAN	Percentage of basin with urban development	3.3413	percent

Low-Flow Statistics


Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	237	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	3.4321	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.7	feet	4.13	5.21
URBAN	Percent Urban	3.3413	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	33.4	ft ³ /s	46	46
30 Day 2 Year Low Flow	45.4	ft ³ /s	38	38
7 Day 10 Year Low Flow	16.1	ft ³ /s	51	51
30 Day 10 Year Low Flow	22	ft ³ /s	46	46
90 Day 10 Year Low Flow	37.5	ft ³ /s	41	41



NPDES Permit Fact Sheet
Mountain View MHP

NPDES Permit No. PA0080616

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI Discharge Name		Permit Number	Disc Flow (mgd)
38.82	Mountain View	PA0080616	0.0110
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	25	50	
Dissolved Oxygen			5

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
OTF	0303	CO NEWAGO CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Avg. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
38.820	Mountain MHP	PA0080616	0.011	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name					
OTF	0303	CO NEWAGO CREEK					
NH3-N Acute Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
38.820 Mountain MHP		16.75	00	16.75	50	0	0
NH3-N Chronic Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
38.820 Mountain MHP		1.69	25	1.69	25	0	0
Dissolved Oxygen Allocations							
RMI	Discharge Name	CBOD5 Baseline Multiple (mg/L)	NH3-N Baseline Multiple (mg/L)	Dissolved Oxygen Baseline Multiple (mg/L)	Critical Reach	Percent Reduction	
38.820 Mountain MHP		25	25	5	0	0	

Wednesday, January 8, 2025 Version 1.1 Page 1 of 1

Wednesday, January 8, 2025 Version 1.1 Page 1 of 1

Page: 1 No Filter

NPDES Permit Fact Sheet
Mountain View MHP

NPDES Permit No. PA0080616

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name	
6TF	6303	CONEWAGO CREEK	
RBH	Total Discharge Flow (mgd)	Analytic Temperature (°C)	Analytic pH
38,600	0.011	20.006	7.000
Reach Width (ft)	Reach Depth (ft)	Reach W (ft)	Reach Velocity (fts)
71,026	0.908	78.377	0.228
Reach DO (mg/L)	Reach DO (mg/L)	Reach DO (mg/L)	Reach DO (mg/L)
0.03	0.018	0.03	0.700
Reach DO (mg/L)	Reach Kt (1/day)	Hi Equation	Reach DO Goal (mg/L)
8.209	0.151	Tklogou	5
Reach Travel Time (days)			
0.228			
Subreach Results			
Travel Time	CBOD5	NH3-N	D.O.
(days)	(mg/L)	(mg/L)	(mg/L)
0.023	2.00	0.03	8.24
0.040	2.00	0.03	8.24
0.066	2.00	0.03	8.24
0.091	2.02	0.03	8.24
0.114	2.02	0.03	8.24
0.137	2.02	0.03	8.24
0.161	2.00	0.03	8.24
0.182	2.02	0.03	8.24
0.205	2.02	0.03	8.24
0.228	2.02	0.02	8.24

Wednesday, January 8, 2025 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameters	Value	Notes
WLA Method	EMPR	Use Inputted Q1-10 and Q30-10 Flows
Q1-10/Q7-10 Ratio	0.61	Use Inputted W/L Ratio
Q30-10/Q7-10 Ratio	1.26	Use Inputted Reach Travel Times
D.O. Saturation	90.0 0%	Temperature Adj. Use Vr
D.O. Goal	5	Use Balanced Technology

Wednesday, January 8, 2025 Version 1.1 Page 1 of 1

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name								
6TF	6303	CONEWAGO CREEK								
RBH	Stream Flow (cfs)	Net Stream Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fts)	Reach Time (days)	Analytic Temp (°C)	Analytic pH
(days)	(cfs)	(cfs)	(ft)	(ft)	(ft)		(fts)	(days)	(°C)	

Q7-10 Flow
38,600 14.67 0.00 14.67 .017 0.00 0.029 .906 71.03 78.38 0.23 0.228 20.01 7.00

Q1-10 Flow
38,600 9.39 0.00 9.39 .017 0.00 0.029 NA NA 0.18 0.292 20.01 7.00

Q30-10 Flow
38,600 19.96 0.00 19.96 .017 0.00 0.029 NA NA 0.27 0.192 20.00 7.00

Wednesday, January 8, 2025 Version 1.1 Page 1 of 1

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RBH	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
6TF	6303	CONEWAGO CREEK	38.620	386.00	219.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trv Time (days)	Rch Velocity (fts)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Temp (°C)	Temp (°F)	Stream pH
Q7-10	0.007	0.00	0.00	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10	0.00	0.00	0.00	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00

Discharge Data

Name	Rating Flow (mgd)	Permit Flow (mgd)	Design Flow (mgd)	Design Conc. (mg/L)	Reserve Factor	Disc Temp (°C)	Disc pH
Mountain MHP	PA0080616	0.0110	0.0110	0.0110	0.0000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc. (mg/L)	Trib Conc. (mg/L)	Stream Conc. (mg/L)	Rate Coef (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Wednesday, January 8, 2025 Version 1.1 Page 1 of 2

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMS (ft)	Elevation (sq mi)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
OTF	0003	CONEWAGO CREEK	37.970	364.70	237.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Turbidity (mg/l)	Temp (°C)	Stream pH
QT-16	0.007	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
QT-16		0.00	0.000	0.000							
Q30-16		0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Dis. Flow (mgd)	Permitted Dis. Flow (mgd)	Design Dis. Flow (mgd)	Reactive Factor	Disc. Temp (°C)	Disc. pH
Mountain MHP	PA0080616	0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Fate Coef
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	
NH3-N	25.00	0.00	0.00	0.70

Wednesday, January 6, 2025 Version 1.1 Page 3 of 2

Page: 1 2 | No Filter

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.63	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	10	XXX	20	2/month	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4	2/month	24-Hr Composite

Compliance Sampling Location: 

Other Comments: 

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]