

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0081051  
 APS ID 988363  
 Authorization ID 1425589

**Applicant and Facility Information**

Applicant Name	<u>Round Top Sewer Cooperative, Inc.</u>	Facility Name	<u>Round Top Campground</u>
Applicant Address	<u>2 N Riverside Plaza Suite 800</u> <u>Chicago, IL 60606-2682</u>	Facility Address	<u>180 Knight Road</u> <u>Gettysburg, PA 17325-8767</u>
Applicant Contact	<u>Greggory Kane</u>	Facility Contact	<u>Scott Liddick</u>
Applicant Phone	<u>(312) 279-1692</u>	Facility Phone	<u>(717) 334-9565</u>
Client ID	<u>348398</u>	Site ID	<u>261174</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Cumberland Township</u>
Connection Status		County	<u>Adams</u>
Date Application Received	<u>January 31, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>February 3, 2023</u>	If No, Reason	
Purpose of Application	<u>NPDES permit renewal.</u>		

**Summary of Review**

Kline Engineering, on behalf of the Round Top Sewage Cooperative, Inc., applied to the Pennsylvania Department of Environmental Protection (DEP) for renewal and issuance of the NPDES permit. The permit was reissued on July 20, 2017 and became effective on August 1, 2018. The ownership transfer NPDES PA0081051 T-1 was issued on April 15, 2019. The permit expires on July 31, 2023.

The average annual design flow and hydraulic design capacity is 0.042 MGD.

The WQM Part II No. 0188405 original was issued on December 1, 1998, 0188405 A-1 & 0188405 A-2 amendment were issued on 11/6/2000 & 11/1/2006, and 0188405 T-1 & 0188405 T-2 transfer were issued on July 20, 2018 & April 15, 2019.

Sludge use and disposal description and location(s): N/A due to the sludge is hauled by Smith's Disposal Facility, LLC.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the permit.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	May 26, 2023
X		Maria D. Bebenek, P.E., for Daniel W. Martin Daniel W. Martin, P.E. / Environmental Engineer Manager	June 30, 2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.042
Latitude	39° 46' 36.00"	Longitude	-77° 13' 49.84"
Quad Name	Gettysburg	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Plum Run (WWF)	Stream Code	59062
NHD Com ID	53320972	RMI	0.8
Drainage Area	0.11	Yield (cfs/mi <sup>2</sup> )	0.013
Q <sub>7-10</sub> Flow (cfs)	0.0014	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	452	Slope (ft/ft)	
Watershed No.	13-D	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	City of Frederick, MD		
PWS Waters	Monocacy River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	More than 36.0 miles

Changes Since Last Permit Issuance: none

**Drainage Area**

The discharge is to UNT to Plum Run at RMI 0.80 mile. A drainage area upstream of the discharge is estimated to be 0.11 mi.<sup>2</sup>, according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

**Stream Flow**

According to StreamStats, the point of first use has a Q<sub>7-10</sub> of 0.0014 cfs and a drainage area of 0.11 mi.<sup>2</sup>, which results in a Q<sub>7-10</sub> low flow yield of 0.019 cfs/mi.<sup>2</sup>. This information is used to obtain a chronic or 30-day (Q<sub>30-10</sub>), and an acute or 1-day (Q<sub>1-10</sub>) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 0.0014 \text{ cfs} \\
 \text{Low Flow Yield} &= 0.0014 \text{ cfs} / 0.11 \text{ mi.}^2 = 0.013 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 0.0014 \text{ cfs} = 0.002 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.0014 \text{ cfs} = 0.001 \text{ cfs}
 \end{aligned}$$

The resulting Q<sub>7-10</sub> dilution ratio is:  $Q_{\text{stream}} / Q_{\text{discharge}} = 0.0014 \text{ cfs} / [0.042 \text{ MGD} * (1.547 \text{ cfs/MGD})] = 0.022:1$

**UNT to Plum Run**

25 Pa. Code § 93.9o classifies UNT to Plum Run as Warm Water Fishes and Migratory Fishes (WWF & MF) surface water. Based on the 2022 Integrated Report, UNT to Plum Run, assessment unit ID 10203, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

**Public Water Supply**

The nearest downstream public water supply intake is the City of Frederick, MD on Monocacy River, which is more than 36.0 miles downstream of this discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Round Top Campground				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
0188405		12/1/1998		
0188405 A-1		11/6/2000		
0188405 A-2		11/1/2016		
0188405 T-1		7/20/2018		
0188405 T-2		4/15/2019		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Tertiary	Extended Aeration With Solids Removal	Ultraviolet	0.042
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.042		Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: none

Other Comments:

Per the site inspection dated December 10, 2018, the plant consists of the following treatment units:

- One bar screen
- One EQ tank
- One aeration tank
- One clarifier
- One Ultra-screen Disk Filter
- One UV
- One sludge holding

The chemicals used Aluminum Sulfate for phosphorus reduction, and Soda Ash Life for pH control.

Biosolids:

The total sewage sludge /biosolids production within the facility for the previous year was 0.901 dry tons.

Compliance History	
<b>Summary of DMRs:</b>	A summary of past 12-month DMRs is presented on the pages 4 & 5.
<b>Summary of Inspections:</b>	8/16/2022: Mr. Hoy, DEP's WQET, conducted a compliance evaluation inspection. There were no violations noted during the inspection. Recommendations were keeping the composite sampler refrigerator for temperature verification; ensure results observed during three points pH calibration are recorded on the on-site calibration log; and utilizing the on-site auto dialer alarm system.  12/10/2018: Mr. Benham, DEP WQET, conducted a compliance evaluation inspection. There were no violations identified during inspection.
<b>Other Comments:</b>	There are no open violations against the facility or the permittee.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from April 1, 2022 to March 31, 2023)

Parameter	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22
Flow (MGD) Average Monthly	0.0077	0.0062	0.0096	0.0099	0.00837	0.0069	0.0063	0.0062	0.008	0.0068	0.0102	0.0103
Flow (MGD) Daily Maximum	0.02	0.0118	0.0261	0.0423	0.0225	0.0142	0.0219	0.0138	0.0319	0.0325	0.0359	0.0263
pH (S.U.) Daily Minimum	7.1	7.0	6.8	6.7	6.8	6.9	6.9	7.0	6.9	7.2	7.1	7.3
pH (S.U.) Daily Maximum	7.7	7.8	7.7	7.6	7.4	7.6	7.7	7.7	7.8	7.8	7.9	7.7
DO (mg/L) Daily Minimum	9.1	9.0	8.5	9.0	8.4	7.2	7.0	7.0	7.3	8.0	7.1	9.0
CBOD5 (mg/L) Average Monthly	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 3.3	< 2.4	< 2.4
TSS (mg/L) Average Monthly	1.0	1.0	2.0	1.0	1.0	2.0	1.0	2.5	2.5	3.0	1.0	1.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 2	< 1	< 1	< 1	< 1	< 2	< 1
Fecal Coliform (No./100 ml) IMAX	< 1	< 1	< 1	< 1	< 1	5	< 1	< 1	< 1	< 1	3	< 1
UV Intensity (mW/cm <sup>2</sup> ) Daily Minimum	0.6	0.9	0.7	1.8	1.9	3	4.0	4.5	3.1	4.0	2.7	3.1
Nitrate-Nitrite (lbs/day) Average Quarterly	< 2			< 5			< 3			< 5		
Nitrate-Nitrite (mg/L) Average Quarterly	< 21.4			< 70.4			< 50.4			< 69.4		
Total Nitrogen (lbs/day) Average Quarterly	< 2			< 5			< 3			< 5		
Total Nitrogen (mg/L) Average Quarterly	< 21.9			< 70.9			< 50.9			< 69.9		
Ammonia (lbs/day) Average Monthly	< 0.007	< 0.004	< 0.006	< 0.006	< 0.007	< 0.007	< 0.01	< 0.006	< 0.008	< 0.007	< 0.008	< 0.008
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
TKN (lbs/day) Average Quarterly	< 0.04			< 0.04			< 0.03			< 0.04		
TKN (mg/L) Average Quarterly	< 0.5			< 0.5			< 0.5			< 0.5		

**NPDES Permit Fact Sheet  
Round Top Campground**

**NPDES Permit No. PA0081051**

Total Phosphorus (lbs/day) Average Monthly	0.01	0.01	0.02	0.02	0.09	0.06	0.2	0.08	0.09	0.04	0.03	0.02
Total Phosphorus (mg/L) Average Monthly	0.2	0.3	0.3	0.4	1.2	1.0	1.5	1.5	1.2	0.5	0.4	0.3

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.042</u>
<b>Latitude</b> <u>39° 46' 35.99"</u>	<b>Longitude</b> <u>-77° 13' 49.97"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Total Residual Chlorine is not applied.

**Water Quality-Based Limitations**

**Ammonia (NH<sub>3</sub>-N):**

NH<sub>3</sub>-N calculations were based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached computer model of the stream:

- \* Discharge pH                    7.0                    (Default per 391-2000-007)
- \* Discharge Temperature    20°C                    (Default per 391-2000-007)
- \* Stream pH                        7.0                    (Default per 391-2000-006)
- \* Stream Temperature        25°C                    (Default for WWF per 391-2000-003)
- \* Background NH<sub>3</sub>-N            0 mg/L                    (Assumed since no nearby upstream WWTPs)

Regarding NH<sub>3</sub>-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 1.93 mg/L NH<sub>3</sub>-N as a monthly average (AML) and 3.86 mg/L NH<sub>3</sub>-N instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects. However, the existing permit limits of 1.0 mg/L average monthly & 2.0 mg/L IMAX for summer and 3.0 mg/L average monthly & 6.0 mg/L IMAX for winter are more stringent and will remain in the proposed permit. Monitoring frequency will also remain the same 2/month. DMR data and site inspections reflect that the plant is capable of meeting this limit.

**CBOD<sub>5</sub>:**

The WQM 7.0 model (ver. 1.1) suggests a monthly average CBOD<sub>5</sub> limit of 25.0 mg/L. However, the existing permit limits of 10.0 mg/L average monthly & 20.0 mg/L IMAX are more stringent and will remain in the proposed permit. The minimum monitoring frequency will remain the same 2/month.

**Dissolved Oxygen (D.O.):**

The D.O. goal is 6.0 mg/L. However, a minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BPNPSM-PMT-033 and has been applied to other point source dischargers throughout the state.

**pH:**

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

**Fecal Coliform:**

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

**E. Coli:**

As recommended by DEP's SOP No. BCW-PMT-033, version 1.9 revised March 22, 2021, a routine monitoring for E. Coli will be included in the permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

**UV:**

The UV system daily monitor and report the UV light intensity (mW/cm<sup>2</sup>) will remain in the proposed permit.

**Total Suspended Solids (TSS):**

The existing limits of 10.0 mg/L average monthly, and 20.0 mg/L instantaneous maximum will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations below these limits. The minimum monitoring frequency will remain the same 2/month.

**Total Phosphorus:**

The existing permit limits of 1.5 mg/L as a monthly average and 3.0 mg/L as an instantaneous maximum are being continued in this renewal, consistent with DEP's Technical Guidance for Phosphorus (391-2000-018) and 25 Pa. Code § 96.5. The minimum monitoring frequency will remain the same 2/month.

**Total Nitrogen:**

Monitoring requirements for Total Nitrogen are being added to all NPDES permits in the State if the permit does not already include them, as authorized by 25 Pa. Code § 92a.61. Controlling nutrients in waterways requires data collection. The existing minimum monitoring and report calculation of quarterly for Total Nitrogen permit will remain in the proposed permit.

**Toxics:**

DEP utilizes a Toxics Management Spreadsheet (TMS) (last modified on March 2021, ver. 1.3) to facilitate calculations necessary for completing a reasonable potential analysis and determining WQBELs for toxic pollutants. The effluent testing information renewal application (page 7) indicates that there are no toxic pollutants of concern.

**Stormwater:**

There is no known stormwater outfall associated with this facility.

**Chesapeake Bay Strategy:**

According to DEP's Chesapeake Bay Phase II Watershed Implementation Plan (WIP) Wastewater Supplement, this facility is considered a phase 5 non-significant sewage discharger with design flow less than 0.2 MGD but greater than 0.002 MGD. In general, DEP will issue permits for all phase 5 facilities with monitoring and reporting for Total Nitrogen (TN) and Total Phosphorus (TP) throughout the permit term at a frequency no less than annually. Furthermore, DEP's SOP No. BPNPSM-PMT-033 states that in general, at a minimum, monitoring for TN and TP should be included in new and reissued permits for sewage discharges with design flows > 2,000 gpd. At this time, the Department is not requiring a total maximum annual nitrogen or phosphorus loading cap. Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, and TN monitoring is already included in the existing permit and will remain in the proposed renewal.

The quarterly "Monitor & Report" requirements for Nitrate-Nitrite as N, and Total Kjeldahl Nitrogen; and quarterly calculation "Monitor & Report" for TN will remain in the proposed permit.

**Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

**303(d) Listed Streams:**

The stream is listed as attaining its designated use(s).

**WQM 7.0:**

The following data were used in the attached computer model (WQM 7.0) of the stream:

- Discharge pH 7.0 (Default per 391-2000-007)
- Discharge Temperature 20°C (Default per 391-2000-013)
- Stream pH 7.0 (Default per 392-2000-013)
- Stream Temperature 25°C (Default per 392-2000-013)

The following two nodes were used in modeling:

Node 1: Outfall 001 to UNT to Plum Run (59062)  
 Elevation: 452 ft (USGS National Map Viewer)  
 Drainage Area: 0.11 mi<sup>2</sup> (USGS PA StreamStats)  
 River Mile Index: 0.8 (PA DEP eMapPA)  
 Low Flow Yield: 0.013 cfs/mi<sup>2</sup>  
 Discharge Flow: 0.042 MGD

Node 2: At 59062 confluence with Plum Run  
 Elevation: 398 ft (USGS National Map Viewer)  
 Drainage Area: 0.35 mi<sup>2</sup> (USGS PA StreamStats)  
 River Mile Index: 0.001 (PA DEP eMapPA)  
 Low Flow Yield: 0.013 cfs/mi<sup>2</sup>  
 Discharge Flow: 0.0 MGD

The screenshot displays the USGS StreamStats web application interface. On the left is a navigation sidebar with options like 'SELECT A STATE / REGION' (Pennsylvania), 'IDENTIFY A STUDY AREA' (Basin Delineated), and 'BUILD A REPORT'. The main content area is divided into two sections: 'Basin Characteristics' and 'Low-Flow Statistics'.

**Basin Characteristics Table:**

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	0.11	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	4.2	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.55	miles per square mile

**Low-Flow Statistics Parameters Table:**

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.11	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	2.55	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.2	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

A warning message is displayed: "One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors."

**Low-Flow Statistics Flow Report Table:**

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.00448	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.00696	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.00138	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.00216	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.00418	ft <sup>3</sup> /s



**USGS StreamStats**

SELECT A STATE / REGION  
Pennsylvania

IDENTIFY A STUDY AREA  
Basin Delineated

SELECT SCENARIOS

**BUILD A REPORT** Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

**Basin Characteristics**

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	0.35	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	4.2	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	3.16	miles per square mile

**Low-Flow Statistics**

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.35	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	3.16	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.2	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0132	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.0203	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.00427	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.00661	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.0123	ft <sup>3</sup> /s

Low-Flow Statistics Citations

**Analysis Results WQM 7.0**

Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | **Effluent Limitations**

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.80	Round Top Camp	PA0081051	0.0420

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	1.93	3.86	
Dissolved Oxygen			6

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

rptEffLimits

### WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name	Discharge Point	Parameter	E/T Limit (mg/L)	E/T Limit (mg/L)	E/T Limit (mg/L)
130	50052	Trlb 50052 to Plum Run					
0.000	Round Top Camp	FR0010101	0.042	CSODS	25		
				NH5-N	1.03	3.96	
				Dissolved Oxygen			6

Thursday, May 25, 2023 Version 1.1 Page 1 of 1

rpt\_WLA

### WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name	Baseline Discharge (mg/L)	Baseline WLA (mg/L)	Multiple Criteria (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
<b>NH5-N Acute Allocations</b>								
0.000	Round Top Camp		16.66	16.0	16.66	16.0	0	0
<b>NH5-N Chronic Allocations</b>								
0.000	Round Top Camp		1.57	1.03	1.57	1.03	0	0
<b>Dissolved Oxygen Allocations</b>								
0.000	Round Top Camp		25	25	1.03	1.03	6	6

Thursday, May 25, 2023 Version 1.1 Page 1 of 1

rptDOSim

### WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name	Total Discharge (mg/L)	Analysis Temperature (°C)	Analysis pH
0.000			0.042	20.708	7.000
2.305			0.56	6.467	0.001
243.0			14.96	1.88	0.706
6.048			27.276	Overse	6

Reach Width (ft)	Reach Depth (ft)	Reach Velocity (ft/s)	Reach Velocity (ft/s)
2.305	0.56	6.467	0.001
243.0	14.96	1.88	0.706
6.048	27.276	Overse	6

Travel Time (days)	CSODS (mg/L)	NH5-N (mg/L)	O.D. (mg/L)
0.080	22.39	1.81	6.83
0.121	20.44	1.73	7.12
0.161	18.66	1.66	7.30
0.242	17.04	1.59	7.46
0.302	15.56	1.52	7.59
0.362	14.21	1.46	7.72
0.423	12.98	1.40	7.84
0.483	11.85	1.34	7.94
0.544	10.82	1.28	8.04
0.604	9.89	1.23	8.13

Thursday, May 25, 2023 Version 1.1 Page 1 of 1

rptModelSpecs

### WQM 7.0 Modeling Specifications

Parameter	Value	Use Inputted Q1-10 and Q35-10 Flows
WLA Method	EMPR	<input type="checkbox"/>
Q1-10/Q1-10 Ratio	0.84	<input type="checkbox"/>
Q35-10/Q1-10 Ratio	1.36	<input type="checkbox"/>
O.D. Substition	90.00%	<input type="checkbox"/>
O.D. Goal	6	<input checked="" type="checkbox"/>
		Use Inputted Reach Travel Times
		Temperature Adjust. For
		Use Selected Technology

Thursday, May 25, 2023 Version 1.1 Page 1 of 1

rptHydro

### WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name	Trib 59062 to Plum Run										
130	59062	Trib 59062 to Plum Run											
RMI	Stream Flow (cfs)	PWS With Flow (cfs)	Net Stream Flow (cfs)	Disc. Flow (cfs)	Reach Slope (ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (ft/sec)	Reach Time (days)	Analysis Temp (°C)	Analysis pH	
Q7-10 Flow	0.00	0.00	0.00	0.00	.065	0.01280	.396	2.31	64.9	0.08	0.004	20.11	7.00
Q1-10 Flow	0.00	0.00	0.00	0.00	.065	0.01280	NA	NA	NA	0.08	0.007	20.07	7.00
Q30-10 Flow	0.00	0.00	0.00	0.00	.065	0.01280	NA	NA	NA	0.08	0.001	20.10	7.00

Thursday, May 25, 2023 Version 1.1 Page 1 of 1

rptGeneral

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sqm)	Slope (ft)	PWS Withdrawal (mgd)	Apply FC
130	59062	Trib 59062 to Plum Run	0.001	452.00	0.11	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (dsem)	Trib Flow (cfs)	Stream Flow (cfs)	Rich Flow Time (days)	Rich Velocity (ft/sec)	WD Ratio	Rich Width (ft)	Rich Depth (ft)	Temperature (°C)	Tributary pH	Stream Temp (°C)
Q7-10	0.013	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

#### Discharge Data

Name	Permit Number	Existing Disc. Flow (mgd)	Permitted Disc. Flow (mgd)	Design Disc. Flow (mgd)	Reactive Factor	Disc. Temp (°C)	Disc. pH
Round Top Camp	PA0081051	0.0000	0.0420	0.0420	0.000	20.00	7.00

#### Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib Conc. (mg/L)	Stream Conc. (mg/L)	Fake Coef. (1/days)
CSOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NP3-N	25.00	0.00	0.00	0.70

Thursday, May 25, 2023 Version 1.1 Page 1 of 2

rptGeneral

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sqm)	Slope (ft)	PWS Withdrawal (mgd)	Apply FC
130	59062	Trib 59062 to Plum Run	0.001	358.00	0.35	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (dsem)	Trib Flow (cfs)	Stream Flow (cfs)	Rich Flow Time (days)	Rich Velocity (ft/sec)	WD Ratio	Rich Width (ft)	Rich Depth (ft)	Temperature (°C)	Tributary pH	Stream Temp (°C)
Q7-10	0.013	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

#### Discharge Data

Name	Permit Number	Existing Disc. Flow (mgd)	Permitted Disc. Flow (mgd)	Design Disc. Flow (mgd)	Reactive Factor	Disc. Temp (°C)	Disc. pH
Round Top Camp	PA0081051	0.0000	0.0000	0.0000	0.000	20.00	7.00


#### Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib Conc. (mg/L)	Stream Conc. (mg/L)	Fake Coef. (1/days)
CSOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NP3-N	25.00	0.00	0.00	0.70

Thursday, May 25, 2023 Version 1.1 Page 2 of 2

NPDES Permit Fact Sheet  
Round Top Campground

NPDES Permit No. PA0081051





**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD5	XXX	XXX	XXX	10.0	XXX	20	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Ammonia May 1 - Oct 31	Report	XXX	XXX	1.0	XXX	2.0	2/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	3.0	XXX	6.0	2/month	24-Hr Composite
Total Phosphorus	Report	XXX	XXX	1.5	XXX	3.0	2/month	24-Hr Composite
Nitrate-Nitrite as N	Report Qrtly	XXX	XXX	Report Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Kjeldahl Nitrogen	Report Qrtly	XXX	XXX	Report Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Nitrogen	Report Qrtly	XXX	XXX	Report Qrtly	XXX	XXX	1/quarter	Calculation

<b>Proposed Effluent Limitations and Monitoring Requirements</b>
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Daily Max	XXX	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD <sub>5</sub>	XXX	XXX	XXX	10.0	XXX	20	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia May 1 - Oct 31	Report	XXX	XXX	1.0	XXX	2.0	2/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	3.0	XXX	6.0	2/month	24-Hr Composite
Total Phosphorus	Report	XXX	XXX	1.5	XXX	3.0	2/month	24-Hr Composite
TKN	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Nitrate-Nitrite	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Nitrogen	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Calculation

Compliance Sampling Location:





Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: SOP No. BCW-PMT-033
<input type="checkbox"/>	Other: [redacted]