

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0081132
 APS ID 274668
 Authorization ID 1456431

Applicant and Facility Information

Applicant Name	<u>Solanco School District</u>	Facility Name	<u>Solanco Swift Middle School</u>
Applicant Address	<u>121 S Hess Street</u> <u>Quarryville, PA 17566</u>	Facility Address	<u>1866 Robert Fulton Highway</u> <u>Quarryville, PA 17566</u>
Applicant Contact	<u>Bruce Bennett</u>	Facility Contact	<u>Bruce Bennett</u>
Applicant Phone	<u>(717) 940-6138</u>	Facility Phone	<u>(717) 940-6138</u>
Client ID	<u>40172</u>	Site ID	<u>451659</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Fulton Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lancaster</u>
Date Application Received	<u>September 29, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 5, 2023</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Renewal.</u>		

Summary of Review

Solanco School District has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The existing permit was issued March 28, 2019, and became effective on April 1, 2019, authorizing discharge of treated sewage from the facility into Conowingo Creek. The existing permit expiration date was March 31, 2024, and the permit has been administratively extended since that time.

Changes in this renewal: E. Coli monitoring has been added to the permit.

Sludge use and disposal description and location(s): Sludge holding tank with offsite disposal.

Supplemental information for this facility is provided at the end of this fact sheet.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	March 28, 2024
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	April 15, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.01</u>
Latitude	<u>39° 48' 32.07"</u>	Longitude	<u>76° 10' 0.66"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Conowingo Creek (CWF)</u>	Stream Code	<u>7162</u>
NHD Com ID	<u>57470347</u>	RMI	<u>7.97</u>
Drainage Area	<u>14.5 mi²</u>	Yield (cfs/mi ²)	<u>0.099</u>
Q ₇₋₁₀ Flow (cfs)	<u>1.43</u>	Q ₇₋₁₀ Basis	<u>USGS PA StreamStats</u>
Elevation (ft)	<u>370</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>7-K</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>N/A</u>	Exceptions to Criteria	<u>N/A</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Nutrients, Siltation, Habitat Alterations</u>		
Source(s) of Impairment	<u>Agriculture, Habitat Modification – Other Than Hydromodification</u>		
TMDL Status	<u>Final</u>	Name	<u>Conowingo Creek</u>
Nearest Downstream Public Water Supply Intake	<u>Bainbridge, MD</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>20</u>

Changes Since Last Permit Issuance: USGS PA StreamStats provided a drainage area of 14.5 mi² and a Q₇₋₁₀ flow of 1.43 cfs at the point of discharge.

Other Comments: None

Treatment Facility Summary				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Ultraviolet	0.01
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.01		Not Overloaded	Holding Tank	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The WWTP consists of: Equalization tank, aeration tank, clarifier, dosing tank, three sand beds, UV disinfection, Outfall 001 to Conowingo Creek.

Compliance History	
Summary of DMRs:	A summary of past DMR effluent data is presented on the next page of this fact sheet.
Summary of Inspections:	11/3/2021: A routine inspection was conducted. Field samples were within permitted limits. The outfall was inspected; it was overgrown and the discharge pipe was not visible. No other issues were noted.

Other Comments: There are no open violations for this Applicant for the Clean Water Program.

Compliance History

DMR Data for Outfall 001 (from February 1, 2023 to January 31, 2024)

Parameter	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23
Flow (MGD) Average Monthly	0.005	0.004	0.008	0.007	0.007	0.009	0.004	0.003	0.004	0.004	0.004	0.004
Flow (MGD) Daily Maximum	0.01	0.01	0.1	0.009	0.02	0.07	0.02	0.005	0.007	0.007	0.008	0.007
pH (S.U.) Instantaneous Minimum	6.3	6.2	6.0	6.3	6.4	6.2	6.5	6.4	6.2	6.2	6.3	6.4
pH (S.U.) Instantaneous Maximum	8.3	7.4	7.8	7.7	8.0	8.1	7.2	7.9	6.8	6.8	6.9	6.8
DO (mg/L) Instantaneous Minimum	6.5	5.9	5.4	5.8	6.6	6.5	6.7	7.1	7.0	7.3	8.0	8.1
CBOD5 (lbs/day) Average Monthly	0.4	< 0.08	< 0.2	< 0.1	< 0.09	< 0.04	0.05	< 0.03	< 0.09	< 0.08	< 0.08	< 0.2
CBOD5 (lbs/day) Weekly Average	0.5	< 0.08	0.2	< 0.1	< 0.1	< 0.05	0.07	< 0.03	< 0.1	0.1	0.1	0.2
CBOD5 (mg/L) Average Monthly	9.12	< 2.0	< 2.7	< 2.0	< 2.0	< 2.0	3.2	< 2.0	< 2.0	5.2	< 2.0	< 3.1
CBOD5 (mg/L) Weekly Average	0.5	< 2.0	3.0	< 2.0	< 2.0	< 2.0	4.0	< 2.0	< 2.0	6.0	2.0	4.0
TSS (lbs/day) Average Monthly	< 0.2	< 0.2	< 0.4	< 0.3	< 0.3	< 0.1	< 0.1	< 0.08	< 0.2	< 0.2	< 0.2	< 0.3
TSS (lbs/day) Weekly Average	< 0.3	< 0.2	0.5	0.3	< 0.3	0.2	0.2	< 0.08	< 0.3	< 0.2	< 0.3	< 0.3
TSS (mg/L) Average Monthly	< 5.0	< 5.5	< 6.0	< 5.0	< 7.0	< 6.5	< 7.0	< 5.0	< 5.0	< 5.0	< 5.5	< 5.0
TSS (mg/L) Weekly Average	< 5.0	< 0.2	7.0	5.0	9.0	8.0	9.0	< 5.0	< 5.0	< 5.0	6.0	< 5.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 1.0	3	< 1	< 1	18	31	< 1	< 2	< 1	< 1	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1.0	< 1.0	4	1.0	< 1	42	32	< 1	3	< 1	< 1	1
Nitrate-Nitrite (mg/L) Annual Average		50.2										

**NPDES Permit Fact Sheet
Solanco Swift Middle School**

NPDES Permit No. PA0081132

Total Nitrogen (mg/L) Annual Average		< 51.2										
Ammonia (mg/L) Annual Average		6.19										
TKN (mg/L) Annual Average		< 1.0										
Total Phosphorus (mg/L) Annual Average		4.8										

Existing Effluent Limitations and Monitoring Requirements

Outfall 001

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	Report	Report	XXX	25.0	40.0	50	2/month	24-Hr Composite
Total Suspended Solids	Report	Report	XXX	30.0	45.0	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite as N	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Ammonia-Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Kjeldahl Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.01</u>
Latitude <u>39° 48' 32.07"</u>	Longitude <u>76° 10' 0.66"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

CBOD₅, NH₃-N

Pursuant to 40 CFR § 122.44(d)(1)(i), more stringent requirements should be considered when pollutants are discharged at the levels which have the reasonable potential to cause or contribute to excursions above water quality standards.

WQM 7.0 ver. 1.1b is a water quality model designed to assist DEP in determining appropriate water quality based effluent limits (WQBELs) for carbonaceous biochemical oxygen demand (CBOD₅), ammonia (NH₃-N) and dissolved oxygen (D.O.). DEP's Technical Guidance No. 391-2000-007 provides the technical methods contained in WQM 7.0 for determining wasteload allocations and for determining recommended NPDES effluent limits for point source discharges. The model was utilized for this permit renewal. The model output indicated a CBOD₅ average monthly limit of 25 mg/l, an NH₃-N average monthly limit of 25 mg/l, and a D.O. minimum limit of 5.0 mg/l were protective of water quality. The flow data used to run the model was acquired from USGS PA StreamStats and is included as an attachment. The CBOD₅ limit is the same as the existing permit limit, which will remain in the permit. DEP's SOP No. BCW-PMT-033 states that, "for existing discharges, if WQM modeling results for summer indicates that an average monthly limit of 25 mg/l is acceptable, the application manager will generally establish a year-round monitoring requirement for ammonia-nitrogen, at a minimum. This is consistent with the existing monitoring requirement for ammonia-nitrogen.

There are no industrial/commercial users contributing industrial wastewater to the system and Solanco School District does not currently have an EPA-approved pretreatment program. Accordingly, evaluating reasonable potential of toxic pollutants is not necessary as effluent levels of toxic pollutants are expected to be insignificant.

Additional Considerations

Chesapeake Bay Total Maximum Daily Load (TMDL)

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the *Pennsylvania Chesapeake Watershed Implementation Plan (WIP)*, dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a *Phase 2 Watershed Implementation Plan Wastewater Supplement (Phase 2*

Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. A new update to the WIP was published as the Phase 3 WIP in August 2019. As part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on December 17, 2019, and is the basis for the development of any Chesapeake Bay related permit parameters. Sewage discharges have been prioritized based on their design flow to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual Cap Loads based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. For Phase 4 and 5 facilities, Cap Loads are not currently being implemented for renewed or amended permits for facilities that do not increase design flow.

This facility is considered a Phase 5 non-significant facility with a design flow less than 0.2 MGD but greater than 0.002 MGD. According to the Phase 3 WIP, TN and TP monitoring is recommended for this facility, which is consistent with the existing permit.

Conowingo Creek TMDL

This WWTP discharges into a local TMDL called the Conowingo Creek TMDL. The TMDL plan has been developed to improve the water quality in the Conowingo Creek Watershed. Excess nutrient and sediment loads from agriculture are causing the impairments. The TMDL does not include a wasteload allocation (WLA) for point sources, therefore there are not any additional monitoring requirements or limits for this facility.

Dissolved Oxygen

A minimum D.O. limit of 5.0 mg/L is a D.O. water quality criterion found in 25 Pa. Code § 93.7(a). This limit is included in the existing NPDES permit based BPJ. It is still recommended to include this limit in the draft permit to ensure that the facility continues to achieve compliance with DEP water quality standards.

Fecal Coliform

PA Code § 92a.47.(a)(4) requires a monthly average limit of 200/100 mL as a geometric mean and an instantaneous maximum limit not greater than 1,000/100 mL from May through September for fecal coliform. PA Code § 92a.47.(a)(5) requires a monthly average limit of 2,000/100 mL as a geometric mean and an instantaneous maximum limit not greater than 10,000/100 mL from October through April for fecal coliform. This is consistent with the existing permit limits.

E. Coli

PA Code § 92a.61 requires IMAX reporting of E. Coli. Per DEP's SOP No. BCW-PMT-033, sewage dischargers with a design flow of 0.002 – 0.05 mgd will include E. Coli monitoring with a frequency of 1/year. This parameter has been added to the renewal permit.

Ultraviolet (UV) Monitoring

DEP's SOP No. BPNPSM-PMT-033 recommends at a minimum, routine monitoring of UV transmittance, dosage, or intensity when the facility is utilizing a UV disinfection system. The monitoring should occur at the same frequency as would be used for TRC. Presumably, this recommendation was implemented as a part of the proper operation and maintenance requirement specified in Part B of the NPDES permit, requesting permittees to demonstrate the effectiveness of UV disinfection system. However, per the previous fact sheet, this facility was constructed prior to the requirement for UV monitoring. Bruce Bennett stated that the facility does not have capabilities to monitor the UV system, and requested that UV monitoring be waived. Therefore, UV monitoring will not be required as part of this permit. Should the facility upgrade the UV equipment in the future, UV monitoring would be incorporated into the permit.

Sampling Frequency & Sample Type

The monitoring requirements were established based on BPJ and/or Table 6-3 of DEP's Technical Guidance No. 362-0400-001.

Anti-Degradation

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303(d) Listed Streams

The discharge is located on a stream segment that is designated on the 303(d) list as impaired. There is an aquatic life impairment for siltation and nutrients due to agriculture, and habitat alterations due to habit modification – other than hydromodification.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit unless any exceptions are addressed by DEP in this fact sheet.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	Report	Report	XXX	25.0	40.0	50	2/month	24-Hr Composite
TSS	Report	Report	XXX	30.0	45.0	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Ammonia	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
TKN	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: None

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [redacted]

Map | eFacts Query | Advanced Query | Filter Plant Source Search

ESRI Streets & Imagery Topographic National Geographic

ESRI Navigation Tools: [Zoom In] [Zoom Out] [Home] [Previous View] [Next View] [Full Screen] [Layers] [Help] [Print]

Locate Latitude and Longitude

Decimal Degrees DD/MM/SS

	Degrees	Minutes	Seconds
Latitude:	39	48	30
Longitude:	-76	9	30

Latitude: 39.808333 Longitude: -76.158333

Fulton House
(Birthplace of 401 Robert Fulton)


0 0.1 0.2mi

POWERED BY
esri

Copyright:© 2013 National Geographic Society, i-cubed

Solanco Swift Middle School PA0081132 Outfall 001

Region ID: PA
 Workspace ID: PA20240327140535536000
 Clicked Point (Latitude, Longitude): 39.80877, -76.16686
 Time: 2024-03-27 10:06:04 -0400



[-] Collapse All

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.9972	degrees
DRNAREA	Area that drains to a point on a stream	14.5	square miles
ROCKDEP	Depth to rock	5	feet
URBAN	Percentage of basin with urban development	1.2379	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	14.5	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	3.9972	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5	feet	4.13	5.21
URBAN	Percent Urban	1.2379	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	3.03	ft ³ /s	46	46
30 Day 2 Year Low Flow	3.93	ft ³ /s	38	38
7 Day 10 Year Low Flow	1.43	ft ³ /s	51	51
30 Day 10 Year Low Flow	1.89	ft ³ /s	46	46

Statistic	Value	Unit	SE	ASEp
90 Day 10 Year Low Flow	3.02	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.


USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.19.4
StreamStats Services Version: 1.2.22
NSS Services Version: 2.2.1

Solanco Swift Middle School PA0081132 RMI = 6.82

Region ID: PA
 Workspace ID: PA20240327141254225000
 Clicked Point (Latitude, Longitude): 39.79502, -76.16954
 Time: 2024-03-27 10:13:15 -0400



[-] Collapse All

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.8548	degrees
DRNAREA	Area that drains to a point on a stream	16.8	square miles
ROCKDEP	Depth to rock	5	feet
URBAN	Percentage of basin with urban development	1.097	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	16.8	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	3.8548	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5	feet	4.13	5.21
URBAN	Percent Urban	1.097	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	3.35	ft ³ /s	46	46
30 Day 2 Year Low Flow	4.37	ft ³ /s	38	38
7 Day 10 Year Low Flow	1.57	ft ³ /s	51	51
30 Day 10 Year Low Flow	2.08	ft ³ /s	46	46

Statistic	Value	Unit	SE	ASEp
90 Day 10 Year Low Flow	3.38	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.19.4
StreamStats Services Version: 1.2.22
NSS Services Version: 2.2.1

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07K	7162	CONOWINGO CREEK	7.970	370.00	14.50	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	1.43	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Solanco Swift	PA0081132	0.0100	0.0100	0.0100	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07K	7162	CONOWINGO CREEK	6.820	350.00	16.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	1.57	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
07K		7162				CONOWINGO CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
7.970	1.43	0.00	1.43	.0155	0.00329	.553	18.89	34.18	0.14	0.507	20.05	7.00
Q1-10 Flow												
7.970	0.92	0.00	0.92	.0155	0.00329	NA	NA	NA	0.11	0.649	20.08	7.00
Q30-10 Flow												
7.970	1.94	0.00	1.94	.0155	0.00329	NA	NA	NA	0.16	0.428	20.04	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
07K 7162 CONOWINGO CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	7.970 Solanco Swift	16.65	50	16.65	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	7.970 Solanco Swift	1.88	25	1.88	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	7.97 Solanco Swift	25	25	25	25	5	5	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07K	7162	CONOWINGO CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
7.970	0.010	20.054	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
18.887	0.553	34.181	0.139	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.25	0.129	0.27	0.703	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.208	4.340	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.507	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.051	2.23	0.26	8.23
	0.101	2.22	0.25	8.23
	0.152	2.20	0.24	8.23
	0.203	2.19	0.23	8.23
	0.254	2.17	0.22	8.23
	0.304	2.16	0.22	8.23
	0.355	2.15	0.21	8.23
	0.406	2.13	0.20	8.23
	0.457	2.12	0.19	8.23
	0.507	2.10	0.19	8.23