

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0081345

APS ID

311209

Authorization ID

1518090

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<u>Grier Foundation</u>	Facility Name	<u>Grier School</u>
Applicant Address	<u>2522 Grier School Road PO Box 308</u>	Facility Address	<u>2522 Grier School Road</u>
	<u>Tyrone, PA 16686-0308</u>		<u>Tyrone, PA 16686-5013</u>
Applicant Contact	<u>Geoffrey Grier</u>	Facility Contact	<u>Geoffrey Grier</u>
Applicant Phone	<u>(814) 684-3000</u>	Facility Phone	<u>(814) 684-3000</u>
Client ID	<u>43830</u>	Site ID	<u>453118</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Warriors Mark Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Huntingdon</u>
Date Application Received	<u>February 28, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 4, 2025</u>	If No, Reason	
Purpose of Application	<u>NPDES Permit Renewals.</u>		

**Summary of Review**

EADS Group, Inc., on behalf of Grier Foundation, has applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The permit was issued on August 25, 2020, became effective on September 1, 2020, and expired on August 31, 2025.

Grier School owns, operates, and maintains the wastewater treatment plant located in Warriors Mark Townships, Huntingdon County. The aeration secondary treatment plant discharges treated municipal wastewater to Little Juniata River, which is classified for High Quality-Cold Water Fishes (HQ-CWF). The facility has a design average annual flow of 0.0225 MGD.

WQM Part II No. 3113401 was issued in 1995. The WQM permit No. 3113401 A-1 was amended on 2/18/2014 to add aerobic sludge digestion capability to the treatment process. The WQM permit No. 3113401 A-2 was amended on 4/25/2024 to replace Chlorine disinfection to UV disinfection. The amendment construction project was done on 8/26/2025 and the plant was put into operation on 9/2/2025, *reference this factsheet pages 13 & 14.*

Sludge use and disposal description and location(s): N/A because sludge is hauled by Wilts Septic Service.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the proposed permit. The UV system daily monitor and report UV intensity ( $\mu\text{W}/\text{cm}^2$ ) included in the proposed permit.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	September 19, 2025
X		<i>Maria D Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	October 17, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0225
Latitude	40° 38' 42.86"	Longitude	-78° 11' 49.63"
Quad Name	Tyrone	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Little Juniata River (CWF)	Stream Code	15664
NHD Com ID	65604836	RMI	12.22 miles
Drainage Area	179 mi. <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.07
Q <sub>7-10</sub> Flow (cfs)	13.2	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	833	Slope (ft/ft)	
Watershed No.	11-A	Chapter 93 Class.	CWF
Existing Use	HQ-CWF	Existing Use Qualifier	Designated Class A Wild Trout
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	Mifflintown Borough Municipal Authority, Juniata County		
PWS Waters	Juniata River	Flow at Intake (cfs)	
PWS RMI	34.4 miles	Distance from Outfall (mi)	Approximate 80.0 miles

Changes Since Last Permit Issuance:

#### Drainage Area

The discharge is to Little Juniata River at RMI 12.2 miles. A drainage area upstream of the discharge is estimated to be 179 mi.<sup>2</sup>, according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

#### Stream Flow

According to USGS StreamStats, the point of first use at the confluence with Little Juniata River (Stream Code 15664) has a Q<sub>7-10</sub> of 13.2 cfs and a drainage area of 179 mi.<sup>2</sup>, which results in a Q<sub>7-10</sub> low flow yield of 0.07 cfs/mi.<sup>2</sup>. This information is used to obtain a chronic or 30-day (Q<sub>30-10</sub>), and an acute or 1-day (Q<sub>1-10</sub>) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 13.2 \text{ cfs} \\
 \text{Low Flow Yield} &= 13.2 \text{ cfs} / 179 \text{ mi.}^2 = 0.07 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 13.2 \text{ cfs} = 17.95 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 13.2 \text{ cfs} = 8.45 \text{ cfs}
 \end{aligned}$$

The resulting Q<sub>7-10</sub> dilution ratio is: Q<sub>stream</sub> / Q<sub>discharge</sub> = 13.2 cfs / [0.0225 MGD \* (1.55 cfs/MGD)] = 378.5:1

#### Little Juniata River

Under 25 Pa Code § 93.9n, the Little Juniata River is designated as Class A Wild Trout and HQ-CWF during the permit cycle. Since the discharge predates the designation and the stream is attaining its uses, no further action is warranted at this time. Integrate Report 2024, Little Juniata River (Assessment Unit ID 16851) is not impaired.

#### Potable Water Supply Intake

The nearest downstream public water supply intake is the Mifflintown Borough Municipal Authority, Juniata County intake on the Juniata River, approximately 80.0 miles from the point of discharge. Given the nature and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Grier School				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
3113401	1995			
3113401 A-1	2/18/2014			
3113401 A-2	4/25/2024			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Ultraviolet	0.0225
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0225		Not Overloaded	Aerobic Digestion	Combination of methods

Changes Since Last Permit Issuance:

Other Comments:

The WWTP train is as follows:

Comminutor / Bar Screen (1) ⇒ EQ inline type Aerated (1) ⇒ Aeration Tanks (3) ⇒ Final Clarifiers (2) ⇒ Fixed Media Filters (2) ⇒ UV Disinfection (1) ⇒ Post Aeration Tank (1) ⇒ Aerated Sludge Holding Tank (1) ⇒ Discharge to Little Juniata River

Biosolids:

The total sewage sludge/biosolids production within the facility for the previous year was 4.0 dry tons.

Industrial/Commercial Users:

The permit application indicated there are no commercial or industrial contributors to the treatment plant.

Compliance History	
<b>Summary of DMRs:</b>	DMRs reported last 12 months in the next page.
<b>Summary of Inspections:</b>	<p>8/26/2025: Mr. Clark, DEP WQS, conducted a partial inspection to check on the construction of the new sewage treatment plant. All of the treatment tanks were in place and the electrical work had been completed. The system was tested after being filled with clear water. The only problem found so far was a faulty module from the automatic D.O. blower control. A replacement unit had been ordered. The new treatment system is scheduled to go online next Tuesday (9/2/2025). There were no violations noted during the inspection.</p> <p>4/24/2025: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. Effluent was clear. The field test results were within permitted limits. There were no violations noted during inspection. Recommendations were: 1. Install an in-ground or external grease trap to kitchen drains to prevent oil and grease related problems at the treatment plant. 2. Perform routine process control testing on a regular basis and record all results. 3. Locate the outfall pipe.</p>
<b>Other Comments:</b>	There are no open violations associated with this facility or permittee.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from August 1, 2024 to July 31, 2025)

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Flow (MGD) Average Monthly	0.00157 2	0.00070 6	0.00330 2	0.00433 5	0.00219 6	0.00491 2	0.00274 4	0.00196	0.00381 8	0.00380 4	0.00336 5	0.00144
Flow (MGD) Daily Maximum	0.00627 4	0.00298	0.00738 2	0.00851 4	0.00642 9	0.00791 4	0.00959 2	0.00597 6	0.00648 1	0.00805 8	0.00845 0	0.00725 5
pH (S.U.) Daily Minimum	6.67	6.18	7.39	7.17	7.17	7.47	7.62	7.41	7.27	7.16	7.46	7.55
pH (S.U.) Instantaneous Maximum	8.15	8.08	8.31	8.24	8.52	7.78	8.75	8.4	8.12	7.89	8.47	8.53
DO (mg/L) Daily Minimum	7.84	8.28	6.51	8.41	9.89	7.8	11.1	8.72	7.13	9.36	9.5	8.07
TRC (mg/L) Average Monthly	0.3	0.2	0.4	0.3	0.4	0.3	0.3	0.3	0.3	0.3	0.2	0.3
TRC (mg/L) Instantaneous Maximum	0.53	1.08	0.85	0.63	0.93	0.63	0.73	0.78	0.53	0.56	0.43	0.89
CBOD5 (mg/L) Average Monthly	< 4.0	< 3.0	< 5.0	< 3.0	< 3.0	< 3.0	< 3.0	< 4.0	< 3.0	< 3.0	< 3.0	< 3.0
TSS (mg/L) Average Monthly	15	5.0	7.0	6.0	8.0	12.0	6.0	8.0	4.0	6.0	< 3.0	< 2.0
Fecal Coliform (No./100 ml) Geometric Mean	< 111	< 4.0	< 14.0	< 16.0	18	91	24	< 28	37	27	114	< 6.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	3080.4	4.0	48.4	63.2	20.8	665.6	34.4	201.6	39.2	182.8	774	8.0
Nitrate-Nitrite (mg/L) Average Quarterly		46.25			44.49			< 53.7			< 50.56	
Total Nitrogen (mg/L) Average Quarterly		< 46.75			< 44.99			< 54.20			< 51.06	
TKN (mg/L) Average Quarterly		< 0.5			< 0.50			< 0.50			< 0.50	
Total Phosphorus (mg/L) Average Quarterly		5.28			5.18			4.72			9.39	

Existing Effluent Limitations and Monitoring Requirements

Outfall 001.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD <sub>5</sub>	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
TKN	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Nitrate-Nitrite	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Calculation
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD <sub>5</sub>	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
TKN	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Nitrate-Nitrite	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Calculation
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite

Compliance Sampling Location:

Other Comments:

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 40° 38' 42.86"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.0225  
Longitude -78° 11' 49.63"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The facility utilizes UV disinfection.

**Water Quality-Based Limitations**

**Ammonia (NH<sub>3</sub>-N):**

NH<sub>3</sub>-N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached WQM 7.0 computer model of the stream:

- \* Discharge pH = 7.0 (Default)
- \* Discharge Temperature = 20°C (Default)
- \* Stream pH = 7.0 (Default)
- \* Stream Temperature = 20°C (Default for CWF)
- \* Background NH<sub>3</sub>-N = 0 mg/L (Default)

Analysis Results WQM 7.0

Hydrodynamics		NH <sub>3</sub> -N Allocations		D.O. Allocations		D.O. Simulation		Effluent Limitations																	
RMI	Discharge Name	Permit Number Disc Flow (mgd)																							
12.20	Grier School	PA0081345   0.0225																							
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Effluent Limit 30 Day Average (mg/L)</th> <th>Effluent Limit Maximum (mg/L)</th> <th>Effluent Limit Minimum (mg/L)</th> </tr> </thead> <tbody> <tr> <td>CBOD<sub>5</sub></td> <td>25</td> <td></td> <td></td> </tr> <tr> <td>NH<sub>3</sub>-N</td> <td>25</td> <td>50</td> <td></td> </tr> <tr> <td>Dissolved Oxygen</td> <td></td> <td></td> <td>5</td> </tr> </tbody> </table>										Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)	CBOD <sub>5</sub>	25			NH <sub>3</sub> -N	25	50		Dissolved Oxygen			5
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)																						
CBOD <sub>5</sub>	25																								
NH <sub>3</sub> -N	25	50																							
Dissolved Oxygen			5																						
Record: 1 of 1   < Back   Next >   No Filter   Search																									
<input type="button" value="Print"/>		<input type="button" value="Archive"/>		<input type="button" value="Cancel"/>																					

The attached computer printout of the WQM 7.0 stream model indicates that no limitation on NH<sub>3</sub>-N as a monthly average is necessary to protect the aquatic life from toxicity effects.

**Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>):**

The attached computer printout of the WQM 7.0 stream model indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing limits of 25.0 mg/L monthly average, and 50.0 mg/L instantaneous maximum will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

**Dissolved Oxygen (D.O.):**

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

**Fecal Coliform:**

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

**E. Coli:**

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

**Total Suspended Solids (TSS):**

The existing technology-based limits of 30.0 mg/L average monthly, and 60.0 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

**pH:**

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa Code § 95.2(1).

**UV:**

The UV system daily monitor and report the UV intensity ( $\mu\text{W}/\text{cm}^2$ ) after update to replace chlorine disinfection system will be in the proposed permit.

**Chesapeake Bay Strategy:**

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases I, II, and III) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase IV (0.2 -0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase V (below 0.2 MGD) will monitor during current permit renewal once a year. However, any facility in Phases IV and V that undergoes expansion is subjected to cap load right away. This plant, classified as a phase V, will be required to monitor and report for Total Phosphorus, Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, and Total Nitrogen.

Additionally, according to SOP for establishing effluent limitation for individual sewage, monitoring frequency for nutrients should be equivalent to conventional pollutants in Table 6-3 of DEP's *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001) ("Permit Writer's Manual") where the facility discharges to nutrient-impaired waters, or a lesser frequency for discharges to waters not impaired for nutrients. Quarterly monitoring frequency is required for this discharge since the receiving stream is not nutrient impaired. These requirements will remain in the proposed permit.

**Stormwater:**

There is no stormwater outfall associated with this facility.

**Toxics:**

Review of the permit application revealed no toxic parameters of concern. The application states that there are no industrial wastewater contributions.

**Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**303d Listed Streams:**

The discharge is not located on a 303d listed stream segment.

**Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

**WQM 7.0**

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	20°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	20°C	(Default for CWF)
*	Background NH <sub>3</sub> -N	=	0 mg/L	(Default)

Node 1: Outfall 001 on Little Juniata River (15664)

Elevation: 832.85 ft (USGS National Map Viewer)  
Drainage Area: 179 mi.<sup>2</sup> (USGS PA StreamStats)  
River Mile Index: 12.2 (PA DEP eMapPA)  
Low Flow Yield: 0.07 cfs/mi.<sup>2</sup>  
Discharge Flow: 0.0225 MGD (NPDES Application)

Node 2: Just before confluence Little Juniata River to Sinking Run

Elevation: 773.35 ft (USGS National Map Viewer)  
Drainage Area: 189 mi.<sup>2</sup> (USGS PA StreamStats)  
River Mile Index: 8.82 (PA DEP eMapPA)  
Low Flow Yield: 0.07 cfs/mi.<sup>2</sup>  
Discharge Flow: 0.000 MGD

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
12.20	Grier School	PA0081345	0.0225
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	25	50	
Dissolved Oxygen			5

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

NPDES Permit Fact Sheet  
Grier School

NPDES Permit No. PA0081345

**rptEffLimits**

**WQM 7.0 Effluent Limits**

SWP Basin	Stream Code	Stream Name	EFL Limit 30-day Ave.			
			Disch. Flow (mgd)	Parameter	EFL Limit Max (mg/L)	EFL Limit Min (mg/L)
11A	15664	LITTLE JUNIATA RIVER	0.023	CBOD5	25	
12,200	Grier School	PA0081345		NH3-N	25	50
				Dissolved Oxygen		5

Thursday, September 18, 2025 Version 1.1 Page 1 of 1

**rpt\_WLA**

**WQM 7.0 Wasteload Allocations**

SWP Basin	Stream Code	Stream Name	WLA					
			RMID	Discharge Name	Baseline Critical (mg/L)	Baseline WLA (mg/L)	Multiple Critical (mg/L)	Multiple WLA (mg/L)
11A	15664	LITTLE JUNIATA RIVER						
12,200	Grier School		16.70	00	16.70	50	0	0

**NH3-N Acute Allocations**

RMID	Discharge Name	Baseline Critical (mg/L)	Baseline WLA (mg/L)	Multiple Critical (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
12,200	Grier School	1.00	25	1.00	25	0	0

**NH3-N Chronic Allocations**

RMID	Discharge Name	CBOD5 (mg/L)	Baseline Critical (mg/L)	Baseline WLA (mg/L)	Multiple Critical (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
12,200	Grier School	25	25	25	25	5	0	0

**Dissolved Oxygen Allocations**

RMID	Discharge Name	CBOD5 (mg/L)	Baseline Critical (mg/L)	Baseline WLA (mg/L)	Multiple Critical (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
12,200	Grier School	25	25	25	25	5	0	0

Thursday, September 18, 2025 Version 1.1 Page 1 of 1

Page: 1 No Filter

Page: 1 No Filter

**rptDOSim**

**WQM 7.0 D.O. Simulation**

SWP Basin	Stream Code	Stream Name	Inputs			
			Total Discharge Flow (mgd)	Analytic Temp (degree C)	Analytic DO	
11A	15664	LITTLE JUNIATA RIVER	0.003	20.000	7.000	
12,200	Reach Width (ft)	Reach Depth (ft)	Reach WDRate	Reach Velocity (fts)		
37268	0.819		0.002	0.268		
Reach: CBOD5 (mg/L)	Reach Kc (1/day)	Reach NH3-N (mg/L)	Reach Kd (1/day)			
2.00	0.030	0.07	0.700			
Reach DO (mg/L)	Reach DO (1/day)	K1 Equation	Reach DO Load (mg/L)			
8.234	0.001	Takengou	0			
Reach Travel Time (days)	Substrate Results					
0.771	Trav Time	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)		
		(days)	(mg/L)	(mg/L)		
	0.077	2.00	0.07	8.23		
	0.154	2.00	0.06	8.24		
	0.231	2.00	0.06	8.24		
	0.309	2.00	0.06	8.24		
	0.386	2.00	0.05	8.24		
	0.463	2.00	0.05	8.24		
	0.540	2.00	0.05	8.24		
	0.617	2.00	0.04	8.24		
	0.694	2.00	0.04	8.24		
	0.771	2.00	0.04	8.24		

Thursday, September 18, 2025 Version 1.1 Page 1 of 1

**rptModelSpecs**

**WQM 7.0 Modeling Specifications**

Parameters	Value	Notes	
WIA Method	EMPR	Use Inputted Q1-10 and Q30-10 Flowrat	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.61	Use Inputted WIA Ratio	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Use Inputted Reach Travel Times	<input type="checkbox"/>
D.O. Saturation	90.00%	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Goal	5	Use Balanced Technology	<input checked="" type="checkbox"/>

Thursday, September 18, 2025 Version 1.1 Page 1 of 1

Page: 1 No Filter

Page: 1 No Filter

10

NPDES Permit Fact Sheet  
Grier School

NPDES Permit No. PA0081345

**rptHydro**

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin	Stream Code	Stream Name									
11A	15664	LITTLE JUNIATA RIVER									
RB	Shear Flow	PWS With Stream	Net Disch Flow	Reach Slope	Depth	Width	WD Ratio	Velocity	Reach Time	Analysis Temp	Analysis pH
(cfs)	(cfs)	(cfs)	(cfs)	(ft)	(ft)	(ft)	(ft)	(ft/s)	(days)	(°C)	
<b>Q7-10 Flow</b>											
12.000	12.53	0.00	12.53	.0348 0.00033	819	57.36	69.93	0.27	0.771	20.00	7.00
<b>Q1-10 Flow</b>											
12.000	8.03	0.00	8.02	.0348 0.00033	NA	NA	NA	0.21	0.660	20.00	7.00
<b>Q30-10 Flow</b>											
12.000	17.04	0.00	17.04	.0348 0.00033	NA	NA	NA	0.32	0.650	20.00	7.00

Thursday, September 18, 2003 Version 1.1 Page 1 of 1

**rptGeneral**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name									
11A	15664	LITTLE JUNIATA RIVER									
RBM	Elevation	Drainage Area (sq mi)	Slope (ft)	PWS Withdrawal (mgd)	Apply FC						
(ft)	(ft)	(sq mi)	(ft/ft)	(mgd)							
12.208 832.85 179.00 0.000000 0.00 <input checked="" type="checkbox"/>											
<b>Stream Data</b>											
Design Cond.	LFV	Trib Flow	Stream Flow	Rich Trav Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tributary Temp	Stream Temp	Stream pH
(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)	(ft)	(ft)	(°C)	(°C)		
Q7-10 0.070 0.00 0.00 0.0000 0.0000 0.0 0.00 0.00 20.00 7.00 0.00 0.00											
Q1-10 0.00 0.00 0.00 0.0000 0.0000 0.0 0.00 0.00 20.00 7.00 0.00 0.00											
Q30-10 0.00 0.00 0.00 0.0000 0.0000 0.0 0.00 0.00 20.00 7.00 0.00 0.00											
<b>Discharging Data</b>											
Name	Permit Number	Existing Design Disch Flow (mgd)	Permitted Design Disch Flow (mgd)	Design Factor	Disc Temp (°C)	Disc pH					
Grier School	PA0081345	0.0225	0.0225	0.0225	0.0000	20.00	7.00				
<b>Parameter Data</b>											
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Flow Coef (1/day)							
CB-ODS	25.00	2.00	0.00	1.50							
Dissolved Oxygen	5.00	8.24	0.00	0.00							
NH4-N	25.00	0.00	0.00	0.70							

Thursday, September 18, 2003 Version 1.1 Page 1 of 2

Page: 1

Page: 1

No Filter

No Filter

**rptGeneral**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name									
11A	15664	LITTLE JUNIATA RIVER									
RBM	Elevation	Drainage Area (sq mi)	Slope (ft)	PWS Withdrawal (mgd)	Apply FC						
(ft)	(ft)	(sq mi)	(ft/ft)	(mgd)							
12.208 832.85 179.00 0.000000 0.00 <input checked="" type="checkbox"/>											
<b>Stream Data</b>											
Design Cond.	LFV	Trib Flow	Stream Flow	Rich Trav Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tributary Temp	Stream Temp	Stream pH
(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)	(ft)	(ft)	(°C)	(°C)		
Q7-10 0.070 0.00 0.00 0.0000 0.0000 0.0 0.00 0.00 20.00 7.00 0.00 0.00											
Q1-10 0.00 0.00 0.00 0.0000 0.0000 0.0 0.00 0.00 20.00 7.00 0.00 0.00											
Q30-10 0.00 0.00 0.00 0.0000 0.0000 0.0 0.00 0.00 20.00 7.00 0.00 0.00											
<b>Discharging Data</b>											
Name	Permit Number	Existing Design Disch Flow (mgd)	Permitted Design Disch Flow (mgd)	Design Factor	Disc Temp (°C)	Disc pH					
Grier School	PA0081345	0.0000	0.0000	0.0000	20.00	7.00					
<b>Parameter Data</b>											
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Flow Coef (1/day)							
CB-ODS	25.00	2.00	0.00	1.50							
Dissolved Oxygen	5.00	8.24	0.00	0.00							
NH4-N	25.00	0.00	0.00	0.70							


Thursday, September 18, 2003 Version 1.1 Page 2 of 2

Page: 2

Page: 1

No Filter

No Filter



**USGS StreamStats**

**BUILD A REPORT** Report Built >

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the 'Build Report' button.

**Hide Basin Characteristics**

Basin Characteristics can be edited here

Parameter	Value
DRNAREA	179
PRECIP	40
STRDEN	1.85
ROCKDEP	4.4
CARBON	12.06

Select available reports to display:

- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports
- Hydrologic Features Report

**Open Report**

POWERED BY WIM

Zoom Map Scale: Lat: 40.645239 Long: -78.197119

5 km 3 mi

**Basin Characteristics**

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	12.06	percent
DRNAREA	Area that drains to a point on a stream	179	square miles
PRECIP	Mean Annual Precipitation	40	inches
ROCKDEP	Depth to rock	4.4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.85	miles per square mile

**Low-Flow Statistics**

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
CARBON	Percent Carbonate	12.06	percent	0	99
DRNAREA	Drainage Area	179	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	40	inches	35	50.4
ROCKDEP	Depth to Rock	4.4	feet	3.32	5.65
STRDEN	Stream Density	1.85	miles per square mile	0.51	3.1

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	24.3	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	31.3	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	13.2	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	17.1	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	24.5	ft <sup>3</sup> /s	36	36

Batch Processor Report About ? Help


Layers

Base Maps Application Layers

National Layers

PA Map Layers

12



[External] RE: Follow Up is the Grier Foundation WQM Part II No. 3113401 A-2 modification construction complete or not?

○ Dan Beyer <dbeyer@eadsgroup.com>  
 To ○ Le, Hilary  
 Cc ○ ggrier@grier.org; ○ Brian Bloom; ○ Sam McCloskey  
 ⓘ You replied to this message on 9/17/2025 3:29 PM.

 20250915160820726.pdf  
 203 KB

Wed 9/17/2025 3:24 PM

**ATTENTION:** This email message is from an external sender. Do not open links or attachments from unknown senders. To report suspicious email, use the [Report Phishing button in Outlook](#).

Good afternoon Hilary,

The construction of the new WWTP was just completed on August 26, 2025. The owner is in the process of signing the construction certification.


Thanks,



Daniel Beyer, P.E.  
Municipal/Site Department Manager







814.944.5035 ext. 136  
814.659.4552 mobile  
1126 8th Ave., Altoona, PA 16602

[dbeyer@eadsgroup.com](mailto:dbeyer@eadsgroup.com)



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

WATER QUALITY MANAGEMENT  
POST CONSTRUCTION CERTIFICATION

PERMITTEE IDENTIFIER																									
Permittee	Grier Foundation																								
Municipality	Warriors Mark Township																								
County	Huntingdon																								
WQM Permit No.	<u>3113401 A-2</u>																								
Facility Type	Sewage																								
All of the above information should be taken directly from the Water Quality Management Permit.																									
CERTIFICATION																									
<p>This certification must be completed and returned to the permits section of the DEP's regional office issuing the WQM permit within 30 days of completion of the project and received by DEP prior to operation, and if requested, as-built drawings, photographs (if available) and a discussion of any DEP-approved deviations from the design plans during construction.</p> <p>I, being a Registered Professional Engineer in Pennsylvania, do hereby certify to the best of my knowledge and belief, based upon personal observation and interviews, that the above facility approved under the Water Quality Management Permit has been constructed in accordance with the plans, specifications and modifications approved by DEP.</p>																									
Construction Completion Date (MM/DD/YYYY):	09/02/2025																								
 Engineer s Seal	<table border="1"> <thead> <tr> <th colspan="2">Professional Engineer</th> </tr> </thead> <tbody> <tr> <td>Name</td> <td>Daniel J. Beyer (Please Print or Type)</td> </tr> <tr> <td>Signature</td> <td></td> </tr> <tr> <td>Date</td> <td>09/18/2025</td> </tr> <tr> <td>License Expiration Date</td> <td>09/30/2025</td> </tr> <tr> <td>Firm or Agency</td> <td>The EADS Group, Inc.</td> </tr> <tr> <td>Telephone</td> <td>814-944-5035</td> </tr> <tr> <th colspan="2">Permittee or Authorized Representative</th> </tr> <tr> <td>Name</td> <td>Geoffrey Grier (Please Print or Type)</td> </tr> <tr> <td>Signature</td> <td></td> </tr> <tr> <td>Title</td> <td>President, The Grier Foundation</td> </tr> <tr> <td>Telephone</td> <td>814-684-3000</td> </tr> </tbody> </table>	Professional Engineer		Name	Daniel J. Beyer (Please Print or Type)	Signature		Date	09/18/2025	License Expiration Date	09/30/2025	Firm or Agency	The EADS Group, Inc.	Telephone	814-944-5035	Permittee or Authorized Representative		Name	Geoffrey Grier (Please Print or Type)	Signature		Title	President, The Grier Foundation	Telephone	814-684-3000
Professional Engineer																									
Name	Daniel J. Beyer (Please Print or Type)																								
Signature																									
Date	09/18/2025																								
License Expiration Date	09/30/2025																								
Firm or Agency	The EADS Group, Inc.																								
Telephone	814-944-5035																								
Permittee or Authorized Representative																									
Name	Geoffrey Grier (Please Print or Type)																								
Signature																									
Title	President, The Grier Foundation																								
Telephone	814-684-3000																								

RE: [External] RE: Follow Up is the Grier Foundation WQM Part II No. 3113401 A-2 modification construction complete or not?

Dan Beyer <dbeyer@eadsgroup.com>  
 To:  Le, Hilary  
 Cc:  ggrier@grier.org;  Brian Bloom;  Sam McCloskey

Thu 9/18/2025 8:52 AM

 Waste Quality Management Certification Sep 18 2025.pdf  
 369 KB

Good morning Hilary,

Please find attached the completed/signed Post Construction Certification. Please note that I revised the date on the form to match when the plant was put into operation. The plant was put into operation on September 2, 2025.

Thanks,  
Dan

**From:** Le, Hilary <hle@pa.gov>  
**Sent:** Wednesday, September 17, 2025 3:29 PM  
**To:** Dan Beyer <dbeyer@eadsgroup.com>  
**Cc:** ggrier@grier.org; Brian Bloom <bbloom@eadsgroup.com>; Sam McCloskey <sam@mccloskeybuilders.com>  
**Subject:** RE: [External] RE: Follow Up is the Grier Foundation WQM Part II No. 3113401 A-2 modification construction complete or not?  
  
 — — —

**Warning: Unusual sender** <hle@pa.gov>  
 You don't usually receive emails from this address. Make sure you trust this sender before taking any actions.

Thanks Dan! Can you please provide the date when the new plant started operation?

Thanks!  
Hilary

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]