

Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0081574
APS ID 69
Authorization ID 1489344

Applicant and Facility Information

Applicant Name	<u>Salisbury Township</u>	Facility Name	<u>Salisbury Township Gap STP</u>
Applicant Address	<u>5581 Old Philadelphia Pike</u>	Facility Address	<u>5350 Park Avenue</u>
	<u>Gap, PA 17527-9791</u>		<u>Gap, PA 17527</u>
Applicant Contact	<u>Kirsten Peachey</u>	Facility Contact	<u>Brian Norris</u>
Applicant Phone	<u>(717) 768-8059</u>	Facility Phone	<u>(610) 633-8009</u>
Client ID	<u>35929</u>	Site ID	<u>452223</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Salisbury Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lancaster</u>
Date Application Received	<u>June 20, 2024</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>June 20, 2024</u>	If No, Reason	<u>Significant CB Discharge</u>
Purpose of Application	<u>NPDES Renewal.</u>		

Summary of Review

Salisbury Township has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The existing permit was issued December 13, 2019, and became effective on January 1, 2020, authorizing discharge of treated sewage from the facility into UNT to Pequea Creek. The existing permit expiration date was December 31, 2024, and the permit has been administratively extended since that time.

Per the previous fact sheet, Salisbury TWP Gap STP was originally designed for 0.06 million gallons per day (MGD) in the early 1980s to serve the Village of Gap. The facility was expanded several times over the years, with a third expansion to 0.58 MGD in 2007. In 2007, the 0.1 MGD extended aeration plant was demolished, and the 0.24 MGD aboveground extended aeration tank and clarifiers were converted to 0.58 MGD sequencing batch reactors (SBRs). This conversion used the Aqua PASS Phased Activated Sludge System with the addition of two 40' diameter clarifiers (Part II Permit No. 3605414). The existing equalization (EQ) tank was divided into anaerobic/anoxic/oxic stages to promote nutrient removal. Construction was completed around May 15, 2008. The units are followed by ultraviolet (UV) disinfection. The new plant was designed for Total Phosphorus (TP) and Total Nitrogen (TN) nutrient removal in anticipation of the Chesapeake Bay requirements.

Changes in this renewal: Total Copper and Total Zinc monitoring have been added to the permit. E. Coli monitoring has been added to the permit.

Sludge use and disposal description and location(s): Sludge holding tank with offsite disposal.

Supplemental information for this facility is provided at the end of this fact sheet.

Public Participation

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	February 13, 2025
X		Maria D. Bebeneck for Daniel W. Martin, P.E. / Environmental Engineer Manager	March 7, 2025

Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	.58
Latitude	39° 59' 43.5"	Longitude	76° 1' 13.2"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary of Pequea Creek (CWF)	Stream Code	7533
NHD Com ID	57464113	RMI	0.32
Drainage Area	1.01 mi ²	Yield (cfs/mi ²)	0.132
Q ₇₋₁₀ Flow (cfs)	0.133	Q ₇₋₁₀ Basis	USGS PA StreamStats
Elevation (ft)	442	Slope (ft/ft)	
Watershed No.	7-K	Chapter 93 Class.	CWF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	Siltation, Nutrients, Organic Enrichment, Habitat Alterations, Siltation, Pathogens		
Source(s) of Impairment	Habitat Modification – Other Than Hydromodification, Agriculture, Agriculture, Habitat Modification – Other Than Hydromodification, Agriculture, Source Unknown		
TMDL Status	Final	Name	Pequea Creek
Nearest Downstream Public Water Supply Intake	Holtwood Power Plant		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	45

Changes Since Last Permit Issuance: None

Other Comments: USGS PA StreamStats provided a drainage area of 1.01 mi² and a Q₇₋₁₀ of 0.133 cfs at the point of discharge.

Treatment Facility Summary				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Total Nitrogen Reduction	Activated Sludge	Ultraviolet	0.58
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.68	1209	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The treatment process consists of: Pump Station, Pre-Anoxic Tank, Anoxic Tank, Stage Aeration Tanks, Primary Clarifiers, UV Disinfection, Re-Aeration Tank, Outfall 001 to UNT to Pequea Creek.

Compliance History	
Summary of DMRs:	A summary of past DMR effluent data is presented on the next page of this fact sheet.
Summary of Inspections:	6/23/2020: An administrative inspection was conducted. All treatment units were operable, and there were no outstanding needs at the time of inspection.

Other Comments: There are currently no open violations associated with the Applicant.

Existing Effluent Limitations and Monitoring Requirements

Outfall 001

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Ultraviolet light transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Carbonaceous Biochemical Oxygen Demand (CBOD5)	67	101	XXX	14	21	28	1/week	8-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Suspended Solids	145	218	XXX	30	45	60	1/week	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	29	XXX	XXX	6.0	XXX	12	1/week	24-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	9.7	XXX	XXX	2.0	XXX	4.0	1/week	24-Hr Composite
Total Phosphorus	9.7	XXX	XXX	2.0	XXX	4.0	1/week	24-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

Parameter	Effluent Limitations					Monitoring Requirements	
	Mass Units (lbs)		Concentrations (mg/L)			Minimum Measurement Frequency	Required Sample Type
	Monthly	Annual	Minimum	Monthly Average	Maximum		
Ammonia-N	Report	Report	XXX	Report	XXX	1/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	1/week	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	1/week	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	1/week	24-Hr Composite
Net Total Nitrogen	XXX	13,150	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	1,643	XXX	XXX	XXX	1/year	Calculation

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

Compliance History

DMR Data for Outfall 001 (from December 1, 2023 to November 30, 2024)

Parameter	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23
Flow (MGD) Average Monthly	0.23105	0.24189	0.25427	0.25890	0.24875	0.25937	0.30346	0.35015	0.29102	0.26418	0.29029	0.26590
Flow (MGD) Daily Maximum	0.25220	0.30010	0.32700	0.33690	0.32320	0.30320	0.33060	0.49620	0.35620	0.29710	0.40360	0.37480
pH (S.U.) Instantaneous Minimum	7.22	7.26	7.17	7.17	7.17	7.16	7.17	7.16	7.10	7.13	7.15	7.15
pH (S.U.) Instantaneous Maximum	7.42	7.46	7.44	7.45	7.49	7.42	7.42	7.44	7.37	7.42	7.34	7.80
DO (mg/L) Instantaneous Minimum	7.0	7.0	6.0	6.0	6.0	6.0	7.0	7.0	7.0	7.0	7.0	7.0
CBOD5 (lbs/day) Average Monthly	< 4.76	< 4.01	< 4.98	< 4.16	< 4.19	< 5.77	< 4.9	< 6.41	< 5.56	< 5.06	< 5.63	< 4.59
CBOD5 (lbs/day) Weekly Average	7.48	5.28	6.98	< 4.34	< 4.58	9.08	< 5.3	7.72	6.98	6.85	9.36	< 6.25
CBOD5 (mg/L) Average Monthly	< 2.48	< 2.12	< 2.23	< 2.0	< 2.0	< 2.65	< 2.0	< 2.44	< 2.43	< 2.3	< 2.38	< 2.0
CBOD5 (mg/L) Weekly Average	3.9	2.6	2.9	< 2.0	< 2.0	3.8	< 2.0	3.5	2.8	3.2	3.9	< 2.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	449.4	369.6	385.9	403.6	533.4	562.9	665.6	376.2	379.8	509.7	699.9	817.5
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	533.9	427.5	593.5	517.0	638.9	746.1	786.0	449.5	531.5	599.5	797.1	1242.3
BOD5 (mg/L) Raw Sewage Influent Average Monthly	222.5	190.4	173.0	193.8	258.8	266.0	272.5	139.0	164.5	233.3	295.2	372.5
TSS (lbs/day) Average Monthly	< 2.94	3.02	< 5.23	< 3.17	< 6.14	4.46	< 5.94	< 4.12	< 2.91	4.32	< 11.11	< 3.69
TSS (lbs/day) Raw Sewage Influent Average Monthly	382.5	356.0	402.3	386.4	387.1	384.9	609.6	343.0	338.5	454.2	784.6	591.5

NPDES Permit Fact Sheet
Salisbury Township Gap STP

NPDES Permit No. PA0081574

TSS (lbs/day) Raw Sewage Influent Daily Maximum	504.8	502.9	748.0	541.9	467.9	525.9	1024.4	520.5	657.2	673.0	1072.1	974.8
TSS (lbs/day) Weekly Average	4.15	5.85	12.03	6.52	11.46	7.17	13.75	6.62	4.99	8.56	19.21	7.47
TSS (mg/L) Average Monthly	< 1.5	1.6	< 2.25	< 1.5	< 2.8	2	< 2.5	< 1.6	< 1.25	2	< 4.6	< 1.75
TSS (mg/L) Raw Sewage Influent Average Monthly	188.8	181.6	182.0	188.5	186.4	179.5	251.3	125.4	145.0	207.8	331.4	277.0
TSS (mg/L) Weekly Average	2	3	5	3	5	3	6	3	2	4	8	4
Fecal Coliform (No./100 ml) Geometric Mean	< 3.6	< 5.7	< 7.8	< 2.4	< 2	< 4.4	< 7.1	< 4.6	< 17.6	< 2	< 6.2	< 2.5
Fecal Coliform (No./100 ml) Instantaneous Maximum	21	257	474	3	< 2	30	52	33	1850	< 2	42	5
UV Transmittance (%) Instantaneous Minimum	3.0	3.0	3.0	2.6	3.0	3.8	3.0	2.5	2.6	3.0	3.3	3.0
Nitrate-Nitrite (mg/L) Average Monthly	3.01	3.94	3.04	2.05	3.80	3.68	2.64	3.27	5.80	6.27	6.93	7.37
Nitrate-Nitrite (lbs) Total Monthly	175.18	225.42	198.33	128.95	249.19	223.9	200.12	269.0	409.82	402.08	509.95	518.62
Total Nitrogen (mg/L) Average Monthly	8.21	< 4.93	< 5.44	< 3.0	< 4.3	< 4.34	< 3.69	< 4.21	< 7.16	7.74	< 7.9	< 7.95
Total Nitrogen (lbs) Total Monthly	470.22	< 284.92	< 368.02	< 191.15	< 281.69	< 265.82	< 279.7	< 340.61	< 503.31	493.31	< 582.11	< 559.24
Total Nitrogen (lbs) Effluent Net Total Annual			< 5154									
Total Nitrogen (lbs) Total Annual			< 5154									
Ammonia (lbs/day) Average Monthly	< 9.344	0.671	4.053	< 0.541	< 0.08	< 0.065	< 0.547	< 0.519	0.119	1.359	1.066	< 0.181
Ammonia (mg/L) Average Monthly	< 4.96	0.336	1.708	< 0.25	< 0.038	< 0.03	< 0.228	< 0.204	0.053	0.643	0.446	< 0.09
Ammonia (lbs) Total Monthly	< 280.32	20.8	121.6	< 16.76	< 2.47	< 1.95	< 16.95	< 15.57	3.7	39.4	33.03	< 5.6
Ammonia (lbs) Total Annual			< 255									

NPDES Permit Fact Sheet
Salisbury Township Gap STP

NPDES Permit No. PA0081574

TKN (mg/L) Average Monthly	5.2	< 0.988	< 2.398	< 0.95	< 0.5	< 0.655	< 1.058	< 0.934	< 1.353	1.463	< 0.972	< 0.583
TKN (lbs) Total Monthly	295.04	< 59.5	< 169.69	< 62.2	< 32.5	< 41.92	< 79.57	< 71.61	< 93.5	91.23	< 72.16	< 40.62
Total Phosphorus (lbs/day)												
Average Monthly	0.266	0.155	0.436	0.198	2.376	0.58	0.243	0.307	0.352	0.282	0.241	0.144
Total Phosphorus (mg/L)												
Average Monthly	0.138	0.082	0.19	0.093	1.086	0.285	0.1	0.118	0.155	0.13	0.1	0.065
Total Phosphorus (lbs) Total Monthly	7.99	4.8	13.09	6.14	73.67	17.4	7.53	9.2	10.91	8.17	7.48	4.46
Total Phosphorus (lbs) Effluent Net Total Annual			205									
Total Phosphorus (lbs) Total Annual			205									

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 59' 43.5"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .58
Longitude 76° 1' 13.2"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

CBOD₅, NH₃-N

Pursuant to 40 CFR § 122.44(d)(1)(i), more stringent requirements should be considered when pollutants are discharged at the levels which have the reasonable potential to cause or contribute to excursions above water quality standards.

WQM 7.0 ver. 1.1b is a water quality model designed to assist DEP in determining appropriate water quality based effluent limits (WQBELs) for carbonaceous biochemical oxygen demand (CBOD₅), ammonia (NH₃-N) and dissolved oxygen (D.O.). DEP's Technical Guidance No. 391-2000-007 provides the technical methods contained in WQM 7.0 for determining wasteload allocations and for determining recommended NPDES effluent limits for point source discharges. The model was utilized for this permit renewal. The model output indicated a CBOD₅ average monthly limit of 14.38 mg/l, an NH₃-N average monthly limit of 2.15 mg/l, and a D.O. minimum limit of 5.0 mg/l were protective of water quality. The flow data used to run the model was acquired from USGS PA StreamStats and is included as an attachment. The existing permit limits for these parameters are more stringent and will remain in the renewal.

Toxics

Effluent sample results for toxic pollutants reported on the renewal application were entered into DEP's Toxics Management Spreadsheet Version 1.4 to develop appropriate permit requirements for toxic pollutants of concern. The Toxics Management Spreadsheet combines the functions of PENTOXSD and DEP's Toxics Screening Analysis. Stream pH and hardness inputs were based on data from WQN Station ID 284 from November 2012 to December 2017. Based on effluent sample results reported on the application, the Toxics Management Spreadsheet recommended monitoring for Total Copper and Total Zinc.

This data was analyzed based on the guidelines found in DEP's Water Quality Toxics Management Strategy (Document No. 361-0100-003) and DEP's SOP No. BPNPSM-PMT-033. The results are attached to this fact sheet. The Toxics Management Spreadsheet uses the following logic:

- Establish average monthly and instantaneous maximum (IMAX) limits in the draft permit where the maximum reported concentration exceeds 50% of the WQBEL.

- b. For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- c. For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10%-50% of the WQBEL.

Since the reported maximum concentrations were between 10%-50% of their respective WQBEL, per DEP's SOP No. BPNPSM-PMT-033, monitoring will be necessary for these parameters. They have been added to the NPDES Permit with a monitoring frequency of 1/week and a sample type of 8-Hr Composite to be consistent with the existing parameters.

Additional Considerations

Chesapeake Bay Total Maximum Daily Load (TMDL)

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the *Pennsylvania Chesapeake Watershed Implementation Plan* (WIP), dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a *Phase 2 Watershed Implementation Plan Wastewater Supplement* (Phase 2 Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. A new update to the WIP was published as the Phase 3 WIP in August 2019. As part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on July 29, 2022, and is the basis for the development of any Chesapeake Bay related permit parameters. Sewage discharges have been prioritized based on their design flow to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual Cap Loads based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. For Phase 4 and 5 facilities, Cap Loads are not currently being implemented for renewed or amended permits for facilities that do not increase design flow.

Salisbury Township Gap WWTP is a Phase 2 significant discharger. The facility's waste load allocation (WLA) is tracked under an individual WLA as a significant discharger in the Phase 3 Supplement. The following Cap Loads specified in the current Phase 3 Supplement will be included in the draft permit:

NPDES Permit No.	Phase	Facility	Latest Permit Issuance Date	Permit Expiration Date	Cap Load Compliance Start Date	TN Cap Load (lbs/yr)	TN Offsets Included in Cap Load (lbs/yr)	TP Cap Load (lbs/yr)	TN Delivery Ratio	TP Delivery Ratio
PA0081574	2	Salisbury Township	12/13/2019	12/31/2024	10/1/2012	13,150	-	1,643	0.552	0.553

The previous fact sheet states that as an alternative to the WIP, some facilities were able to use their projected 2010 flow with a TN concentration of 8 mg/l and a TP concentration of 1.0 mg/l to develop Cap Loads. The Cap Loads for Gap WWTP were developed using the projected 2010 flow of 0.54 million gallons per day (MGD). The Cap Loads are unchanged from the previous renewal. DEP's SOP for New and Reissuance Sewage Individual NPDES Permit Applications recommends that Significant Chesapeake Bay sewage discharges should monitor for nutrients at a minimum of 1/week as 24-hour composites. The Phase 2 Supplement states that "the minimum monitoring frequency for TN species and TP in new or renewed NPDES permits for significant sewage dischargers will be 2/week." This is consistent with the existing permit requirements.

Dissolved Oxygen

A minimum D.O. limit of 5.0 mg/L is a D.O. water quality criterion found in 25 Pa. Code § 93.7(a). This limit is included in the existing NPDES permit based BPJ. It is still recommended to include this limit in the draft permit to ensure that the facility continues to achieve compliance with DEP water quality standards.

Total Phosphorus

For Total Phosphorus (TP), the current NPDES permit requires the permittee to comply with average monthly and IMAX limits of 2.0 mg/L and 4.0 mg/L, respectively. These existing limits will remain unchanged in the permit to protect the local watershed.

Fecal Coliform

PA Code § 92a.47.(a)(4) requires a monthly average limit of 200/100 mL as a geometric mean and an instantaneous maximum limit not greater than 1,000/100 mL from May through September for fecal coliform. PA Code § 92a.47.(a)(5) requires a monthly average limit of 2,000/100 mL as a geometric mean and an instantaneous maximum limit not greater than 10,000/100 mL from October through April for fecal coliform. These limits are consistent with the existing permit.

E. Coli

PA Code § 92a.61 requires IMAX reporting of E. Coli. Per DEP's SOP No. BCW-PMT-033, sewage dischargers with a design flow of ≥ 0.05 mgd and < 1 mgd will include E. Coli monitoring with a frequency of 1/quarter. This parameter has been added to the renewal permit.

UV Monitoring

DEP's SOP No. BPNPSM-PMT-033 recommends at a minimum, routine monitoring of UV transmittance, dosage, or intensity when the facility is utilizing a UV disinfection system. The monitoring should occur at the same frequency as would be used for TRC. This recommendation was implemented as a part of the proper operation and maintenance requirement specified in Part B of the NPDES permit, requesting permittees to demonstrate the effectiveness of UV disinfection system. This is a reasonable approach and has been assigned to other facilities equipped with similar technology. A monitoring requirement for UV Transmittance is included in the existing permit, and will remain in the renewal.

Pequea Creek TMDL

A TMDL exists for Pequea Creek for phosphorus and sediment. The TMDL was completed and approved on April 9, 2001 and was revised in 2006. The TMDL established a permit limit for TP of 1,904 lbs/year for this facility. This TMDL requirement is met by the Chesapeake Bay Cap Load for TP of 1,643 lbs/year, which is an existing limit in the permit.

Influent BOD₅ and Total Suspended Solids (TSS) Monitoring

As a result of negotiation with US EPA, influent monitoring of TSS and BOD₅ are required for any publicly owned treatment works (POTWs); therefore, influent sampling of BOD₅ and TSS will remain in the permit.

Sampling Frequency & Sample Type

The monitoring requirements were established based on BPJ and/or Table 6-3 of DEP's Technical Guidance No. 362-0400-001.

Anti-Degradation

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303(d) Listed Streams

The discharge is located on a stream segment that is designated on the 303(d) list as impaired. There is a recreational impairment due to pathogens from an unknown source.⁸ There is an aquatic life impairment due to siltation from habitat modification – other than hydromodification, nutrients from agriculture, organic enrichment from agriculture, habitat alterations from habitat modification – other than hydromodification, siltation from agriculture. The proposed effluent limits include limits for fecal coliform, TN, TP, and DO.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit unless any exceptions are addressed by DEP in this fact sheet.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	67	101	XXX	14.0	21.0	28	1/week	8-Hr Composite
BOD5		Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Raw Sewage Influent	Report	145	218	XXX	30	45	1/week	8-Hr Composite
TSS		Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	XXX	2000			
Fecal Coliform (No./100 ml) Oct 1 - Apr 30		XXX	XXX	Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30		XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Ammonia Nov 1 - Apr 30	29	XXX	XXX	6.0	XXX	12	1/week	24-Hr Composite
Ammonia May 1 - Oct 31	9.7	XXX	XXX	2.0	XXX	4	1/week	24-Hr Composite
Total Phosphorus	9.7	XXX	XXX	2.0	XXX	4	1/week	24-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Copper	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/week	8-Hr Composite
Total Zinc	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/week	8-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations					Monitoring Requirements	
	Mass Units (lbs)		Concentrations (mg/L)			Minimum Measurement Frequency	Required Sample Type
	Monthly	Annual	Minimum	Monthly Average	Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	1/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	1/week	24-Hr Composite
Nitrite-Nitrate as N	Report	XXX	XXX	Report	XXX	1/week	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	1/week	24-Hr Composite
Net Total Nitrogen	XXX	13,150	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	1,643	XXX	XXX	XXX	1/year	Calculation

Compliance Sampling Location: Outfall 001

Other Comments: None

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033, BCW-PMT-002
<input type="checkbox"/>	Other: [REDACTED]


Salisbury Township Gap STP PA0081574 Outfall 001

Region ID: PA

Workspace ID: PA20250207182022928000

Clicked Point (Latitude, Longitude): 39.99562, -76.02022

Time: 2025-02-07 13:20:45 -0500



 [Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.4462	degrees
DRNAREA	Area that drains to a point on a stream	1.01	square miles
ROCKDEP	Depth to rock	5.3	feet
URBAN	Percentage of basin with urban development	17.1097	percent

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	3.4462	degrees	1.7	6.4
DRNAREA	Drainage Area	1.01	square miles	4.78	1150
ROCKDEP	Depth to Rock	5.3	feet	4.13	5.21
URBAN	Percent Urban	17.1097	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.295	ft^3/s
30 Day 2 Year Low Flow	0.388	ft^3/s
7 Day 10 Year Low Flow	0.133	ft^3/s
30 Day 10 Year Low Flow	0.181	ft^3/s
90 Day 10 Year Low Flow	0.306	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government

as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.26.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


Salisbury Township Gap STP PA0081574 RMI = 0.0

Region ID: PA

Workspace ID: PA20250207182743988000

Clicked Point (Latitude, Longitude): 39.99879, -76.01691

Time: 2025-02-07 13:28:06 -0500



[Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.3544	degrees
DRNAREA	Area that drains to a point on a stream	1.09	square miles
ROCKDEP	Depth to rock	5.3	feet
URBAN	Percentage of basin with urban development	15.8533	percent

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	3.3544	degrees	1.7	6.4
DRNAREA	Drainage Area	1.09	square miles	4.78	1150
ROCKDEP	Depth to Rock	5.3	feet	4.13	5.21
URBAN	Percent Urban	15.8533	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.301	ft^3/s
30 Day 2 Year Low Flow	0.399	ft^3/s
7 Day 10 Year Low Flow	0.134	ft^3/s
30 Day 10 Year Low Flow	0.184	ft^3/s
90 Day 10 Year Low Flow	0.315	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government

as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.26.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07K		7533	Trib	07533 of Pequea Creek	0.320	442.00	1.01	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10 0.100 0.00 0.13 0.000 0.000 0.0 0.00 0.00 20.00 7.00 22.10 8.30 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000										
Discharge Data										
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
Gap STP		PA0081574		0.5800	0.5800	0.5800	0.000	20.00	7.00	
Parameter Data										
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5				25.00	2.00	0.00	1.50			
Dissolved Oxygen				5.00	8.24	0.00	0.00			
NH3-N				25.00	0.00	0.00	0.70			

Input Data WQM 7.0

Design Cond.	SWP Basin	Stream Code	Stream Name			RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
	(ft)	(sq mi)	(ft/ft)	(mgd)	<input checked="" type="checkbox"/>						
	07K	7533 Trib 07533 of Pequea Creek	0.000	438.00	1.09	0.00000	0.00				
Stream Data											
	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream pH	Temp pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)
Q7-10	0.100	0.00	0.13	0.000	0.000	0.0	0.00	0.00	20.00	7.00	22.10
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
Discharge Data											
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor			Disc Temp (°C)	Disc pH	
			0.0000	0.0000	0.0000	0.000			25.00	7.00	
Parameter Data											
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5		25.00	2.00	0.00	1.50					
	Dissolved Oxygen		3.00	8.24	0.00	0.00					
	NH3-N		25.00	0.00	0.00	0.70					

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
07K			7533			Trib 07533 of Pequea Creek							
RMI	Stream Flow	PWS Wth	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
Q7-10 Flow													
0.320	0.13	0.00	0.13	.8973 0.00237	.525	9.8	18.68	0.20	0.098	20.27	7.06		
Q1-10 Flow													
0.320	0.09	0.00	0.09	.8973 0.00237	NA	NA	NA	0.20	0.100	20.18	7.04		
Q30-10 Flow													
0.320	0.18	0.00	0.18	.8973 0.00237	NA	NA	NA	0.21	0.095	20.35	7.08		

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07K	7533	Trib 07533 of Pequea Creek					
NH3-N Acute Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.320	Gap STP	15.97	17.48	15.97	17.48	1	0
NH3-N Chronic Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.320	Gap STP	1.79	2.15	1.79	2.15	0	0
Dissolved Oxygen Allocations							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
0.32	Gap STP	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
		14.38	14.38	2.15	2.15	5	5
						0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
07K	7533	Trib 07533 of Pequea Creek			
<u>RMI</u>		<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.320		0.580	20.271	7.057	
<u>Reach Width (ft)</u>		<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
9.801		0.525	18.678	0.200	
<u>Reach CBOD5 (mg/L)</u>		<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
12.78		0.845	1.87	0.715	
<u>Reach DO (mg/L)</u>		<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
5.419		4.536	Tsivoglou	5	
<u>Reach Travel Time (days)</u>		Subreach Results			
0.098		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
		0.010	12.68	1.86	5.36
		0.020	12.57	1.85	5.31
		0.029	12.47	1.83	5.27
		0.039	12.36	1.82	5.23
		0.049	12.26	1.81	5.19
		0.059	12.16	1.79	5.15
		0.068	12.06	1.78	5.12
		0.078	11.96	1.77	5.09
		0.088	11.86	1.76	5.06
		0.098	11.76	1.75	5.04

WQM 7.0 Effluent Limits

SWP Basin		Stream Code	Stream Name				
07K	7533	Trib 07533 of Pequea Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.320	Gap STP	PA0081574	0.580	CBOD5	14.38		
				NH3-N	2.15	4.3	
				Dissolved Oxygen			5



Discharge Information

Instructions Discharge Stream

Facility: Salisbury Township - Gap STP NPDES Permit No.: PA0081574 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Sewage Effluent

Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)
			AFC	CFC	THH	
0.58	152	7				

		Discharge Pollutant	Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L		765									
	Chloride (PWS)	mg/L		337									
	Bromide	mg/L	<	1									
	Sulfate (PWS)	mg/L		38.9									
	Fluoride (PWS)	mg/L											
Group 2	Total Aluminum	µg/L											
	Total Antimony	µg/L											
	Total Arsenic	µg/L											
	Total Barium	µg/L											
	Total Beryllium	µg/L											
	Total Boron	µg/L											
	Total Cadmium	µg/L											
	Total Chromium (III)	µg/L											
	Hexavalent Chromium	µg/L											
	Total Cobalt	µg/L											
	Total Copper	mg/L		0.007									
	Free Cyanide	µg/L											
	Total Cyanide	µg/L											
	Dissolved Iron	µg/L											
	Total Iron	µg/L											
	Total Lead	µg/L		0.001									
	Total Manganese	µg/L											
	Total Mercury	µg/L											
	Total Nickel	µg/L											
	Total Phenols (Phenolics) (PWS)	µg/L											
	Total Selenium	µg/L											
	Total Silver	µg/L											
	Total Thallium	µg/L											
	Total Zinc	mg/L		0.084									
	Total Molybdenum	µg/L											
	Acrolein	µg/L	<										
	Acrylamide	µg/L	<										
	Acrylonitrile	µg/L	<										
	Benzene	µg/L	<										
	Bromoform	µg/L	<										



Stream / Surface Water Information

Instructions **Discharge** **Stream**

Salisbury Township - Gap STP, NPDES Permit No. PA0081574, Outfall 001

Receiving Surface Water Name: UNT Pequea Creek

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity y (fps)	Travel Time (days)	Tributary	Stream
Point of Discharge	007533	0.32	442	1.01					Hardness	pH
End of Reach 1	007533	0	438	1.09					Hardness*	pH*

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity y (fps)	Travel Time (days)	Tributary	Stream
Point of Discharge	0.32	0.1	0.133						Hardness	pH
End of Reach 1	0	0.1	0.134						Hardness*	pH*

Q_h

Location	RMI	LFY (cfs/mi ²)	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity y (fps)	Travel Time (days)	Tributary	Stream
Point of Discharge	0.32								Hardness	pH
End of Reach 1	0								Hardness*	pH*



Model Results

Instructions **Results**

[RETURN TO INPUTS](#)

[SAVE AS PDF](#)

[PRINT](#)

Salisbury Township - Gap STP, NPDES Permit No. PA0081574, Outfall 001

Hydrodynamics

Wasteload Allocations

AFC

CCT (min): 0.119

PMF: 1

Analysis Hardness (mg/l): 160.78

Analysis pH: 7.06

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	
Total Copper	0	0	0	0	21.022	21.9	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	107.865	149	Chem Translator of 0.722 applied
Total Zinc	0	0	0	0	175.223	179	Chem Translator of 0.978 applied

CFC

CCT (min): 0.119

PMF: 1

Analysis Hardness (mg/l): 160.78

Analysis pH: 7.06

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	
Total Copper	0	0	0	0	13.438	14.0	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	4.203	5.82	Chem Translator of 0.722 applied
Total Zinc	0	0	0	0	176.657	179	Chem Translator of 0.986 applied

THH

CCT (min): 0.119

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	500,000	500,000	N/A
Chloride (PWS)	0	0	0	0	250,000	250,000	N/A
Sulfate (PWS)	0	0	0	0	250,000	250,000	N/A

Total Copper	0	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A
Total Zinc	0	0	0	0	N/A	N/A	N/A

CRL

CCT (min): 1.499

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Stream Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A
Total Zinc	0	0	0	0	N/A	N/A	N/A

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Concentration Limits				Governing WQBEL Basis	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	ML	IMAX			
Total Copper	Report	Report	Report	Report	mg/L	0.016	CFC
Total Zinc	Report	Report	Report	Report	mg/L	0.18	AFC

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Lead	6.69	µg/L	Discharge Conc ≤ 10% WQBEL