

Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0081647
APS ID 310016
Authorization ID 1510327

Applicant and Facility Information

Applicant Name	<u>White Run Region Municipal Authority</u>	Facility Name	<u>White Run STP</u>
Applicant Address	<u>2001 Baltimore Pike</u>	Facility Address	<u>2001 Baltimore Pike</u>
	<u>Gettysburg, PA 17325-7015</u>		<u>Gettysburg, PA 17325-7015</u>
Applicant Contact	<u>Donald Hubbard</u>	Facility Contact	<u>Richard Reinburg</u>
Applicant Phone	<u>(717) 334-7476</u>	Facility Phone	<u>(717) 334-9137</u>
Client ID	<u>77706</u>	Site ID	<u>253436</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Mount Joy Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Adams</u>
Date Application Received	<u>December 20, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 23, 2024</u>	If No, Reason	
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

Keller Engineers, on behalf of the White Run Regional Municipal Authority (Authority/Permittee), applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The permit was reissued on February 24, 2020, and became effective on March 1, 2020. The permit expires on August 31, 2025.

The WWTP currently has an average annual design flow of 0.330 MGD, a hydraulic capacity of 0.390 MGD, and an organic design capacity of 740 lbs BOD/day. The collection system has sewers from Mt. Joy Township (55%), Straban Township (21%), and Mt. Pleasant Township (24%).

WQM Part II No. 0100407 was issued 12/26/2000, and 0100407 A-1 amendment was issued 6/25/2024 to modification.

Sludge use and disposal description and location(s): N/A because sludge is hauled by facility's contractor.

Changes from the previous permit: The E. Coli monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	July 25, 2025
X		Daniel W. Martin Daniel W. Martin, P.E. / Environmental Engineer Manager	August 26, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.33
Latitude	39° 47' 22.01"	Longitude	-77° 11' 56.56"
Quad Name	Gettysburg	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	White Run (WWF)	Stream Code	59099
NHD Com ID	53320632	RMI	0.52
Drainage Area	12.8 mi. ²	Yield (cfs/mi ²)	0.03
Q ₇₋₁₀ Flow (cfs)	0.38	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	409.18	Slope (ft/ft)	
Watershed No.	13-D	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Flow Regime Modification, Nutrients, Siltation		
Source(s) of Impairment	Dam OR Impoundment, Rural (Residential Areas),		
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	City of Frederick, MD		
PWS Waters	Monocacy River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	Approximate 38 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Little Juniata River at RMI 0.52 mile. A drainage area upstream of the discharge is estimated to be 12.8 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Slow Flow

According to StreamStats, the point of first use has a Q₇₋₁₀ of 0.38 cfs and a drainage area of 12.8 mi.², which results in a Q₇₋₁₀ low flow yield of 0.030 cfs/mi.². This is a relatively low Q₇₋₁₀, but it is consistent with the known geologic features of the area. This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 0.38 \text{ cfs} \\
 \text{Low Flow Yield} &= 0.38 \text{ cfs} / 12.8 \text{ mi.}^2 = 0.030 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 0.39 \text{ cfs} = 0.53 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.39 \text{ cfs} = 0.25 \text{ cfs}
 \end{aligned}$$

The resulting Q₇₋₁₀ dilution ratio is: Q_{stream} / Q_{discharge} = 0.38 cfs / [0.330 MGD * (1.547 cfs/MGD)] = 0.74:1


Public Water Supply

The nearest downstream public water supply intake is the City of Frederick, Maryland on the Monocacy River, approximately 38 miles downstream of this discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: White Run Regional STP				
WQM Permit No.	Issuance Date			
0100407	12/26/2000			
0100407 A-1	6/25/2024			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia And Phosphorus	Sequencing Batch Reactor	Ultraviolet	0.33
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.39	740	Not Overloaded	Aerobic Digestion	Land Application

Changes Since Last Permit Issuance:

Other Comments:



The WWTP train is as follows:

Mechanical Bar Screen (1) \Rightarrow Pre-React Chamber (2) \Rightarrow Sequencing Batch Reactor (2) \Rightarrow Ultraviolet Disinfection Unit (1) \Rightarrow Discharge

NPDES Permit Fact Sheet**NPDES Permit No. PA0081647****White Run STP**

The system incorporates the addition of Aluminum Sulfate (for Coagulation and Phosphorus removal). Six aerated sludge digesters are on-site.

Residual solids are held in 2 aerobic digesters prior to liquid application on farm fields.

Biosolids:

The total sewage sludge/biosolids production within the facility for the previous year was 27.94 dry tons.

Industrial/Commercial Users:

The permit application indicated there are no commercial or industrial contributors to the treatment plant.

Compliance History	
Summary of DMRs:	DMRs reported last 12 months are summarized in the next pages.
Summary of Inspections:	1/16/2025: Mr. Hoy, DEP WQS, conducted a compliance elevation inspection. There were no violations noted during the inspection. There were recommendations 1. The NIST thermometers are replaced as soon as possible and the calibrated or replaced annually. 2. The Excel files of the influent supplemental report, the effluent supplemental report, the sewage sludge supplemental report, and the Annual Chesapeake Bay Spreadsheet (V2.2) are submitted to eDMR monthly. 3. Printing copies of the final DMR submitted to Greenport for on-site records retention. 4. Performing 3-point calibration for the pH meter. 7/25/2024: Mr. Hoy, DEP WQS, conducted a response to complaint of sewage odors inspection. There were no violations noted during the inspection.
Other Comments:	There are currently no open violations associated with the permittee or the facility.

Other Comments: 

The table below summarizes the influent/effluent testing results submitted along with the application.

Influent Testing Results			Effluent Testing Results		
Parameter	Min/Max Value	Average Value	Parameter	Min/Max Value	Average Value
BOD ₅ (mg/L)	mg/L	mg/L	pH (minimum)	6.6 S.U.	
BOD ₅ (lbs/day)	lbs/day	lbs/day	pH (maximum)	7.6 S.U.	
TSS (mg/L)	mg/L	mg/L	D.O (minimum)	6.1/20.3 mg/L	7.56 mg/L
TSS (lbs/day)	lbs/day	lbs/day	TRC	mg/L	mg/L
TN (mg/L)	52 mg/L	52 mg/L	Fecal Coliform	1/613 No./100 mL	8.35 No./100 mL
TN (lbs/day)	53.77 lbs/day	53.77 lbs/day	CBOD ₅	2.4/7.8 mg/L	2.6 mg/L
TP (mg/L)	5.5 mg/L	5.5 mg/L	TSS	1/28 mg/L	4.8 mg/L
TP (lbs/day)	5.69 lbs/day	5.69 lbs/day	NH ₃ -N	0.1/0.79 mg/L	0.15 mg/L
NH ₃ -N (mg/L)	45 mg/L	45 mg/L	TN	5.1/20.3 mg/L	10.9 mg/L
NH ₃ -N (lbs/day)	46.54 lbs/day	46.54 lbs/day	TP	0.5/2.5 mg/L	1.23 mg/L
TDS (mg/L)	844 mg/L	844 mg/L	Temp	No Data	No Data
TDS (lbs/day)	872.8 lbs/day	872.8 lbs/day	TKN	0.5/2.7 mg/L	1.07 mg/L
TKN	52 mg/L	52 mg/L	NO ₂ -N + NO ₃ -N	4/16.4 mg/L	9.76 mg/L
NO ₂ -N + NO ₃ -N	0.8 mg/L	0.8 mg/L	TDS	794 mg/L	794 mg/L
			Chloride	210 mg/L	210 mg/L
			Bromide	<0.5 mg/L	<0.5 mg/L
			Sulfate	100 mg/L	100 mg/L
			Oil and Grease	5.0 mg/L	5.0 mg/L
			Total Copper	0.006 mg/L	0.006 mg/L
			Total Lead	< 0.001 mg/L	< 0.001 mg/L
			Total Zinc	0.087 mg/L	0.087 mg/L

Compliance History

DMR Data for Outfall 001 (from June 1, 2024 to May 31, 2025)

Parameter	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24
Flow (MGD) Average Monthly	0.274	0.194	0.158	0.180	0.147	0.180	0.147	0.160	0.155	0.188	0.164	0.164
Flow (MGD) Daily Maximum	0.431	0.292	0.208	0.296	0.212	0.313	0.184	0.219	0.197	0.529	0.21	0.202
pH (S.U.) Daily Minimum	6.5	6.5	6.3	6.3	6.8	6.4	6.8	6.7	6.8	6.7	6.8	6.7
pH (S.U.) Instantaneous Maximum	7.4	7.3	7.4	7.5	7.7	7.7	7.5	7.4	7.4	7.5	7.4	7.4
DO (mg/L) Daily Minimum	5.4	6.2	6.2	5.3	6.9	6.9	6.6	7.0	6.0	5.4	6.0	6.0
CBOD5 (lbs/day) Average Monthly	6.4	4.9	< 4.1	< 4.0	< 3.3	< 3.4	< 3.0	< 3.5	< 3.5	< 4.1	< 3.6	3.6
CBOD5 (lbs/day) Weekly Average	10	6	5	< 6	4	< 4	< 3	< 4	< 4	5	< 4	4
CBOD5 (mg/L) Average Monthly	< 2.9	< 2.5	< 3.0	< 2.4	< 2.6	< 2.40	< 2.4	< 2.40	< 2.4	< 2.50	< 2.4	< 2.4
CBOD5 (mg/L) Weekly Average	4.4	2.8	3.6	< 2.4	3.0	< 2.40	< 2.4	< 2.4	2.4	2.90	< 2.4	2.4
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	581	477	384	320	304	366	303	393	340	389	358	327
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	1053	585	405	378	323	569	369	447	392	464	440	374
BOD5 (mg/L) Raw Sewage Influent Average Monthly	257	255	270	201	233	258	245.75	292	231	240	238	217
TSS (lbs/day) Average Monthly	5.4	6.6	4.4	4.4	2.3	2.2	2.7	3.3	3	7.7	4.9	3.9
TSS (lbs/day) Raw Sewage Influent Average Monthly	400	485	336	336	213	201	224	337	224	225	230	171
TSS (lbs/day) Raw Sewage Influent Daily Maximum	475	583	380	380	437	351	279	414	254	314	348	263
TSS (lbs/day) Weekly Average	9	12	6	6	4	4	5	6	5	22	12	11

NPDES Permit Fact Sheet
White Run STP

NPDES Permit No. PA0081647

TSS (mg/L) Average Monthly	2.5	3.3	3.2	2.8	1.80	1.60	2.3	2.3	2.0	4.30	3.4	2.5
TSS (mg/L) Raw Sewage Influent Average Monthly	181	248	236	217	157	143	182.00	229	152	145	156	114
TSS (mg/L) Weekly Average	4.0	5.0	4.0	4.0	3.0	3.00	4.0	4.0	3.0	11.0	9	7
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 2	< 1	< 1	< 1	< 1	< 1	< 1	2	< 4	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	4.0	2	2	5	< 1	2	1	2	3	5	80	1
UV Intensity (mW/cm ²) Daily Minimum	100	100	100	100	100	100	100	100	100	100	100	100
UV Intensity (mW/cm ²) Average Monthly	100	100	100	100	100	100	100	100	100	100	100	100
Nitrate-Nitrite (mg/L) Average Monthly	< 8.1	< 11.6	< 10.7	< 18.2	< 20.41	< 14.3	< 15.2	< 16.70	< 14.4	< 14.9	< 14.2	< 12.97
Nitrate-Nitrite (lbs) Total Monthly	551	703	< 460	< 847	< 823	< 628	< 562	< 762	< 636	730	< 658	< 594
Total Nitrogen (mg/L) Average Monthly	< 8.8	< 13.21	< 16.81	< 18.5	< 20.91	< 14.94	< 16.12	< 17.36	< 14.90	< 15.5	< 14.8	< 14.40
Total Nitrogen (lbs) Total Monthly	597	< 750	< 714	< 866	< 843	< 658	< 598	< 795	< 658	760	< 687	658
Total Nitrogen (lbs) Total Annual									< 8076			
Ammonia (lbs/day) Average Monthly	< 0.3	< 0.2	< 5.8	< 0.2	< 0.1	< 0.20	< 0.1	< 0.1	< 0.1	< 0.2	< 0.1	< 0.2
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 4.3	< 0.1	< 0.1	< 0.10	< 0.1	< 0.10	< 0.10	< 0.1	< 0.1	< 0.1
Ammonia (lbs) Total Monthly	< 9.3	< 7.1	< 178.4	< 4.7	< 4.1	< 5	< 3.7	< 4.6	< 4.4	< 5.1	< 4.6	5
Ammonia (lbs) Total Annual									< 91			
TKN (mg/L) Average Monthly	< 0.7	< 0.84	< 6.1	< 0.5	< 0.5	< 0.68	0.97	< 0.71	< 0.50	< 0.6	< 0.6	< 1.4
TKN (lbs) Total Monthly	< 46	< 48	< 254	< 23	< 20	< 30	36	< 32	< 22	< 29	< 29	64
Total Phosphorus (lbs/day) Average Monthly	1.9	1.7	0.5	0.7	0.7	0.9	0.9	1.2	1.5	1.3	3.6	2.1
Total Phosphorus (mg/L) Average Monthly	0.9	0.9	0.4	0.4	0.5	0.60	0.8	0.80	1.0	0.8	2.4	1.5

NPDES Permit Fact Sheet
White Run STP

NPDES Permit No. PA0081647

Total Phosphorus (lbs)	60	50	16.3	19.5	21.3	27	28	36.9	44	40.2	112	64
Total Monthly												
Total Phosphorus (lbs)									643			
Total Annual												

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	Report	XXX	XXX	1/day	Recorded
CBOD ₅	68.0	110.0 Wkly Avg	XXX	25.0	40.0	50.0	1/week	8-Hr Composite
TSS	82.0	123.0 Wkly Avg	XXX	30.0	45.0	60.0	1/week	8-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Ammonia May 1 - Oct 31	6.9	XXX	XXX	2.5	XXX	5.0	1/week	8-Hr Composite
Ammonia Nov 1 - Apr 30	20.0	XXX	XXX	7.5	XXX	15.0	1/week	8-Hr Composite
Total Phosphorus	5.5	XXX	XXX	2.0	XXX	4.0	1/week	8-Hr Composite

Existing Effluent Limitations and Monitoring Requirements

Outfall 001, Chesapeake Bay

Parameter ⁽¹⁾	Effluent Limitations					Monitoring Requirements	
	Mass Units (lbs)		Concentrations (mg/L)			Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Minimum	Monthly Average	Maximum		
Ammonia---N	Report	Report	XXX	Report	XXX	1/week	8-Hr Composite
Kjeldahl---N	Report	XXX	XXX	Report	XXX	1/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	1/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	1/week	8-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	Report	XXX	XXX	1/day	Recorded
CBOD ₅	68	110	XXX	25	40	50	1/week	8-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	82	123	XXX	30	45	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ammonia Nov 1 - Apr 30	20	XXX	XXX	7.5	XXX	15	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	6.9	XXX	XXX	2.5	XXX	5	1/week	8-Hr Composite
Total Phosphorus	5.5	XXX	XXX	2.0	XXX	4	1/week	8-Hr Composite

Compliance Sampling Location: 

Other Comments: 

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite

Compliance Sampling Location: 

Other Comments: 

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 47' 22.01"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.33
Longitude -77° 11' 56.56"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: [redacted]

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

- Discharge pH = 7.0 (Default)
- Discharge Temperature = 25°C (Default)
- Stream pH = 7.0 (Default)
- Stream Temperature = 25°C (Default for WWF)
- Background NH₃-N = 0 (Default)

Analysis Results WQM 7.0

Hydrodynamics		NH ₃ -N Allocations		D.O. Allocations		D.O. Simulation		Effluent Limitations			
RMI	Discharge Name	Permit Number Disc. Flow (mgd)									
0.52	White Run	PA0081647 0.3300									
		Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)						
		CBOD ₅	25	5.54	5						
		NH ₃ -N	2.77								
		Dissolved Oxygen									
Record: 1 of 1 < Back No Filter Search											
Print		< Back		Next >		Archive		Cancel			

White Run STP

The model input data and results are attached. The printout of the WQM 7.0 output indicates that at a discharge of 0.330 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 2.77 mg/L NH₃-N as a monthly average and 5.54 mg/L NH₃-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects.

The more stringent summer in existing limits of 2.5 mg/L monthly average & 5.0 mg/L IMAX will remain in the proposed permit due to anti-backsliding requirements. The winter effluent limit will be set at three-times the summer limits. Recent DMRs and inspection reports indicate that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Summer average monthly mass limit: 2.5 mg/L x 0.330 MGD x 8.34 = 6.88 (6.8) lbs/day

Winter average monthly mass limit: 7.5 mg/L x 0.330 MGD x 8.34 = 20.0 lbs/day

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model indicates that a monthly average limit of 25 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations well below this existing limit. Mass limits are calculated as follows:

Average monthly mass limit: 25 mg/L x 0.330 MGD x 8.34 = 68.8 (68.0) lbs/day

Average weekly mass limit: 40 mg/L x 0.330 MGD x 8.34 = 110.0 lbs/day

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/quarter will be included in the permit to be consistent with the recommendation from this SOP.

pH:

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa. Code § 95.2(1).

Total Suspended Solids (TSS):

The existing limits of 30 mg/L average monthly and 60 mg/L instantaneous maximum will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations well below these limits. Mass limits are calculated as follows:

Average monthly mass limit: 30 mg/L x 0.330 MGD x 8.34 = 82.5 (82.0) lbs/day

Average weekly mass limit: 45 mg/L x 0.330 MGD x 8.34 = 123.8 (123.0) lbs/day

UV:

The UV system daily monitor and report the UV light intensity (mW/cm²) after update to replace chlorine disinfection to UV disinfection system will be in the amendment permit.

Influent BOD₅ and TSS Monitoring:

The permit will include influent BOD₅ and TSS monitoring at the same frequency as is done for effluent in order to implement Chapter 94.12 and assess percent removal requirements, per DEP policy.

Toxics:

Review of the permit application revealed no toxic parameters of concern. The application states that there are no industrial wastewater contributions.

Stormwater:

There is no stormwater outfall associated with this facility.

White Run STP

Phosphorus:

Technology-based phosphorus limits of 2.0 mg/L average monthly and 4.0 mg/L instantaneous maximum were applied by the original 1998 protection report. The limits will remain in the proposed permit. Recent DMR data and inspection reports indicate consistent achievement. Mass limits are calculated as follows:

Average monthly mass limit: $2.0 \text{ mg/L} \times 0.330 \text{ MGD} \times 8.34 = 5.5 \text{ lbs/day}$

Total Dissolved Solids (TDS) / Sulfate / Chloride / Bromide / 1,4-Dioxane:

Total Dissolved Solids (TDS) and its major constituents including sulfate, chloride, and bromide have emerged as pollutants of concern in several major watersheds in the Commonwealth. The conservative nature of these solids allows them to accumulate in surface waters and they may remain a concern even if the immediate downstream public water supply is not directly impacted. Under the authority of § 92a.61, statewide guidance distributed by the Department's Central Office on January 23, 2014 stated the following:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

- *Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.*
- *Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.*
- *Where the concentration of 1,4-dioxane (CAS 123-91-1) in a discharge exceeds 10 µg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for 1,4-dioxane. Discharges of 0.1 MGD or less should monitor and report for 1,4-dioxane if the concentration of 1,4-dioxane in the discharge exceeds 100 µg/L.*

The table below compares the above thresholds for monitoring requirements with the concentrations documented in the current application:

Table 5. Department Monitoring Thresholds and Expected Discharge Concentrations for TDS and Related Parameters

Parameter	Threshold for Discharges >0.1 MGD	Threshold for Discharges ≤0.1 MGD	Max. Concentration in Application
TDS	1,000 mg/L or 20,000 lbs/day	5,000 mg/L	794 mg/L
Sulfate	NA	NA	100 mg/L
Chloride	NA	NA	210 mg/L
Bromide	1 mg/L	10 mg/L	<0.50 mg/L
1,4-Dioxane	10 µg/L	100 µg/L	(Not Expected to be Present)

Based on the sampling results in the application, no monitoring will be required for the above parameters of concern.

Chesapeake Bay Strategy:

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases I, II, and III) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase IV (0.2 -0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly. However, any facility in Phases IV that undergoes expansion is subjected to cap load right away. This plant is classified as a phase IV, the existing TN and TP "Monitor & Report" requirements will remain in the proposed permit.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality waters are impacted by this discharge. No Exceptional Value waters are impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

White Run STP

303(d) Listed Streams:

eMapPA lists White Run as impaired (non-attaining) at the discharge point for nutrients and siltation due to small residential runoff and for flow alterations due to an upstream impoundment, which was created on March 29, 1999. Approximately 0.52 river miles downstream, Rock Creek is listed as impaired (non-attaining) for nutrients due to agriculture and a municipal point source, which was created on May 19, 2009. A TMDL has not yet been written for these impairments.

WQM 7.0 Data:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	25°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	25°C	(Default for WWF)
*	Background NH ₃ -N	=	0	(Default)

Node 1: Outfall 001 on White Run (59099)
 Elevation: 409.18 ft (USGS National Map Viewer)
 Drainage Area: 12.8 mi.² (USGS PA StreamStats)
 River Mile Index: 0.52 (PA DEP eMapPA)
 Q₇₋₁₀ Low Flow Yield: 0.030 cfs/mi.²
 Discharge Flow: 0.330 MGD (NPDES permit)

Node 2: Just before confluence with Rock Creek
 Elevation: 402.13 ft (USGS National Map Viewer)
 Drainage Area: 13.0 mi.² (USGS PA StreamStats)
 River Mile Index: 0.01 (PA DEP eMapPA)
 Q₇₋₁₀ Low Flow Yield: 0.030 cfs/mi.²
 Discharge Flow: 0.000 MGD

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation **Effluent Limitations**

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.52	White Run	PA0081647	0.3300

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	2.77	5.54	
Dissolved Oxygen			5

Record: 1 of 1 < Back Next > No Filter Search

Print Archive Cancel

NPDES Permit Fact Sheet
White Run STP

NPDES Permit No. PA0081647

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name
130	59099	WHITE RUN

RBM	Name	Permit Number	Disch. Flow (mgd)	Parameter	Eff. Limit 30-day Avg. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
0.520	White Run	PA0081647	0.330	CBOD5	25	2.77	5.54
				Dissolved Oxygen	5		

Friday, July 25, 2025 Version 1.1 Page 1 of 1

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
130	59099	WHITE RUN

NHS-N Acute Allocations						
RBM	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach
0.520 White Run		11.07	16.4	11.07	16.4	0

NHS-N Chronic Allocations						
RBM	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach
0.520 White Run		1.37	2.77	1.37	2.77	0

Dissolved Oxygen Allocations						
RBM	Discharge Name	CBOD5 Baseline Criterion (mg/L)	CBOD5 Baseline WLA (mg/L)	NH3-N Baseline Criterion (mg/L)	NH3-N Baseline WLA (mg/L)	Dissolved Oxygen Baseline Criterion (mg/L)
0.52 White Run		25	2.77	2.77	5	5

Friday, July 25, 2025 Version 1.1 Page 1 of 1

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name
130	59099	WHITE RUN

RBM	Total Discharge Flow (mgd)	Anaerobic Temperature (°C)	Amplitude
0.520	0.330	29.000	7.000
Reach Width (ft)	Reach Depth (ft)	Reach WDRatio	Reach Velocity (fts)
16,148	0.519	31.121	0.107
Reach CBOD5 (mg/L)	Reach Kc (1/day)	Reach NH3-N (mg/L)	Reach Rn (1/day)
Reach DO (mg/L)	Reach Kt (1/day)	Reach DO (mg/L)	Reach DO Goal (mg/L)
0.392	0.370	0.36	5
Reach Travel Time (days)		Kr Equation	Over
0.292		Over	

Subreach Results			
Travel Time (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
0.029	14.37	1.53	6.18
0.058	13.66	1.49	6.10
0.088	12.98	1.44	6.10
0.117	12.33	1.40	6.15
0.146	11.72	1.36	6.22
0.175	11.14	1.32	6.30
0.204	10.58	1.28	6.38
0.234	10.06	1.24	6.47
0.263	9.50	1.20	6.55
0.292	9.00	1.17	6.63

Friday, July 25, 2025 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameters	Value	Notes
WIA Method	BM/PR	Use Inputted Q1-10 and Q30-10 Flowrat
Q1-10Q7-10 Ratio	0.61	Use Inputted W/D Ratio
Q30-10Q7-10 Ratio	1.36	Use Inputted Reach Travel Times
D.O. Saturation	90.00%	Temperature Adjust Kr
D.O. Goal	5	Use Balanced Technology

Friday, July 25, 2025 Version 1.1 Page 1 of 1

NPDES Permit Fact Sheet
White Run STP

NPDES Permit No. PA0081647

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name: WHITE RUN											
RM	Stress Flow	PWS	Net Flow	Disch.	Reach Slope	Depth	Width	WD Ratio	Reach Trav Time	Analytic Temp	Analytic pH		
(cfs)	(cfs)	(cfs)	(cfs)	(ft)	(ft)	(ft)	(ft)	(ft)	(days)	(°C)			
Q7-10 Flow	0.520	0.38	0.00	0.36	.5105	0.00262	519	16.15	31.12	0.11	0.92	25.00	7.00
Q1-10 Flow	0.520	0.25	0.00	0.25	.5105	0.00262	NA	NA	NA	0.10	0.321	25.00	7.00
Q30-10 Flow	0.520	0.52	0.00	0.52	.5105	0.00262	NA	NA	NA	0.12	0.269	25.00	7.00

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name: WHITE RUN									
RM	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC						
(ft)	(ft)	(sq mi)	(ft/ft)	(mgd)							
13D	59099	WHITE RUN	0.520	409.18	12.80	0.000000	0.00	<input checked="" type="checkbox"/>			

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rich Trav Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tributary Temp	Stream Temp	Stream pH
(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)	(ft)	(ft)	(ft)	(°C)	(°C)	
Q7-10	0.000	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	25.00	7.00	7.00
Q1-10	0.000	0.00	0.00	0.0000	0.000	0.0000	0.0000	0.0000	25.00	7.00	7.00
Q30-10	0.000	0.00	0.00	0.0000	0.0000	0.0000	0.0000	0.0000	25.00	7.00	7.00

Discharging Data

Name	Permit Number	Existing Design Disch Flow (mgd)	Permitted Design Disch Flow (mgd)	Design Disch Flow (mgd)	Reactive Factor	Disc Temp (°C)	Disc pH
White Run	PA0081647	0.3000	0.3000	0.3000	0.0000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc. (mg/L)	Trib Conc. (mg/L)	Stream Conc. (mg/L)	Rate Coef. (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NRGW	25.00	0.00	0.00	0.70

Friday, July 25, 2025

Version 1.1

Page 1 of 1

Friday, July 25, 2025

Version 1.1

Page 1 of 2

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name: WHITE RUN									
RM	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC						
(ft)	(ft)	(sq mi)	(ft/ft)	(mgd)							
13D	59099	WHITE RUN	0.010	402.13	13.00	0.000000	0.00	<input checked="" type="checkbox"/>			

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rich Trav Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tributary Temp	Stream Temp	Stream pH
(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)	(ft)	(ft)	(ft)	(°C)	(°C)	
Q7-10	0.000	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	25.00	7.00	0.00
Q1-10	0.000	0.00	0.00	0.0000	0.000	0.0000	0.0000	0.0000	25.00	7.00	0.00
Q30-10	0.000	0.00	0.00	0.0000	0.0000	0.0000	0.0000	0.0000	25.00	7.00	0.00

Discharging Data

Name	Permit Number	Existing Design Disch Flow (mgd)	Permitted Design Disch Flow (mgd)	Design Disch Flow (mgd)	Reactive Factor	Disc Temp (°C)	Disc pH
White Run	PA0081647	0.0000	0.0000	0.0000	0.0000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc. (mg/L)	Trib Conc. (mg/L)	Stream Conc. (mg/L)	Rate Coef. (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NRGW	25.00	0.00	0.00	0.70



Friday, July 25, 2025

Version 1.1

Page 2 of 2

Page: 14 2 No Filter


17



NPDES Permit Fact Sheet

White Run STP

NPDES Permit No. PA0081647



Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]