

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0081817
 APS ID 632726
 Authorization ID 1241053

Applicant and Facility Information

Applicant Name	<u>Juniata County School District</u>	Facility Name	<u>East Juniata High School</u>
Applicant Address	<u>32944 Route 35 N</u> <u>Mc Alisterville, PA 17049-8109</u>	Facility Address	<u>32944 Route 35 N</u> <u>Mc Alisterville, PA 17049-8109</u>
Applicant Contact	<u>Benjamin Fausey</u>	Facility Contact	<u>Benjamin Fausey</u>
Applicant Phone	<u>(717) 436-2111</u>	Facility Phone	<u>(717) 463-2111</u>
Client ID	<u>32830</u>	Site ID	<u>451519</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Fayette Township</u>
Connection Status		County	<u>Juniata</u>
Date Application Received	<u>August 1, 2018</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 18, 2018</u>	If No, Reason	
Purpose of Application	<u>Renewal of existing NPDES Permit</u>		

Summary of Review

The Juniata County School District has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit for the East Juniata High School STP. The permit was last reissued on January 29, 2014 and became effective on February 1, 2014. The permit expired on January 31, 2019 but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days. A file review of documents associated with the discharge or permittee may be available at the PA DEP southcentral regional office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file reviews, contact the SCRO file review coordinator at 717.705.4700.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Aaron Baar / Permits Section	December 10, 2019
		Daniel W. Martin, P.E. / Environmental Engineer Manager	
		Maria D. Bebenek, P.E. / Program Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.016
Latitude	40° 39' 19.79"	Longitude	-77° 12' 57.88"
Quad Name	Beaver Springs	Quad Code	1328
Wastewater Description: Sewage Effluent			
Receiving Waters	Cocolamus Creek (TSF)	Stream Code	11638
NHD Com ID	66203613	RMI	0.11
Drainage Area	9.0	Yield (cfs/mi ²)	0.0608
Q ₇₋₁₀ Flow (cfs)	0.547	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	647.57	Slope (ft/ft)	
Watershed No.	12-B	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	Newport Borough		
PWS Waters	Juniata River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	

Drainage Area

The discharge is to Cocolamus Creek at RMI 0.11. A drainage area upstream of the discharge point is determined to be 9.0 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, this watershed has a Q₇₋₁₀ of 0.547 cfs and a drainage area of 9.0 mi², which results in a LFY of 0.0608 cfs/mi².

Cocolamus Creek

Cocolamus Creek is classified as a TSF waterway. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed as attaining uses. No local TMDL has been taken into consideration during this review.

Public Water Supply Intake

The nearest downstream public water supply intake is the Newport Borough intake located on the Juniata River. Considering the distance and nature of the discharge, the discharge is not expected to significantly affect the water supply.

Class A Wild Trout Streams

The receiving stream is not a Class A Wild Trout stream.

Treatment Facility Summary				
Treatment Facility Name: East Juniata Hs				
WQM Permit No.		Issuance Date		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Ultraviolet	0.016
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.016		Not Overloaded		Other WWTP

The Juniata County School District owns and operates the East Juniata High School sanitary wastewater treatment facility located in Fayette Township, Juniata County. The facility serves only the East Juniata High School, all wastes are residential in nature, and all sewer systems are 100% separated. Having an annual average design flow of 0.016 MGD and a hydraulic design capacity of 0.016 MGD, this facility consists of a grinder pump, an aeration tank, secondary clarification, UV disinfection, a back-up chlorinator, a chlorine contact/aeration tank, and the outfall (Outfall 001). No chemical amendments are identified in the application and the application does not disclose how solids are managed at the facility.

Compliance History	
Summary of DMRs:	A summary of past DMR data is presented on the next page.
Summary of Inspections:	<p>Since the last NPDES permit renewal on January 29, 2014, there are records in the Department's File Room that the facility has been inspected four times. The notes from the inspections are as follows:</p> <p>1/09/2015: Pat Bowen, DEP Water Quality Specialist, conducted a routine inspection. No violations were noted.</p> <p>12/01/2015: Pat Bowen, DEP Water Quality Specialist, conducted a routine inspection. Fecal Coliform violations were noted in August and September.</p> <p>11/15/2016: Pat Bowen, DEP Water Quality Specialist, conducted a routine inspection. No violations were noted.</p> <p>4/08/2019: Michael Benham, DEP Water Quality Specialist, conducted a routine inspection. A record keeping violations was documented.</p>

Other Comments: A records review revealed that there are Clean Water open violations associated with this facility.

Existing Effluent Limits

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Instantaneous Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/discharge	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Nitrate-Nitrite	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	XXX	XXX	1/year	Calculation
TKN	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite

DMR Data

DMR Data for Outfall 001 (from November 1, 2018 to October 31, 2019)

Parameter	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18
Flow (MGD) Average Monthly	0.0016	0.0019	0.0009	0.0006	0.0012	0.0028	0.0019	0.0021	0.0018	0.0014	0.0019	0.0025
Flow (MGD) Daily Maximum	0.0053	0.0030	0.0024	0.0014	0.0046	0.0074	0.0039	0.0045	0.0039	0.0085	0.0103	0.0069
pH (S.U.) Minimum	6.8	7.1	7.6	7.6	7.5	6.9	6.9	6.8	6.9	6.9	6.5	7.5
pH (S.U.) Maximum	8.1	8.0	8.2	8.1	8.1	7.9	8.1	8.3	7.9	8.3	8.4	8.0
DO (mg/L) Minimum	7.9	7.8	7.4	7.1	7.6	7.4	8.9	10.7	11.8	11.0	10.6	9.0
TRC (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.01	< 0.01	< 0.01	< 0.1	< 0.1	< 0.1
TRC (mg/L) Instantaneous Maximum	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.01	< 0.01	< 0.01	< 0.1	< 0.1	< 0.1
CBOD5 (mg/L) Average Monthly	< 1.0	< 1.0	< 1.0	1.25	< 1.0	< 1	1.9	1.3	3.65	1.85	1.2	1.05
TSS (mg/L) Average Monthly	14.5	8.5	12	20	7	2.5	3.5	2.5	14	< 1	< 1	11
Fecal Coliform (CFU/100 ml) Geometric Mean	15	10	13	7	2679	417	1732	456	146	22	84	138
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	27	16	42	8	13800	1130	3000	946	520	54	126	530
UV Transmittance (%) Minimum	154.8	154.8	154.8	155	155	154.3	154.3	154.3	153.4	153.4	153.9	153.9
Nitrate-Nitrite (mg/L) Annual Average											58.3	
Total Nitrogen (mg/L) Annual Average											< 1	
TKN (mg/L) Annual Average											< 1	
Total Phosphorus (mg/L) Annual Average											3.9	

Compliance History

Effluent Violations for Outfall 001, from: December 1, 2018 To: October 31, 2019

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	06/30/19	Geo Mean	2679	CFU/100 ml	200	CFU/100 ml
Fecal Coliform	05/31/19	Geo Mean	417	CFU/100 ml	200	CFU/100 ml
Fecal Coliform	06/30/19	IMAX	13800	CFU/100 ml	1000	CFU/100 ml
Fecal Coliform	05/31/19	IMAX	1130	CFU/100 ml	1000	CFU/100 ml

Other Comments: The nature of the violations appear to be operational in nature, not a reflection on the ability of the treatment plant to meet discharge limits.

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.016</u>
Latitude <u>40° 39' 19.86"</u>	Longitude <u>-77° 12' 57.95"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

Water Quality-Based Limitations

CBOD₅, NH₃-N and Dissolved Oxygen (DO)

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD₅, NH₃-N and DO. DEP's guidance 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges.

The model output indicated that existing summer WQBEL of 250 mg/L for CBOD₅ is still appropriate. The output also indicated that the WQBEL for NH₃-N is high enough (25 mg/L) that ammonia limits are not needed at this time.

The monitoring frequency and sample type for CBOD₅ and DO are proposed to remain unchanged. Routine monitoring for NH₃-N is proposed to be added to the permit.

Total Residual Chlorine

Since chlorine is sometimes used for disinfection, Total Residual Chlorine (TRC) effluent levels must be regulated in accordance with 25 Pa Code §92a.48(b). DEP's TRC_CALC worksheet is utilized to determine if the existing BAT TBEL is still appropriate. The worksheet indicates that existing limits of 0.5 mg/L (average monthly) and 1.6 mg/L (IMAX) are still protective of water quality.

Toxics

DEP's NPDES permit application for minor sewages (less than 1.0 MGD) does not require sampling for heavy metals including Total Copper, Total Lead, and Total Zinc.

Best Professional Judgment (BPJ) Limitations

Dissolved Oxygen

A minimum of 5.0 mg/L for DO is an existing effluent limit and will remain unchanged in the draft permit as recommended by DEP's SOP. This requirement has also been assigned to other sewage facilities in the region. 5.0 mg/L is taken directly from 25 Pa. Code § 93.7(a) and it is also determined to be appropriate according to water quality modeling.

Total Phosphorus & Total Nitrogen

DEP's SOP no. BPNPSM-PMT-033 recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, a routine monitoring for ammonia is recommended to be introduced into this permit renewal.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Chesapeake Bay TMDL

The Department formulated a strategy in April 2007, to comply with the EPA's and Chesapeake Bay Foundation's requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011 and Phase 2 in March 2012. In accordance with the Phase 2 WIP and its supplement, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 2 WIP categorizes this facility as a phase 5 non-significant sewage facility that has a design flow less than 0.2 MGD but greater than 0.002 MGD. The WIP recommends monitoring and reporting for Total Nitrogen and Total Phosphorus throughout the permit term at a frequency no less than annual. The monitoring of these pollutants once every six months will be written in the permit in conformity with other permits issued in the region.

Monitoring Frequency and Sample Type

The facility currently is required to collect 8-hr composite effluent samples of non-Bay parameters twice a month, which is consistent with DEP Guidance 362-0400-001 (Table 6-3).

The monitoring frequency for Bay parameters is proposed to be increased in this permit from 1/year to once every six months in conformity with other permits issued in the region.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-backsliding Requirement

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal. This approach is in accordance with 40 CFR §122.44(l)(1).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Instantaneous Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/discharge	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Nitrate-Nitrite	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/6 months	8-Hr Composite
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	XXX	XXX	1/6 months	Calculation
Ammonia	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/6 months	8-Hr Composite
TKN	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/6 months	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/6 months	8-Hr Composite

Compliance Sampling Location: Outfall 001



Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]