

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0081850
APS ID 1084
Authorization ID 1255156

Applicant and Facility Information

Applicant Name	<u>Gettysburg Borough Municipal Authority Adams County</u>	Facility Name	<u>Gettysburg Municipal Authority Water System</u>
Applicant Address	<u>601 E Middle Street, PO Box 3307 Gettysburg, PA 17325-1951</u>	Facility Address	<u>Water Works Road Gettysburg, PA 17325</u>
Applicant Contact	<u>Mark Guise</u>	Facility Contact	<u>Mark Guise</u>
Applicant Phone	<u>(717) 334-6738</u>	Facility Phone	<u>(717) 334-6738</u>
Client ID	<u>78262</u>	Site ID	<u>239068</u>
SIC Code	<u>4941</u>	Municipality	<u>Cumberland Township</u>
SIC Description	<u>Trans. & Utilities - Water Supply</u>	County	<u>Adams</u>
Date Application Received	<u>November 30, 2018</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 13, 2018</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

Gettysburg Municipal Authority has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit No. PA0081850 was last reissued on May 23, 2014 and became effective on June 1, 2014. The permit expired on May 31, 2019 but the terms and conditions of the permit have been extended since that time.

The treatment plant is designed for 100% recycle of filter backwash water and treatment plant overflow. However, in the event that 100% recycle is not possible, the authority has chosen to continue to renew the NPDES permit for the discharge. Outfall 001 discharges to a dry swale which flows to Marsh Creek. The point of first use is the confluence with Marsh Creek approximately 8.14 miles.

Marsh Creek is classified as Cold-Water Fishes (CWF) according to chapter 93. The design flow is 0.215 MGD. According to previous protection reports, inspection reports, and DMR data, there has been only one discharge from this facility (on December 2018) since June 01, 2014.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and publish in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilary H. Le / Environmental Engineering Specialist	December 23, 2019
		Daniel W. Martin, P.E. / Environmental Engineer Manager	
		Maria D. Bebenek, P.E. / Clean Water Program Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.215
Latitude	39° 47' 49.8"	Longitude	-77° 16' 28.7"
Quad Name	Fairfield	Quad Code	
Wastewater Description: Sludge thickener decant			
Receiving Waters	Marsh Creek (CWF)	Stream Code	NA (dry swale) (58903)
NHD Com ID	53320624	RMI	8.14 mile
Drainage Area	56.4 mi. ²	Yield (cfs/mi ²)	0.05 cfs/mi. ²
Q ₇₋₁₀ Flow (cfs)	2.85	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	460.67	Slope (ft/ft)	
Watershed No.	13-D	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Not Assessed		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	City of Frederick, Maryland		
PWS Waters	Monocacy River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	Approximate 40 miles

Drainage Area

The discharge is to Marsh Creek at RMI 8.14 miles. A drainage area upstream of the discharge is estimated to be 56.4 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to the previous protection report, the discharge is to a dry swale to Marsh Creek (58903). According to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>, the discharge point has a Q₇₋₁₀ of 2.85 cfs and a drainage area of 56.4 mi.², which results in a theoretical low flow yield of 0.05 cfs/mi.² (2.85 cfs / 56.4 mi.²).

The resulting Q₇₋₁₀ dilution ratio is: $Q_{\text{stream}} / Q_{\text{discharge}} = 2.85 \text{ cfs} / [0.215 \text{ MGD} * (1.55 \text{ cfs/MGD})] = 8.55:1$

Public Water Supply

The nearest downstream public water supply intake is for the city of Frederick, Maryland on the Monocacy River, approximately 40 miles downstream of this discharge. Considering distance and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Gettysburg Water Treatment Plant				
WQM Permit No.		Issuance Date		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial	Primary	Sedimentation Tanks	No Disinfection	0.215
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.215		Not Overloaded		

Changes Since Last Permit Issuance: none

Other Comments: The treatment facility consists only of a gravity sludge thickener (used to treat filter backwash). Supernatant from the sludge thickener is designed to be recycled back through the water treatment plant with a discharge only occurring in emergency situations. Sludge is hauled out periodically.

Compliance History	
Summary of DMRs:	There were Discharge Monitoring Reports (DMRs) reports but there were no data because there has been only one discharge from the facility (on December 2018) since June 1, 2014.
Summary of Inspections:	10/30/2017: Mr. Bowen, DEP WQS, conducted compliance evaluation inspection. There were no violations noted during inspection. NPDES permitted outfall receives flow from a gravity overflow standpipe on the water treatment plant backwash gravity thickener. Filters are generally backwashed once per three days. Sludge is removed from the thickener approximately every 12 weeks and hauled to Maryland for land application.
Other Comments:	There are no open violations associated with this facility or permittee.

Development of Effluent Limitations

Outfall No. 001 **Design Flow (MGD)** 0.215
Latitude 39° 47' 49.8" **Longitude** -77° 16' 28.7"

Wastewater Description: Sludge thickener decant

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

Effluent Limitations Evaluation:

The previous protection report developed limitations based on Best Practicable Control Technology Currently Available (BPT), according to guidance document 362-2183-003 (*Technology-Based Control Requirements for Water Treatment Plant Wastes*).

The attached Total Residual Chlorine (TRC) Excel spreadsheet calculator, which uses the equations and calculations from guidance document 391-2000-015, was also used (Pages # 6). However, the limits from the existing permit will remain in the proposed permit since they are more stringent.

The Department’s guidance document for discharges to “dry streams” (391-2000-014) states that “for wastewater discharges other than discharges of treated sewage and similar oxygen-consuming wastes, no additional treatment requirements are applicable under this guidance. However, federal Effluent Limitation Guidelines (ELGs) are still applicable, and other technology-based requirements may be applied consistent with regional requirements.”

As noted in the previous protection report, document 362-2183-003 states that due to the cost of finished water quality concern, Best Available Technology Economically Achievable (BAT) options may not be feasible. Therefore, it may not be appropriate to require further effluent reduction to controls beyond BPT options. Except where the recycle of wastewater is feasible, BAT and Best Conventional Pollutant Control Technology (BCT) should be equivalent to BPT.

This facility has chosen to recycle as the first option for disposal of the backwash water and overflow. Therefore, BPT-based limitations are appropriate for this facility.

The guidance document defines BPT technology-based effluent control requirements as follows:

Parameter	Monthly Average (mg/L)	Daily Maximum (mg/L)
Total Suspended Solids	30	60
Total Iron	2	4
Total Aluminum	4	8
Total Manganese	1	2
Flow	Monitor	
pH	6 to 9 at all times	
Total Residual Chlorine	0.5	1.0

The limits in the above table are equivalent to the existing permit limits. It is recommended that all existing effluent limitations remain in effect.

Toxics:

An evaluation of the data submitted with the permit application and the previous protection reports indicates that there are no additional parameters of concern.

Chesapeake Bay Strategy:

The Supplement to Phase II Watershed Implementation Plan states the following (Pages # 19): “For non-significant Industrial Waste (IW) facilities, monitoring and reporting of Total Nitrogen (TN) and Total Phosphorus (TP) will be required throughout the permit term in renewed or amended permits anytime the facility has the potential to introduce a net TN or TP increase to the load contained within the intake water used in processing. In general, facilities that discharge groundwater and cooling water with no addition of chemicals containing N or P do not require monitoring.”

Gettysburg Municipal Authority Water System

This is a non-significant industrial discharge facility that will not need a phosphorus or nitrogen loading cap. TN and TP "Monitor & Report" requirement will not be necessary since this facility discharges groundwater without any chemical additives containing nitrogen or phosphorus.

Antidegradation (93.4)

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303d Listed Streams

The discharge is not located on a 303d listed stream segment.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

TRC Spreadsheet:

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
2.85	= Q stream (cfs)	0.5	= CV Daily	
0.215	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA afc = 2.752		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 1.026		5.1d
		WLA cfc = 2.676		
		LTAMULT cfc = 0.581		
		LTA_cfc = 1.556		
Source	Reference	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635		
WLA afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	1.5 * (av_mon_limit / AML_MULT) / LTAMULT_afc			

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	XXX	1.0	Daily when Discharging	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	75	2/month	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10.0	2/month	8-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5.0	2/month	8-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	2/month	8-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	Daily when Discharging	Grab
TSS	XXX	XXX	XXX	30	60	75	2/month	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10	2/month	8-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5	2/month	8-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	2/month	8-Hr Composite

Compliance Sampling Location:

Other Comments: No changes are being made to the existing permit limits.

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]