

Application Type Amendment, Major
 Facility Type Industrial
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
 INDIVIDUAL INDUSTRIAL WASTE (IW)
 AND IW STORMWATER**

Application No. PA0081850 A-1
 APS ID 1084
 Authorization ID 1333358

Applicant and Facility Information

Applicant Name	<u>Gettysburg Borough Municipal Authority Adams County</u>	Facility Name	<u>Gettysburg Municipal Authority Water System</u>
Applicant Address	<u>601 E Middle Street PO Box 3307 Gettysburg, PA 17325-1951</u>	Facility Address	<u>Water Works Road Gettysburg, PA 17325</u>
Applicant Contact	<u>Mark Guise</u>	Facility Contact	<u>Mark Guise</u>
Applicant Phone	<u>(717) 334-6738</u>	Facility Phone	<u>(717) 334-6738</u>
Client ID	<u>78262</u>	Site ID	<u>239068</u>
SIC Code	<u>4941</u>	Municipality	<u>Cumberland Township</u>
SIC Description	<u>Trans. & Utilities - Water Supply</u>	County	<u>Adams</u>
Date Application Received	<u>November 12, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>November 17, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>Permit amendment to add approximately 0.06 MGD discharge the filter-to-waste to existing Outfall during WTP start up.</u>		

Summary of Review

The treatment facility consists only of a gravity sludge thickener (used to treat filter backwash). Supernatant from the sludge thickener is designed to be recycled back through the water treatment plant with a discharge only occurring in emergency situations. Sludge is hauled out periodically. The design flow remains unchanged of 0.215 MGD. Outfall 001 discharges to a dry swale which flows to Marsh Creek.

Buchart Horn, on behalf of Gettysburg Municipal Authority Water System NPDES PA0081850, has applied to the Pennsylvania Department of Environmental Protection (PA DEP) in an amendment to add approximately 60,000 gallons (0.06 MGD) discharge of filter-to-waste to existing NPDES Outfall 001 during WTP start up. The modification will install the new filter-to-waste piping and automatic valves to discharge the filter-to-waste water through the existing Outfall 001.

This amendment will not affect any other components of the wastewater treatment plant. Therefore, the amendment permit will not affect the existing permit with reissuance on May 13, 2020 and effective date on June 1, 2020.

There are no open violations against the facility or permittee.

Planning for the proposed project was not required.

Based on the review in this report, it is recommended that the amended permit be drafted. While the application has been processed as an amendment, there are no changes permit limits. All other requirements will remain unchanged.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	December 3, 2020
		Daniel W. Martin, P.E. / Environmental Engineer Manager	
		Maria D. Bebenek, P.E. / Clean Water Program Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.215</u>
Latitude	<u>39° 47' 49.8"</u>	Longitude	<u>-77° 16' 28.7"</u>
Quad Name	<u>Fairfield</u>	Quad Code	<u></u>
Wastewater Description: <u>Water Treatment Effluent</u>			
Receiving Waters	<u>Marsh Creek (CWF)</u>	Stream Code	<u>NA (dry swale) (58903)</u>
NHD Com ID	<u>53320624</u>	RMI	<u>8.14 miles</u>
Drainage Area	<u>56.4 mi.²</u>	Yield (cfs/mi ²)	<u>0.05</u>
Q ₇₋₁₀ Flow (cfs)	<u>2.85</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>460.67</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>13-D</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Not Assessed</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Nearest Downstream Public Water Supply Intake	<u>City of Frederick, Maryland</u>		
PWS Waters	<u>Monocacy River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>Approximate 40 miles</u>

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Marsh Creek at RMI 8.14 miles. A drainage area upstream of the discharge is estimated to be 56.4 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to the previous protection report, the discharge is to a dry swale to Marsh Creek (58903). According to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>, the discharge point has a Q₇₋₁₀ of 2.85 cfs and a drainage area of 56.4 mi.², which results in a theoretical low flow yield of 0.05 cfs/mi.² (2.85 cfs / 56.4 mi.²).

$$\text{The resulting } Q_{7-10} \text{ dilution ratio is: } Q_{\text{stream}} / Q_{\text{discharge}} = 2.85 \text{ cfs} / [0.215 \text{ MGD} * (1.55 \text{ cfs/MGD})] = 8.55:1$$

Public Water Supply

The nearest downstream public water supply intake is for the city of Frederick, Maryland on the Monocacy River, approximately 40 miles downstream of this discharge. Considering distance and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Gettysburg Water Treatment Plant				
WQM Permit No.		Issuance Date		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial	Primary	Sedimentation Tanks	No Disinfection	0.215
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.215		Not Overloaded		

Changes Since Last Permit Issuance: Permit amendment to add approximately 60,000 gallons (0.06 MGD) discharge as filter-to-waste to existing NPDES Outfall 001 during WTP start up.

Development of Effluent Limitations

Outfall No. 001
 Latitude 39° 47' 49.8"

Design Flow (MGD) 0.215
 Longitude -77° 16' 28.7"

Wastewater Description: Sludge thickener decant

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Best Professional Judgment (BPJ) Limitations

The filter-to-waste effluent to be added to existing Outfall 001 testing results were entered onto the Toxics Screening Analysis Spreadsheet. The attached PENTOX results indicate that WQBEL limits are not necessary for these parameters.

TOXICS SCREENING ANALYSIS WATER QUALITY POLLUTANTS OF CONCERN VERSION 2.7						
CLEAR FORM						
Facility: <u>Gettysburg MA</u>		NPDES Permit No.: <u>PA0081850</u>		Outfall: <u>001</u>		
Analysis Hardness (mg/L): <u>183</u>		Discharge Flow (MGD): <u>0.215</u>		Analysis pH (SU): <u>7</u>		
Stream Flow, Q ₇₋₁₀ (cfs): <u>2.85</u>						
Parameter	Maximum Concentration in Application or DMRs (µg/L)	Most Stringent Criterion (µg/L)	Candidate for PENTOXSD Modeling?	Most Stringent WQBEL (µg/L)	Screening Recommendation	
Group 1	Total Dissolved Solids	300000	500000	No		
	Chloride	20000	250000	No		
	Bromide	< 200	N/A	No		
	Sulfate	120000	250000	No		
	Fluoride	200	2000	No		
Group 2	Total Aluminum	14	750	No		
	Total Antimony	1	5.6	No		
	Total Arsenic	< 1	10	No (Value < QL)		
	Total Barium	60	2400	No		
	Total Beryllium	< 1	N/A	No		
	Total Boron	240	1600	No		
	Total Cadmium	< 0.2	0.423	No (Value < QL)		
	Total Chromium	< 0.4	N/A	No		
	Hexavalent Chromium	< 0.25	10.4	No (Value < QL)		
	Total Cobalt	< 0.2	19	No (Value < QL)		
	Total Copper	14	15.6	No		
	Total Cyanide	5	N/A	No		
	Total Iron	220	1500	No		
	Dissolved Iron	190	300	No		
	Total Lead	< 1	6.9	No (Value < QL)		
	Total Manganese	860	1000	No		
	Total Mercury	< 0.2	0.05	No (Value < QL)		
	Total Molybdenum	2.1	N/A	No		
	Total Nickel	< 1	87	No (Value < QL)		
	Total Phenols (Phenolics)	< 10	5	Yes		
	Total Selenium	3	5.0	No		
	Total Silver	< 0.2	10.7	No (Value < QL)		
Total Thallium	< 1	0.24	No (Value < QL)			
Total Zinc	< 5	199.9	No (Value < QL)			

The following are permit requirements as part of this amendment:

1. **Effluent Volume Monitoring**
The requirement to monitor the volume of effluent will remain in the amendment permit per 40 CFR § 122.44(i)(1)(ii).
2. **pH Effluent Limits**
The existing pH effluent limits of 6.0 SU (instantaneous minimum) and 9.0 SU (instantaneous maximum) are secondary treatment standards found in 40 CFR §133.102(c). These effluent limits will remain unchanged in the amendment permit.
3. **Total Residual Chlorine (TRC) limits**
The existing TRC limit of 0.5 mg/L (average monthly) and 1.0 mg/L (instantaneous maximum) will remain unchanged in the amendment permit.
4. **Total Suspended Solids (TSS) Effluent Limits**
The existing TSS effluent limits of 30 mg/L (average monthly), 60 mg/L (daily maximum), and 75 mg/L (instantaneous maximum) are secondary treatment standards found in 40 CFR §133.102(b) and 25 Pa. Code § 92a.47(a)(1) and (2). These effluent limits will remain unchanged in the amendment permit.
5. **Total Aluminum Effluent Limits**
The existing Total Aluminum effluent limits of 4.0 mg/L (average monthly), 8.0 mg/L (daily maximum), and 10.0 mg/L (instantaneous maximum) are secondary treatment standards found in guidance document 362-0400-001 table 5-2 and 25 Pa. Code § 93.7. These effluent limits will remain unchanged in the amendment permit.
6. **Total Iron Effluent Limits**
The existing Total Iron effluent limits of 2.0 mg/L (average monthly), 4.0 mg/L (daily maximum), and 5.0 mg/L (instantaneous maximum) are secondary treatment standards found in guidance document 362-0400-001 table 5-2 and 25 Pa. Code § 93.7. These effluent limits will remain unchanged in the amendment permit.
7. **Total Manganese Effluent Limits**
The existing Total Manganese effluent limits of 1.0 mg/L (average monthly), 2.0 mg/L (daily maximum), and 2.5 mg/L (instantaneous maximum) are secondary treatment standards found in guidance document 362-0400-001 table 5-2 and 25 Pa. Code § 93.7. These effluent limits will remain unchanged in the amendment permit.
8. **Total Phenolic Effluent Limits**
Limitation and/or monitoring recommendations on the spreadsheet follow the logic presented in DEPs SOP No. BCW-PMT-037, revised October 1, 2020, to establish limits in the permit where the maximum reported concentration exceeds 50% of the WQBEL, or for non-conservative pollutants to establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL, or to establish monitoring requirements for conservative pollutants where the maximum reported concentration is between 10% - 50% of the WQBEL.

Total Phenolics (PWS) is not necessary to monitor and report in the amendment permit.

Analysis Results

Effluent Limits

Hydrodynamics Wasteload Allocations **Effluent Limits**

RMI	Name	Permit Number	Disc Flow (mgd)			
8.14	Gettysburg MA	PA0081850	0.2150			

Parameter	Effluent Limit (µg/L)	Governing Criterion	Max. Daily Limit (µg/L)	Most Stringent	
				WQBEL (µg/L)	WQBEL Criterion
▶ PHENOLICS (PWS)	1000000	INPUT	1560000	NA	NA

Record: 1 of 1 No Filter Search

Record: 1 of 1 No Filter Search

Number of Samples: 4

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	Daily when Discharging	Grab
TSS	XXX	XXX	XXX	30	60	75	2/month	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10	2/month	8-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5.0	2/month	8-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	2/month	8-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	Daily when Discharging	Grab
TSS	XXX	XXX	XXX	30	60	75	2/month	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10	2/month	8-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5.0	2/month	8-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	2/month	8-Hr Composite

NPDES Permit Fact Sheet
Gettysburg Municipal Authority Water System

NPDES Permit No. PA0081850 A-1

USGS StreamStats

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button.

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Continue

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy &

PRECIP	Mean Annual Precipitation	42	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	2.55	miles per square mile
ROCKDEP	Depth to rock	4.6	feet
CARBON	Percentage of area of carbonate rock	0	percent


Low-Flow Statistics Parameters (100 Percent (56.3 square miles) Low Flow Region 2)

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	56.4	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	42	inches	35	50.4
STRDEN	Stream Density	2.55	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.6	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Flow Report (100 Percent (56.3 square miles) Low Flow Region 2)

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	5.63	ft ³ /s	38	38
30 Day 2 Year Low Flow	7.53	ft ³ /s	33	33
7 Day 10 Year Low Flow	2.85	ft ³ /s	51	51
30 Day 10 Year Low Flow	3.75	ft ³ /s	46	46
90 Day 10 Year Low Flow	5.56	ft ³ /s	36	36



Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: No. BCW-PMT-037, revised October 1, 2020
<input type="checkbox"/>	Other: [redacted]