



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0081884

APS ID

311055

Authorization ID

1516077

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	Cuttin Co. LLC	Facility Name	Cuttin Co.
Applicant Address	25 Sandoe Road	Facility Address	32 W Aster Way
	Gettysburg, PA 17325-7561		Gettysburg, PA 17325-6059
Applicant Contact	Victor Fiorino	Facility Contact	Troy Martin
Applicant Phone	(717) 337-1196	Facility Phone	(717) 420-7331
Client ID	139947	Site ID	451147
Ch 94 Load Status	Not Overloaded	Municipality	Straban Township
Connection Status	No Limitations	County	Adams
Date Application Received	February 13, 2025	EPA Waived?	Yes
Date Application Accepted	February 18, 2025	If No, Reason	
Purpose of Application	NPDES permit renewal.		

Summary of Review

Keller Engineers Inc. on behalf of the Cuttin Company LLC applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on June 11, 2020, and became effective on July 1, 2020. The permit expired on June 30, 2025.

The average annual design flow and hydraulic design capacity is 0.010 MGD.

The WQM No. 0187401 amendment was issued on 1/19/2000.

Sludge use and disposal description and location(s): N/A because sludge is hauled by the facility's contractor.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the permit. The Total Copper monitoring and report average quarterly will remove from the proposed permit.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	May 16, 2025
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	June 30, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.01
Latitude	39° 53' 33.18"	Longitude	-77° 10' 48.70"
Quad Name	Biglerville	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to Beaverdam Creek (WWF)	Stream Code	9013
NHD Com ID	57473073	RMI	0.55
Drainage Area	0.11 mi. ²	Yield (cfs/mi ²)	See comments below
Q ₇₋₁₀ Flow (cfs)	See comments below	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	544	Slope (ft/ft)	
Watershed No.	7-F	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Siltation		
Source(s) of Impairment	Agriculture		
TMDL Status	Final	Name	Beaverdam Creek TMDL
Nearest Downstream Public Water Supply Intake	PP & L Bruner Island		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	54.0 miles	Distance from Outfall (mi)	Approximate 60 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to UNT to Beaverdam Creek at RMI 0.55 mile. A drainage area upstream of the discharge is estimated to be 0.11 sq.mi, according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

According to StreamStats, the gage station No. 1574000 on West Conewago Creek has a Q₇₋₁₀ of 39.2 cfs and a drainage area of 512 mi.², which is near Manchester, PA. The Q₇₋₁₀ of discharge was calculated as follows:

$$\begin{aligned}
 \text{Low Flow Yield} &= Q_{7-10\text{gage}} / \text{Drainage Area}_{\text{gage}} = 39.2 \text{ cfs} / 512 \text{ mi.}^2 = 0.08 \text{ cfs/mi.}^2 \\
 Q_{7-10\text{discharge}} &= 0.08 \text{ cfs/mi.}^2 * \text{Drainage Area}_{\text{discharge}} = 0.08 \text{ cfs/mi.}^2 * 0.11 \text{ mi.}^2 = 0.009 \text{ cfs} \\
 Q_{30-10} &= 1.36 * Q_{7-10\text{discharge}} = 1.36 * 0.009 \text{ cfs} = 0.01 \text{ cfs} \\
 Q_{1-10} &= 0.64 * Q_{7-10\text{discharge}} = 0.64 * 0.009 \text{ cfs} = 0.006 \text{ cfs}
 \end{aligned}$$

UNT to Beaverdam Creek to West Conewago Creek

25 Pa Code 93.9o classifies UNT to Beaverdam Creek to West Conewago Creek as Warm-Water Fishes (WWF) & Migratory Fishes (MF) surface water. Based on the 2024 Integrated Report, UNT to Beaverdam Creek, is impaired for aquatic life due to siltation from agriculture and impaired for recreational purposes due to pathogens from an unknown source. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Public Water Supply Intake

The nearest downstream public water supply intake is the PP & L Bruner Island on the Susquehanna River, located approximately 60 miles from the discharge. Based on the discharge from the discharge point, the discharge is not expected to impact water supply standards.

Treatment Facility Summary				
Treatment Facility Name: Cuttin Company STP (Formerly Biggerstaff)				
WQM Permit No.	Issuance Date			
0187401 A-1	1/19/2000			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Aerated Lagoon	Hypochlorite	0.01
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.01		Not Overloaded		

Changes Since Last Permit Issuance:

Other Comments:

The WWTP train is as follows:

Primary Solids removal (1) ⇒ Lift Station ⇒ Primary Lagoon ⇒ Primary Wetland Filter Bed (2) ⇒ Secondary Lagoon ⇒ Secondary Wetland Filter Bed (2) ⇒ Chlorine Contact Tank (1) ⇒ Discharge (outfall)

The system incorporates chemical addition in the form of chlorine for disinfection.

Industrial/Commercial Users:

The permit application indicated there is no industrial/commercial contributor to the treatment plant.

Biosolids:

Liquid Biosolids are hauled off site by facility's contractor.

Compliance History	
Summary of DMRs:	DMRs reported last 12 months are summarized in the next page.
Summary of Inspections:	1/12/2023: Mr. Hoy, DEP WQS, conducted a compliance evaluation inspection. The discharge was clear. The field test results indicated in permit limits. DEP's Requested to collecting 8-hour composite samples are required by Part A of Permit. DEP's Recommends revising the 9/12/2022 Copper result from 0.15 mg/L to 0.005 mg/L, submit the laboratories and date to have a complete daily effluent supplemental report each month, and use a NIST thermometer for the storage refrigerator.
Other Comments:	There are currently no open violations associated with the permittee or the facility.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from April 1, 2024 to March 31, 2025)

Parameter	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24
Flow (MGD) Average Monthly	0.0028	0.0029	0.0011	0.0021	0.0013	0.0011	0.0016	0.0051	0.0013	0.0019	0.00257	0.00401
Flow (MGD) Daily Maximum	0.018	0.0097	0.0026	0.011	0.0025	0.0038	0.0047	0.0511	0.0065	0.0079	0.0076	0.02106
pH (S.U.) Instantaneous Minimum	7.1	7.2	7.0	7.2	7.5	7.5	7.2	7.1	7.4	7.1	7.0	7.0
pH (S.U.) Instantaneous Maximum	7.6	7.6	7.6	7.7	7.8	7.8	7.8	7.8	7.8	7.7	7.6	7.5
DO (mg/L) Instantaneous Minimum	8.4	9.8	9.4	8.0	9.1	8.0	7.8	7.6	7.3	7.4	7.6	8.3
TRC (mg/L) Average Monthly	0.06	0.09	0.14	0.10	0.08	0.17	0.14	0.13	0.11	0.11	0.07	0.08
TRC (mg/L) Instantaneous Maximum	0.24	0.25	0.29	0.25	0.23	0.38	0.18	0.31	0.26	0.36	0.25	0.20
CBOD5 (mg/L) Average Monthly	< 2.0	< 3.0	< 2.0	< 2.0	< 2.4	< 2.0	< 2.0	< 3.0	< 2.0	3.0	< 2.0	< 2.0
TSS (mg/L) Average Monthly	2.0	9	2.0	2.0	2.0	3.0	2	1.0	2.0	1.0	1.0	5.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 5.0	< 1.0	< 1.0	< 7.0	< 1.0	< 1.0	21	< 1.0	< 4.0	< 5.0	< 1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1.0	63	< 1.0	1.0	48	< 1.0	1.0	435	< 1.0	15	29	< 1.0
Nitrate-Nitrite (mg/L) Annual Average				< 1.37								
Nitrate-Nitrite (lbs) Total Annual				< 4.0								
Total Nitrogen (mg/L) Annual Average				< 2.05								
Total Nitrogen (lbs) Total Annual				< 6.0								
Ammonia (mg/L) Average Monthly	2.5	1.4	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10

NPDES Permit Fact Sheet**Cuttin Co.****NPDES Permit No. PA0081884**

TKN (mg/L) Annual Average				0.68									
TKN (lbs) Total Annual				2.0									
Total Phosphorus (mg/L) Annual Average				2.60									
Total Phosphorus (lbs) Total Annual				9.0									
Total Copper (mg/L) Average Quarterly	0.008			0.011			0.007			< 0.005			

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.21	XXX	0.68	1/day	Grab
CBOD ₅	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	1.5	XXX	3.0	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	4.5	XXX	9.0	2/month	8-Hr Composite
Total Kjeldahl Nitrogen	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	2/year	8-Hr Composite
Nitrate-Nitrite as N	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	2/year	8-Hr Composite
Total Nitrogen	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	2/year	Calculation
Total Phosphorus	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	2/year	8-Hr Composite
Copper, Total	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 53' 33.18"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.01
Longitude -77° 10' 48.70"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

Water Quality-Based Limitations

Ammonia (NH₃-N)

NH₃-N calculations were first based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

- Discharge pH = 7.0 (Default)
- Discharge Temperature = 25°C (Default)
- Stream pH = 7.0 (Default)
- Stream Temperature = 20°C (Default)
- Background NH₃-N = 0 (Default)

Analysis Results WQM 7.0

Hydrodynamics	NH3-N Allocations	D.O. Allocations	D.O. Simulation	Effluent Limitations																								
<table border="1"> <thead> <tr> <th>RMI</th> <th>Discharge Name</th> <th>Permit Number</th> <th>Disc Flow (mgd)</th> </tr> </thead> <tbody> <tr> <td>0.55</td> <td>Cuttin Company</td> <td>PA0081884</td> <td>0.0100</td> </tr> </tbody> </table> <table border="1"> <thead> <tr> <th>Parameter</th> <th>Effluent Limit 30 Day Average (mg/L)</th> <th>Effluent Limit Maximum (mg/L)</th> <th>Effluent Limit Minimum (mg/L)</th> </tr> </thead> <tbody> <tr> <td>CBOD₅</td> <td>10</td> <td></td> <td></td> </tr> <tr> <td>NH₃-N</td> <td>1.5</td> <td>3</td> <td></td> </tr> <tr> <td>Dissolved Oxygen</td> <td></td> <td></td> <td>5</td> </tr> </tbody> </table> <p>Record: 1 of 1 No Filter Search </p>					RMI	Discharge Name	Permit Number	Disc Flow (mgd)	0.55	Cuttin Company	PA0081884	0.0100	Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)	CBOD ₅	10			NH ₃ -N	1.5	3		Dissolved Oxygen			5
RMI	Discharge Name	Permit Number	Disc Flow (mgd)																									
0.55	Cuttin Company	PA0081884	0.0100																									
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)																									
CBOD ₅	10																											
NH ₃ -N	1.5	3																										
Dissolved Oxygen			5																									
Print	< Back	Next >	Archive	Cancel																								

The model input data and results are attached. The printout of the WQM 7.0 output indicates that at a discharge of 0.01 MGD, limits of 1.5 mg/L NH₃-N as a monthly average and 3.0 mg/L NH₃-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects for summer, to calculate winter limits based on a typical multiplier of 3 used by DEP. The current NH₃-N limits of 1.5 mg/L monthly average and 3.0 mg/L IMAX for summer will remain in the proposed permit. Additionally, the facility's recent DMRs indicate that the facility has been consistently achieving concentrations under these limits.

Carbonaceous Biochemical Oxygen Demand (CBOD₅)

The attached computer printout of the WQM 7.0 stream model indicates that a monthly average limit of 10.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. The existing limits of 10.0 mg/L monthly average and 20.0 mg/L instantaneous maximum are same and will remain in the proposed permit due to the stream classification as a High-Quality Cold-Water Fishery. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

Dissolved Oxygen (D.O.)

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

pH

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa Code § 95.2(2).

Fecal Coliform

The recent coliform guidance in 25 Pa. Code § 92a.47(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean (average monthly) and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean (average monthly) and an instantaneous maximum not greater than 10,000/100 ml, respectively.

E. Coli

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Total Suspended Solids (TSS)

The more stringent existing limits of 10.0 mg/L average monthly and 20.0 mg/L instantaneous maximum will remain in the proposed permit due to the stream classification as a High-Quality Cold-Water Fishery. Past DMRs and inspection reports show that the facility has been consistently achieving these limits.

Total Residual Chlorine (TRC)

Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), the facility's discharge must meet a monthly average limit of 0.09 mg/L and an instantaneous maximum limit of 0.3 mg/L.

Due to the fact that the point of first use is approximately 1000 feet downstream of the outfall, the limits may be relaxed slightly due to the likelihood of significant chlorine decay due to evaporation, infiltration, and the presence of organic matter in the flow path up to the point of first use. According to modeling performed by WQM 7.0 the travel time in dry conditions and at maximum discharge flow is fairly lengthy, at 0.256 days. Photos taken for the 2001 protection report support the assumption of a relatively slow flow and the presence of significant organic matter. Heavy vegetation as well as a cattle grazing area in the flow path were observed.

There appears to be limited available literature relating to the calculation of TRC decay in a dry stream. However, a web-based review did reveal that a rough approximation of TRC decay may be obtained via the following equation:

$$C_o = C_d e^{-kt}$$

where,

$k = 20/\text{day}$ (default TRC decay rate)

$C_o = \text{TRC concentration required at point of first use (mg/L)}$

$t = \text{time of travel from outfall to point of first use (days)}$

$C_d = \text{TRC concentration required at discharge point (mg/L)}$

Cuttin Co.

The TRC decay rate constant of 20/day is recommended in EPA's "Technical Guidance Manual for Performing Wasteload Allocations; Book 2, Chapter 3, Toxic Substances" June 1984, Appendix D. This manual is cited in recent wasteload analysis procedures for both the states of Utah and Iowa. The November 2010 draft version of "Iowa Surface Water Quality Standards Implementation (WLA Procedure)" recommends the use of the aforementioned decay rate specifically for situations with zero background flow (i.e., dry stream channels).

Utilizing $C_0 = 0.05$ mg/L and $t = 0.256$ days for the first-order decay equation above yields:

$$C_d = C_0 / (e^{-kt}) = 0.05 \text{ mg/L} / (e^{(-20/d)(0.256d)}) = 8.4 \text{ mg/L}$$

The above approximation illustrates very large amounts of decay occurring along the 1000 ft reach, implying that the existing TRC limits should be sufficient. Via best professional judgment, the existing limits of 0.21 mg/L and 0.68 mg/L will remain in place. Recent DMR data indicates that the facility has been consistently achieving these limits.

TRC EVALUATION													
Input appropriate values in A3:A9 and D3:D9													
0.009	= Q stream (cfs)	0.5	= CV Daily										
0.01	= Q discharge (MGD)	0.5	= CV Hourly										
30	= no. samples	1	= AFC_Partial Mix Factor										
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor										
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)										
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)										
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)										
Source	Reference	AFC Calculations	Reference	CFC Calculations									
TRC	1.3.2.iii	WLA_afc = 0.205	1.3.2.iii	WLA_cfc = 0.192									
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581									
PENTOXSD TRG	5.1b	LTA_afc = 0.076	5.1d	LTA_cfc = 0.112									
Source	Effluent Limit Calculations												
PENTOXSD TRG	5.1f	AML MULT = 1.231		AFC									
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.094											
		INST MAX LIMIT (mg/l) = 0.307											
WLA_afc	$(.019/e^{(-k*AFC_tc)}) + [(AFC_Yc*Qs*.019/Qd*e^{(-k*AFC_tc)})... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$												
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$												
LTA_afc	wla_afc*LTAMULT_afc												
WLA_cfc	$(.011/e^{(-k*CFC_tc)}) + [(CFC_Yc*Qs*.011/Qd*e^{(-k*CFC_tc)})... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$												
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$												
LTA_cfc	wla_cfc*LTAMULT_cfc												
AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$												
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)												
INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$												

Toxic

This is a minor sewage facility receiving domestic wastewater only and the current application does not require sampling of toxic pollutants (or heavy metals) for those facilities with design flows less than 0.1 MGD. Review of the permit application revealed no toxic parameters of concern. The application states that there are no industrial / commercial wastewater contributions. Therefore, the Total Copper monitoring and report average quarterly will remove from the proposed permit.

Chesapeake Bay Strategy

According to DEP's Chesapeake Bay Phase II Watershed Implementation Plan (WIP) Wastewater Supplement, this facility is considered a phase 5 non-significant sewage discharger with design flow less than 0.2 MGD but greater than 0.002 MGD. In general, DEP will issue permits for all phase 5 facilities with monitoring and reporting for Total Nitrogen (TN) and Total Phosphorus (TP) throughout the permit term at a frequency no less than annually. Furthermore, DEP's SOP No. BPNPSM-PMT-033 states that in general, at a minimum, monitoring for TN and TP should be included in new and reissued permits for sewage discharges with design flows > 2,000 gpd. At this time, the Department is not requiring a total maximum annual nitrogen or phosphorus loading cap. This plant, classified as a phase 5, to monitor and report TKN, Nitrate-Nitrite as N, TN and TP two time a year will remain in the proposed permit.

Cuttin Co.*Local Total Maximum Daily Loading (TMDL)*

The subject facility discharges into the Beaverdam Creek TMDL. Beaverdam Creek is a tributary of the Susquehanna River in Adams County, South Central Pennsylvania (PA). A Total Maximum Daily Load (TMDL) for sediment was developed to address impairments noted in Pennsylvania's 2008 Section 303(d) and Integrated Lists. The impairments were documented during biological surveys of the aquatic life present in the watershed (6/06/2006). Excessive siltation resulting from agricultural activities has been identified as the cause of these impairments in the basin.

The existing sediment loading in the Beaverdam Creek Watershed is 1,289,291 pounds per year (3,532 pounds per day). Based on a comparison to a similar, unimpaired watershed, Little Conewago Creek, the maximum sediment loading that should still allow water quality objectives to be met in the Beaverdam Creek Watershed is 1,111,570 pounds per year (3,045 pounds per day).

The waste load allocation (WLA) portion of the TMDL equation is the total loading of a pollutant that is assigned to point sources. There are two NPDES permitted discharges in the Beaverdam Creek Watershed and a bulk reserve allocation of 1.0% of the TMDL to account for the dynamic nature of permit activity. The permit limit for total suspended solids (TSS) for the Cuttin Company facility is 10 mg/L (monthly average) and a loading rate of 304.41 lbs/yr which is prescribed by the TMDL for this discharge.

Total Phosphorus

The previous protection report did not apply phosphorus limits for this facility based on the following method. This will remain in the proposed permit.

The phosphorus load to the lower Susquehanna River is:

$$10 \text{ mg/L} \times 0.010 \text{ MGD} \times 8.34 = 0.83 \text{ lbs/day}$$

This load represents 0.02% (0.83 lbs/day / 3,814 lbs/day x 100%) of the total estimated load to the lower Susquehanna River, which is well below the minimum requirement of 0.25% required for the establishment of phosphorus limits.

Additional Consideration*Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Monitoring Frequency and Sample Type

The facility currently is required to collect daily effluent grab samples for D.O., TRC, and pH; bi-monthly effluent grab samples of CBOD₅, TSS, ammonia-nitrogen, and fecal coliform; annually effluent grab samples of TP; and annually effluent calculation samples of TN. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the renewal permit monitoring frequencies will remain the same as those specified in the existing permit.

Antidegradation (93.4)

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303d LISTED STREAMS

eMap PA lists UNT 09013 as impaired for siltation due to agriculture. The receiving waters are included in "Beaverdam Creek TMDL," which was finalized on July 29, 2011. The TMDL lists a wasteload allocation for TSS only, allocating 304.41 lbs/yr based on the existing monthly average limit of 10 mg/L. A TSS reduction from the current limit is not prescribed.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

WQM 7.0

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	25°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	20°C	(Default)
*	Background NH ₃ -N	=	0	(Default)

Node 1: Outfall 001 (9013)

Elevation:	544 ft (USGS National Map Viewer)
Drainage Area:	0.11 mi. ² (USGS PA StreamStats)
River Mile Index:	0.55 mile (PA DEP eMapPA)
Low Flow Yield:	0.08 cfs/mi. ²
Discharge Flow:	0.01 MGD

Node 2: On UNT (9013) just before Trib. 8990

Elevation:	520 ft (USGS National Map Viewer)
Drainage Area:	0.23 mi. ² (USGS PA StreamStats)
River Mile Index:	0.001 mile (PA DEP eMapPA)
Low Flow Yield:	0.08 cfs/mi. ²
Discharge Flow:	0.000 MGD

Analysis Results WQM 7.0

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.55	Cuttin Company	PA0081884	0.0100
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	10		
NH3-N	1.5	3	
Dissolved Oxygen			5

Record: 1 of 1 | < Back | Next > | No Filter | Search | Print | Archive | Cancel |

NPDES Permit Fact Sheet
Cuttin Co.

NPDES Permit No. PA0081884

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
OTF	9013	Trib 09013 to Beaverdam Creek					
RM# Name Permit Number Disch. Flow (mgd) Parameter Eff. Limit 30-day Ave. (mg/L) Eff. Limit Maximum (mg/L) Eff. Limit Minimum (mg/L)							
0.050	Cuttin Company	PA0081884	0.010	CBOD5	10		
				NH3N	1.5	3	
				Dissolved Oxygen	5		

Wednesday, May 14, 2025 Version 1.1 Page 1 of 1

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name					
OTF	9013	Trib 09013 to Beaverdam Creek					
NH3-N Acute Allocations							
RM#	Discharge Name	Baseline Criteria (mg/L)	Baseline WLA (mg/L)	Multiple Criteria (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.050	Cuttin Company	12.37	3	12.37	3	0	0
NH3-N Chronic Allocations							
RM#	Discharge Name	Baseline Criteria (mg/L)	Baseline WLA (mg/L)	Multiple Criteria (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.050	Cuttin Company	1.37	1.5	1.37	1.5	0	0
Dissolved Oxygen Allocations							
RM#	Discharge Name	CBOD5 (mg/L)	NH3N (mg/L)	Dissolved Oxygen (mg/L)	Critical Reach	Percent Reduction	
0.05	Cuttin Company	10	10	1.5	5	0	0

Wednesday, May 14, 2025 Version 1.1 Page 1 of 1

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name	
OTF	9013	Trib 09013 to Beaverdam Creek	
RM# Total Discharge Flow (mgd) Analytic Temperature (°C) Analytic pH			
0.050	0.010	25.187	7.000
Reach Width (ft)	Reach Depth (ft)	Reach W/L Ratio	Reach Velocity (fts)
0.500	0.500	0.000	0.000
Reach CBOD5 (mg/L)	Reach DO (1/day)	Reach NH3-N (mg/L)	Reach NO (1/day)
7.10	1.220	0.96	0.895
Reach DO (mg/L)	Reach Kt (1/day)	Kt Equation	Reach DO Goal (mg/L)
6.176	27.192	Overall	5
Reach Travel Time (days)			
0.756			
Sub-reach Results			
Travel Time	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
(days)	(mg/L)	(mg/L)	(mg/L)
0.070	0.30	0.69	7.76
0.151	5.70	0.64	7.76
0.227	5.70	0.64	7.76
0.303	4.40	0.73	7.76
0.378	4.40	0.66	7.76
0.454	3.70	0.64	7.76
0.529	3.30	0.60	7.76
0.605	3.02	0.56	7.76
0.680	2.72	0.52	7.76
0.756	2.41	0.49	7.76

Wednesday, May 14, 2025 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameters	Value	Notes
W/LA Method	EMPR	Use Inputted W/L Ratio
Q1-10Q7-10 Ratio	0.64	Use Inputted Reach Travel Times
Q30-10Q7-10 Ratio	1.06	Temperature Adjust Kt
D.O. Saturation	90.00%	Use Balanced Technology
D.O. Goal	5	

Wednesday, May 14, 2025 Version 1.1 Page 1 of 1

NPDES Permit Fact Sheet
Cuttin Co.

NPDES Permit No. PA0081884

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name
OTF	9013	Trib 09013 to Beaverdam Creek

RM	Stream Flow	PWS With	Net	Disch.	Reach	Depth	Width	WD	Velocity	Reach	Analysis	Analysis	Analysis
	(cfs)	(cfs)	(cfs)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft/s)	(days)	(°C)	(°C)	(pH)
Q7-10 Flow	0.050	0.01	0.00	0.05	.0155	0.000308	298	1.03	0.14	0.04	0.756	23.19	7.00
Q1-10 Flow	0.050	0.01	0.00	0.05	.0155	0.000308	NA	NA	NA	0.04	0.818	23.07	7.00
Q30-10 Flow	0.050	0.01	0.00	0.05	.0155	0.000308	NA	NA	NA	0.05	0.706	22.82	7.00

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RM	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mpg)	Apply FC
OTF	9013	Trib 09013 to Beaverdam Creek	0.001	520.00	0.23	0.000000	0.00	<input checked="" type="checkbox"/>

Stream Data											
Design Cond.	LFY	Trib Flow	Streams Flow	Rich Trav Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tabular Temp, pH		
(cfs)	(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)	(ft)	(ft)	(°C) (pH)		
Q7-10	0.050	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10	0.050	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00	0.00	0.00
Q30-10	0.050	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00	0.00	0.00

Discharge Data									
Name	Permit Number	Existing Disch. Flow (mpg)	Purified Design Disch. Flow (mpg)	Design Disch. Flow (mpg)	Reactive Factor	Disch. Temp (°C)	Disch. pH	Stream Conc. (mpg/L)	Temp, pH (°C)
Cuttin Company	PA-0081884	0.0000	0.0100	0.0100	0.0000	25.00	7.00	0.00	0.00

Parameter Data									
Parameter Name	Disc. Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Fate Coef. (1/day)	Disc. Temp (°C)	Disc. pH	Stream pH	Temp, pH (°C)	Conc. (mg/L)
CB-005	25.00	2.00	0.00	1.50	0.00	0.00	0.00	0.00	0.00
Dissolved Oxygen	5.00	8.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NH4-N	25.00	0.00	0.00	0.70	0.00	0.00	0.00	0.00	0.00

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RM	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mpg)	Apply FC
OTF	9013	Trib 09013 to Beaverdam Creek	0.001	520.00	0.23	0.000000	0.00	<input checked="" type="checkbox"/>

Stream Data											
Design Cond.	LFY	Trib Flow	Streams Flow	Rich Trav Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tabular Temp, pH		
(cfs)	(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)	(ft)	(ft)	(°C) (pH)		
Q7-10	0.050	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10	0.050	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00	0.00	0.00
Q30-10	0.050	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00	0.00	0.00

Discharge Data									
Name	Permit Number	Existing Disch. Flow (mpg)	Purified Design Disch. Flow (mpg)	Design Disch. Flow (mpg)	Reactive Factor	Disch. Temp (°C)	Disch. pH	Stream Conc. (mpg/L)	Temp, pH (°C)
Cuttin Company	PA-0081884	0.0000	0.0000	0.0000	0.0000	25.00	7.00	0.00	0.00

Parameter Data									
Parameter Name	Disc. Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Fate Coef. (1/day)	Disc. Temp (°C)	Disc. pH	Stream pH	Temp, pH (°C)	Conc. (mg/L)
CB-005	25.00	2.00	0.00	1.50	0.00	0.00	0.00	0.00	0.00
Dissolved Oxygen	5.00	8.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NH4-N	25.00	0.00	0.00	0.70	0.00	0.00	0.00	0.00	0.00

Wednesday, May 14, 2020

Version 1.1

Page 2 of 2

13


Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.21	XXX	0.68	1/day	Grab
CBOD ₅	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	4.5	XXX	9.0	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	1.5	XXX	3.0	2/month	8-Hr Composite
TKN	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	2/year	8-Hr Composite
Nitrate-Nitrite	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	2/year	8-Hr Composite
Total Nitrogen	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	2/year	Calculation
Total Phosphorus	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	2/year	8-Hr Composite

Compliance Sampling Location:



USGS StreamStats

BUILD A REPORT Report Built >

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button.

Hide Basin Characteristics

Basin Characteristics can be edited here

Calculate Missing Parameters

Parameter	Value
DNAREA	0.11
BSLOPD	0.3497
ROCKDEP	4
URBAN	23.8028
PRECIP	41
STRDEN	1.81
CARBON	0

Select available reports to display:

- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports
- Hydrologic Features Report

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

BSLOPD Mean Basin Slope degrees 0.3497 degrees 1.7 6.4

DNAREA Drainage Area 0.11 square miles 4.78 1150

ROCKDEP Depth to Rock 4 feet 4.13 5.21

URBAN Percent Urban 23.8028 percent 0 89

Low-Flow Statistics Parameters [1.0 Percent (0.000846 square miles) Low Flow Region 2]

PARAMETER CODE	PARAMETER NAME	VALUE	UNITS	MIN LIMIT	MAX LIMIT
CARBON	Percent Carbonate	0	percent	0	99
DNAREA	Drainage Area	0.11	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
ROCKDEP	Depth to Rock	4	feet	3.32	5.65
STRDEN	Stream Density	1.81	miles per square mile	0.51	3.1

Low-Flow Statistics Disclaimers [99.0 Percent (0.108 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [99.0 Percent (0.108 square miles) Low Flow Region 1]

STATISTIC	VALUE	UNIT
7 Day 2 Year Low Flow	0.000588	ft^3/s
30 Day 2 Year Low Flow	0.00155	ft^3/s
7 Day 10 Year Low Flow	0.0000834	ft^3/s
30 Day 10 Year Low Flow	0.000248	ft^3/s
90 Day 10 Year Low Flow	0.0016	ft^3/s

Low-Flow Statistics Disclaimers [1.0 Percent (0.000846 square miles) Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [1.0 Percent (0.000846 square miles) Low Flow Region 2]

STATISTIC	VALUE	UNIT
7 Day 2 Year Low Flow	0.0056	ft^3/s
30 Day 2 Year Low Flow	0.00872	ft^3/s
7 Day 10 Year Low Flow	0.00168	ft^3/s
30 Day 10 Year Low Flow	0.00267	ft^3/s
90 Day 10 Year Low Flow	0.00534	ft^3/s

Low-Flow Statistics Flow Report [Area-Averaged]

STATISTIC	VALUE	UNIT
7 Day 2 Year Low Flow	0.000638	ft^3/s
30 Day 2 Year Low Flow	0.00162	ft^3/s
7 Day 10 Year Low Flow	0.0000994	ft^3/s
30 Day 10 Year Low Flow	0.000272	ft^3/s
90 Day 10 Year Low Flow	0.00164	ft^3/s

Batch Processor Report About ? Help

Layers

Base Maps Application Layers National Layers PA Map Layers

USGS StreamStats

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the 'Build Report' button.

Hide Basin Characteristics

Basin Characteristics can be edited here

Parameter	Value
DRNAREA	512
BSLOPD	3.8619
ROCKDEP	4.6
URBAN	3.2443

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports
- Hydrologic Features Report

[Open Report](#)

POWERED BY

USGS Home | Contact USGS | Search USGS
Accessibility | FOIA | Privacy | Policy & Notices

Map showing Maryland and surrounding states with major roads and rivers.

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.8619	degrees
DRNAREA	Area that drains to a point on a stream	512	square miles
ROCKDEP	Depth to rock	4.6	feet
URBAN	Percentage of basin with urban development	3.2443	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	3.8619	degrees	1.7	6.4
DRNAREA	Drainage Area	512	square miles	4.78	1150
ROCKDEP	Depth to Rock	4.6	feet	4.13	5.21
URBAN	Percent Urban	3.2443	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	76.7	ft ³ /s	46	46
30 Day 2 Year Low Flow	102	ft ³ /s	38	38
7 Day 10 Year Low Flow	39.2	ft ³ /s	51	51
30 Day 10 Year Low Flow	52	ft ³ /s	46	46
90 Day 10 Year Low Flow	84	ft ³ /s	41	41

Map showing Maryland and surrounding states with major roads and rivers.

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	0.4836	degrees
DRNAREA	Area that drains to a point on a stream	0.23	square miles
ROCKDEP	Depth to rock	4	feet
URBAN	Percentage of basin with urban development	14.5183	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	0.4836	degrees	1.7	6.4
DRNAREA	Drainage Area	0.23	square miles	4.78	1150
ROCKDEP	Depth to Rock	4	feet	4.13	5.21
URBAN	Percent Urban	14.5183	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown error.

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.00159	ft ³ /s
30 Day 2 Year Low Flow	0.00388	ft ³ /s
7 Day 10 Year Low Flow	0.000252	ft ³ /s
30 Day 10 Year Low Flow	0.000689	ft ³ /s
90 Day 10 Year Low Flow	0.0038	ft ³ /s

Batch Processor | Report | About | Help

Layers

Base Maps

Application Layers

National Layers

PA Map Layers

Batch Processor | U.S. Department of the Interior | U.S. Geological Survey | Policies

USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built >

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the 'Build Report' button.

Hide Basin Characteristics

Basin Characteristics can be edited here

Parameter	Value
DRNAREA	0.23
BSLOPD	0.4836
ROCKDEP	4
URBAN	14.5183

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports
- Hydrologic Features Report

[Open Report](#)

POWERED BY

USGS Home | Contact USGS | Search USGS
Accessibility | FOIA | Privacy | Policy & Notices

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	0.4836	degrees
DRNAREA	Area that drains to a point on a stream	0.23	square miles
ROCKDEP	Depth to rock	4	feet
URBAN	Percentage of basin with urban development	14.5183	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	0.4836	degrees	1.7	6.4
DRNAREA	Drainage Area	0.23	square miles	4.78	1150
ROCKDEP	Depth to Rock	4	feet	4.13	5.21
URBAN	Percent Urban	14.5183	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown error.

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.00159	ft ³ /s
30 Day 2 Year Low Flow	0.00388	ft ³ /s
7 Day 10 Year Low Flow	0.000252	ft ³ /s
30 Day 10 Year Low Flow	0.000689	ft ³ /s
90 Day 10 Year Low Flow	0.0038	ft ³ /s

16

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: . BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]