

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0082163
 APS ID 276559
 Authorization ID 1274258

Applicant and Facility Information

Applicant Name	<u>New Life For Girls Inc.</u>	Facility Name	<u>New Life For Girls Home</u>
Applicant Address	<u>PO Box 170 5925 Lewisberry Road Dover, PA 17315-0170</u>	Facility Address	<u>PO Box 170 5925 Lewisberry Road Dover, PA 17315-0170</u>
Applicant Contact	<u>Jose Pacheco</u>	Facility Contact	<u>Jose Pacheco</u>
Applicant Phone	<u>(717) 266-5614</u>	Facility Phone	<u>(717) 266-5614</u>
Client ID	<u>4658</u>	Site ID	<u>443110</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Conewago Township</u>
Connection Status		County	<u>York</u>
Date Application Received	<u>May 3, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 23, 2019</u>	If No, Reason	
Purpose of Application	<u>Authorization to discharge to UNT Laurel Run in Watershed 7F.</u>		

Summary of Review

The New Life for Girls Home has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit for the New Life for Girls Home STP. The permit was last reissued to the New Life for Girls Home on October 17, 2014 and became effective on November 1, 2014. The permit expired on October 31, 2019 but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days. A file review of documents associated with the discharge or permittee may be available at the PA DEP southcentral regional office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file reviews, contact the SCRO file review coordinator at 717.705.4700.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Aaron Baar / Permits Section Aaron Baar	September 24, 2020
		Daniel W. Martin, P.E. / Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.005
Latitude	40° 4' 49.68"	Longitude	-76° 48' 56.08"
Quad Name	Dover	Quad Code	1831
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Laurel Run (WWF)	Stream Code	08510
NHD Com ID	57465123	RMI	0.28
Drainage Area	0.42 mi ²	Yield (cfs/mi ²)	0.1054 (basin)
Q ₇₋₁₀ Flow (cfs)	0.044	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	466.53	Slope (ft/ft)	
Watershed No.	7-F	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	Wrightsville Water Supply Company		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	43.54	Distance from Outfall (mi)	27.3

Drainage Area

The discharge is to UT to Laurel Run at RMI 0.28. A drainage area upstream of the discharge point is determined to be 0.42 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

The watershed for the UT to Laurel Run is too small for accurate projections, so a LFY for the UT to Laurel Run watershed was used to calculate a LFY for the area tributary to Outfall 001, from which a Q₇₋₁₀ flow upstream of Outfall 001 was calculated. According to StreamStats, the watershed has a Q₇₋₁₀ of 0.447 cfs and a drainage area of 4.24 mi², which results in a watershed LFY of 0.1054 cfs/mi². Multiplying this basin-wide LFY by the drainage area upstream of Outfall 001, 0.42 mi², yielded an estimated Q₇₋₁₀ flow of 0.0506 cfs.

UT to Laurel Run

UT to Laurel Run is classified as a WWF waterway. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Public Water Supply Intake

The nearest downstream public water supply intake is the Wrightsville Water Supply Company intake located on the Susquehanna River. Considering the distance and nature of the discharge, the discharge is not expected to significantly affect the water supply.

Class A Wild Trout Streams

The receiving stream is not a Class A Wild Trout stream.

Treatment Facility Summary				
Treatment Facility Name: New Life For Girls Home				
WQM Permit No.		Issuance Date		
6774414		8/21/74		
6708407		8/12/08		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.005
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.01	20.9	Not Overloaded		

The New Life for Girls Home owns and operates the New Life for Girls Home sanitary wastewater treatment facility located in Conewago Township, York County. The facility serves only the New Life for Girls Home, all wastes are residential in nature, and all sewer systems are 100% separated. Having an annual average design flow of 0.005 MGD and a hydraulic design capacity of 0.005 MGD, this facility consists of a headworks (comminutor), aeration tank, secondary clarification, a chlorine contact tank, a post-aeration tank, effluent septic tanks x2, a polishing pond (3 cells and 3 aeration lines) and the outfall (Outfall 001). The facility utilizes soda ash (pH control), sodium hypochlorite (disinfection) and aluminum sulfate (phosphorus precipitation) as chemical amendments. Solids are stored in an onsite sludge holding tank for offsite disposal.

Compliance History	
Summary of DMRs:	A summary of past DMR data is presented on the next page.
Summary of Inspections:	Since the last NPDES permit renewal, there are no records in the Department's File Room that the facility has been inspected.

Other Comments: A records review revealed that there are no Clean Water open violations associated with this permittee as of September 24, 2020.

Existing Permit Limits

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.37	XXX	1.21	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	12.9	XXX	25	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	4.3	XXX	8.6	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4.0	2/month	Grab
Total Nitrogen (lbs/year)	XXX	Report Annl Avg	XXX	Report Annl Avg	XXX	4.0	1/year	Calculation
Total Phosphorus (lbs/year)	XXX	Report Annl Avg	XXX	Report Annl Avg	XXX	4.0	1/year	Calculation

Compliance History

DMR Data for Outfall 001 (from August 1, 2019 to July 31, 2020)

Parameter	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19	AUG-19
Flow (MGD) Average Monthly	0.0024	0.0021	0.002	0.0021	0.0019	0.0019	0.002	0.0021	0.0029	0.0058	0.0044	0.004
Flow (MGD) Daily Maximum	0.0061	0.003	0.003	0.003	0.0039	0.0033	0.0034	0.0036	0.0076	0.0132	0.0055	0.0099
pH (S.U.) Minimum	6.8	6.9	6.9	6.9	6.7	6.9	6.9	6.8	6.9	6.7	6.6	6.7
pH (S.U.) Maximum	7.3	8.0	8.0	7.6	7.7	7.7	7.8	7.6	7.6	7.5	7.6	7.6
DO (mg/L) Minimum	6.0	6.0	6.0	8.0	7.6	9.0	6.0	6.4	7.2	7.0	7.6	7.0
TRC (mg/L) Average Monthly	0.09	0.06	0.09	0.08	0.08	0.06	0.09	0.08	0.05	0.06	0.04	0.07
TRC (mg/L) Instantaneous Maximum	0.21	0.35	0.17	0.26	0.31	0.15	0.23	0.16	0.18	0.15	0.25	0.30
CBOD5 (mg/L) Average Monthly	< 2	< 2.4	< 3.5	< 2	2.4	2.5	2.8	2.6	4.0	< 2.7	< 2.0	< 2.0
CBOD5 (mg/L) Instantaneous Maximum	< 2	2.7	4.9	< 2	2.6	2.5	3.4	3.2	5.0	3.3	< 2.0	< 2
TSS (mg/L) Average Monthly	< 5	< 5.0	5.0	< 5	< 6.5	< 5.0	< 5.0	< 6.0	< 5.0	< 7.0	< 5.0	7
TSS (mg/L) Instantaneous Maximum	5	< 5	5	< 5	8.0	< 5.0	< 5	7	< 5.0	9.0	5	9
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 1	1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1
Total Nitrogen (lbs/year) Other Annual Final Effluent Annual Average								110				

Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	.005
Latitude	40° 4' 49.85"	Longitude	-76° 48' 56.12"
Wastewater Description: Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

Water Quality-Based Limitations

CBOD₅, NH₃-N and Dissolved Oxygen (DO)

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD₅, NH₃-N and DO. DEP's guidance 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges.

The model was utilized, and the model output indicated that existing limits for both CBOD₅ and ammonia are lower than those specified in the model. Due to anti-backsliding provisions, however, the existing limits are deemed to be still appropriate. The existing D.O. limit of 5 mg/L is also considered still appropriate.

The monitoring frequency and sample type for CBOD₅, DO and ammonia are proposed to remain unchanged.

Total Residual Chlorine

Since chlorine is used for disinfection, Total Residual Chlorine (TRC) effluent levels must be regulated in accordance with 25 Pa Code §92a.48(b). DEP's TRC_CALC worksheet was utilized to determine if the existing BAT TBEL is still appropriate. The worksheet indicated that existing limits for TRC are lower than those specified in the worksheet. Due to anti-backsliding provisions, however, the existing limits are deemed to be still appropriate.

Toxics

There are no industrial contributions to this facility. DEP's NPDES permit application for minor sewages (less than 1.0 MGD) does not require sampling for heavy metals including Total Copper, Total Lead, and Total Zinc.

Best Professional Judgment (BPJ) Limitations

Total Phosphorus & Total Nitrogen

DEP's SOP no. BPNPSM-PMT-033 recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. The monitoring of NOx and TKN have been added to this permit to facilitate the collection of TN data. Also, the reporting frequency of TN is proposed to be increased in this permit to once every six months (from 1/year) in conformity with other Chesapeake Bay Phase 5 permits issued in the region.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Chesapeake Bay TMDL

The Department formulated a strategy in April 2007, to comply with the EPA's and Chesapeake Bay Foundation's requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011 and Phase 2 in March 2012. In accordance with the Phase 3 WIP and its supplement, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 3 WIP categorizes this facility as a phase 5 non-significant sewage facility that has a design flow less than 0.2 MGD but greater than 0.002 MGD. The WIP recommends monitoring and reporting for Total Nitrogen and Total Phosphorus throughout the permit term at a frequency no less than annual. The monitoring of NOx, TKN and TN once every six months will be written in the permit in conformity with other permits issued in the region.

Monitoring Frequency and Sample Type

The facility currently is required to collect 2/month grab effluent samples for CBOD5, TSS, fecal, TP and ammonia. This monitoring frequency is consistent with Table 6-3 of DEP's technical guidance no. 362-0400-001 and will remain unchanged in this permit.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-backsliding Requirement

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal. This approach is in accordance with 40 CFR §122.44(l)(1).

Mass Loading Limitations

All effluent mass loading limits are based on the formula: design flow x concentration limit x conversion factor of 8.34.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.37	XXX	1.21	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25	XXX	50	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite as N	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	Grab
Nitrate-Nitrite as N (Total Load, lbs)	XXX	Report SEMI AVG	XXX	XXX	XXX	XXX	1/6 months	Calculation
Total Nitrogen (Total Load, lbs)	XXX	Report SEMI AVG	XXX	XXX	XXX	XXX	1/6 months	Calculation
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	12.9	XXX	25.0	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	4.3	XXX	8.6	2/month	Grab
Ammonia-Nitrogen (Total Load, lbs)	XXX	Report Total Wkly	XXX	XXX	XXX	XXX	2/month	Calculation

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Kjeldahl Nitrogen	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	Grab
Total Kjeldahl Nitrogen (Total Load, lbs) (lbs)	XXX	Report SEMI AVG	XXX	XXX	XXX	XXX	1/6 months	Calculation
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4.0	2/month	Grab
Total Phosphorus (Total Load, lbs) (lbs)	XXX	Report Wkly Avg	XXX	XXX	XXX	XXX	2/month	Calculation

Compliance Sampling Location: Outfall 001



PA0082163 Report
4.pdf



PA0082163
TRC_CALC.xlsx



PA0082163
StreamStats Basin.p



PA0082163



PA0082163



PA0082163 Report
5.pdf



PA0082163 Report
6.pdf



PA0082163 Report
1.pdf



PA0082163 Report
2.pdf



PA0082163 Report
3.pdf



Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]