

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0082279
APS ID 5459
Authorization ID 1315552

Applicant and Facility Information

Applicant Name	<u>Spring Creek Joint Sewer Authority Huntingdon County</u>	Facility Name	<u>Spring Creek STP</u>
Applicant Address	<u>PO Box 373 Three Springs, PA 17264-0373</u>	Facility Address	<u>Pa-994 East Of Three Springs Boro Three Springs, PA 17264</u>
Applicant Contact	<u>Robert Trego</u>	Facility Contact	<u>Rodney Thomas</u>
Applicant Phone	<u>(814) 448-3414</u>	Facility Phone	<u>(814) 448-3414</u>
Client ID	<u>143583</u>	Site ID	<u>246978</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Clay Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Huntingdon</u>
Date Application Received	<u>May 5, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 3, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Renewal.</u>		

Summary of Review

Spring Creek Sewer Authority has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on September 23, 2015 and became effective on October 1, 2015. The permit expired on September 30, 2020, and the permit has been administratively extended since that time.

The facility has an average annual design flow of 0.132 MGD and hydraulic capacity is 0.17 MGD that discharges to Three Springs Creek. The application states the following flow contribution sources: 54% of Three Springs Borough, 37% of Saltillo Borough, and 9% of Clay Township.

WQM Part II No. 3109401 original was issued on May 28, 2009.

Changes from the previous permit: Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	October 29, 2020
		Daniel W. Martin, P.E. / Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.17
Latitude	40° 11' 34.85"	Longitude	-77° 58' 24.95"
Quad Name	Orbisonia	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Three Springs Creek (CWF)	Stream Code	12866
NHD Com ID	66212017	RMI	3.35
Drainage Area	23.6 mi. ²	Yield (cfs/mi ²)	0.02
Q ₇₋₁₀ Flow (cfs)	0.43	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	696.99	Slope (ft/ft)	
Watershed No.	12-C	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	Mifflintown Municipal Authority, Juniata County		
PWS Waters	Juniata River	Flow at Intake (cfs)	
PWS RMI	34.4 miles	Distance from Outfall (mi)	Approximate 64 miles

Changes Since Last Permit Issuance: none

Drainage Area

The discharge is to Three Springs Creek at RMI 3.35 miles. A drainage area upstream of the discharge is estimated to be 23.6 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

According to StreamStats, the discharge point on Three Springs Creek has a Q₇₋₁₀ of 0.43 cfs and a drainage area of 23.6 mi.², which results in a Q₇₋₁₀ low flow yield of 0.02 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$Q_{7-10} = 0.43 \text{ cfs}$$

$$\text{Low Flow Yield} = 0.43 \text{ cfs} / 23.6 \text{ mi.}^2 \approx 0.02 \text{ cfs/mi.}^2$$

$$Q_{30-10} = 1.36 * 0.43 \text{ cfs} \approx 0.58 \text{ cfs}$$

$$Q_{1-10} = 0.64 * 0.4 \text{ cfs} \approx 0.28 \text{ cfs}$$

The resulting Q₇₋₁₀ dilution ratio is: $Q_{\text{stream}} / Q_{\text{discharge}} = 0.43 \text{ cfs} / [0.132 \text{ MGD} * (1.55 \text{ cfs/MGD})] = 2.1:1$

Three Springs Creek

25 Pa Code § 93.9n classifies Three Springs Creek as Cold Water and Migratory Fishes (CWF, MF) surface water. Based on the 2018 Integrated Report, Three Springs Creek, assessment unit ID 9875, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Public Water Supply

The nearest downstream public water supply intake is the Mifflintown Municipal Authority, Juniata County, approximately 64 miles downstream of this discharge. Considering distance and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Spring Creek STP				
WQM Permit No.		Issuance Date		
3109401		5/28/2009		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia And Phosphorus	Sequencing Batch Reactor	Gas Chlorine	0.132
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.17	275	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: none

Other Comments: The facility hydraulic capacity is a 170,000 GPD system with the following treatment units:

- One (1), Wet Well
- Two (2), Sequencing Batch Reactors
- One (1), Chlorine Contact Tank
- One (1), Dechlorination Tank
- One (1), Post Aeration Tank
- Two (2), Reed Beds
- Two (2), Aerobic Digesters
- One (1), Sludge Pad

The chemical is used at treatment Sodium Hypochlorite (liquid) for disinfection, and Sodium Bisulfite (liquid) for dechlorination.

Compliance History	
Summary of DMRs:	The DMRs reported from September 1, 2019 to August 31, 2020 is summarized in the Table below (Pages # 5, 6, & 7).
Summary of Inspections:	<p>11/4/2019: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. There was recommendation to create and post Standard Operating Procedure for plant operations. The effluent was clear. The field test results were within permit limits. There were no violations noted during inspection.</p> <p>10/24/2018: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. There were recommendations to remove weeds from chlorine contact tank and SBR basin; and remove leaves from effluent meter stilling well. The effluent was clear. The field tests results were within the permit limits. There were no violations noted during inspection.</p> <p>10/4/2017: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. There were recommendations to remove weeds from chlorine contact tank, and more accurate TRC results. The effluent was clear. The field test results were within permit limits. There were no violations noted during inspection.</p>
Other Comments:	There are currently no open violations associated to the permittee or the facility.

Other Comment:

The table below summarizes the influent/effluent testing results submitted along with the application.

<i>Influent Testing Results</i>			<i>Effluent Testing Results</i>		
Parameter	Min/Max Value	Average Value	Parameter	Min/Max Value	Average Value
BOD ₅ (mg/L)	742 mg/L	mg/L	pH (minimum)	6.4 S.U.	
BOD ₅ (lbs/day)	756 lbs/day	lbs/day	pH (maximum)	8.0 S.U.	
TSS (mg/L)	444 mg/L	mg/L	D.O (minimum)	6.2 mg/L	mg/L
TSS (lbs/day)	1070 lbs/day	lbs/day	TRC	0.61 mg/L	<0.04 mg/L
TN (mg/L)	14.37 mg/L	mg/L	Fecal Coliform	1,376 No./100mL	3.0 No./100 mL
TN (lbs/day)	21.93 lbs/day	lbs/day	CBOD ₅	12.6 mg/L	< 4.92 mg/L
TP (mg/L)	4.30 mg/L	mg/L	TSS	11.6 mg/L	mg/L
TP (lbs/day)	6.56 lbs/day	lbs/day	NH ₃ -N	0.35 mg/L	mg/L
NH ₃ -N (mg/L)	21.96 mg/L	mg/L	TN	19.97 mg/L	mg/L
NH ₃ -N (lbs/day)	33.52 lbs/day	lbs/day	TP	4.05 mg/L	mg/L
TDS (mg/L)	388 mg/L	mg/L	Temp	55.4 F	F
TDS (lbs/day)	592 lbs/day	lbs/day	TKN	2.29 mg/L	mg/L
TKN	14.32 mg/L	mg/L	NO ₂ -N + NO ₃ -N	18.82 mg/L	mg/L
NO ₂ -N + NO ₃ -N	<0.05 mg/L	mg/L	TDS	286 mg/L	mg/L
			Chloride	54.8 mg/L	mg/L
			Bromide	< 0.4 mg/L	mg/L
			Sulfate	50.2 mg/L	mg/L
			Oil and Grease	< 5.0 mg/L	mg/L
			Total Copper	< 0.01 mg/L	mg/L
			Total Lead	< 0.008 mg/L	mg/L
			Total Zinc	0.053 mg/L	mg/L

Compliance History

DMR Data for Outfall 001 (from September 1, 2019 to August 31, 2020)

Parameter	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19
Flow (MGD) Average Monthly	0.050	0.057	0.063	0.116	0.144	0.104	0.086	0.088	0.072	0.056	0.050	0.053
Flow (MGD) Daily Maximum	0.072	0.084	0.092	0.271	0.36	0.324	0.115	0.216	0.133	0.152	0.183	111
pH (S.U.) Minimum	6.8	6.6	6.6	7.0	7.2	6.7	6.8	6.8	6.6	6.9	6.8	6.9
pH (S.U.) Maximum	7.5	7.4	7.6	7.6	7.6	7.5	7.6	7.5	7.5	7.6	7.5	7.6
DO (mg/L) Minimum	5.2	6.3	7.2	8.7	8.6	5.8	7.5	8.1	8.6	6.8	7.2	6.7
TRC (mg/L) Average Monthly	0.07	< 0.03	< 0.06	< 0.02	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03
TRC (mg/L) Instantaneous Maximum	0.52	0.13	0.61	0.16	0.24	0.10	0.13	0.08	0.10	0.19	0.13	0.10
CBOD5 (lbs/day) Average Monthly	< 2	3	5	8	5	< 5	4	< 3	< 2	< 3	< 2	3
CBOD5 (lbs/day) Daily Maximum	3	5	10	17	8	12	5	4	4	4	2	4
CBOD5 (mg/L) Average Monthly	< 5	5	10	9	4	< 6	6	< 4	< 4	< 6	< 4	6
CBOD5 (mg/L) Weekly Average	7	6	23	22	7	9	7	6	6	8	5	9
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	56	60	53	95	109	116	85	71	115	147	99	84
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	79	89	90	145	177	161	101	145	175	316	195	115
BOD5 (mg/L) Raw Sewage Influent Average Monthly	151.6	124	103.8	102	93.3	160	122	103.8	205.5	347.9	232	179
TSS (lbs/day) Average Monthly	2	2	5	4	5	4	2	3	3	3	2	2
TSS (lbs/day) Raw Sewage Influent Average Monthly	67	74	83	102	158	94	57	105	111	125	128	109
TSS (lbs/day) Raw Sewage Influent Daily Maximum	78	85	128	116	295	135	78	159	181	167	195	152
TSS (lbs/day) Weekly Average	3	3	13	6	10	5	3	5	3	4	3	4

**NPDES Permit Fact Sheet
Spring Creek STP**

NPDES Permit No. PA0082279

TSS (mg/L) Average Monthly	5	4	10	5	4	5	3	4	6	7	5	5
TSS (mg/L) Raw Sewage Influent Average Monthly	174	150	164	113	120	133	83	133	202	290	314	229
TSS (mg/L) Weekly Average	9	4	23	8	6	10	5	6	7	12	7	8
Fecal Coliform (CFU/100 ml) Average Monthly	< 10	67	10	< 3	< 2	< 3	< 1	< 1	19	< 2	< 3	< 3
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	1203.3	613	191.8	11.9	3	21.6	1	2	378.4	3.1	130.5	8.3
Nitrate-Nitrite (mg/L) Average Monthly	5.246	8.723	7.442	4.159	4.159	3.607	3.557	5.706	9.759	9.186	8.963	9.216
Nitrate-Nitrite (lbs) Total Monthly	65	145	111	119	166	87	73	126	168	118	111	133
Total Nitrogen (mg/L) Average Monthly	6.56	9.4025	9.4045	5.118	4.794	3.76	4.26	6.42	10.637	10.31	10.086	10.316
Total Nitrogen (lbs) Effluent Net Total Monthly	79	155	140	144	190	88	88	142	183	132	125	150
Total Nitrogen (lbs) Total Monthly	79	155	140	144	190	88	88	142	183	132	125	150
Total Nitrogen (lbs) Effluent Net Total Annual												2232
Total Nitrogen (lbs) Total Annual												2232
Ammonia (lbs/day) Average Monthly	< 0.02	< 0.02	< 0.02	< 0.07	< 0.06	< 0.04	< 0.03	< 0.04	< 0.03	< 0.02	< 0.05	< 0.05
Ammonia (mg/L) Average Monthly	< 0.05	< 0.05	< 0.05	< 0.1	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.1	< 0.1
Ammonia (lbs) Total Monthly	< 0.06	< 0.8	< 0.7	< 2.3	< 2	< 1	< 1	< 1	< 0.9	< 0.6	< 1	< 1.6
Ammonia (lbs) Total Annual												< 20.4
TKN (mg/L) Average Monthly	< 1.27	< 0.63	< 1.915	< 0.87	< 0.588	0.86	< 0.65	< 0.67	< 0.831	< 1.08	< 1	< 1
TKN (lbs) Total Monthly	< 15	< 10	< 29	< 23	< 22	21	< 13	< 15	< 15	< 14	< 12	< 15
Total Phosphorus (mg/L) Average Monthly	4.23	3.9	2.83	1.85	1.58	1.76	1.73	1.67	2.01	2.4	3.4	2.98

NPDES Permit Fact Sheet
Spring Creek STP

NPDES Permit No. PA0082279

Total Phosphorus (lbs) Effluent Net Total Monthly	50	63	42	51	62	38	35	36	36	31	40	41
Total Phosphorus (lbs) Total Monthly	50	63	42	51	62	38	35	36	36	31	40	41
Total Phosphorus (lbs) Effluent Net Total Annual												537
Total Phosphorus (lbs) Total Annual												537

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.132</u>
Latitude <u>40° 11' 34.81"</u>	Longitude <u>-77° 58' 24.91"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model indicates that a monthly average limit of 25 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing limits of 25 mg/L monthly average (AML), 40mg/l average weekly limit (AWL), and 50 mg/L instantaneous maximum will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 25 \text{ mg/L} \times 0.17 \text{ MGD} \times 8.34 = 35.45 \text{ (35.0) lbs/day} \\ \text{Average weekly mass limit: } & 40 \text{ mg/L} \times 0.17 \text{ MGD} \times 8.34 = 56.71 \text{ (57.0) lbs/day} \end{aligned}$$

Ammonia (NH₃-N):

NH₃-N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	20°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	25°C	(Default)
*	Background NH ₃ -N	=	0 mg/L	(Default)

The model input data and results are attached. The printout of the WQM 7.0 output indicates that at a discharge of 0.17 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 5.94 mg/L NH₃-N as a monthly average and 11.88 mg/L NH₃-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects. The more stringent summer in existing limits of 4.5 mg/L monthly average & 9.0 mg/L IMAX will remain in the proposed permit due to anti-backsliding requirements. The winter effluent limit will be set at three-times the summer limits. Recent DMRs and inspection reports indicate that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Summer average monthly mass limit: } & 4.5 \text{ mg/L} \times 0.17 \text{ MGD} \times 8.34 = 6.38 \text{ (6.4) lbs/day} \\ \text{Winter average monthly mass limit: } & 6.4 \text{ lbs/day} \times 3 = 19.14 \text{ (19.0) lbs/day} \end{aligned}$$

Total Suspended Solids (TSS):

The existing technology-based limits of 30 mg/L average monthly, 45 mg/L average weekly, and 60 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 30 \text{ mg/L} \times 0.17 \text{ MGD} \times 8.34 = 42.53 \text{ (42.0) lbs/day} \\ \text{Average weekly mass limit: } & 45 \text{ mg/L} \times 0.17 \text{ MGD} \times 8.34 = 63.80 \text{ (64.0) lbs/day} \end{aligned}$$

Dissolved Oxygen (DO):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

pH:

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa. Code § 95.2(1).

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

Total Residual Chlorine (TRC):

The attached computer printout utilizes the equations and calculations as presented in the Department's 2003 Implementation Guidance for Residual Chlorine (TRC) (ID # 391-2000-015) for developing chlorine limitations. The attached printout indicates that an average monthly water quality limit of 0.25 mg/L and IMAX of 0.81 mg/L would be needed to prevent toxicity concerns. The existing permit had an average monthly water limit of 0.25 mg/L and IMAX of 0.82 mg/L. This is consistent with the existing permit. Recent DMR data indicates that the facility has been consistently achieving concentrations below these more stringent limits.

Chesapeake Bay Strategy:

In the Phase 2 WIP Wastewater Supplement revised on December 17, 2019, Attachment C Non-Significant Discharges with Cap Loads in NPDES Permits of this document shows that Spring Creek STP has been allocated 7,306 lbs/year of TN and 974 lbs/year of TP. This approach is consistent with the Chesapeake Bay TMDL and was based on the actual performance data previously evaluated by the Department. Since the permittee is easily capable of achieving compliance with these loads, the Department determines that no "compliance schedule" for the requirements associated with the Chesapeake Bay Strategy is necessary. Accordingly, the Chesapeake Bay nutrient existing limitations and monitoring requirements will remain in the proposed permit.

Influent BOD₅ and TSS Monitoring:

The permit will include influent BOD₅ and TSS monitoring at the same frequency as is done for effluent in order to implement 25 Pa. Code § 94.12 and assess percent removal requirements, per DEP policy.

Stormwater:

There is no stormwater outfall associated with this facility.

Biosolids Management:

Dried biosolids periodically removed from the sludge drying beds and then disposed of by a certified hauler.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303d Listed Streams:

The discharge is not located on a 303d listed stream segment. The stream segment that receive the discharge is listed as attaining its uses for aquatic life and fish consumption.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

WQM 7.0 Data

D.O. Goal: 5.0 mg/L

Node 1: Outfall 001 on Three Springs Creek (12866)
 Elevation: 696.99 ft (USGS National Map Viewer)
 Drainage Area: 23.6 mi.² (USGS PA StreamStats)
 River Mile Index: 3.35 (PA DEP eMapPA)
 Q₇₋₁₀ Low Flow Yield: 0.020 cfs/mi.²
 Discharge Flow: 0.17 MGD (NPDES permit)

Node 2: Just before confluence with Trib. 12874 to Three Springs Creek
 Elevation: 687.07 ft (USGS National Map Viewer)
 Drainage Area: 23.7 mi.² (USGS PA StreamStats)
 River Mile Index: 3.00 (PA DEP eMapPA)
 Q₇₋₁₀ Low Flow Yield: 0.020 cfs/mi.²
 Discharge Flow: 0.000 MGD

The screenshot displays the USGS StreamStats web application. On the left, a sidebar contains navigation options like 'Show Basin Characteristics' and 'Select available reports to display:'. The main content area is divided into several sections:

- Basin Characteristics:** A table showing parameters like ROCKDEP (Depth to rock) and CARBON (Percentage of area of carbonate rock).
- Low-Flow Statistics Parameters:** A table listing parameters such as DRNAREA (Drainage Area), PRECIP (Mean Annual Precipitation), STRDEN (Stream Density), ROCKDEP (Depth to Rock), and CARBON (Percent Carbonate).
- Low-Flow Statistics Flow Report:** A table showing flow statistics for different return periods (7 Day 2 Year, 30 Day 2 Year, 7 Day 10 Year, 30 Day 10 Year, 90 Day 10 Year) with columns for Value, Unit, SE, and SEp.
- Map:** A satellite map on the right showing the geographic location of the site, with a 'Layers' panel overlaid.

NPDES Permit Fact Sheet
Spring Creek STP

NPDES Permit No. PA0082279

Waiting for streamstats.usg... x

File Edit View Favorites Tools Help

Check Point Mobile - Sign... Free Hotmail intraDEP PSIMSIInternal - Logon Suggested Sites Web Slice Gallery

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

▼ Show Basin Characteristics

Select available reports to display:

Basin Characteristics Report

Scenario Flow Reports

[Continue](#)

POWERED BY **WIM**

[USGS Home](#) [Contact USGS](#) [Search USGS](#)
[Accessibility](#) [FOIA](#) [Privacy](#) [Policy & Notices](#)

	area	mile
ROCKDEP	Depth to rock	3.6 feet
CARBON	Percentage of area of carbonate rock	5.14 percent

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	23.7	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	37	inches	35	50.4
STRDEN	Stream Density	1.89	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	3.6	feet	3.32	5.65
CARBON	Percent Carbonate	5.14	percent	0	99

Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	1.2	ft ³ /s	38	38
30 Day 2 Year Low Flow	1.8	ft ³ /s	33	33
7 Day 10 Year Low Flow	0.434	ft ³ /s	51	51
30 Day 10 Year Low Flow	0.683	ft ³ /s	46	46
90 Day 10 Year Low Flow	1.28	ft ³ /s	36	36

PLI: Prediction Interval-Lower, Plu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.43	= Q stream (cfs)		0.5	= CV Daily	
0.17	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.541		1.3.2.iii	WLA_cfc = 0.519
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.201		5.1d	LTA_cfc = 0.302
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.248		AFC	
		INST_MAX_LIMIT (mg/l) = 0.811			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST_MAX_LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation **Effluent Limitations**

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
3.35	Spring Creek	PA0082279	0.1700

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	5.94	11.88	
Dissolved Oxygen			5

Record: 1 of 1 No Filter Search

Analysis Results WQM 7.0

Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | Effluent Limitations

<u>RMI</u> 3.350	<u>Total Discharge Flow (mgd)</u> 0.170	<u>Analysis Temperature (°C)</u> 21.789	<u>Analysis pH</u> 7.000
<u>Reach Width (ft)</u> 16.116	<u>Reach Depth (ft)</u> 0.514	<u>Reach WD Ratio</u> 31.355	<u>Reach Velocity (fps)</u> 0.089
<u>Reach C-BOD5 (mg/L)</u> 10.23	<u>Reach Kc (1/days)</u> 1.276	<u>Reach NH3-N (mg/L)</u> 2.12	<u>Reach Kn (1/days)</u> 0.803
<u>Reach DO (mg/L)</u> 7.083	<u>Reach Kr (1/days)</u> 15.304	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 5

Reach Travel Time (days)
0.241

Subreach Results

TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
0.024	9.89	2.08	7.06
0.048	9.57	2.04	7.05
0.072	9.25	2.00	7.07
0.096	8.95	1.97	7.09
0.121	8.66	1.93	7.13
0.145	8.37	1.89	7.16
0.169	8.10	1.86	7.21
0.193	7.83	1.82	7.25
0.217	7.57	1.78	7.29
0.241	7.33	1.75	7.33

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

rptEffLimits

WQM 7.0 Effluent Limits

WQM 7.0

WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0
WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0
WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0

Monday, October 26, 2020 Version 1.0b Page 1 of 1

Page: 1 No Filter

rpt_WLA

WQM 7.0 Wasteload Allocations

WQM 7.0

WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0
WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0

Monday, October 26, 2020 Version 1.0b Page 1 of 1

Page: 1 No Filter

rptDOSim

WQM 7.0 D.O. Simulation

WQM 7.0

WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0
WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0

Monday, October 26, 2020 Version 1.0b Page 1 of 1

Page: 1 No Filter

rptModelSpecs

WQM 7.0 Modeling Specifications

WQM 7.0

WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0
WQM 7.0	WQM 7.0	WQM 7.0	WQM 7.0

Monday, October 26, 2020 Version 1.0b Page 1 of 1

Page: 1 No Filter

rptHydro

WQM 7.0 Hydrodynamic Outputs

WQM 7.0	Station	Flow	Velocity	Depth	Width	Area	Wetted Perim	Hydraulic Radius	Velocity	Flow	Area	Wetted Perim	Hydraulic Radius
Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50
3.33	0.47	0.00	0.47	263.0	0.00007	314	16.0	31.58	0.08	0.241	21.78	7.00	
3.33	0.47	0.00	0.50	263.0	0.00007	NA	NA	NA	0.08	0.276	20.33	7.00	
3.33	0.44	0.00	0.46	263.0	0.00007	NA	NA	NA	0.10	0.218	21.40	7.00	

Monday, October 26, 2020 Version 1.0a Page 1 of 1

Page: 1 | No Filter

rptGeneral

Input Data WQM 7.0

WQM 7.0	Station	Flow	Velocity	Depth	Width	Area	Wetted Perim	Hydraulic Radius	Velocity	Flow	Area	Wetted Perim	Hydraulic Radius
Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50
3.33	0.47	0.00	0.47	263.0	0.00007	314	16.0	31.58	0.08	0.241	21.78	7.00	
3.33	0.47	0.00	0.50	263.0	0.00007	NA	NA	NA	0.08	0.276	20.33	7.00	
3.33	0.44	0.00	0.46	263.0	0.00007	NA	NA	NA	0.10	0.218	21.40	7.00	

Challenge Data

Name	Permit Number	Flow	Velocity	Depth	Width	Area	Wetted Perim	Hydraulic Radius	Velocity	Flow	Area	Wetted Perim	Hydraulic Radius
		Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50
Spring Creek	PA0082279	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

Parameter Data

Parameter Name	Flow	S.S.	Biochemical	Ammonia
	Q10	Q50	Q10	Q50
CH2O5	3.00	3.00	0.00	1.00
Dissolved Oxygen	0.00	8.24	0.00	0.00
NH3-N	3.00	0.00	0.00	0.70

Monday, October 26, 2020 Version 1.0a Page 1 of 2

Page: 1 | No Filter

rptGeneral

Input Data WQM 7.0

WQM 7.0	Station	Flow	Velocity	Depth	Width	Area	Wetted Perim	Hydraulic Radius	Velocity	Flow	Area	Wetted Perim	Hydraulic Radius
Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50
3.33	0.47	0.00	0.47	263.0	0.00007	314	16.0	31.58	0.08	0.241	21.78	7.00	
3.33	0.47	0.00	0.50	263.0	0.00007	NA	NA	NA	0.08	0.276	20.33	7.00	
3.33	0.44	0.00	0.46	263.0	0.00007	NA	NA	NA	0.10	0.218	21.40	7.00	

Challenge Data

Name	Permit Number	Flow	Velocity	Depth	Width	Area	Wetted Perim	Hydraulic Radius	Velocity	Flow	Area	Wetted Perim	Hydraulic Radius
		Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50	Q10	Q50
Spring Creek	PA0082279	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

Parameter Data

Parameter Name	Flow	S.S.	Biochemical	Ammonia
	Q10	Q50	Q10	Q50
CH2O5	3.00	3.00	0.00	1.00
Dissolved Oxygen	0.00	8.24	0.00	0.00
NH3-N	3.00	0.00	0.00	0.70

Monday, October 26, 2020 Version 1.0a Page 2 of 2

Page: 2 | No Filter

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Average Weekly	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
Influent (BOD ₅ and TSS)	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.25	XXX	0.82	1/day	Grab
CBOD ₅	35	57	XXX	25	40	50	1/week	8-Hr Composite
Total Suspended Solids	42	64	XXX	30	45	60	1/week	8-Hr Composite
NH ₃ -N (5/1 to 10/31)	6.4	XXX	XXX	4.5	XXX	9.0	1/week	8-Hr Composite
NH ₃ -N (11/1 to 4/30)	19	XXX	XXX	13.5	XXX	27	1/week	8-Hr Composite
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Annual	Minimum	Average Monthly	Average Weekly	Instant. Maximum		
Ammonia---N	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Kjeldahl---N	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculate
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Net Total Nitrogen	Report	7,306	XXX	XXX	XXX	XXX	1/month	Calculate
Net Total Phosphorus	Report	974	XXX	XXX	XXX	XXX	1/month	Calculate

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.25	XXX	0.82	1/day	Grab
CBOD5	35.0	57.0 Wkly Avg	XXX	25.0	40.0	50	1/week	8-Hr Composite
TSS	42.0	64.0 Wkly Avg	XXX	30.0	45.0	60.0	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Ammonia May 1 - Sep 30	6.4	XXX	XXX	4.5	XXX	9.0	1/week	8-Hr Composite
Ammonia Oct 1 - Apr 30	19.0	XXX	XXX	13.5	XXX	27.0	1/week	8-Hr Composite

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia---N	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Kjeldahl---N	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Net Total Nitrogen	Report	7,306	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	974	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input checked="" type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]