



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0083186

APS ID

1070617

Authorization ID

1529772

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	<u>Applegreen PA Welcome Center LLC</u>	Facility Name	<u>Sideling Hill Turnpike Plaza</u>
Applicant Address	<u>208 Harristown Road</u>	Facility Address	<u>3748 N Hess Road Mile Marker 172 3 PA Turnpike</u>
	<u>Glen Rock, NJ 07452</u>		<u>Waterfall, PA 16689-6908</u>
Applicant Contact	<u>James Carey</u>	Facility Contact	<u>Sasha McComsey</u>
Applicant Phone	<u>(443) 206-6899</u>	Facility Phone	<u>(717) 569-7021</u>
Client ID	<u>370385</u>	Site ID	<u>2485</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Taylor Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Fulton</u>
Date Application Received	<u>June 5, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 11, 2025</u>	If No, Reason	
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

Applegreen PA Welcome Centers, LLC – Sideling Hill Turnpike Plaza has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The permit was issued on October 22, 2020, and became effective on November 1, 2020. The permit authorized discharge of treated sewage from the existing wastewater treatment plant (WWTP) located in Taylor Township, Fulton County to Lick Branch. The existing permit expiration date is October 31, 2025.

The NPDES PA0083186 A-1 & WQM No. 2922401 T-1 ownership transfer were issued on 9/27/2022. The discharge design flow and hydraulic design capacity is 0.04 MGD. Sideling Hill Service Plaza contributes 100% of the wastewater to the treatment plant.

The WQM Nos. 5675030 A-1 & 5675030 A-2 dated 8/25/2003 & 1/25/2005.

Sludge use and disposal description and location(s): N/A because sludge hauling by facility's contractor.

Changes from the previous permit: The E. Coli monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	September 12, 2025
x		<i>Maria D. Bebenek</i> for Daniel W. Martin, P.E. / Environmental Engineer Manager	September 18, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.04
Latitude	40° 3' 41.37"	Longitude	-78° 4' 55.81"
Quad Name	Hustontown	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Lick Branch (HQ-CWF)	Stream Code	12986
NHD Com ID	66213883	RMI	3.05
Drainage Area	0.84 mi. ²	Yield (cfs/mi ²)	0.04
Q ₇₋₁₀ Flow (cfs)	0.03	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	1100	Slope (ft/ft)	
Watershed No.	12-C	Chapter 93 Class.	HQ-CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Southern Huntingdon County School District		
PWS Waters	Aughwick Creek	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	Approximate 33.0 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Lick Branch at RMI 3.05 miles. A drainage area upstream of the discharge is estimated to be 0.84 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to USGS StreamStats, the point of first use at the confluence with Lick Branch (12986) has a Q₇₋₁₀ of 0.03 cfs and a drainage area of 0.84 mi.², which results in a Q₇₋₁₀ low flow yield of 0.036 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 0.03 \text{ cfs} \\
 \text{Low Flow Yield} &= 0.03 \text{ cfs} / 0.84 \text{ mi.}^2 = 0.036 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 0.03 \text{ cfs} = 0.04 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.03 \text{ cfs} = 0.02 \text{ cfs}
 \end{aligned}$$

Lick Branch to Wooden Bridge Creek, Aughwick Creek to Juniata River

Under 25 Pa Code § 93.9n, the Lick Branch to Wooden Bridge Creek to Aughwick Creek is designated as Class A Wild Trout and HQ-CWF during the permit cycle. Since the discharge predates the designation and the stream is attaining its uses, no further action is warranted at this time. Integrate Report 2024, Lick Branch (Assessment Unit ID 20516) is not impaired.

Potable Water Supply Intake

The nearest downstream public water supply intake is the Southern Huntingdon County School District, Huntingdon County intake on the Aughwick Creek, approximately 33.0 miles from the point of discharge. Given the nature and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary												
Treatment Facility Name: Applegree PA Welcome Center LLC - Sideling Hill Turnpike Plaza												
<table border="1"> <thead> <tr> <th>WQM Permit No.</th><th>Issuance Date</th></tr> </thead> <tbody> <tr> <td>5675030 A-1</td><td>8/25/2003</td></tr> <tr> <td>5675030 A-2</td><td>1/25/2005</td></tr> <tr> <td>2922401 T-1</td><td>9/27/2022</td></tr> </tbody> </table>		WQM Permit No.	Issuance Date	5675030 A-1	8/25/2003	5675030 A-2	1/25/2005	2922401 T-1	9/27/2022			
WQM Permit No.	Issuance Date											
5675030 A-1	8/25/2003											
5675030 A-2	1/25/2005											
2922401 T-1	9/27/2022											
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)								
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Chlorine With Dechlorination	0.04								
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal								
0.04		Not Overloaded	Aerobic Digestion	Other WWTP								

Changes Since Last Permit Issuance: none

Other Comments:

The process consists of a comminutor, three (3) EQ tanks, an oxidation ditch, two (2) secondary clarifiers, two (2) media filters, a chlorine contact tank, a dechlorination system, and a post aeration unit prior to discharge through the outfall (Outfall 001).

The subject facility utilizes the following chemicals as part of their treatment process.

- Sodium hypochlorite for disinfection
- Sodium bisulfite for dechlorination
- Alum for settling/phosphorus removal
- Soda ash for pH control

Biosolids:

The total sewage sludge/biosolids production within the facility for the previous year was 6.4 dry tons.

Compliance History	
Summary of DMRs:	DMRs reported last 12 months are summarized in next page.
Summary of Inspections:	<p>4/18/2025: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. There were no violations noted during inspection. The field sample test results were within the permit limits. Recommendations were to repair the broken valve for soda as feed system and install a second back-up valve, and test sludge for % solids when hauled from the treatment plant.</p> <p>3/28/2024: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. There were no violations noted during inspection. The field sample test results were within the permit limits. Recommendations were to record both grab and analysis times for daily effluent test, repair chlorine holding tank mixer, and lower temperature of effluent sampler fridge.</p>
Other Comments:	There are no open violations associated with the permittee or the facility.

Other Comments: 

Compliance History

DMR Data for Outfall 001 (from August 1, 2024 to July 31, 2025)

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Flow (MGD) Average Monthly	0.0187	0.0197	0.0185	0.0161	0.017	0.0167	0.016	0.0196	0.0193	0.0203	0.021	0.023
Flow (MGD) Daily Maximum	0.0332	0.0278	0.0282	0.0241	0.0323	0.0373	0.0262	0.0318	0.036	0.0391	0.0344	0.0419
pH (S.U.) Instantaneous Minimum	6.42	6.83	6.47	6.42	6.24	6.25	6.74	6.79	7.0	6.9	7.14	6.63
pH (S.U.) IMAX	8.23	8.22	7.66	8.02	8.09	8.06	8.34	8.12	8.06	7.87	7.93	7.84
DO (mg/L) Instantaneous Minimum	7.07	7.32	8.25	8.92	9.83	9.55	9.02	8.72	8.31	7.55	7.38	6.78
TRC (mg/L) Average Monthly	0.04	0.04	0.05	0.02	0.04	0.06	< 0.07	0.06	0.08	0.08	0.06	0.08
TRC (mg/L) Instantaneous Maximum	0.47	0.39	0.20	0.10	0.14	0.21	0.18	0.28	0.34	0.29	0.25	0.32
CBOD5 (mg/L) Average Monthly	2.3	< 2.2	< 2.0	< 2.0	2.6	3.0	< 2.0	< 3.5	4.0	< 6.8	< 3.0	< 3.0
TSS (mg/L) Average Monthly	< 4.0	< 4.1	< 4.8	< 6.3	< 4.0	< 4.0	< 4.0	5.2	< 4.0	< 4.0	3.8	7.3
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 1	< 8	< 3	2	< 1	< 5	< 5
Fecal Coliform (No./100 ml) Instantaneous Maximum	2	1	2	< 1	< 1	< 1	60	7	5	1	< 5	< 5
Nitrate-Nitrite (mg/L) Semi-Annual Average		38.5						58.5				
Total Nitrogen (mg/L) Semi-Annual Average		0.90						59.2				
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
TKN (mg/L) Semi-Annual Average		39.4						< 0.5				
Total Phosphorus (mg/L) Semi-Annual Average		2.44						6.75				

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly		Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.15	XXX	0.49	1/day	Grab
CBOD ₅	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	8-Hr Composite
Total Kjeldahl Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	2/year	8-Hr Composite
Nitrate-Nitrite as N	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	2/year	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	2/year	Calculation
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	2/year	8-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.15	XXX	0.49	1/day	Grab
CBOD ₅	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	8-Hr Composite
TKN	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	8-Hr Composite
Nitrate-Nitrite	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	Calculation
Total Phosphorus	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	8-Hr Composite

Compliance Sampling Location:

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	0.04	
Latitude	40° 3' 41.37"	Longitude	-78° 4' 55.81"	
Wastewater Description:	Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The existing effluent CBOD₅ and TSS limits of 10 mg/L as a monthly average will remain in place as per the intermittent and ephemeral stream guidance (ID # 391-2000-014).

The following technology-based limitations apply, subject to water quality analysis and best professional judgement (BPJ) where applicable:

Consistent with the Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers (91-2000-014), the following parameters are subject to the effluent limitations.

- CBOD₅ - 10 mg/L as a monthly average
- TSS - 10 mg/L as a monthly average
- Total N - 5 mg/L as a monthly average

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃-N calculations were first based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

Discharge pH	=	7.0	(Default)
Discharge Temperature	=	20°C	(Default)
Stream pH	=	7.0	(Default)
Stream Temperature	=	20°C	(Default)
Background NH ₃ -N	=	0	(Default)

The printout of the WQM 7.0 output indicates that at a discharge of 0.04 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 3.14 mg/L NH₃-N as average monthly (AML) and 6.28 mg/L NH₃-N instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects. However, the more stringent existing limits of 3.0 mg/L AML and 6.0 mg/L IMAX will remain in the proposed permit due to anti-backsliding requirements. Additionally, past DMRs and inspection reports show that the facility has been consistently achieving concentrations under these limits.

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI	Discharge Name	Permit Number	Disc. Flow (mgd)
3.05	Sideling Hill	PA0083186	0.0400
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	3.14	6.28	
Dissolved Oxygen			5

Record: 1 of 1 | No Filter | Search | Print | < Back | Next > | Archive | Cancel |

Also, the NH₃-N winter effluent limit will be 9.0 mg/L for average monthly and 18.0 mg/L for IMAX based on a typical multiplier of 3.0 used by DEP to calculate.

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

pH:

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa Code § 95.2(1).

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Biosolids Management:

Approximately 2,000 GPD of activated sludge is wasted from the biological treatment process on a near daily basis to a sludge holding for thickening and then to two sludge drying beds for further dewatering. Following dewatering in the sludge drying beds, the biosolids are disposed of at Walters Septic Ag. Site in East Hanover Township, PA (DEP Permit No. PAG-07-3504) or at the Manheim Borough WWTP in Manheim, PA (DEP Permit No. 020893).

Toxics:

No toxic parameters of concern associated with this discharge. The discharge consists entirely of domestic sewage, no industrial users discharge to the facility.

Total Residual Chlorine (TRC):

The attached computer printout utilizes the equations and calculations as presented in the Department's 2003 Implementation Guidance for Total Residual Chlorine, dated 11/15/94 (ID No. 391-2000-015) for developing chlorine limitations. The attached printout indicates that an average monthly water quality limit of 0.5 mg/L and 1.6 mg/L max daily would be needed to prevent toxicity concerns. This is consistent with the existing permit. The treatment facility is meeting this limit.

TRC EVALUATION									
Input appropriate values in A3:A9 and D3:D9									
0.03	= Q stream (cfs)	0.5	= CV Daily						
0.04	= Q discharge (MGD)	0.5	= CV Hourly						
30	= no. samples	1	= AFC_Partial Mix Factor						
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor						
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)						
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)						
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)						
Source	Reference	AFC Calculations	Reference	CFC Calculations					
TRC	1.3.2.iii	WLA_afc = 0.174	1.3.2.iii	WLA_cfc = 0.162					
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581					
PENTOXSD TRG	5.1b	LTA_afc= 0.065	5.1d	LTA_cfc = 0.094					
Source	Effluent Limit Calculations								
PENTOXSD TRG	5.1f	AML MULT = 1.231							
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.080							
		INST MAX LIMIT (mg/l) = 0.260							
AFC									
WLA_afc	$(.019/e(-k* AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k* AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$								
LTA_afc	wla_afc*LTAMULT_afc								
WLA_cfc	$(.011/e(-k* CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k* CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$								
LTA_cfc	wla_cfc*LTAMULT_cfc								
AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$								
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)								
INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$								

Chesapeake Bay Strategy:

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase 4 (0.2 -0.4mgd) will be required to monitor and report TN and TP during permit renewal monthly and Phase 5 (below 0.2mdg) will monitor during current permit renewal once a year unless two years of monitoring completed and documented. Any facility in Phases 4 and 5 that undergoes expansion is subjected to cap load right away. This plant is classified as a phase 5, will be required to monitor and report Total Phosphorus, Nitrate-Nitrite as N, Total Kjeldahl Nitrogen and Total Nitrogen once a year.

Stormwater:

There is no known stormwater outfall associated with this facility.

Anti-Degradation (93.4)

The effluent limits for this discharge have been developed to ensure that the existing instream water used and the level of water quality necessary to protect the existing uses are maintained and protected. The basin is classified as a HQ-CWF. The discharge pre-dates the Chapter 93 designation of HQ-CWF for Lick Branch, and is not expected to impact the stream.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

303d Listed Streams:

The discharge is not located on a 303d listed stream segment.

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	20°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	20°C	(Default for CWF)
*	Background NH ₃ -N	=	0 mg/L	(Default)

Node 1: Outfall 001 on Lick Branch (12986)

Elevation: 1100.0 ft (USGS National Map Viewer)
 Drainage Area: 0.84 mi.² (USGS PA StreamStats)
 River Mile Index: 3.05 (PA DEP eMapPA)
 Low Flow Yield: 0.036 cfs/mi.²
 Discharge Flow: 0.04 MGD (NPDES Application)

Node 2: Just before confluence Lick Branch to Wooden Creek

Elevation: 1000.0 ft (USGS National Map Viewer)
 Drainage Area: 3.29 mi.² (USGS PA StreamStats)
 River Mile Index: 0.5 (PA DEP eMapPA)
 Low Flow Yield: 0.036 cfs/mi.²
 Discharge Flow: 0.000 MGD

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation **Effluent Limitations**

		Permit Number Disc Flow (mgd)		
RMI	Discharge Name	PA0083186	0.0400	
3.05	Sideling Hill			
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)	
CBOD5	25			
NH3-N	3.14	6.28		
Dissolved Oxygen			5	

Record: 1 of 1 < Back Next > No Filter Search

Print < Back Next > Archive Cancel

NPDES Permit Fact Sheet Sideling Hill Turnpike Plaza

NPDES Permit No. PA0083186

rptEffLimits

WQM 7.0 Effluent Limits						
SWP Basin	Stream Code	Stream Name				
12C	12986	LUCK BRANCH				
RM#	Name	Permit Number	Disc. Flow (mgd)	Parameter	EFL Limit 30-day Avg. (mg/L)	EFL Limit Max. lim. (mg/L)
3.050	Slideling HBI	PA0003166	0.010	CBOD5	25	
				NH3N	3.14	0.28
				Dissolved Oxygen		5

Wednesday, September 10, 2014

Version 1.1

Page 1 of 1

WQM 7.0 Wasteload Allocations							
SWP Basin		Stream Code		Stream Name			
12C		13946		LICK BRANCH			
NHS-N Amots Allocations							
RM#	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3,050	Stinking Hill	16.76	22	16.76	22	0	0
NHS-N Chronic Allocations							
RM#	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3,050	Stinking Hill	1.00	3.14	1.00	3.14	0	0
Dissolved Oxygen Allocations							
RM#		CH ₃ CO ₃		NH ₄ NO ₃		Dissolved Oxygen	
Discharge Name		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
3,050	Stinking Hill	25	25	3.14	3.14	5	5

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name	
12C	13966	LICK BRANCH	
<u>Basin</u> 3,050	<u>Total Discharge Flow (m³/s)</u> 0.0048	<u>Analysis Temperature (°C)</u> 20.000	<u>Analysis pH</u> 7.000
<u>Reach Width (m)</u> 4.49	<u>Reach Depth (m)</u> 0.30	<u>Reach Volume (m³)</u>	<u>Reach Velocity (m/s)</u>
<u>Reach CDO50 (mg/L)</u> 17.05	<u>Reach Kt (1/day)</u> 0.005	<u>Reach NH3-N (mg/L)</u> 2.11	<u>Reach K6 (1/day)</u> 0.760
<u>Reach DO (mg/L)</u> 6.000	<u>Reach Kr (1/day)</u> 23.000	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 5
<u>Reach Travel Time (days)</u> 2.020	<u>Sub-reach Results</u>		
Travel Time	CDO50 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
0.263	14.05	1.76	8.13
0.525	11.21	1.46	8.24
0.788	9.11	1.22	8.24
1.050	7.29	1.01	8.24
1.313	5.66	0.84	8.24
1.576	4.30	0.70	8.24
1.838	3.10	0.58	8.24
2.101	2.06	0.49	8.24
2.363	1.46	0.40	8.24
2.626	2.00	0.34	8.24

Wednesday, September 10, 2025 Version 1.1 Page 1 of 1

WQM 7.0 Modeling Specifications			
Parameter:	Both	Use Inputted Q1-10 and Q30-10 Flow:	<input checked="" type="checkbox"/>
WIA Method:	DM PR	Use Inputted WID Ratio:	<input type="checkbox"/>
Q1-10/Q7-10 Ratio:	0.64	Use Inputted Reach Travel Times:	<input type="checkbox"/>
Q30-10/Q7-10 Ratio:	1.36	Temperature Adjust K:	<input type="checkbox"/>
D. O. Saturation:	90.00%	Use Balanced Technology:	<input checked="" type="checkbox"/>
D. O. Goal:	5		

NPDES Permit Fact Sheet
Sideling Hill Turnpike Plaza

NPDES Permit No. PA0083186

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
12C	12986	LICK BRANCH										
RIM	Stream Flow	PWS With Stream Flow	Net Flow	Dis. Rate	Reach Slope	Depth	Width	WD Ratio	Velocity	Reach Time	Analytic Temp	Analytic pH
(cfs)	(cfs)	(cfs)	(%)	(ft)	(ft)	(ft)	(ft)	(fps)	(days)	(°C)		
3.050	0.03	0.00	0.03	.0019	0.00743	346	4.9	12.97	0.06	2.626	20.00	7.00
Q1-T10 Flow												
3.050	0.03	0.00	0.03	.0019	0.00743	NA	NA	NA	0.06	2.818	20.00	7.00
Q1-10 Flow												
3.050	0.04	0.00	0.04	.0019	0.00743	NA	NA	NA	0.06	2.467	20.00	7.00
Q30-10 Flow												

Wednesday, September 10, 2005 Version 1.1 Page 1 of 1

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name									
12C	12986	LICK BRANCH									
RIM	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC						
(ft)	(sq mi)	(ft/mi)	(mgft)	(mgft)							
3.050	1000.00	3.29	0.000000	0.00	<input checked="" type="checkbox"/>						

Stream Data

Design Cond.	LFY	Trib. Flow	Stream Flow	Rich Tr. Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Temp	Turbidity	Stream pH	Stream Temp
(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)	(ft)	(ft)	(ft)	(°C)	(°C)	(°C)	
Q1-T10	0.036	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	0.00	
Q1-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	0.00	
Q30-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	0.00	

Discharge Data

Name	Permit Number	Existing Design Flow (mgd)	Permitted Design Flow (mgd)	Design Flow (mgd)	Release Factor	Disc Temp (°C)	Disc pH
Sideling Hill	PA-0083186	0.0000	0.0000	0.0000	20.00	7.00	

Parameter Data

Parameter Name	Disc Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Rate Coef. (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NaOH	25.00	0.00	0.00	0.70

Wednesday, September 10, 2005 Version 1.1 Page 1 of 2

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name									
12C	12986	LICK BRANCH									
RIM	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC						
(ft)	(sq mi)	(ft/mi)	(mgft)	(mgft)							
3.050	1000.00	3.29	0.000000	0.00	<input checked="" type="checkbox"/>						

Stream Data

Design Cond.	LFY	Trib. Flow	Stream Flow	Rich Tr. Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Temp	Turbidity	Stream pH	Stream Temp
(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)	(ft)	(ft)	(ft)	(°C)	(°C)	(°C)	
Q1-T10	0.036	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	0.00	
Q1-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	0.00	
Q30-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	0.00	

Discharge Data



Name	Permit Number	Existing Design Flow (mgd)	Permitted Design Flow (mgd)	Design Flow (mgd)	Release Factor	Disc Temp (°C)	Disc pH
Sideling Hill	PA-0083186	0.0000	0.0000	0.0000	20.00	7.00	


Parameter Data

Parameter Name	Disc Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Rate Coef. (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NaOH	25.00	0.00	0.00	0.70

Wednesday, September 10, 2005 Version 1.1 Page 2 of 2

12





Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]