

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0083569  
 APS ID 277725  
 Authorization ID 1445310

**Applicant and Facility Information**

|                           |   |                  |   |
|---------------------------|---|------------------|---|
| Applicant Name            | <u>Riverview Homeowners Association</u>                             | Facility Name    | <u>Riverview Estates Development</u>              |
| Applicant Address         | <u>656 Excavating Drive</u><br><u>Roaring Spring, PA 16673-8538</u> | Facility Address | <u>Riverview Road</u><br><u>Everett, PA 15537</u> |
| Applicant Contact         | <u>Phillip Keith</u>  | Facility Contact | <u>Andrew Meloy</u>                               |
| Applicant Phone           | <u>(814) 329-0118</u>   | Facility Phone   | <u>(814) 329-8811</u>                             |
| Client ID                 | <u>36829</u>  | Site ID          | <u>447409</u>                                     |
| Ch 94 Load Status         | <u>Not Overloaded</u>   | Municipality     | <u>West Providence Township</u>                   |
| Connection Status         |   | County           | <u>Bedford</u>                                    |
| Date Application Received | <u>June 24, 2023</u>  | EPA Waived?      | <u>Yes</u>  |
| Date Application Accepted | <u>July 19, 2023</u>  | If No, Reason    |   |
| Purpose of Application    | <u>This is an application for NPDES renewal.</u>                    |                  |   |

| Approve | Deny | Signatures   | Date             |
|---------|------|--|------------------|
| X       |      | Nicholas Hong, P.E. / Environmental Engineer<br>Nick Hong (via electronic signature) | October 2, 2023  |
| x       |      | Daniel W. Martin, P.E. / Environmental Engineer Manager<br>Maria D. Bebenek          | October 11, 2023 |
| x       |      | Maria D. Bebenek, P.E. / Environmental Program Manager<br>Maria D. Bebenek           | October 11, 2023 |

### Summary of Review

The application submitted by the applicant requests a NPDES renewal permit for the Riverview Estates located at Riverview Road, Everett, PA 15537 in Bedford County, municipality of West Providence. The existing permit became effective on June 1, 2019 and expires(d) on May 31, 2024. The application for renewal was received by DEP Southcentral Regional Office (SCRO) on June 24, 2023.

The purpose of this Fact Sheet is to present the basis of information used for establishing the proposed NPDES permit effluent limitations. The Fact Sheet includes a description of the facility, a description of the facility's receiving waters, a description of the facility's receiving waters attainment/non-attainment assessment status, and a description of any changes to the proposed monitoring/sampling frequency. Section 6 provides the justification for the proposed NPDES effluent limits derived from technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), total maximum daily loading (TMDL), antidegradation, anti-backsliding, and/or whole effluent toxicity (WET). A brief summary of the outlined descriptions has been included in the Summary of Review section.

The subject facility is a 0.015 MGD treatment facility. The applicant does not anticipate any proposed upgrades to the treatment facility in the next five years. The NPDES application has been processed as a Minor Sewage Facility (Level 1) due to the type of sewage and the design flow rate for the facility. The applicant disclosed the Act 14 requirement to Bedford County and West Providence Township and the notice was received by the parties on June 22, 2023. A planning approval letter was not necessary as the facility is neither new or expanding.

Utilizing the DEP's web-based Emap-PA information system, the receiving waters has been determined to be Raystown Branch Juniata River. The sequence of receiving streams that the Raystown Branch Juniata River discharges into are Juniata River, and the Susquehanna River which eventually drains into the Chesapeake Bay. The subject site is subject to the Chesapeake Bay implementation requirements. The receiving water has protected water usage for trout stocking fish (TSF) and migratory fish (MF). No Class A Wild Trout fisheries are impacted by this discharge. The absence of high quality and/or exceptional value surface waters removes the need for an additional evaluation of anti-degradation requirements.

The Raystown Branch Juniata River is a Category 2 stream listed in the 2022 Integrated List of All Waters (formerly 303d Listed Streams). This stream is an attaining stream that supports aquatic life. The receiving waters is not subject to a total maximum daily load (TMDL) plan to improve water quality in the subject facility's watershed.

The existing permit and proposed permit differ as follows:

- Monitoring for pH, DO, and TRC shall be reduced to 5x/week
- Due to the EPA triennial review, monitoring for E. Coli shall be 1x/year.

Sludge use and disposal description and location(s): Biosolids / sewage sludge disposed at Orchard Lane Ex located in Blair County under permit number PA007005

The proposed permit will expire five (5) years from the effective date.

Based on the review in this report, it is recommended that the permit be drafted. DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Any additional information or public review of documents associated with the discharge or facility may be available at PA DEP Southcentral Regional Office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file review, contact the SCRO File Review Coordinator at 717.705.4700.

## **1.0 Applicant**

### **1.1 General Information**

This fact sheet summarizes PA Department of Environmental Protection's review for the NPDES renewal for the following subject facility.

Facility Name: Riverview Estates

NPDES Permit # PA0083569

Physical Address: Riverview Road  
Everett, PA 15537

Mailing Address: 656 Excavating Drive  
Roaring Spring, PA 16673

Contact: Keith Philip  
Owner  
[orchardlaneinc@embarqmail.com](mailto:orchardlaneinc@embarqmail.com)  
(814) 329-0118

Consultant: Andrew Meloy  
Operator  
ETS  
[etsllc17@gmail.com](mailto:etsllc17@gmail.com)  
(814) 329-8811

### **1.2 Permit History**

Permit submittal included the following information.

- NPDES Application
- Effluent Sample Data

## **2.0 Treatment Facility Summary**

### **2.1.1 Site location**

The physical address for the facility is Riverview Road, Everett, PA 15537. A topographical and an aerial photograph of the facility are depicted as Figure 1 and Figure 2.

Figure 1: Topographical map of the subject facility





Figure 2: Aerial Photograph of the subject facility



**2.2 Description of Wastewater Treatment Process**

The subject facility is a 0.015 MGD design flow facility. The subject facility treats wastewater using an aeration basin, a clarifier, a dosing tank, multiple sand bed filters, a chlorine contact tank, and post aeration prior to discharge through the outfall. The facility is being evaluated for flow, pH, dissolved oxygen (DO), TRC, CBOD, TSS, fecal coliform, total nitrogen and total phosphorus. The existing permits limits for the facility is summarized in Section 2.4.

The treatment process is summarized in the table.

| Treatment Facility Summary                                  |                            |                   |                     |                        |
|---|----------------------------|-------------------|---------------------|------------------------|
| Treatment Facility Name: Riverview Estates Homeowners Assoc |                            |                   |                     |                        |
| Waste Type  | Degree of Treatment        | Process Type      | Disinfection        | Avg Annual Flow (MGD)  |
| Sewage  | Secondary                  | Extended Aeration | Hypochlorite        |                        |
| Hydraulic Capacity (MGD)                                    | Organic Capacity (lbs/day) | Load Status       | Biosolids Treatment | Biosolids Use/Disposal |
| 0.015   |                            | Not Overloaded    | Aerobic Digestion   | Combination of methods |

**2.3 Facility Outfall Information**

The facility has the following outfall information for wastewater.

|   |               |                   |                 |
|---|---------------|-------------------|-----------------|
| Outfall No.                             | 001           | Design Flow (MGD) | .015            |
| Latitude                                | 40° 0' 43.56" | Longitude         | -78° 19' 37.36" |
| Wastewater Description: Sewage Effluent |               |                   |                 |

**2.3.1 Operational Considerations- Chemical Additives**

Chemical additives are chemical products introduced into a waste stream that is used for cleaning, disinfecting, or maintenance and which may be detected in effluent discharged to waters of the Commonwealth. Chemicals excluded are those used for neutralization of waste streams, the production of goods, and treatment of wastewater.

The subject facility utilizes the following chemicals as part of their treatment process.

- Chlorine for disinfection
- Sodium sulfate for dichlorination
- Lime for pH adjustment

**2.4 Existing NPDES Permits Limits**

The existing NPDES permit limits are summarized in the table.

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. A. For Outfall 001, Latitude 40° 0' 43.56", Longitude 78° 19' 37.36", River Mile Index 75.5, Stream Code 13349

Receiving Waters: Raystown Branch Juniata River

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from **June 1, 2019** through **May 31, 2024**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

| Parameter                                      | Effluent Limitations                |                        |                       |                    |         |                  | Monitoring Requirements                      |                      |
|--|-------------------------------------|------------------------|-----------------------|--------------------|---------|------------------|--|----------------------|
|  | Mass Units (lbs/day) <sup>(1)</sup> |                        | Concentrations (mg/L) |                    |         |                  | Minimum <sup>(2)</sup> Measurement Frequency | Required Sample Type |
|  | Average Monthly                     | Average Weekly         | Minimum               | Average Monthly    | Maximum | Instant. Maximum |  |                      |
| Flow (MGD)                                     | Report                              | Report Daily Max       | XXX                   | XXX                | XXX     | XXX              | Continuous                                   | Measured             |
| pH (S.U.)                                      | XXX                                 | XXX                    | 6.0<br>Inst Min       | XXX                | XXX     | 9.0              | 1/day  | Grab                 |
| Dissolved Oxygen                               | XXX                                 | XXX                    | 5.0<br>Inst Min       | XXX                | XXX     | XXX              | 1/day  | Grab                 |
| Total Residual Chlorine (TRC)                  | XXX                                 | XXX                    | XXX                   | 0.5                | XXX     | 1.6              | 1/day  | Grab                 |
| Carbonaceous Biochemical Oxygen Demand (CBOD5) | XXX                                 | XXX                    | XXX                   | 25                 | XXX     | 50               | 2/month                                      | 8-Hr Composite       |
| Total Suspended Solids                         | XXX                                 | XXX                    | XXX                   | 30                 | XXX     | 60               | 2/month                                      | 8-Hr Composite       |
| Fecal Coliform (No./100 ml)<br>Oct 1 - Apr 30  | XXX                                 | XXX                    | XXX                   | 2000<br>Geo Mean   | XXX     | 10000            | 2/month                                      | Grab                 |
| Fecal Coliform (No./100 ml)<br>May 1 - Sep 30  | XXX                                 | XXX                    | XXX                   | 200<br>Geo Mean    | XXX     | 1000             | 2/month                                      | Grab                 |
| Nitrate-Nitrite as N                           | XXX                                 | XXX                    | XXX                   | Report<br>Annl Avg | XXX     | XXX              | 1/year                                       | 8-Hr Composite       |
| Total Nitrogen (Total Load, lbs)<br>(lbs)      | XXX                                 | Report<br>Total Annual | XXX                   | XXX                | XXX     | XXX              | 1/year                                       | Calculation          |
| Ammonia-Nitrogen                               | XXX                                 | XXX                    | XXX                   | Report<br>Annl Avg | XXX     | XXX              | 1/year                                       | 8-Hr Composite       |

**Outfall001, Continued (from Permit Effective Date through Permit Expiration Date)**

| Parameter               | Effluent Limitations                |                        |                       |                    |         |                  | Monitoring Requirements                      |                      |
|-------------------------|-------------------------------------|------------------------|-----------------------|--------------------|---------|------------------|--|----------------------|
|                         | Mass Units (lbs/day) <sup>(1)</sup> |                        | Concentrations (mg/L) |                    |         |                  | Minimum <sup>(2)</sup> Measurement Frequency | Required Sample Type |
|                         | Average Monthly                     | Average Weekly         | Minimum               | Average Monthly    | Maximum | Instant. Maximum |  |                      |
| Total Kjeldahl Nitrogen | XXX                                 | XXX                    | XXX                   | Report<br>Annl Avg | XXX     | XXX              | 1/year                                       | 8-Hr Composite       |
| Total Phosphorus        | XXX                                 | Report<br>Total Annual | XXX                   | Report<br>Annl Avg | XXX     | XXX              | 1/year                                       | 8-Hr Composite       |

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

### **3.0 Facility NPDES Compliance History**

#### **3.1 Summary of Inspections**

A summary of the most recent inspections during the existing permit review cycle is as follows.

The DEP inspector noted the following during the inspection.

04/27/2020:

- The facility was contacted by phone if there were any staffing or operational issues at the plant related to the COVID-19 outbreak. The operator reported that the treatment plant is operating normally and staffing is adequate. Routine checks at the plant were still taking place and effluent testing was being conducted as required. A review of monthly DMRs and supplemental reports showed an effluent reporting error for fecal coliform. The operator has been reporting the fecal coliform value as a monthly average instead of a geometric mean. This same error was found on the DMR's for other facilities this operator is responsible for. The miscalculated fecal coliform results were higher than they would be if the geometric mean was reported. The geometric mean should be reported on all future monitoring reports.

08/19/2020:

- An administrative inspection of the Riverview Estates STP. Reviewed past reports and DMRs.
- An inspection conducted on April 27, 2020 noted a reporting violation for fecal coliform.
- A review of the monthly discharge monitoring reports (DMRs) showed that the fecal coliform value was being reported as an average instead of a geometric mean.
- A non-compliance report attached to the DMR attributed the violations to a faulty blower and noted that the blower was repaired.

10/15/2021:

- The facility stated they recently replaced the chlorine feeds lines and that caused an overdose of chlorine. The operator stated that they diluted the chlorine in the storage container.
- The secondary clarifier contained an abundance of floating sludge on the surface and in the effluent troughs. The sludge blanket appeared to be about one foot below the water surface. The operator should investigate the cause of the excess sludge. The wasting or return rates may need to be adjusted.
- The sand bed dosing tank also contained some floating sludge and debris
- DEP was unable to locate any laboratory results or bench sheets more current than November 2020.
- 8-hour composite samples were taken by hand but the individual grab times were no longer being recorded in the log book.
- Sludge was last hauled out in May 2020.
- There were two containers with buffer solution on a shelf but there were no labels on the containers and no expiration dates.
- The outfall pipe for the treatment plant could not be located. The operator stated that the tropical storm deposited a lot of debris along the bank and may have covered it up. DEP requested that the outfall be located

11/30/2021:

- There was nothing significant to report.

10/26/2022:

- A layer of thick scum over the entire surface of the clarifier tank and sludge in the corners of three of the sand filters was observed. The operator thinks the scum in the clarifier and sludge on the sand was due to a recent plant upset. He explained that on 10/22/2022 a fire occurred in the main control panel and burned up some of the wires and switches. This caused the blowers and pumps to turn off. The facility was unsure how long the power was off. An electrician had been out to the plant since the fire but neither operator knew when the repairs would be taking place.

Operating high voltage electrical equipment without circuit breakers is unsafe and the panel should be repaired or replaced as soon as possible.

- A leak in the concrete block wall separating the aeration tank and sludge holding tank was recently repaired.
- DEP was unable to view some of the plant monitoring records. There were no recent laboratory sample results or chain of custody forms on site. The most recent sample results were from September 2021. The last receipt for sludge hauling activity was from May 5, 2020. Sludge removed from the plant on May 5, 2020 was not reported on the biosolids disposal supplemental form included with the May 2020 DMR.

02/14/2023:

- This was a follow-up inspection to check on violations noted during the inspection from October 26, 2022.
- The fire that damaged electrical components were replaced, including new controls modules, wiring, and switches. A sludge return valve was also repaired. The basket used to hold dechlorination tablets broke loose and needed to be located. The basket is lowered into an effluent manhole and the force flow caused the basket to enter the pipe and did not allow for a convenient sample point.
- Laboratory results and plant bench sheets that could not be located during last inspection are now on site and include records for the past three years.
- The four individual grab times for the composite samples were not being recorded. The log book notes the time of the first and last sample but not the time for the other two samples. The operator will begin to record all grab times.
- The most current sludge hauling record was from May 2020. The operator thinks sludge is removed from the plant about twice per year and that the association secretary probably has the receipts. Copies of sludge hauling records for past five years should be kept at the treatment plant. A sludge removal supplemental form needs to be submitted for any month sludge was hauled out.

07/26/2023:

- This was a follow-up inspection to check on record keeping violations noted during the inspection on February 24, 2023. The four individual grab times for the composite sample are now being recorded in the log book.
- The missing sludge disposal records are now on site. There are sludge hauling receipts from 2020, 2021, 2022, and 2023.
- An abundance of floating sludge was observed along the clarifier weirs and in the sand bed dosing tank. The sand bed filters also have a thin layer of dried sludge on the surface. Checking the solids content of the treatment system and investigating the cause of the floating sludge was recommended. The dosing tank and sand beds should be free of sludge.
- Laboratory sample results for 2023 except for one test on June 6, 2023 was not locatable on site. Copies of lab results from January 2023 through June 2023 should be available on site for review.

### **3.2 Summary of DMR Data**

A review of approximately 1-year of DMR data shows that the monthly average flow data for the facility exceeded the design capacity of the treatment system. In August 2022, the maximum average flow data for the DMR reviewed was 0.017 MGD. The design capacity of the treatment system is 0.015 MGD. The facility did not have three consecutive months of flows exceeding 0.015 MGD.

The off-site laboratory used for the analysis of the parameters was Fairway Labs located at 2019 9<sup>th</sup> Avenue, Altoona, PA 16602.



DMR Data for Outfall 001 (from June 1, 2022 to May 31, 2023)

| Parameter  | MAY-23       | APR-23  | MAR-23       | FEB-23 | JAN-23  | DEC-22  | NOV-22  | OCT-22  | SEP-22       | AUG-22       | JUL-22        | JUN-22       |
|--|--------------|---------|--------------|--------|---------|---------|---------|---------|--------------|--------------|---------------|--------------|
| Flow (MGD)<br>Average Monthly                              | 0.01244<br>2 | 0.01018 | 0.01254      | 0.0116 | 0.01123 | 0.01272 | 0.0122  | 0.01082 | 0.01082<br>4 | 0.01758<br>9 | 0.00990<br>83 | 0.00993<br>8 |
| Flow (MGD)<br>Daily Maximum                                | 0.09359      | 0.01336 | 0.02127<br>3 | 0.0264 | 0.0156  | 0.04433 | 0.02974 | 0.01584 | 0.02677      | 0.1292       | 0.01554       | 0.01437      |
| pH (S.U.)<br>Instantaneous<br>Minimum                      | 6.75         | 6.92    | 6.99         | 6.94   | 6.88    | 6.92    | 6.85    | 6.69    | 6.73         | 6.72         | 6.83          | 6.58         |
| pH (S.U.)<br>Instantaneous<br>Maximum                      | 7.36         | 7.50    | 7.51         | 7.4    | 7.80    | 7.88    | 7.93    | 7.35    | 7.14         | 7.2          | 7.3           | 7.41         |
| DO (mg/L)<br>Instantaneous<br>Minimum                      | 6.3          | 7.2     | 8.5          | 9.0    | 8.7     | 8.4     | 7.0     | 6.60    | 5.8          | 5.7          | 5.8           | 6.2          |
| TRC (mg/L)<br>Average Monthly                              | < 0.2        | 0.3     | 0.2          | 0.4    | 0.40    | 0.3     | 0.3     | < 0.3   | 0.3          | 0.3          | 0.3           | 0.3          |
| TRC (mg/L)<br>Instantaneous<br>Maximum                     | 1.3          | 1.49    | 0.37         | 0.49   | 0.56    | 0.44    | 0.36    | 0.44    | 0.45         | 0.44         | 0.41          | 0.38         |
| CBOD5 (mg/L)<br>Average Monthly                            | < 3.0        | < 3.0   | < 5.0        | < 3.0  | < 3.0   | < 3.0   | < 3.0   | < 3.0   | < 7.0        | < 3.0        | < 3.0         | < 5          |
| TSS (mg/L)<br>Average Monthly                              | < 2.0        | < 4.0   | < 2.0        | 15     | < 9.0   | < 2.0   | < 2.0   | < 1.60  | < 2          | < 3.0        | < 5.0         | 3            |
| Fecal Coliform<br>(No./100 ml)<br>Geometric Mean           | < 4.0        | 55      | < 4.0        | 14     | 13      | 256     | 16      | 13.0    | 8.0          | 40           | 61            | 46           |
| Fecal Coliform<br>(No./100 ml)<br>Instantaneous<br>Maximum | 4.0          | 100     | < 4.0        | 48.8   | 39.2    | 2419    | 85.7    | 13.4    | 66.3         | 187          | 63.1          | 98.8         |
| Nitrate-Nitrite (mg/L)<br>Annual Average                   |              |         |              |        |         | < 40.29 |         |         |              |              |               |              |
| Total Nitrogen (lbs)<br>Total Annual                       |              |         |              |        |         | < 128   |         |         |              |              |               |              |
| Ammonia (mg/L)<br>Annual Average                           |              |         |              |        |         | < 1     |         |         |              |              |               |              |
| TKN (mg/L)<br>Annual Average                               |              |         |              |        |         | < 0.5   |         |         |              |              |               |              |

**NPDES Permit Fact Sheet  
Riverview Estates Development**

**NPDES Permit No. PA0083569**

|   |  |  |  |  |  |      |  |  |  |  |  |  |
|---|--|--|--|--|--|------|--|--|--|--|--|--|
| Total Phosphorus<br>(lbs/day)<br>Total Annual |  |  |  |  |  | < 11 |  |  |  |  |  |  |
| Total Phosphorus<br>(mg/L)<br>Annual Average  |  |  |  |  |  | 3.61 |  |  |  |  |  |  |

### 3.3 Non-Compliance

#### 3.3.1 Non-Compliance- NPDES Effluent

A summary of the non-compliance to the permit limits for the existing permit cycle is as follows.

From the DMR data beginning in June 1, 2019 to September 22, 2023, the following were observed effluent non-compliances.

| Summary of Non-Compliance with NPDES Permit Limits   |                               |                         |                               |              |                     |              |                 |                       |   |
|--|-------------------------------|-------------------------|-------------------------------|--------------|---------------------|--------------|-----------------|-----------------------|---|
| Beginning June 1, 2019 and ending September 22, 2023 |                               |                         |                               |              |                     |              |                 |                       |   |
| NON_COMPLIANCE_DATE                                  | NON_COMPL_TYPE_DESC           | NON_COMPL_CATEGORY_DESC | PARAMETER                     | SAMPLE_VALUE | VIOLATION_CONDITION | PERMIT_VALUE | UNIT_OF_MEASURE | STAT_BASE_CODE        | FACILITY_COMMENTS                             |
| 7/26/2019  | Violation of permit condition | Effluent                | pH                            | 5.94         | <                   | 6.0          | S.U.            | Instantaneous Minimum | LIME NEEDED TO BE INCREASED.                  |
| 7/27/2020  | Violation of permit condition | Effluent                | Dissolved Oxygen              | 4.4          | <                   | 5.0          | mg/L            | Instantaneous Minimum |   |
| 5/29/2021  | Late DMR Submission           | Other Violation         |                               |              |                     |              |                 |                       |   |
| 5/27/2021  | Violation of permit condition | Effluent                | Total Residual Chlorine (TRC) | 0.6          | >                   | .5           | mg/L            | Average Monthly       |   |
| 8/28/2021  | Violation of permit condition | Effluent                | Total Residual Chlorine (TRC) | 0.7          | >                   | .5           | mg/L            | Average Monthly       | ISSUES WITH CL2 PUMP.. REPAIRED               |
| 8/28/2023  | Violation of permit condition | Effluent                | Fecal Coliform                | 1732.9       | >                   | 1000         | No./100 ml      | Instantaneous Maximum | Inadequate disinfection - added more chlorine |
| 8/28/2023  | Violation of permit condition | Effluent                | Fecal Coliform                | 323          | >                   | 200          | No./100 ml      | Geometric Mean        | Inadequate disinfection-Added more chlorine   |

#### 3.3.2 Non-Compliance- Enforcement Actions

A summary of the non-compliance enforcement actions for the current permit cycle is as follows:

Beginning in June 1, 2019 to September 22, 2023, there were no observed enforcement actions.

#### 3.4 Summary of Biosolids Disposal

A summary of the biosolids disposed of from the facility is as follows.

| 2023   |                |          |          |
|--|----------------|----------|----------|
| Sewage Sludge / Biosolids Production Information   |                |          |          |
| Hauled Off-Site  |                |          |          |
| Date (YEAR)  | Tons Dewatered | % Solids | Dry Tons |
| January  |                |          |          |
| February   |                |          |          |
| March  |                |          |          |
| April  |                |          |          |
| May  |                |          |          |
| June   | 4000           | 0.16     | 6.4      |
| July   |                |          |          |
| August   |                |          |          |
| Notes:   |                |          |          |
| Biosolids / sewage sludge disposed at Orchard Lane Excavation located in Blair County under permit number PA007005 |                |          |          |

**3.5 Open Violations**

As of September 2023, the table summarizes open violations.

**Summary of Open Violations**

| INSP ID | VIOLATION ID | DATE       | VIOLATION CODE | VIOLATION  |
|---------|--------------|------------|----------------|--|
| 3266827 | 933298       | 10/15/2021 | 92A.44         | NPDES - Violation of effluent limits in Part A of permit   |
| 3266827 | 933299       | 10/15/2021 | 92A.41(A)10B   | NPDES - Failure to utilize approved analytical methods   |
| 3266827 | 933300       | 10/15/2021 | 92A.41(A)8     | NPDES - Failure to provide information or records required by  |
| 3266827 | 933301       | 10/15/2021 | 92A.61(F)2     | NPDES - Failure to maintain records for at least 3 years   |
| 3283270 | 936644       | 11/17/2021 | 92A.44         | NPDES - Violation of effluent limits in Part A of permit   |
| 3448336 | 973642       | 10/26/2022 | 92A.41(A)5     | NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance |

**4.0 Receiving Waters and Water Supply Information Detail Summary**

**4.1 Receiving Waters**

The receiving waters has been determined to be Raystown Branch Juniata River. The sequence of receiving streams that the Raystown Branch Juniata River discharges into are Juniata River, and the Susquehanna River which eventually drains into the Chesapeake Bay.

**4.2 Public Water Supply (PWS) Intake**

The closest PWS to the subject facility is Saxton Municipal Water Authority (PWS ID #4050221) located approximately 37 miles downstream of the subject facility on the Juniata River. Based upon the distance and the flow rate of the facility, the PWS should not be impacted.

**4.3 Class A Wild Trout Streams**

Class A Wild Trout Streams are waters that support a population of naturally produced trout of sufficient size and abundance to support long-term and rewarding sport fishery. DEP classifies these waters as high-quality coldwater fisheries.

The information obtained from EMAP suggests that no Class A Wild Trout Fishery will be impacted by this discharge.

**4.4 2022 Integrated List of All Waters (303d Listed Streams)**

Section 303(d) of the Clean Water Act requires States to list all impaired surface waters not supporting uses even after appropriate and required water pollution control technologies have been applied. The 303(d) list includes the reason for impairment which may be one or more point sources (i.e. industrial or sewage discharges) or non-point sources (i.e. abandoned mine lands or agricultural runoff and the pollutant causing the impairment such as metals, pH, mercury or siltation).

States or the U.S. Environmental Protection Agency (EPA) must determine the conditions that would return the water to a condition that meets water quality standards. As a follow-up to listing, the state or EPA must develop a Total Maximum Daily Load (TMDL) for each waterbody on the list. A TMDL identifies allowable pollutant loads to a waterbody from both point and non-point sources that will prevent a violation of water quality standards. A TMDL also includes a margin of safety to ensure protection of the water.

The water quality status of Pennsylvania's waters uses a five-part categorization (lists) of waters per their attainment use status. The categories represent varying levels of attainment, ranging from Category 1, where all designated water uses are met to Category 5 where impairment by pollutants requires a TMDL for water quality protection.

The receiving waters is listed in the 2022 Pennsylvania Integrated Water Quality Monitoring and Assessment Report as a Category 2 waterbody. The surface waters is an attaining stream that supports aquatic life. The designated use has been classified as protected waters for trout stocking fishes (TSF) and migratory fishes (MF).

**4.5 Low Flow Stream Conditions**

Water quality modeling estimates are based upon conservative data inputs. The data are typically estimated using either a stream gauge or through USGS web based StreamStats program. The NPDES effluent limits are based upon the combined flows from both the stream and the facility discharge.

A conservative approach to estimate the impact of the facility discharge using values which minimize the total combined volume of the stream and the facility discharge. The volumetric flow rate for the stream is based upon the seven-day, 10-year low flow (Q710) which is the lowest estimated flow rate of the stream during a 7 consecutive day period that occurs once in 10 -year time period. The facility discharge is based upon a known design capacity of the subject facility.

The closest WQN station to the subject facility is the Raystown Branch Juniata River at Saxton, PA (WQN223). This WQN station is located approximately 38 miles downstream of the subject facility.

The closest gauge station to the subject facility is the Raystown Branch Juniata River at Saxton, PA (USGS station number 1562000). This gauge station is located approximately 38 miles downstream of the subject facility.

For WQM modeling, pH and stream water temperature data from the water quality network station was used. pH was estimated to be 8.0 and the stream water temperature was estimated to be 23.3 C.

The hardness of the stream was estimated from the water quality network to be 96 mg/l CaCO<sub>3</sub>.

The low flow yield and the Q710 for the subject facility was estimated as shown below.

| Gauge Station Data  |   |                                      |
|---|---|--------------------------------------|
| USGS Station Number   | 1562000                                     |                                      |
| Station Name  | Raystown Branch Juniata River at Saxton, PA |                                      |
| Q710  | 67.1  | ft <sup>3</sup> /sec                 |
| Drainage Area (DA)  | 756   | mi <sup>2</sup>                      |
| <b>Calculations</b>   |   |                                      |
| The low flow yield of the gauge station is:                                 |   |                                      |
| Low Flow Yield (LFY) = Q710 / DA  |   |                                      |
| LFY = ( 67.1 ft <sup>3</sup> /sec / 756 mi <sup>2</sup> )                   |   |                                      |
| LFY =   | 0.0888                                      | ft <sup>3</sup> /sec/mi <sup>2</sup> |
| The low flow at the subject site is based upon the DA of                    |   |                                      |
|   | 454   | mi <sup>2</sup>                      |
| Q710 = (LFY@gauge station)(DA@Subject Site)                                 |   |                                      |
| Q710 = (0.0888 ft <sup>3</sup> /sec/mi <sup>2</sup> )(454 mi <sup>2</sup> ) |   |                                      |
| Q710 =  | 40.296                                      | ft <sup>3</sup> /sec                 |

**4.6 Summary of Discharge, Receiving Waters and Water Supply Information**

|  |  |   |                                |
|--|--|---|--------------------------------|
| Outfall No.                                    | <u>001</u>                                     | Design Flow (MGD)                       | <u>.015</u>                    |
| Latitude                                       | <u>40° 0' 43.04"</u>                           | Longitude                               | <u>-78° 19' 37.15"</u>         |
| Quad Name                                      | <u></u>  | Quad Code                               | <u></u>                        |
| Wastewater Description: <u>Sewage Effluent</u> |  |   |                                |
| Receiving Waters                               | <u>Raystown Branch Juniata River (TSF)</u>     | Stream Code                             | <u>13349</u>                   |
| NHD Com ID                                     | <u>65847203</u>                                | RMI                                     | <u>75.5</u>                    |
| Drainage Area                                  | <u>454</u>                                     | Yield (cfs/mi <sup>2</sup> )            | <u>0.0888</u>                  |
| Q <sub>7-10</sub> Flow (cfs)                   | <u>40.296</u>                                  | Q <sub>7-10</sub> Basis                 | <u>StreamStats/Streamgauge</u> |
| Elevation (ft)                                 | <u>975</u>                                     | Slope (ft/ft)                           | <u></u>                        |
| Watershed No.                                  | <u>11-C</u>                                    | Chapter 93 Class.                       | <u>TSF, MF</u>                 |
| Existing Use                                   | <u></u>  | Existing Use Qualifier                  | <u></u>                        |
| Exceptions to Use                              | <u></u>  | Exceptions to Criteria                  | <u></u>                        |
| Assessment Status                              | <u>Attaining Use(s) supports aquatic life.</u> |   |                                |
| Cause(s) of Impairment                         | <u>Not applicable</u>                          |   |                                |
| Source(s) of Impairment                        | <u>Not applicable</u>                          |   |                                |
| TMDL Status                                    | <u>Not applicable</u>                          | Name                                    | <u></u>                        |
| Background/Ambient Data                        |  | Data Source                             |                                |
| pH (SU)  | <u>8.0</u>                                     | <u>WQN223; median July to Sept</u>      |                                |
| Temperature (°C)                               | <u>23.3</u>                                    | <u>WQN223; median July to Sept</u>      |                                |
| Hardness (mg/L)                                | <u>96</u>                                      | <u>WQN223; median historical</u>        |                                |
| Other:   | <u></u>  | <u></u>                                 |                                |
| Nearest Downstream Public Water Supply Intake  |  | <u>Saxton Municipal Water Authority</u> |                                |
| PWS Waters                                     | <u>Juniata River</u>                           | Flow at Intake (cfs)                    | <u></u>                        |
| PWS RMI  | <u>41</u>                                      | Distance from Outfall (mi)              | <u>37</u>                      |

**5.0: Overview of Presiding Water Quality Standards**

**5.1 General**

There are at least six (6) different policies which determines the effluent performance limits for the NPDES permit. The policies are technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), antidegradation, total maximum daily loading (TMDL), anti-backsliding, and whole effluent toxicity (WET) The effluent performance limitations enforced are the selected permit limits that is most protective to the designated use of the receiving waters. An overview of each of the policies that are applicable to the subject facility has been presented in Section 6.

**5.2.1 Technology-Based Limitations**

TBEL treatment requirements under section 301(b) of the Act represent the minimum level of control that must be imposed in a permit issued under section 402 of the Act (40 CFR 125.3). Available TBEL requirements for the state of Pennsylvania are itemized in PA Code 25, Chapter 92a.47.

The presiding sources for the basis for the effluent limitations are governed by either federal or state regulation. The reference sources for each of the parameters is itemized in the tables. The following technology-based limitations apply, subject to water quality analysis and best professional judgement (BPJ) where applicable:

| Parameter                    | Limit (mg/l)    | SBC             | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD <sub>5</sub>            | 25              | Average Monthly | 133.102(a)(4)(i)   | 92a.47(a)(1)     |
|                              | 40              | Average Weekly  | 133.102(a)(4)(ii)  | 92a.47(a)(2)     |
| Total Suspended Solids       | 30              | Average Monthly | 133.102(b)(1)      | 92a.47(a)(1)     |
|                              | 45              | Average Weekly  | 133.102(b)(2)      | 92a.47(a)(2)     |
| pH                           | 6.0 – 9.0 S.U.  | Min – Max       | 133.102(c)         | 95.2(1)          |
| Fecal Coliform (5/1 – 9/30)  | 200 / 100 ml    | Geo Mean        | -                  | 92a.47(a)(4)     |
| Fecal Coliform (5/1 – 9/30)  | 1,000 / 100 ml  | IMAX            | -                  | 92a.47(a)(4)     |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml  | Geo Mean        | -                  | 92a.47(a)(5)     |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX            | -                  | 92a.47(a)(5)     |
| Total Residual Chlorine      | 0.5             | Average Monthly | -                  | 92a.48(b)(2)     |

**5.3 Water Quality-Based Limitations**

WQBEL are based on the need to attain or maintain the water quality criteria and to assure protection of designated and existing uses (PA Code 25, Chapter 92a.2). The subject facility that is typically enforced is the more stringent limit of either the TBEL or the WQBEL.

Determination of WQBEL is calculated by spreadsheet analysis or by a computer modeling program developed by DEP. DEP permit engineers utilize the following computing programs for WQBEL permit limitations: (1) MS Excel worksheet for Total Residual Chlorine (TRC); (2) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen Version 1.1 (WQM Model) and (3) Toxics using DEP Toxics Management Spreadsheet for Toxics pollutants.

The modeling point nodes utilized for this facility are summarized below.

| <b>General Data 1</b> | <b>(Modeling Point #1)</b> | <b>(Modeling Point #2)</b> | <b>Units</b> |
|-----------------------|----------------------------|----------------------------|--------------|
| Stream Code           | 13349                      | 13349                      |              |
| River Mile Index      | 75.5                       | 74.35                      | miles        |
| Elevation             | 975                        | 970                        | feet         |
| Latitude              | 40.011944                  | 40.005797                  |              |
| Longitude             | -78.326944                 | -78.308847                 |              |
| Drainage Area         | 454                        | 460                        | sq miles     |
| Low Flow Yield        | 0.0888                     | 0.0888                     | cfs/sq mile  |

### **5.3.1 Water Quality Modeling 7.0**

The WQM Model is a computer model that is used to determine NPDES discharge effluent limitations for Carbonaceous BOD (CBOD5), Ammonia Nitrogen (NH3-N), and Dissolved Oxygen (DO) for single and multiple point source discharges scenarios. WQM Model is a complete-mix model which means that the discharge flow and the stream flow are assumed to instantly and completely mixed at the discharge node.

WQM recommends effluent limits for DO, CBOD5, and NH3-N in mg/l for the discharge(s) in the simulation.

Four types of limits may be recommended. The limits are

- (a) a minimum concentration for DO in the discharge as 30-day average;
- (b) a 30-day average concentration for CBOD5 in the discharge;
- (c) a 30-day average concentration for the NH3-N in the discharge;
- (d) 24-hour average concentration for NH3-N in the discharge.

The WQM Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

**The applicable WQM Effluent Limit Type are discussed in Section 6 under the corresponding parameter which is either DO, CBOD, or ammonia-nitrogen.**

### **5.3.2 Toxics Modeling**

Since the facility has a design flow rate not exceeding 0.1 MGD, the facility is not subject to toxics modeling.

### **5.3.3 Whole Effluent Toxicity (WET)**

The facility is not subject to WET.

## **5.4 Total Maximum Daily Loading (TMDL)**

### **5.4.1 TMDL**

The goal of the Clean Water Act (CWA), which governs water pollution, is to ensure that all of the Nation's waters are clean and healthy enough to support aquatic life and recreation. To achieve this goal, the CWA created programs designed to regulate and reduce the amount of pollution entering United States waters. Section 303(d) of the CWA requires states to assess their waterbodies to identify those not meeting water quality standards. If a waterbody is not meeting standards, it is listed as impaired and reported to the U.S. Environmental Protection Agency. The state then develops a plan to clean up the impaired waterbody. This plan includes the development of a Total Maximum Daily Load (TMDL) for the pollutant(s) that were found to be the cause of the water quality violations. A Total Maximum Daily Load (TMDL) calculates the maximum amount of a specific pollutant that a waterbody can receive and still meet water quality standards.



A TMDL for a given pollutant and waterbody is composed of the sum of individual wasteload allocations (WLAs) for point sources and load allocations (LAs) for nonpoint sources and natural background levels. In addition, the TMDL must include an implicit or explicit margin of safety (MOS) to account for the uncertainty in the relationship between pollutant loads and the quality of the receiving waterbody. The TMDL components are illustrated using the following equation:

$$\text{TMDL} = \Sigma \text{WLAs} + \Sigma \text{LAs} + \text{MOS}$$

Pennsylvania has committed to restoring all impaired waters by developing TMDLs and TMDL alternatives for all impaired waterbodies. The TMDL serves as the starting point or planning tool for restoring water quality.

#### **5.4.1.1 Local TMDL**

The subject facility does not discharge into a local TMDL.

#### **5.4.1.2 Chesapeake Bay TMDL Requirement**

The Chesapeake Bay Watershed is a large ecosystem that encompasses approximately 64,000 square miles in Maryland, Delaware, Virginia, West Virginia, Pennsylvania, New York and the District of Columbia. An ecosystem is composed of interrelated parts that interact with each other to form a whole. All of the plants and animals in an ecosystem depend on each other in some way. Every living thing needs a healthy ecosystem to survive. Human activities affect the Chesapeake Bay ecosystem by adding pollution, using resources and changing the character of the land.

Most of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the federal Water Pollution Control Act ("Clean Water Act"), 33 U.S.C. § 1313(d). While the Chesapeake Bay is outside the boundaries of Pennsylvania, more than half of the State lies within the watershed. Two major rivers in Pennsylvania are part of the Chesapeake Bay Watershed. They are (a) the Susquehanna River and (b) the Potomac River. These two rivers total 40 percent of the entire Chesapeake Bay watershed.

The overall management approach needed for reducing nitrogen, phosphorus and sediment are provided in the Bay TMDL document and the Phase I, II, and III WIPs which is described in the Bay TMDL document and Executive Order 13508.

The Bay TMDL is a comprehensive pollution reduction effort in the Chesapeake Bay watershed identifying the necessary pollution reductions of nitrogen, phosphorus and sediment across the seven Bay watershed jurisdictions of Delaware, Maryland, New York, Pennsylvania, Virginia, West Virginia and the District of Columbia to meet applicable water quality standards in the Bay and its tidal waters.

The Watershed Implementation Plans (WIPs) provides objectives for how the jurisdictions in partnership with federal and local governments will achieve the Bay TMDL's nutrient and sediment allocations.

Phase 3 WIP provides an update on Chesapeake Bay TMDL implementation activities for point sources and DEP's current implementation strategy for wastewater. The latest revision of the supplement was September 13, 2021.

The Chesapeake Bay TMDL (Appendix Q) categorizes point sources into four sectors:

- Sector A- significant sewage dischargers;
- Sector B- significant industrial waste (IW) dischargers;
- Sector C- non-significant dischargers (both sewage and IW facilities); and
- Sector D- combined sewer overflows (CSOs).

All sectors contain a listing of individual facilities with NPDES permits that were believed to be discharging at the time the TMDL was published (2010). All sectors with the exception of the non-significant dischargers have individual wasteload allocations (WLAs) for TN and TP assigned to specific facilities. Non-significant dischargers have a bulk or aggregate allocation for TN and TP based on the facilities in that sector that were believed to be discharging at that time and their estimated nutrient loads.

Cap Loads will be established in permits as Net Annual TN and TP loads (lbs/yr) that apply during the period of October 1 – September 30. For facilities that have received Cap Loads in any other form, the Cap Loads will be modified accordingly when the permits are renewed.

Offsets have been incorporated into Cap Loads in several permits issued to date. From this point forward, permits will be issued with the WLAs as Cap Loads and will identify Offsets separately to facilitate nutrient trading activities and compliance with the TMDL.

Based upon the supplement the subject facility has been categorized as a Sector C discharger. The supplement defines Sector C as a non-significant dischargers include sewage facilities (Phase 4 facilities:  $\geq 0.2$  MGD and  $< 0.4$  MGD and Phase 5 facilities:  $> 0.002$  MGD and  $< 0.2$  MGD), small flow/single residence sewage treatment facilities ( $\leq 0.002$  MGD), and non-significant IW facilities, all of which may be covered by statewide General Permits or may have individual NPDES permits.

At this time, there are approximately 850 Phase 4 and 5 sewage facilities, approximately 715 small flow sewage treatment facilities covered by a statewide General Permit, and approximately 300 non-significant IW facilities.

For Phase 5 sewage facilities with individual permits (average annual design flow on August 29, 2005  $> 0.002$  MGD and  $< 0.2$  MGD), DEP will issue individual permits with monitoring and reporting for TN and TP throughout the permit term at a frequency no less than annually, unless 1) the facility has already conducted at least two years of nutrient monitoring and 2) a summary of the monitoring results are included in the next permit's fact sheet. If, however, Phase 5 facilities choose to expand, the renewed or amended permits will contain Cap Loads based on the lesser of a) existing TN/TP concentrations at current design average annual flow or b) 7,306 lbs/yr TN and 974 lbs/yr TP.

If no data are available to determine existing concentrations for expanding Phase 4 or 5 facilities, default concentrations of 25 mg/l TN and 4 mg/l TP may be used (these are the average estimated concentrations of all non-significant sewage facilities).

DEP will not issue permits to existing Phase 4 and 5 facilities containing Cap Loads unless it is done on a broad scale or unless the facilities are expanding.

For new Phase 4 and 5 sewage discharges, in general DEP will issue new permits containing Cap Loads of "0" and new facilities will be expected to purchase credits and/or apply offsets to achieve compliance, with the exception of small flow and single residence facilities.

**This facility is subject to Sector C monitoring requirements. Monitoring for nitrogen species and phosphorus shall be 1x/year.**

### **5.5 Anti-Degradation Requirement**

Chapter 93.4a of the PA regulations requires that surface water of the Commonwealth of Pennsylvania may not be degraded below levels that protect the existing uses. The regulations specifically state that *Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected*. Antidegradation requirements are implemented through DEP's guidance manual entitled Water Quality Antidegradation Implementation Guidance (Document #391-0300-02).

The policy requires DEP to protect the existing uses of all surface waters and the existing quality of High Quality (HQ) and Exceptional Value (EV) Waters. Existing uses are protected when DEP makes a final decision on any permit or approval for an activity that may affect a protected use. Existing uses are protected based upon DEP's evaluation of the best available information (which satisfies DEP protocols and Quality Assurance/Quality Control (QA/QC) procedures) that indicates the protected use of the waterbody.

For a new, additional, or increased point source discharge to an HQ or EV water, the person proposing the discharge is required to utilize a nondischarge alternative that is cost-effective and environmentally sound when compared with the cost of the proposed discharge. If a nondischarge alternative is not cost-effective and environmentally sound, the person must use the best available combination of treatment, pollution prevention, and wastewater reuse technologies and assure that any discharge is nondegrading. In the case of HQ waters, DEP may find that after satisfaction of intergovernmental coordination and public participation requirements lower water quality is necessary to accommodate important economic or social development in the area in which the waters are located. In addition, DEP will assure that cost-effective and reasonable best management practices for nonpoint source control in HQ and EV waters are achieved.

**The subject facility's discharge will be to a non-special protection waters and the permit conditions are imposed to protect existing instream water quality and uses. Neither HQ waters or EV waters is impacted by this discharge.**

### **5.6 Anti-Backsliding**

Anti-backsliding is a federal regulation which prohibits a permit from being renewed, reissued, or modified containing effluent limitations which are less stringent than the comparable effluent limitations in the previous permit (40 CFR 122.1.1 and 40 CFR 122.1.2). A review of the existing permit limitations with the proposed permit limitations confirm that the facility is consistent with anti-backsliding requirements. The facility has proposed effluent limitations that are as stringent as the existing permit.

### **6.0 NPDES Parameter Details**

The basis for the proposed sampling and their monitoring frequency that will appear in the permit for each individual parameter are itemized in this Section. The final limits are the more stringent of technology based effluent treatment (TBEL) requirements, water quality based (WQBEL) limits, TMDL, antidegradation, anti-degradation, or WET.

The reader will find in this section:

- a) a justification of recommended permit monitoring requirements and limitations for each parameter in the proposed NPDES permit;
- b) a summary of changes from the existing NPDES permit to the proposed permit; and
- c) a summary of the proposed NPDES effluent limits.

### **6.1 Recommended Monitoring Requirements and Effluent Limitations**

A summary of the recommended monitoring requirements and effluent limitations are itemized in the tables. The tables are categorized by (a) Conventional Pollutants and Disinfection and (b) Nitrogen Species and Phosphorus.

6.1.1 Conventional Pollutants and Disinfection

| Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection |  |                 |  |
|--|--|-----------------|--|
| Riverview Estates, PA0083569   |  |                 |  |
| Parameter  | Permit Limitation Required by <sup>1</sup> : | Recommendation  |  |
| pH (S.U.)  | TBEL   | Monitoring:     | The monitoring frequency shall be 5x/week as a grab sample (SOP).  |
|  |  | Effluent Limit: | Effluent limits may range from pH = 6.0 to 9.0   |
|  |  | Rationale:      | The monitoring frequency has been assigned in accordance with SOP and the effluent limits assigned by Chapter 95.2(1).   |
| Dissolved Oxygen   | BPJ  | Monitoring:     | The monitoring frequency shall be 5x/week as a grab sample (SOP).  |
|  |  | Effluent Limit: | Effluent limits shall be greater than 5.0 mg/l.  |
|  |  | Rationale:      | The monitoring frequency has been assigned in accordance with SOP and the effluent limits assigned by best professional judgement.   |
| CBOD   | TBEL   | Monitoring:     | The monitoring frequency shall be 2x/month as an 8-hr composite sample (Table 6-3).  |
|  |  | Effluent Limit: | Effluent limits shall not exceed 25 mg/l as an average monthly.  |
|  |  | Rationale:      | The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). WQM modeling indicates that the TBEL is more stringent than the WQBEL. Thus, the permit limit is confined to TBEL.   |
| TSS  | TBEL   | Monitoring:     | The monitoring frequency shall be 2x/month as an 8-hr composite sample (Table 6-3).  |
|  |  | Effluent Limit: | Effluent limits shall not exceed 25 mg/l as an average monthly.  |
|  |  | Rationale:      | The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). While there is no WQM modeling for this parameter, the permit limit for TSS is generally assigned similar effluent limits as CBOD or BOD.  |
| TRC  | TBEL   | Monitoring:     | The monitoring frequency shall be 5x/week as a grab sample (SOP).  |
|  |  | Effluent Limit: | The average monthly limit should not exceed 0.5 mg/l and/or 1.6 mg/l as an instantaneous maximum.  |
|  |  | Rationale:      | Chlorine in both combined (chloramine) and free form is extremely toxic to freshwater fish and other forms of aquatic life (Implementation Guidance Total Residual Chlorine 1). The TRC effluent limitations to be imposed on a discharger shall be the more stringent of either the WQBEL or TBEL requirements and shall be expressed in the NPDES permit as an average monthly and instantaneous maximum effluent concentration (Implementation Guidance Total Residual Chlorine 4). Based on the stream flow rate (lowest 7-day flow rate in 10 years) and the design flow rate of the subject facility calculated by the TRC Evaluation worksheet, the TBEL is more stringent than the WQBEL. The monitoring frequency has been assigned in accordance with SOP and the effluent limits assigned by Chapter 92a.48(b)(2) |
| Fecal Coliform   | TBEL   | Monitoring:     | The monitoring frequency shall be 2x/month as a grab sample (Table 6-3).   |
|  |  | Effluent Limit: | Summer effluent limits shall not exceed 200 No./100 mL as a geometric mean. Winter effluent limits shall not exceed 2000 No./100 mL as a geometric mean.   |
|  |  | Rationale:      | The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(4) and 92a.47(a)(5).   |
| E. Coli  | SOP; Chapter 92a.61                          | Monitoring:     | The monitoring frequency shall be 1x/yr as a grab sample (SOP).  |
|  |  | Effluent Limit: | No effluent requirements.  |
|  |  | Rationale:      | Consistent with the SOP- Establishing Effluent Limitations for Individual Sewage Permits (Revised March 22, 2019) and under the authority of Chapter 92a.61, the facility will be required to monitor for E. Coli.   |

Notes:

1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other

2 Monitoring frequency based on flow rate of 0.015 MGD.

3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97

4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)

5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021

**6.1.2 Nitrogen Species and Phosphorus**

| Summary of Proposed NPDES Parameter Details for Nitrogen Species and Phosphorus  |  |                 |  |
|--|--|-----------------|--|
| Riverview Estates, PA0083569   |  |                 |  |
| Parameter  | Permit Limitation Required by <sup>1</sup> : | Recommendation  |  |
| Ammonia-Nitrogen   | Chesapeake Bay TMDL                          | Monitoring:     | The monitoring frequency shall be 1x/yr as an 8-hr composite sample  |
|  |  | Effluent Limit: | No effluent requirements.  |
|  |  | Rationale:      | Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr. |
| Nitrate-Nitrite as N   | Chesapeake Bay TMDL                          | Monitoring:     | The monitoring frequency shall be 1x/yr as an 8-hr composite sample  |
|  |  | Effluent Limit: | No effluent requirements.  |
|  |  | Rationale:      | Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr. |
| Total Nitrogen   | Chesapeake Bay TMDL                          | Monitoring:     | The monitoring frequency shall be 1x/yr as a calculation   |
|  |  | Effluent Limit: | No effluent requirements.  |
|  |  | Rationale:      | Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr. |
| TKN  | Chesapeake Bay TMDL                          | Monitoring:     | The monitoring frequency shall be 1x/yr as an 8-hr composite sample  |
|  |  | Effluent Limit: | No effluent requirements.  |
|  |  | Rationale:      | Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr. |
| Total Phosphorus   | Chesapeake Bay TMDL                          | Monitoring:     | The monitoring frequency shall be 1x/yr as an 8-hr composite sample  |
|  |  | Effluent Limit: | No effluent requirements.  |
|  |  | Rationale:      | Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr. |
| <b>Notes:</b>  |  |                 |  |
| 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other  |  |                 |  |
| 2 Monitoring frequency based on flow rate of 0.015 MGD.  |  |                 |  |
| 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97 |  |                 |  |
| 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)   |  |                 |  |
| 5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021   |  |                 |  |

**6.1.3.1 Implementation of Regulation- Chapter 92a.61**

Chapter 92a.61 provides provisions to DEP to monitor for pollutants that may have an impact on the quality of waters of the Commonwealth. Based upon DEP policy directives issued on March 22, 2021 and in conjunction with EPA's 2017 Triennial Review, monitoring for E. Coli shall be required.

**6.2 Summary of Changes From Existing Permit to Proposed Permit**

A summary of how the proposed NPDES permit differs from the existing NPDES permit is summarized as follows.

| <b>Changes in Permit Monitoring or Effluent Quality</b> |  |   |
|---|--|---|
| <b>Parameter</b>  | <b>Existing Permit</b>                 | <b>Draft Permit</b>   |
| E. Coli   | No monitoring or effluent requirements | Due to the EPA triennial, monitoring shall be required 1x/yr. |
| pH, DO, and TRC   | Monitoring is required 1x/day          | Per SOP, monitoring shall be 5x/week                          |

**6.3.1 Summary of Proposed NPDES Effluent Limits**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

The proposed NPDES effluent limitations are summarized in the table below.

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. A. For Outfall 001, Latitude 40° 0' 43.56", Longitude 78° 19' 37.36", River Mile Index 74.5, Stream Code 13349

Receiving Waters: Raystown Branch Juniata River (TSF)

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from Permit Effective Date through Permit Expiration Date.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

| Parameter                                      | Effluent Limitations                |                        |                       |                    |               |                  | Monitoring Requirements                      |                      |
|--|-------------------------------------|------------------------|-----------------------|--------------------|---------------|------------------|--|----------------------|
|  | Mass Units (lbs/day) <sup>(1)</sup> |                        | Concentrations (mg/L) |                    |               |                  | Minimum <sup>(2)</sup> Measurement Frequency | Required Sample Type |
|  | Average Monthly                     | Average Weekly         | Minimum               | Average Monthly    | Daily Maximum | Instant. Maximum |  |                      |
| Flow (MGD)                                     | Report                              | Report Daily Max       | XXX                   | XXX                | XXX           | XXX              | Continuous                                   | Measured             |
| pH (S.U.)                                      | XXX                                 | XXX                    | 6.0<br>Inst Min       | XXX                | XXX           | 9.0              | 5/week                                       | Grab                 |
| Dissolved Oxygen                               | XXX                                 | XXX                    | 5.0<br>Inst Min       | XXX                | XXX           | XXX              | 5/week                                       | Grab                 |
| Total Residual Chlorine (TRC)                  | XXX                                 | XXX                    | XXX                   | 0.5                | XXX           | 1.6              | 5/week                                       | Grab                 |
| Carbonaceous Biochemical Oxygen Demand (CBOD5) | XXX                                 | XXX                    | XXX                   | 25                 | XXX           | 50               | 2/month                                      | 8-Hr Composite       |
| Total Suspended Solids                         | XXX                                 | XXX                    | XXX                   | 30                 | XXX           | 60               | 2/month                                      | 8-Hr Composite       |
| Fecal Coliform (No./100 ml)<br>Oct 1 - Apr 30  | XXX                                 | XXX                    | XXX                   | 2000<br>Geo Mean   | XXX           | 10000            | 2/month                                      | Grab                 |
| Fecal Coliform (No./100 ml)<br>May 1 - Sep 30  | XXX                                 | XXX                    | XXX                   | 200<br>Geo Mean    | XXX           | 1000             | 2/month                                      | Grab                 |
| E. Coli (No./100 ml)                           | XXX                                 | XXX                    | XXX                   | XXX                | Report        | XXX              | 1/year                                       | Grab                 |
| Nitrate-Nitrite as N                           | XXX                                 | XXX                    | XXX                   | Report<br>Annl Avg | XXX           | XXX              | 1/year                                       | 8-Hr Composite       |
| Total Nitrogen (Total Load, lbs)<br>(lbs)      | XXX                                 | Report<br>Total Annual | XXX                   | XXX                | XXX           | XXX              | 1/year                                       | Calculation          |

Outfall001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter               | Effluent Limitations                |                        |                       |                    |               |                  | Monitoring Requirements                      |                      |
|-------------------------|-------------------------------------|------------------------|-----------------------|--------------------|---------------|------------------|--|----------------------|
|                         | Mass Units (lbs/day) <sup>(1)</sup> |                        | Concentrations (mg/L) |                    |               |                  | Minimum <sup>(2)</sup> Measurement Frequency | Required Sample Type |
|                         | Average Monthly                     | Average Weekly         | Minimum               | Average Monthly    | Daily Maximum | Instant. Maximum |  |                      |
| Ammonia-Nitrogen        | XXX                                 | XXX                    | XXX                   | Report<br>Annl Avg | XXX           | XXX              | 1/year                                       | 8-Hr Composite       |
| Total Kjeldahl Nitrogen | XXX                                 | XXX                    | XXX                   | Report<br>Annl Avg | XXX           | XXX              | 1/year                                       | 8-Hr Composite       |
| Total Phosphorus        | XXX                                 | Report<br>Total Annual | XXX                   | Report<br>Annl Avg | XXX           | XXX              | 1/year                                       | 8-Hr Composite       |

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

**6.3.2 Summary of Proposed Permit Part C Conditions**

The subject facility has the following Part C conditions.

- Chlorine Minimization
- Hauled-in Waste Restrictions
- Chesapeake Bay Nutrient Definitions
- Solids Management for Non-Lagoon Treatment Systems



# Attachment A

## Stream Stats/Gauge Data

14 Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania

Table 1. List of U.S. Geological Survey streamgage locations in and near Pennsylvania with updated streamflow statistics.—Continued

[Latitude and Longitude in decimal degrees; mi<sup>2</sup>, square miles]

| Streamgage number | Streamgage name   | Latitude | Longitude | Drainage area (mi <sup>2</sup> ) | Regulated <sup>1</sup> |
|-------------------|---|----------|-----------|----------------------------------|------------------------|
| 01561000          | Brush Creek at Gapsville, Pa.                                   | 39.956   | -78.254   | 36.8                             | N                      |
| 01562000          | Raystown Branch Juniata River at Saxton, Pa.                    | 40.216   | -78.265   | 756                              | N                      |
| 01562500          | Great Trough Creek near Marklesburg, Pa.                        | 40.350   | -78.130   | 84.6                             | N                      |
| 01563200          | Raystown Branch Juniata River below Rays Dam nr Huntingdon, Pa. | 40.429   | -77.991   | 960                              | Y                      |
| 01563500          | Juniata River at Mapleton Depot, Pa.                            | 40.392   | -77.935   | 2,030                            | Y                      |
| 01564500          | Aughwick Creek near Three Springs, Pa.                          | 40.213   | -77.925   | 205                              | N                      |
| 01565000          | Kishacoquillas Creek at Reedsville, Pa.                         | 40.655   | -77.583   | 164                              | N                      |
| 01565700          | Little Lost Creek at Oakland Mills, Pa.                         | 40.605   | -77.311   | 6.52                             | N                      |
| 01566000          | Tuscarora Creek near Port Royal, Pa.                            | 40.515   | -77.419   | 214                              | N                      |
| 01566500          | Cocolamus Creek near Millerstown, Pa.                           | 40.566   | -77.118   | 57.2                             | N                      |
| 01567000          | Juniata River at Newport, Pa.                                   | 40.478   | -77.129   | 3,354                            | Y                      |
| 01567500          | Bixler Run near Loysville, Pa.                                  | 40.371   | -77.402   | 15.0                             | N                      |
| 01568000          | Sherman Creek at Shermans Dale, Pa.                             | 40.323   | -77.169   | 207                              | N                      |
| 01568500          | Clark Creek near Carsonville, Pa.                               | 40.460   | -76.751   | 22.5                             | LF                     |
| 01569000          | Stony Creek nr Dauphin, Pa.                                     | 40.380   | -76.907   | 33.2                             | N                      |
| 01569800          | Letort Spring Run near Carlisle, Pa.                            | 40.235   | -77.139   | 21.6                             | N                      |
| 01570000          | Conodoguinet Creek near Hogestown, Pa.                          | 40.252   | -77.021   | 470                              | LF                     |
| 01570500          | Susquehanna River at Harrisburg, Pa.                            | 40.255   | -76.886   | 24,100                           | Y                      |
| 01571000          | Paxton Creek near Penbrook, Pa.                                 | 40.308   | -76.850   | 11.2                             | N                      |
| 01571500          | Yellow Breeches Creek near Camp Hill, Pa.                       | 40.225   | -76.898   | 213                              | N                      |
| 01572000          | Lower Little Swatara Creek at Pine Grove, Pa.                   | 40.538   | -76.377   | 34.3                             | N                      |
| 01572025          | Swatara Creek near Pine Grove, Pa.                              | 40.533   | -76.402   | 116                              | N                      |
| 01572190          | Swatara Creek near Inwood, Pa.                                  | 40.479   | -76.531   | 167                              | N                      |
| 01573000          | Swatara Creek at Harper Tavern, Pa.                             | 40.403   | -76.577   | 337                              | N                      |
| 01573086          | Beck Creek near Cleona, Pa.                                     | 40.323   | -76.483   | 7.87                             | N                      |
| 01573160          | Quittapahilla Creek near Belle Grove, Pa.                       | 40.343   | -76.562   | 74.2                             | N                      |
| 01573500          | Manada Creek at Manada Gap, Pa.                                 | 40.397   | -76.709   | 13.5                             | N                      |
| 01573560          | Swatara Creek near Hershey, Pa.                                 | 40.298   | -76.668   | 483                              | N                      |
| 01574000          | West Conewago Creek near Manchester, Pa.                        | 40.082   | -76.720   | 510                              | N                      |
| 01574500          | Codorus Creek at Spring Grove, Pa.                              | 39.879   | -76.853   | 75.5                             | Y                      |
| 01575000          | South Branch Codorus Creek near York, Pa.                       | 39.921   | -76.749   | 117                              | Y                      |
| 01575500          | Codorus Creek near York, Pa.                                    | 39.946   | -76.755   | 222                              | Y                      |
| 01576000          | Susquehanna River at Marietta, Pa.                              | 40.055   | -76.531   | 25,990                           | Y                      |
| 01576085          | Little Conestoga Creek near Churchtown, Pa.                     | 40.145   | -75.989   | 5.82                             | N                      |
| 01576500          | Conestoga River at Lancaster, Pa.                               | 40.050   | -76.277   | 324                              | N                      |
| 01576754          | Conestoga River at Conestoga, Pa.                               | 39.946   | -76.368   | 470                              | N                      |
| 01578310          | Susquehanna River at Conowingo, Md.                             | 39.658   | -76.174   | 27,100                           | Y                      |
| 01578400          | Bowery Run near Quarryville, Pa.                                | 39.895   | -76.114   | 5.98                             | N                      |
| 01580000          | Deer Creek at Rocks, Md.  | 39.630   | -76.403   | 94.4                             | N                      |
| 01581500          | Bynum Run at Bel Air, Md.                                       | 39.541   | -76.330   | 8.52                             | N                      |
| 01581700          | Winters Run near Benson, Md.                                    | 39.520   | -76.373   | 34.8                             | N                      |
| 01582000          | Little Falls at Blue Mount, Md.                                 | 39.604   | -76.620   | 52.9                             | N                      |
| 01582500          | Gunpowder Falls at Glencoe, Md.                                 | 39.550   | -76.636   | 160                              | Y                      |
| 01583000          | Slade Run near Glyndon, Md.                                     | 39.495   | -76.795   | 2.09                             | N                      |
| 01583100          | Piney Run at Dover, Md.   | 39.521   | -76.767   | 12.3                             | N                      |

26 Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania


Table 2. Selected low-flow statistics for streamgage locations in and near Pennsylvania.—Continued

[ft<sup>3</sup>/s; cubic feet per second; —, statistic not computed; <, less than]


| Streamgage number | Period of record used in analysis <sup>1</sup> | Number of years used in analysis | 1-day, 10-year (ft <sup>3</sup> /s) | 7-day, 10-year (ft <sup>3</sup> /s) | 7-day, 2-year (ft <sup>3</sup> /s) | 30-day, 10-year (ft <sup>3</sup> /s) | 30-day, 2-year (ft <sup>3</sup> /s) | 90-day, 10-year (ft <sup>3</sup> /s) |
|-------------------|--|----------------------------------|-------------------------------------|-------------------------------------|------------------------------------|--------------------------------------|-------------------------------------|--------------------------------------|
| 01546000          | 1912–1934                                      | 17                               | 1.8                                 | 2.2                                 | 6.8                                | 3.7                                  | 12.1                                | 11.2                                 |
| 01546400          | 1986–2008                                      | 23                               | 13.5                                | 14.0                                | 19.6                               | 15.4                                 | 22.3                                | 18.7                                 |
| 01546500          | 1942–2008                                      | 67                               | 26.8                                | 29.0                                | 41.3                               | 31.2                                 | 44.2                                | 33.7                                 |
| 01547100          | 1969–2008                                      | 40                               | 102                                 | 105                                 | 128                                | 111                                  | 133                                 | 117                                  |
| 01547200          | 1957–2008                                      | 52                               | 99.4                                | 101                                 | 132                                | 106                                  | 142                                 | 115                                  |
| 01547500          | <sup>2</sup> 1971–2008                         | 38                               | 28.2                                | 109                                 | 151                                | 131                                  | 172                                 | 153                                  |
| 01547500          | <sup>3</sup> 1956–1969                         | 14                               | 90.0                                | 94.9                                | 123                                | 98.1                                 | 131                                 | 105                                  |
| 01547700          | 1957–2008                                      | 52                               | .5                                  | .6                                  | 2.7                                | 1.1                                  | 3.9                                 | 2.2                                  |
| 01547800          | 1971–1981                                      | 11                               | 1.6                                 | 1.8                                 | 2.4                                | 2.1                                  | 2.9                                 | 3.5                                  |
| 01547950          | 1970–2008                                      | 39                               | 12.1                                | 13.6                                | 28.2                               | 17.3                                 | 36.4                                | 23.8                                 |
| 01548005          | <sup>2</sup> 1971–2000                         | 25                               | 142                                 | 151                                 | 206                                | 178                                  | 241                                 | 223                                  |
| 01548005          | <sup>3</sup> 1912–1969                         | 58                               | 105                                 | 114                                 | 147                                | 125                                  | 165                                 | 140                                  |
| 01548500          | 1920–2008                                      | 89                               | 21.2                                | 24.2                                | 50.1                               | 33.6                                 | 68.6                                | 49.3                                 |
| 01549000          | 1910–1920                                      | 11                               | 26.0                                | 32.9                                | 78.0                               | 46.4                                 | 106                                 | 89.8                                 |
| 01549500          | 1942–2008                                      | 67                               | .6                                  | .8                                  | 2.5                                | 1.4                                  | 3.9                                 | 2.6                                  |
| 01549700          | 1959–2008                                      | 50                               | 33.3                                | 37.2                                | 83.8                               | 51.2                                 | 117                                 | 78.4                                 |
| 01550000          | 1915–2008                                      | 94                               | 6.6                                 | 7.6                                 | 16.8                               | 11.2                                 | 24.6                                | 18.6                                 |
| 01551500          | <sup>2</sup> 1963–2008                         | 46                               | 520                                 | 578                                 | 1,020                              | 678                                  | 1,330                               | 919                                  |
| 01551500          | <sup>3</sup> 1901–1961                         | 61                               | 400                                 | 439                                 | 742                                | 523                                  | 943                                 | 752                                  |
| 01552000          | 1927–2008                                      | 80                               | 20.5                                | 22.2                                | 49.5                               | 29.2                                 | 69.8                                | 49.6                                 |
| 01552500          | 1942–2008                                      | 67                               | .9                                  | 1.2                                 | 3.1                                | 1.7                                  | 4.4                                 | 3.3                                  |
| 01553130          | 1969–1981                                      | 13                               | 1.0                                 | 1.1                                 | 1.5                                | 1.3                                  | 1.8                                 | 1.7                                  |
| 01553500          | <sup>2</sup> 1968–2008                         | 41                               | 760                                 | 838                                 | 1,440                              | 1,000                                | 1,850                               | 1,470                                |
| 01553500          | <sup>3</sup> 1941–1966                         | 26                               | 562                                 | 619                                 | 880                                | 690                                  | 1,090                               | 881                                  |
| 01553700          | 1981–2008                                      | 28                               | 9.1                                 | 10.9                                | 15.0                               | 12.6                                 | 17.1                                | 15.2                                 |
| 01554000          | <sup>2</sup> 1981–2008                         | 28                               | 1,830                               | 1,990                               | 3,270                              | 2,320                                | 4,210                               | 3,160                                |
| 01554000          | <sup>3</sup> 1939–1979                         | 41                               | 1,560                               | 1,630                               | 2,870                              | 1,880                                | 3,620                               | 2,570                                |
| 01554500          | 1941–1993                                      | 53                               | 16.2                                | 22.0                                | 31.2                               | 25.9                                 | 35.7                                | 31.4                                 |
| 01555000          | 1931–2008                                      | 78                               | 33.5                                | 37.6                                | 58.8                               | 43.4                                 | 69.6                                | 54.6                                 |
| 01555500          | 1931–2008                                      | 78                               | 4.9                                 | 6.5                                 | 18.0                               | 9.4                                  | 24.3                                | 16.6                                 |
| 01556000          | 1918–2008                                      | 91                               | 43.3                                | 47.8                                | 66.0                               | 55.1                                 | 75.0                                | 63.7                                 |
| 01557500          | 1946–2008                                      | 63                               | 2.8                                 | 3.2                                 | 6.3                                | 4.2                                  | 8.1                                 | 5.8                                  |
| 01558000          | 1940–2008                                      | 69                               | 56.3                                | 59.0                                | 79.8                               | 65.7                                 | 86.2                                | 73.7                                 |
| 01559000          | 1943–2008                                      | 66                               | 104                                 | 177                                 | 249                                | 198                                  | 279                                 | 227                                  |
| 01559500          | 1931–1958                                      | 28                               | 9.3                                 | 10.5                                | 15.0                               | 12.4                                 | 17.8                                | 15.8                                 |
| 01559700          | 1963–1978                                      | 16                               | .1                                  | .1                                  | .2                                 | .1                                   | .3                                  | .2                                   |
| 01560000          | 1941–2008                                      | 68                               | 8.5                                 | 9.4                                 | 15.6                               | 12.0                                 | 20.2                                | 16.2                                 |
| 01561000          | 1932–1958                                      | 27                               | 4                                   | .5                                  | 1.6                                | .8                                   | 2.5                                 | 1.7                                  |
| 01562000          | 1913–2008                                      | 96                               | 64.1                                | 67.1                                | 106                                | 77.4                                 | 122                                 | 94.5                                 |
| 01562500          | 1931–1957                                      | 27                               | 1.1                                 | 1.6                                 | 3.8                                | 2.3                                  | 5.4                                 | 3.7                                  |
| 01563200          | <sup>2</sup> 1974–2008                         | 35                               | —                                   | —                                   | —                                  | 112                                  | 266                                 | 129                                  |
| 01563200          | <sup>3</sup> 1948–1972                         | 25                               | 10.3                                | 28.2                                | 86.1                               | 64.5                                 | 113                                 | 95.5                                 |
| 01563500          | <sup>2</sup> 1974–2008                         | 35                               | 384                                 | 415                                 | 519                                | 441                                  | 580                                 | 493                                  |
| 01563500          | <sup>3</sup> 1939–1972                         | 34                               | 153                                 | 242                                 | 343                                | 278                                  | 399                                 | 333                                  |
| 01564500          | 1940–2008                                      | 69                               | 3.6                                 | 4.2                                 | 10.0                               | 6.2                                  | 14.4                                | 10.6                                 |


## StreamStats Report

Region ID: PA  
Workspace ID: PA20230922174343132000  
Clicked Point (Latitude, Longitude): 40.01212, -78.32668  
Time: 2023-09-22 13:44:09 -0400



Riverview Estates PA0083569 Modeling Point #1 September 2023

 Collapse All

 Basin Characteristics

➤ Basin Characteristics

| Parameter Code | Parameter Description  | Value | Unit                  |
|----------------|--|-------|-----------------------|
| CARBON         | Percentage of area of carbonate rock                               | 14.92 | percent               |
| DRNAREA        | Area that drains to a point on a stream                            | 454   | square miles          |
| PRECIP         | Mean Annual Precipitation  | 38    | inches                |
| ROCKDEP        | Depth to rock  | 4.2   | feet                  |
| STRDEN         | Stream Density -- total length of streams divided by drainage area | 2.4   | miles per square mile |

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [99.9 Percent (453 square miles) Low Flow Region 2]

| Parameter Code | Parameter Name            | Value | Units                 | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| DRNAREA        | Drainage Area             | 454   | square miles          | 4.93      | 1280      |
| PRECIP         | Mean Annual Precipitation | 38    | inches                | 35        | 50.4      |
| STRDEN         | Stream Density            | 2.4   | miles per square mile | 0.51      | 3.1       |
| ROCKDEP        | Depth to Rock             | 4.2   | feet                  | 3.32      | 5.65      |
| CARBON         | Percent Carbonate         | 14.92 | percent               | 0         | 99        |

Low-Flow Statistics Flow Report [99.9 Percent (453 square miles) Low Flow Region 2]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

| Statistic                          | Value         | Unit                       | SE       | ASEp       |
|------------------------------------|---------------|----------------------------|----------|------------|
| 7 Day 2 Year Low Flow<br>Statistic | 41.9<br>Value | ft <sup>3</sup> /s<br>Unit | 38<br>SE | 38<br>ASEp |

| 7 Day 2 Year Low Flow<br>Statistic | 41.9<br>Value | ft <sup>3</sup> /s<br>Unit | 38<br>SE | 38<br>ASEp |
|------------------------------------|---------------|----------------------------|----------|------------|
| 30 Day 2 Year Low Flow             | 55.1          | ft <sup>3</sup> /s         | 33       | 33         |
| 7 Day 10 Year Low Flow             | 22.1          | ft <sup>3</sup> /s         | 51       | 51         |
| 30 Day 10 Year Low Flow            | 29.6          | ft <sup>3</sup> /s         | 46       | 46         |
| 90 Day 10 Year Low Flow            | 43.2          | ft <sup>3</sup> /s         | 36       | 36         |

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.


Application Version: 4.17.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


## StreamStats Report

Region ID: PA  
Workspace ID: PA20230922173832333000  
Clicked Point (Latitude, Longitude): 40.00589, -78.30900  
Time: 2023-09-22 13:38:58 -0400



Riverview Estates PA0083569 Modeling Point #2 September 2023

 Collapse All

 Basin Characteristics

➤ Basin Characteristics

| Parameter Code | Parameter Description  | Value | Unit                  |
|----------------|--|-------|-----------------------|
| CARBON         | Percentage of area of carbonate rock                               | 14.72 | percent               |
| DRNAREA        | Area that drains to a point on a stream                            | 460   | square miles          |
| PRECIP         | Mean Annual Precipitation  | 38    | inches                |
| ROCKDEP        | Depth to rock  | 4.2   | feet                  |
| STRDEN         | Stream Density -- total length of streams divided by drainage area | 2.39  | miles per square mile |

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [99.9 Percent (460 square miles) Low Flow Region 2]

| Parameter Code | Parameter Name            | Value | Units                 | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| DRNAREA        | Drainage Area             | 460   | square miles          | 4.93      | 1280      |
| PRECIP         | Mean Annual Precipitation | 38    | inches                | 35        | 50.4      |
| STRDEN         | Stream Density            | 2.39  | miles per square mile | 0.51      | 3.1       |
| ROCKDEP        | Depth to Rock             | 4.2   | feet                  | 3.32      | 5.65      |
| CARBON         | Percent Carbonate         | 14.72 | percent               | 0         | 99        |

Low-Flow Statistics Flow Report [99.9 Percent (460 square miles) Low Flow Region 2]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

| Statistic                          | Value         | Unit                       | SE       | ASEp       |
|------------------------------------|---------------|----------------------------|----------|------------|
| 7 Day 2 Year Low Flow<br>Statistic | 42.5<br>Value | ft <sup>3</sup> /s<br>Unit | 38<br>SE | 38<br>ASEp |



| 7 Day 2 Year Low Flow<br>Statistic | 42.5<br>Value | ft <sup>3</sup> /s<br>Unit | 33<br>SE | 33<br>ASEp |
|------------------------------------|---------------|----------------------------|----------|------------|
| 30 Day 2 Year Low Flow             | 56            | ft <sup>3</sup> /s         | 33       | 33         |
| 7 Day 10 Year Low Flow             | 22.5          | ft <sup>3</sup> /s         | 51       | 51         |
| 30 Day 10 Year Low Flow            | 30.1          | ft <sup>3</sup> /s         | 46       | 46         |
| 90 Day 10 Year Low Flow            | 44            | ft <sup>3</sup> /s         | 36       | 36         |

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.17.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

# Attachment B

## WQM 7.0 Modeling Output Values

**WQM 7.0 Effluent Limits**

| <u>SWP Basin</u> |           | <u>Stream Code</u> |                 | <u>Stream Name</u>            |                                |                            |                            |
|------------------|-----------|--------------------|-----------------|-------------------------------|--------------------------------|----------------------------|----------------------------|
| 11D              |           | 13349              |                 | RAYSTOWN BRANCH JUNIATA RIVER |                                |                            |                            |
| RMI              | Name      | Permit Number      | Disc Flow (mgd) | Parameter                     | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 75.500           | Riverview | PA0083569          | 0.015           | CBOD5                         | 25                             |                            |                            |
|                  |           |                    |                 | NH3-N                         | 25                             | 50                         |                            |
|                  |           |                    |                 | Dissolved Oxygen              |                                |                            | 5                          |

### WQM 7.0 Wasteload Allocations

|                  |                    |                               |
|------------------|--------------------|-------------------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u>            |
| 11D              | 13349              | RAYSTOWN BRANCH JUNIATA RIVER |

**NH3-N Acute Allocations**

| RMI    | Discharge Name | Baseline<br>Criterion<br>(mg/L) | Baseline<br>WLA<br>(mg/L) | Multiple<br>Criterion<br>(mg/L) | Multiple<br>WLA<br>(mg/L) | Critical<br>Reach | Percent<br>Reduction |
|--------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 75.500 | Riverview      | 2.98                            | 50                        | 2.98                            | 50                        | 0                 | 0                    |

**NH3-N Chronic Allocations**

| RMI    | Discharge Name | Baseline<br>Criterion<br>(mg/L) | Baseline<br>WLA<br>(mg/L) | Multiple<br>Criterion<br>(mg/L) | Multiple<br>WLA<br>(mg/L) | Critical<br>Reach | Percent<br>Reduction |
|--------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 75.500 | Riverview      | .63                             | 25                        | .63                             | 25                        | 0                 | 0                    |

**Dissolved Oxygen Allocations**

| RMI   | Discharge Name | <u>CBOD5</u>       |                    | <u>NH3-N</u>       |                    | <u>Dissolved Oxygen</u> |                    | Critical<br>Reach | Percent<br>Reduction |
|-------|----------------|--------------------|--------------------|--------------------|--------------------|-------------------------|--------------------|-------------------|----------------------|
|       |                | Baseline<br>(mg/L) | Multiple<br>(mg/L) | Baseline<br>(mg/L) | Multiple<br>(mg/L) | Baseline<br>(mg/L)      | Multiple<br>(mg/L) |                   |                      |
| 75.50 | Riverview      | 25                 | 25                 | 25                 | 25                 | 5                       | 5                  | 0                 | 0                    |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name                 | RMI    | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC                            |
|-----------|-------------|-----------------------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 11D       | 13349       | RAYSTOWN BRANCH JUNIATA RIV | 75.500 | 975.00         | 454.00                | 0.00000       | 0.00                 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary |      | Stream    |      |
|--------------|------------|-----------------|-------------------|----------------------|--------------------|----------|----------------|----------------|-----------|------|-----------|------|
|              |            |                 |                   |                      |                    |          |                |                | Temp (°C) | pH   | Temp (°C) | pH   |
| Q7-10        | 0.089      | 0.00            | 0.00              | 0.000                | 0.000              | 0.0      | 0.00           | 0.00           | 23.30     | 8.00 | 0.00      | 0.00 |
| Q1-10        |            | 0.00            | 0.00              | 0.000                | 0.000              |          |                |                |           |      |           |      |
| Q30-10       |            | 0.00            | 0.00              | 0.000                | 0.000              |          |                |                |           |      |           |      |

Discharge Data

| Name      | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-----------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Riverview | PA0083569     | 0.0150                   | 0.0150                    | 0.0150                 | 0.000          | 25.00          | 7.15    |

Parameter Data

| Parameter Name   | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5            | 25.00            | 2.00             | 0.00               | 1.50               |
| Dissolved Oxygen | 5.00             | 8.24             | 0.00               | 0.00               |
| NH3-N            | 25.00            | 0.00             | 0.00               | 0.70               |

**Input Data WQM 7.0**

| SWP Basin | Stream Code | Stream Name                 | RMI    | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC                            |
|-----------|-------------|-----------------------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 11D       | 13349       | RAYSTOWN BRANCH JUNIATA RIV | 74.350 | 970.00         | 460.00                | 0.00000       | 0.00                 | <input checked="" type="checkbox"/> |

**Stream Data**

| Design Cond. | LFY    | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary |      | Stream    |      |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
|              | (cfsm) | (cfs)     | (cfs)       | (days)        | (fps)        |          | (ft)      | (ft)      | Temp (°C) | pH   | Temp (°C) | pH   |
| Q7-10        | 0.089  | 0.00      | 0.00        | 0.000         | 0.000        | 0.0      | 0.00      | 0.00      | 23.30     | 8.00 | 0.00      | 0.00 |
| Q1-10        |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |           |      |           |      |
| Q30-10       |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |           |      |           |      |

| Discharge Data |               |                          |                           |                        |                |                |         |
|----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Name           | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|                |               | 0.0000                   | 0.0000                    | 0.0000                 | 0.000          | 25.00          | 7.00    |

| Parameter Data   |                  |                  |                    |                    |
|------------------|------------------|------------------|--------------------|--------------------|
| Parameter Name   | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
| CBOD5            | 25.00            | 2.00             | 0.00               | 1.50               |
| Dissolved Oxygen | 3.00             | 8.24             | 0.00               | 0.00               |
| NH3-N            | 25.00            | 0.00             | 0.00               | 0.70               |

### WQM 7.0 D.O. Simulation

| <u>SWP Basin</u>                | <u>Stream Code</u>                | <u>Stream Name</u>               |                             |                    |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|--------------------|
| 11D                             | 13349                             | RAYSTOWN BRANCH JUNIATA RIVER    |                             |                    |
| <hr/>                           |                                   |                                  |                             |                    |
| <u>RMI</u>                      | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u>          |                    |
| 75.500                          | 0.015                             | 23.301                           | 7.998                       |                    |
| <u>Reach Width (ft)</u>         | <u>Reach Depth (ft)</u>           | <u>Reach WDRatio</u>             | <u>Reach Velocity (fps)</u> |                    |
| 108.576                         | 0.995                             | 109.094                          | 0.373                       |                    |
| <u>Reach CBOD5 (mg/L)</u>       | <u>Reach Kc (1/days)</u>          | <u>Reach NH3-N (mg/L)</u>        | <u>Reach Kn (1/days)</u>    |                    |
| 2.01                            | 0.009                             | 0.01                             | 0.902                       |                    |
| <u>Reach DO (mg/L)</u>          | <u>Reach Kr (1/days)</u>          | <u>Kr Equation</u>               | <u>Reach DO Goal (mg/L)</u> |                    |
| 8.241                           | 1.551                             | Tsivoglou                        | 5                           |                    |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u>           |                                  |                             |                    |
| 0.188                           | <u>TravTime (days)</u>            | <u>CBOD5 (mg/L)</u>              | <u>NH3-N (mg/L)</u>         | <u>D.O. (mg/L)</u> |
|                                 | 0.019                             | 2.01                             | 0.01                        | 7.76               |
|                                 | 0.038                             | 2.01                             | 0.01                        | 7.76               |
|                                 | 0.056                             | 2.01                             | 0.01                        | 7.76               |
|                                 | 0.075                             | 2.01                             | 0.01                        | 7.76               |
|                                 | 0.094                             | 2.01                             | 0.01                        | 7.76               |
|                                 | 0.113                             | 2.01                             | 0.01                        | 7.76               |
|                                 | 0.132                             | 2.01                             | 0.01                        | 7.76               |
|                                 | 0.151                             | 2.01                             | 0.01                        | 7.76               |
|                                 | 0.169                             | 2.01                             | 0.01                        | 7.76               |
|                                 | 0.188                             | 2.01                             | 0.01                        | 7.76               |

### WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u>   |                      | <u>Stream Code</u> |                          |                             |                        | <u>Stream Name</u>            |               |           |                   |                           |                       |             |
|--------------------|----------------------|--------------------|--------------------------|-----------------------------|------------------------|-------------------------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| 11D                |                      | 13349              |                          |                             |                        | RAYSTOWN BRANCH JUNIATA RIVER |               |           |                   |                           |                       |             |
| RMI                | Stream Flow<br>(cfs) | PWS With<br>(cfs)  | Net Stream Flow<br>(cfs) | Disc Analysis Flow<br>(cfs) | Reach Slope<br>(ft/ft) | Depth<br>(ft)                 | Width<br>(ft) | W/D Ratio | Velocity<br>(fps) | Reach Trav Time<br>(days) | Analysis Temp<br>(°C) | Analysis pH |
| <b>Q7-10 Flow</b>  |                      |                    |                          |                             |                        |                               |               |           |                   |                           |                       |             |
| 75.500             | 40.32                | 0.00               | 40.32                    | .0232                       | 0.00082                | .995                          | 108.58        | 109.09    | 0.37              | 0.188                     | 23.30                 | 8.00        |
| <b>Q1-10 Flow</b>  |                      |                    |                          |                             |                        |                               |               |           |                   |                           |                       |             |
| 75.500             | 38.70                | 0.00               | 38.70                    | .0232                       | 0.00082                | NA                            | NA            | NA        | 0.36              | 0.193                     | 23.30                 | 8.00        |
| <b>Q30-10 Flow</b> |                      |                    |                          |                             |                        |                               |               |           |                   |                           |                       |             |
| 75.500             | 46.36                | 0.00               | 46.36                    | .0232                       | 0.00082                | NA                            | NA            | NA        | 0.40              | 0.174                     | 23.30                 | 8.00        |



### WQM 7.0 Modeling Specifications

|                    |        |                                     |                                     |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters         | Both   | Use Inputted Q1-10 and Q30-10 Flows | <input type="checkbox"/>            |
| WLA Method         | EMPR   | Use Inputted W/D Ratio              | <input type="checkbox"/>            |
| Q1-10/Q7-10 Ratio  | 0.96   | Use Inputted Reach Travel Times     | <input type="checkbox"/>            |
| Q30-10/Q7-10 Ratio | 1.15   | Temperature Adjust Kr               | <input checked="" type="checkbox"/> |
| D.O. Saturation    | 90.00% | Use Balanced Technology             | <input checked="" type="checkbox"/> |
| D.O. Goal          | 5      |                                     |                                     |

# Attachment C

## TRC Evaluation

Riverview Estates  
PA0083569

October 2023

| 1A | B   | C  | D                             | E         | F                                    | G |
|----|---|--|-------------------------------|-----------|--------------------------------------|---|
| 2  | <b>TRC EVALUATION</b>                       |  |                               |           |                                      |   |
| 3  | Input appropriate values in B4:B8 and E4:E7 |  |                               |           |                                      |   |
| 4  | 40.29550265                                 | = Q stream (cfs)   |                               | 0.5       | = CV Daily                           |   |
| 5  | 0.015                                       | = Q discharge (MGD)  |                               | 0.5       | = CV Hourly                          |   |
| 6  | 30  | = no. samples  |                               | 1         | = AFC_Partial Mix Factor             |   |
| 7  | 0.3   | = Chlorine Demand of Stream  |                               | 1         | = CFC_Partial Mix Factor             |   |
| 8  | 0   | = Chlorine Demand of Discharge   |                               | 15        | = AFC_Criteria Compliance Time (min) |   |
| 9  | 0.5   | = BAT/BPJ Value  |                               | 720       | = CFC_Criteria Compliance Time (min) |   |
|    | 0   | = % Factor of Safety (FOS)   |                               | 0         | = Decay Coefficient (K)              |   |
| 10 | Source                                      | Reference  | AFC Calculations              | Reference | CFC Calculations                     |   |
| 11 | TRC   | 1.3.2.iii  | WLA_afc = 553.963             | 1.3.2.iii | WLA_cfc = 540.063                    |   |
| 12 | PENTOXSD TRG                                | 5.1a   | LTAMULT_afc = 0.373           | 5.1c      | LTAMULT_cfc = 0.581                  |   |
| 13 | PENTOXSD TRG                                | 5.1b   | LTA_afc = 206.420             | 5.1d      | LTA_cfc = 313.967                    |   |
| 14 |   |  |                               |           |                                      |   |
| 15 | Source                                      | Effluent Limit Calculations  |                               |           |                                      |   |
| 16 | PENTOXSD TRG                                | 5.1f   | AML_MULT = 1.231              |           |                                      |   |
| 17 | PENTOXSD TRG                                | 5.1g   | AVG MON LIMIT (mg/l) = 0.500  |           | BAT/BPJ                              |   |
| 18 |   |  | INST MAX LIMIT (mg/l) = 1.635 |           |                                      |   |
|    | WLA_afc                                     | (.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...<br>...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) |                               |           |                                      |   |
|    | LTAMULT_afc                                 | EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)   |                               |           |                                      |   |
|    | LTA_afc                                     | wla_afc*LTAMULT_afc  |                               |           |                                      |   |
|    | WLA_cfc                                     | (.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...<br>...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) |                               |           |                                      |   |
|    | LTAMULT_cfc                                 | EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)                                     |                               |           |                                      |   |
|    | LTA_cfc                                     | wla_cfc*LTAMULT_cfc  |                               |           |                                      |   |
|    | AML_MULT                                    | EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))                                     |                               |           |                                      |   |
|    | AVG MON LIMIT                               | MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)   |                               |           |                                      |   |
|    | INST MAX LIMIT                              | 1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)  |                               |           |                                      |   |