

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0083836  
 APS ID 950064  
 Authorization ID 1422264

**Applicant and Facility Information**

Applicant Name	<u>Pine Run Management LLC</u>	Facility Name	<u>Pine Run MHP</u>
Applicant Address	<u>2846 Main Street, Suite 12A</u> <u>Morgantown, PA 19543-0677</u>	Facility Address	<u>1880 Pine Run Road</u> <u>Abbottstown, PA 17301-9723</u>
Applicant Contact	<u>James Perano</u>	Facility Contact	<u>James Perano</u>
Applicant Phone	<u>(610) 286-0490</u>	Facility Phone	<u>(610) 286-0490</u>
Client ID	<u>338199</u>	Site ID	<u>445322</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Hamilton Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Adams</u>
Date Application Received	<u>December 29, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 5, 2023</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal.</u>		

**Summary of Review**

The PA Department of Environmental Protection (DEP or Department) received an NPDES permit renewal application from Pine Run Management, LLC, located in Hamilton Township, Adams County on December 29, 2022. The permit expires on June 30, 2023.

The average annual design flow and hydraulic design capacity is 0.04 MGD and the organic loading capacity is 8.34 lbs BOD<sub>5</sub>/day. The treated effluent is discharged to an UNT to Conewago Creek. The contributing flow is 100% from the MHP.

The WQM Part II No. 0190401 A-1 amendment was issued on 5/3/2016, and 0190401 T-1 ownership transferred was issued on 6/29/2018.

Sludge use and disposal description and location(s): N/A because sludge hauling by Smiths Septic's contractor.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	May 12, 2023
X		<i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	May 26, 2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.04
Latitude	39° 55' 11.42"	Longitude	-76° 59' 18.00"
Quad Name	Abbottstown	Quad Code	1930
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Conewago Creek (WWF)	Stream Code	08303 (secondary)
NHD Com ID	57470973 / 57470779 (secondary)	RMI	0.11
Drainage Area	0.15 mi. <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.005
Q <sub>7-10</sub> Flow (cfs)	0.0008	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	420.33	Slope (ft/ft)	
Watershed No.	7-F	Chapter 93 Class.	WWF
Existing Use	none	Existing Use Qualifier	
Exceptions to Use	none	Exceptions to Criteria	
Assessment Status	See 303d Listed Streams note below		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Wrightsville Boro Water System, York County		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	28.51 miles	Distance from Outfall (mi)	Approximate 54.0 miles

Changes Since Last Permit Issuance: none

**Drainage Area**

The discharge is to Unnamed tributaries to Conewago Creek at RMI 0.11 miles. A drainage area upstream of the discharge is estimated to be 0.15 mi.<sup>2</sup>, according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

**Stream Flow**

According to StreamStats, the point of first use has a Q<sub>7-10</sub> of 0.0008 cfs and a drainage area of 0.15 mi.<sup>2</sup>, which results in a Q<sub>7-10</sub> low flow yield of 0.005 cfs/mi.<sup>2</sup>. This information is used to obtain a chronic or 30-day (Q<sub>30-10</sub>), and an acute or 1-day (Q<sub>1-10</sub>) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 0.0008 \text{ cfs} \\
 \text{Low Flow Yield} &= 0.0008 \text{ cfs} / 0.15 \text{ mi.}^2 = 0.005 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 0.0008 \text{ cfs} = 0.001 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.0008 \text{ cfs} = 0.0005 \text{ cfs}
 \end{aligned}$$

The resulting Q<sub>7-10</sub> dilution ratio is:  $Q_{\text{stream}} / Q_{\text{discharge}} = 0.0008 \text{ cfs} / [0.04 \text{ MGD} * (1.547 \text{ cfs/MGD})] = 0.013:1$

**303d Listed Streams**

The discharge from this facility is in UNT to Conewago Creek at 0.11 RMI which is not listed in eMapPA and stream health couldn't be assessed. The secondary receiving stream is Conewago Creek which is attaining Recreational use and Aquatic Life. The secondary stream is not on 303d list.

**Conewago Creek**

25 Pa. Code § 93.9o classifies Conewago Creek as Warm Water & Migratory Fishes (WWF & MF) surface water. Based on the 2022 Integrated Report, Conewago Creek, assessment unit IDs 11762 & 18584, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

**Public Water Supply**

The nearest downstream public water supply intake is for Wrightsville Boro Water System York County on the Susquehanna River, approximately 54.0 miles downstream of this discharge. Considering distance and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Pine Run MHP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
0190401 A-1		05/03/2016		
0190401 T-1		06/26/2018		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Activated Sludge	Ultraviolet	0.04
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.04	8.34	Not Overloaded	Aerobic Digestion	Land Application

Changes Since Last Permit Issuance: none

Other Comments:

Per DEP's recent visit to the WWTP on June 30, 2021, the treatment facility consists of the following units:

- One basket rack
- Four EQ tanks
- Eight aeration tanks
- Four clarifiers
- One chlorine contact tank, without chlorine addition
- One UV unit
- Two sludge holding tanks

A Point of First Use (POFU) survey was conducted on May 7, 1990 which stated, "The predominance of the stonefly and the Mayfly which emerge in the spring indicate that the stream may be intermittent or at least has extremely low or interstitial summer flows...Point of First Use is at the Point of Discharge."

Chemical used:

Aluminum Sulfate (Alum) is used to remove Phosphorus.

Compliance History	
<b>Summary of DMRs:</b>	A summary of past 12-month DMRs is presented on page 4 & 5.
<b>Summary of Inspections:</b>	<p><b>6/30/2021:</b> Mr. Bettinger, DEP's WQS, conducted compliance evaluation inspection. There were no violations noted during inspection. Recommendations were to ensure copies of all required DMR supplemental forms are retained on-site for a minimum of 3 years and recommend exploring options for an emergency power source. The field test results were within the permit limits.</p> <p><b>6/8/2020:</b> Mr. Bettinger, DEP's WQS, conducted administrative inspection. There were no violations noted during inspection.</p>
<b>Other Comments</b>	<p>There are five (5) open violations against the permittee or applicant.</p> <ul style="list-style-type: none"> <li>- 4/7/2023 (1): NPDES-Violation of effluent limits in Part A of permit.</li> <li>- 8/4/-10/24/2022 &amp; 2/10-5/3/2023 (4)-Safe Drinking Water- Exceeded the Chemical average maximum contaminant level.</li> </ul>

Other Comment:

- Ammonia concentration (mg/L) of monthly average on December 2022 was exceeded 5.38 mg/L, while permit limit of 4.5 mg/L period of November 1 – April 30.

Compliance History

DMR Data for Outfall 001 (from April 1, 2022 to March 31, 2023)

Parameter	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22
Flow (MGD) Average Monthly	0.0078	0.0059	0.008	0.011	0.01	0.006	0.006	0.007	0.007	0.007	0.01	0.008
Flow (MGD) Daily Maximum	0.0312	0.017	0.02	0.052	0.03	0.013	0.023	0.012	0.019	0.013	0.043	0.022
pH (S.U.) Daily Minimum	7.17	7.07	6.93	7.07	6.64	6.96	5.82	6.07	6.42	6.99	7.08	6.89
pH (S.U.) Daily Maximum	7.98	8.24	8.13	7.96	8.31	7.69	8.29	8.37	7.79	8.48	7.86	7.93
DO (mg/L) Daily Minimum	7.75	7.25	7.45	7.17	6.33	7.72	6.92	6.65	5.86	6.79	7.12	6.98
CBOD5 (mg/L) Average Monthly	< 2.6	2.4	< 3.2	< 2.9	< 2.4	< 2.4	< 2.6	< 2.4	< 2.4	< 2.7	< 2.4	< 2.6
TSS (mg/L) Average Monthly	8.0	5.0	7.0	5.0	4.0	3.0	2.0	1.0	4.0	6.0	1.0	6.0
Fecal Coliform (No./100 ml) Geometric Mean	11	1120	49	264	< 1	< 1	< 1	< 1	< 2	< 1	< 1	< 1
Fecal Coliform (No./100 ml) IMAX	33	1120	> 2420	1553	< 1	1	2	< 1	3	< 1	< 1	2
UV Intensity (mW/cm <sup>2</sup> ) Daily Minimum	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.9	0.2	0.1
Nitrate-Nitrite (mg/L) Average Quarterly	< 29.4			< 39.4			< 41.4			< 34.4		
Nitrate-Nitrite (lbs) Total Quarterly	< 129			< 31			< 86			< 189		
Total Nitrogen (mg/L) Average Quarterly	29			39			41			34		
Total Nitrogen (lbs) Total Quarterly	127			30			85			187		
Total Nitrogen (lbs) Total Annual							352					
Ammonia (mg/L) Average Monthly	< 0.6	< 0.1	< 0.18	5.38	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	2.43
Ammonia (mg/L) Average Quarterly	< 0.18			< 0.1			< 0.1			2.43		
Ammonia (lbs) Total Quarterly	< 0.4			< 0.1			< 0.2			5.0		

**NPDES Permit Fact Sheet**  
**Pine Run MHP**

**NPDES Permit No. PA0083836**

Ammonia (lbs) Total Annual							18					
TKN (mg/L) Average Quarterly	< 0.5			< 0.5			< 0.5			< 0.5		
TKN (lbs) Total Quarterly	< 2			< 0.4			< 1			< 3		
Total Phosphorus (mg/L) Average Quarterly	0.26			0.33			0.11			0.32		
Total Phosphorus (lbs) Total Quarterly	1			0.3			0.2			2		
Total Phosphorus (lbs) Total Annual							4					

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.04</u>
<b>Latitude</b> <u>39° 55' 11.42"</u>	<b>Longitude</b> <u>-76° 59' 18.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Total Residual Chlorine is not applied to this facility.

**Water Quality-Based Limitations**

**Ammonia (NH<sub>3</sub>-N):**

NH<sub>3</sub>N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached WQM 7.0 computer model of the stream:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	20°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	25°C	(Default)
*	Background NH <sub>3</sub> -N	=	0 mg/L	(Default)

Regarding NH<sub>3</sub>-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 1.91 mg/L as monthly average (AML) and 3.82 mg/L as instantaneous maximum (IMAX) limit during summer to protect water quality standards. However, the existing limits of 1.5 mg/L as AML and 3.0 mg/L as IMAX are more stringent and will remain in the proposed permit. Winter limits are calculated by multiplying summer limits with a factor of 3. The minimum monitoring frequency will also remain the same as 2/month.

**Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>):**

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. The IMAX limit is 50.0 mg/L. These values are the same as are in existing permit. The minimum monitoring frequency will remain the same as 2/month.

**pH:**

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

**UV:**

The UV system daily monitor and report the UV light intensity (mW/cm<sup>2</sup>) will remain in the proposed permit.

**Total Suspended Solids (TSS):**

There is no water quality criterion for TSS. The existing limits of 30.0 mg/L average monthly and 60.0 mg/L instantaneous maximum will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment, 25 Pa. Code § 92a.47 and 40CFR 133.102(b). The minimum monitoring frequency will remain the same as 2/month.

**Dissolved Oxygen (D.O.):**

The D.O. goal is 6.0 mg/L. However, a minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BCW-PMT-033, version 1.9 revised March 22, 2021, and has been applied to other point source dischargers throughout the state.

**Fecal Coliform:**

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

**E. Coli:**

As recommended by DEP's SOP No. BCW-PMT-033, version 1.9 revised March 22, 2021, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

**Toxics:**

DEP utilizes a Toxics Management Spreadsheet (last modified on March 2021 ver. 1.3) to facilitate calculations necessary for completing a reasonable potential analysis and determining WQBELs for toxic pollutants. The effluent testing information renewal application (page # 7) indicates that there are no toxic pollutants of concern.

**Total Phosphorus:**

Phosphorus limitations are based on the Department's Implementation Guidance for Section 96.5 Phosphorus Discharges to Free-flowing Streams, dated 10/27/97 (ID No. 391-2000-018). Total phosphorus loading from this discharge would be  $8.34 \times 10 \text{ mg/l} \times 0.04 \text{ MGD}$  or 3.336 lbs/day. Using the equation that was documented in EPA's Chesapeake Bay Management Report,  $\text{Total P @ Y} = \text{Total P} \times 0.99^Y$ , where Y = stream miles to PA-MD line, the actual loading to the critical part of the Susquehanna River would be 1.46 lbs/day at an estimated distance of 82.2 miles. This loading represents  $1.46 \text{ lbs/day} \div 3,814 \text{ lbs/day}$  or 0.038% of the total phosphorus loading of all discharges in the Lower Susquehanna River Basin. According to the above phosphorus guidance, phosphorus removal will be required if this percentage is > 0.25%. Therefore, since 0.038% < 0.25%, phosphorus limitations will not be required.

**Chesapeake Bay Strategy:**

Phase 2 WIP identifies Pine Run Management, LLC WWTP as a non-significant Phase 5 facility. DEP's SOP mentioned that for facilities with design flows > 2,000 GPD will include monitoring, at a minimum, for Total Nitrogen and Total Phosphorus, with a monitoring frequency specified in DEP's technical guidance. Therefore, 1/quarter TN species (such as Ammonia-Nitrogen, Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, and Total Nitrogen) and TP monitoring requirements will remain in the proposed permit. The yearly calculation "report" for Ammonia—N, TN & TP will remain in the proposed permit.

**Total Dissolved Solids (TDS):**

Minor facilities with design flow <0.1 MGD are not required to report effluent TDS and constituents.

**WETT:**

Minor facilities and facilities without a formal EPA approved pretreatment program are exempted from WETT.

**Anti-Backsliding**

The proposed limits are at least as stringent as are in existing permit; therefore, anti-backsliding rule is not applicable.

**Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

**WQM 7.0:**

The following data were used in the attached computer model (WQM 7.0) of the stream:

- Discharge pH 7.0 (Default)
- Discharge Temperature 20°C (Default per 391-2000-013)
- Stream pH 7.0 (Default per 391-2000-013)
- Stream Temperature 25°C (Default per 391-2000-013)

The following two nodes were used in modeling:

Node 1: At Outfall 001 on UNT to Conewago Creek (08303)  
 Elevation: 420.93 ft (USGS)  
 Drainage Area: 0.15 mi.<sup>2</sup> (USGS StreamStats)  
 River Mile Index: 0.11 (PA DEP eMapPA)  
 Low Flow Yield: 0.005 cfs/mi.<sup>2</sup> (calculated)  
 Discharge Flow: 0.04 MGD

Node 2: At the confluence with Conewago Creek  
 Elevation: 395.42 ft (USGS National Map Advanced viewer, accessed 3/8/2018)  
 Drainage Area: 0.22 mi.<sup>2</sup> (USGS StreamStats)  
 River Mile Index: 0.001 (PA DEP eMapPA)  
 Low Flow Yield: 0.005 cfs/mi.<sup>2</sup>  
 Discharge Flow: 0.00 MGD

The screenshot displays the USGS StreamStats web application interface. On the left is a navigation sidebar with options like 'SELECT A STATE / REGION' (Pennsylvania), 'IDENTIFY A STUDY AREA' (Basin Delineated), and 'BUILD A REPORT'. The main content area shows a map of a study area with a yellow highlight. Below the map, there are two data tables:

**Basin Characteristics**

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	1.6279	degrees
DRNAREA	Area that drains to a point on a stream	0.15	square miles
ROCKDEP	Depth to rock	4	feet
URBAN	Percentage of basin with urban development	0	percent

**Low-Flow Statistics**

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.15	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	1.6279	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4	feet	4.13	5.21
URBAN	Percent Urban	0	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.00367	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.00686	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.000819	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.00171	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.00536	ft <sup>3</sup> /s

Low-Flow Statistics Citations



The screenshot displays the USGS StreamStats interface. On the left, a sidebar contains navigation options like 'SELECT A STATE / REGION' (Pennsylvania) and 'BUILD A REPORT'. The main content area is divided into two sections:

**Basin Characteristics**

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	2.1066	degrees
DRNAREA	Area that drains to a point on a stream	0.22	square miles
ROCKDEP	Depth to rock	4	feet
URBAN	Percentage of basin with urban development	0.4757	percent

**Low-Flow Statistics**

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.22	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	2.1066	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4	feet	4.13	5.21
URBAN	Percent Urban	0.4757	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.00755	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.0133	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.00189	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.00367	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.0101	ft <sup>3</sup> /s

The screenshot shows the 'Analysis Results WQM 7.0' window with the 'Effluent Limitations' tab selected. The interface includes a table for discharge information and a table for effluent limits.

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.11	Pine Run MHP	PA0083836	0.0400

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	1.91	3.82	
Dissolved Oxygen			6

Record: 1 of 1 | No Filter | Search

Buttons: Print, < Back, Next >, Archive, Cancel

rptEffLimits

### WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name	Discharge	Parameter	525 Limit	525 4day Avg. Limit	525 Maximum Limit	525 Minimum Limit
07F	8303	CONEWAGO CREEK	(mgd)		(mg/L)	(mg/L)	(mg/L)	(mg/L)
0.110	Pine Run MHP	PA0083836	0.040	CSOD5	25			
				NPS-N	1.91	3.92		
				Unsettled Solids			6	

Thursday, May 11, 2023 Version 1.1 Page 1 of 1

rpt\_WLA

### WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name	Baseline Discharge	Baseline WLA	Multiple Discharge	Multiple WLA	Critical Reach	Percent Reduction
07F	8303	CONEWAGO CREEK	(mgd)	(mg/L)	(mg/L)	(mg/L)		
<b>NHS-N Acute Allocations</b>								
0.110	Pine Run MHP		16.71	16.24	16.71	16.24	0	0
<b>NHS-N Chronic Allocations</b>								
0.110	Pine Run MHP		1.99	1.91	1.99	1.91	0	0
<b>Dissolved Oxygen Allocations</b>								
0.110	Pine Run MHP		25	25	1.91	1.91	6	6

Thursday, May 11, 2023 Version 1.1 Page 1 of 1

rptDOSim

### WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
07F	8303	CONEWAGO CREEK			
0.110			10.40	20.000	7.000
Reach Width (ft)	Reach Depth (ft)	Reach WQF Ratio	Reach Velocity (ft/s)	Reach NPS-N (mg/L)	Reach NPS-N (mg/L)
2.204	0.351	6.263	0.081	0.703	0.703
Reach CSOD5 (mg/L)	Reach NPS-N (10days)	Reach NPS-N (10days)	Reach NPS-N (10days)	Reach NPS-N (10days)	Reach NPS-N (10days)
247.2	14.98	1.99	0.703	0.703	0.703
Reach DO (mg/L)	Reach NPS-N (10days)	Reach NPS-N (10days)	Reach NPS-N (10days)	Reach NPS-N (10days)	Reach NPS-N (10days)
6.027	25.021	0.000	0.000	0.000	0.000
Reach Travel Time (days)	<b>Subreach Results</b>				
0.082	Travel Time (days)	CSOD5 (mg/L)	NPS-N (mg/L)	D.O. (mg/L)	
	0.008	24.42	1.91	6.22	
	0.016	24.12	1.91	6.36	
	0.025	23.82	1.91	6.51	
	0.033	23.53	1.91	6.61	
	0.041	23.24	1.91	6.71	
	0.049	22.96	1.91	6.78	
	0.056	22.69	1.91	6.85	
	0.065	22.43	1.91	6.91	
	0.074	22.12	1.91	6.96	
	0.082	21.85	1.91	7.00	

Thursday, May 11, 2023 Version 1.1 Page 1 of 1

rptModelSpecs

### WQM 7.0 Modeling Specifications

Parameters	Units	Use Inputted Q1-10 and Q25-10 Flows
WLA Method	EM/PL	<input type="checkbox"/>
Q1-10/Q1-10 Ratio	0.84	<input type="checkbox"/>
Q25-10/Q1-10 Ratio	1.36	<input type="checkbox"/>
D.O. Substratum	90.00%	<input type="checkbox"/>
D.O. Goal	6	<input type="checkbox"/>

Thursday, May 11, 2023 Version 1.1 Page 1 of 1

rptHydro

### WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code		Stream Name				
SWP	Stream Code	Stream Name	RIM	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply F/C
07F	8303	CONDIVAGO CREEK	0.001	365.42	0.22	0.00000	0.00	<input checked="" type="checkbox"/>

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Flow Time (days)	Rch Velocity (fpm)	WD (feet)	Rch Width (ft)	Rch Depth (ft)	Intubary Temp (°C)	Stream Temp (°C)	pH
Q7-10 Flow	0.110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	25.00	7.00	0.00
Q1-10 Flow	0.110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	25.00	7.00	0.00
Q30-10 Flow	0.110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	25.00	7.00	0.00

Thursday, May 11, 2023      Version 1.1      Page 1 of 1

rptGeneral

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RIM	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply F/C
07F	8303	CONDIVAGO CREEK	0.001	365.42	0.22	0.00000	0.00	<input checked="" type="checkbox"/>

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Flow Time (days)	Rch Velocity (fpm)	WD (feet)	Rch Width (ft)	Rch Depth (ft)	Intubary Temp (°C)	Stream Temp (°C)	pH
Q7-10	0.000	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
Q1-10	0.00	0.00	0.00	0.000	0.000						
Q30-10	0.00	0.00	0.00	0.000	0.000						

Discharge Data		Existing	Permitted	Design	Reserve	Disc Temp	Disc pH
Name	Permit Number	Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)	Reserve Factor	(°C)	
Pine Run MHP	PA0083836	0.0000	0.0000	0.0000	0.0000	20.00	7.00

Parameter Data		Disc Conc	Trib Conc	Stream Conc	Fate Coef
Parameter Name		(mg/L)	(mg/L)	(mg/L)	(1/days)
CSOQS		25.00	2.00	0.00	1.50
Dissolved Oxygen		5.00	8.24	0.00	0.00
NH3-N		25.00	0.00	0.00	0.70

Thursday, May 11, 2023      Version 1.1      Page 1 of 2

rptGeneral

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RIM	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply F/C
07F	8303	CONDIVAGO CREEK	0.001	365.42	0.22	0.00000	0.00	<input checked="" type="checkbox"/>

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Flow Time (days)	Rch Velocity (fpm)	WD (feet)	Rch Width (ft)	Rch Depth (ft)	Intubary Temp (°C)	Stream Temp (°C)	pH
Q7-10	0.005	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
Q1-10	0.00	0.00	0.00	0.000	0.000						
Q30-10	0.00	0.00	0.00	0.000	0.000						


  

Discharge Data		Existing	Permitted	Design	Reserve	Disc Temp	Disc pH
Name	Permit Number	Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)	Reserve Factor	(°C)	
Pine Run MHP	PA0083836	0.0000	0.0000	0.0000	0.0000	20.00	7.00

Parameter Data		Disc Conc	Trib Conc	Stream Conc	Fate Coef
Parameter Name		(mg/L)	(mg/L)	(mg/L)	(1/days)
CSOQS		25.00	2.00	0.00	1.50
Dissolved Oxygen		5.00	8.24	0.00	0.00
NH3-N		25.00	0.00	0.00	0.70

Thursday, May 11, 2023      Version 1.1      Page 2 of 2



**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
D.O.	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
CBOD <sub>5</sub>	XXX	XXX	XXX	25.0	XXX	50	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	1.5	XXX	3	2/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	4.5	XXX	9	2/month	24-Hr Composite

**Existing Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Quarterly Average	Maximum	Instant. Maximum		
Ammonia--N	Report Total quarterly	Report	XXX	Report	XXX	XXX	1/quarter	24-Hr Composite
Kjeldahl--N	Report Total quarterly	XXX	XXX	Report	XXX	XXX	1/quarter	24-Hr Composite
Nitrate-Nitrite as N	Report Total quarterly	XXX	XXX	Report	XXX	XXX	1/quarter	24-Hr Composite
Total Nitrogen	Report Total quarterly	Report	XXX	Report	XXX	XXX	1/quarter	Calculation
Total Phosphorus	Report Total quarterly	Report	XXX	Report	XXX	XXX	1/quarter	24-Hr Composite

<b>Proposed Effluent Limitations and Monitoring Requirements</b>
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	1.5	XXX	3.0	2/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	4.5	XXX	9.0	2/month	24-Hr Composite

Compliance Sampling Location:

Other Comments:

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Total Quarterly	Annual	Monthly	Quarterly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	1/quarter	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	1/quarter	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/quarter	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/quarter	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location:     

Other Comments:



Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [redacted]