

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0084085

APS ID

986271

Authorization ID

1521311

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	<u>CV Estates Management LLC</u>	Facility Name	<u>Country View Estates MHP</u>
Applicant Address	<u>PO Box 677</u>	Facility Address	<u>Bloserville Road</u>
	<u>Morgantown, PA 19543-0677</u>		<u>Newville, PA 17241</u>
Applicant Contact	<u>James Perano</u>	Facility Contact	<u>Jim Perano</u>
Applicant Phone	<u>(610) 286-0490</u>	Facility Phone	<u>(610) 286-0490</u>
Client ID	<u>347766</u>	Site ID	<u>443812</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Upper Frankford Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Cumberland</u>
Date Application Received	<u>March 25, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>April 2, 2025</u>	If No, Reason	
Purpose of Application	<u>NPDES Permit Renewal.</u>		

Summary of Review

CV Estates Management LLC has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on September 21, 2020 and became effective on October 1, 2020. The permit expired on September 30, 2025 but the terms and conditions of the permit have been extended since that time.

It is recommended that the permit be drafted.

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist	November 13, 2025
X		<i>Daniel W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	December 11, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.05025
Latitude	40° 14' 00"	Longitude	77° 21' 16"
Quad Name	Plainfield	Quad Code	1727
Wastewater Description: Sewage Effluent			
Receiving Waters	Blosier Creek (WWF, MF)	Stream Code	10343
NHD Com ID	56406319	RMI	1.87
Drainage Area	4.84 sq.mi.	Yield (cfs/mi ²)	0.147
Q ₇₋₁₀ Flow (cfs)	0.71148	Q ₇₋₁₀ Basis	USGS gage 01570000
Elevation (ft)	503	Slope (ft/ft)	
Watershed No.	7-B	Chapter 93 Class.	WWF, MF
Existing Use	None	Existing Use Qualifier	None
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	N/A		
Source(s) of Impairment	N/A		
TMDL Status	N/A	Name	N/A
Nearest Downstream Public Water Supply Intake	Conodoguinet Creek	Carlisle Borough	
PWS Waters	Conodoguinet Creek	Flow at Intake (cfs)	48
PWS RMI	35.95	Distance from Outfall (mi)	15.4

Drainage Area

The discharge is to Blosier Creek at RM 1.87. A drainage area upstream of the point of discharge is estimated to be 4.84 sq. mi. using USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

USGS StreamStats produced a Q₇₋₁₀ of 0.0395 cfs at the point of discharge. However, the estimated drainage area is lower than the minimum value required to properly calculate the Q₇₋₁₀ which resulted in possible errors in calculations. As a result, DEP determined to correlate a nearby USGS gage station to obtain a low flow yield. This approach has been widely used by DEP and was also used during the last permit renewal. The nearby gage station no. 01570000 on the Conodoguinet Creek is used to calculate a low flow yield of 69.32 cfs / 470 sq.mi = 0.147 cfs/sq.mi. The Q₇₋₁₀ is then calculated to be 0.147 cfs/sq.mi * 4.84 sq.mi. = 0.71148 cfs.

Blosier Creek

Under 25 Pa Code §93.9o, Blosier Creek is designated as warm water fishes and supports migratory fishes. Blosier Creek is a tributary of Conodoguinet Creek which is also warm water fishes. No special protection water is therefore impacted by this discharge. DEP's latest integrated water quality report prepared in 2024, the discharge is located within a stream segment listed as attaining use(s).

Public Water Supply Intake

The nearest downstream public water supply intake is Carlisle Borough located on the Conodoguinet Creek approximately 15 miles from the discharge. Given the distance, the discharge is not expected to affect the water supply.

Treatment Facility Summary				
Treatment Facility Name: Country View Estates MHP				
WQM Permit No.		Issuance Date		
2192402		9/16/1992		
2192402-T1		10/28/1993		
2192402-T2		4/26/2019		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.05025
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.05025	N/A	Not Overloaded	Holding Tank	Other WWTP

This facility serves sanitary wastewater generated from about 200 mobile homes (i.e., Country View Estates MHP). The treatment process, according to the application, is as follows:

Communitor → Equalization tanks (2) → Aeration tanks (6) → Clarifiers (2) → Chlorine contact tank with tablet chlorination (sodium hypochlorite) → outfall to Blosier Creek.

Sludge holding tank is provided for sludge handling process. Alum is added for phosphorous removal and soda ash is added for pH adjustment and clarity.

Compliance History	
Summary of DMRs:	A summary of past 12-month DMR data is presented on the next page.
Summary of Inspections:	04/23/2020: DEP conducted an administrative inspection; no significant violations were found at the time of inspection.
Other Comments:	Since the last permit reissuance, the facility had no permit violations. DEP's database revealed that there is no open violation associated with this facility or permittee that is directly identified by DEP Clean Water Program.

Effluent Data

DMR Data for Outfall 001 (from October 1, 2024 to September 30, 2025)

Parameter	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24
Flow (MGD) Average Monthly	0.016	0.0161	0.0163	0.0162	0.0161	0.0169	0.0163	0.016	0.0172	0.0165	0.0156	0.0152
Flow (MGD) Daily Maximum	0.0206	0.0216	0.022	0.021	0.0295	0.0372	0.0234	0.02	0.0358	0.0238	0.0242	0.0191
pH (S.U.) Instantaneous Minimum	6.8	6.8	6.8	6.8	6.8	6.8	6.0	6.8	6.8	6.8	6.8	6.8
pH (S.U.) Instantaneous Maximum	7.2	7.1	7.4	7.1	7.1	7.1	7.2	7.2	7.2	7.2	7.2	7.2
DO (mg/L) Daily Minimum	8.3	7.4	7.0	6.4	7.3	6.2	8.4	8.2	7.2	8.4	8.0	7.2
TRC (mg/L) Average Monthly	0.24	0.27	0.34	0.33	0.26	0.31	0.28	0.27	0.26	0.24	0.29	0.28
TRC (mg/L) Instantaneous Maximum	0.3	0.35	0.6	0.46	0.38	0.70	0.38	0.32	0.34	0.28	0.43	0.51
CBOD5 (mg/L) Average Monthly	6.2	7.9	6.6	9.3	7.0	3.6	4.1	3.2	4.4	3.2	< 2.5	< 2.4
TSS (mg/L) Average Monthly	4	2	1	1	3	3	2	2	2	2	1	3
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 2	< 3
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	< 1	< 1	< 1	2	1	< 1	< 1	< 1	< 1	6	9
Nitrate-Nitrite (mg/L) Average Monthly	< 4.4	< 7.9	< 4	< 8.2	< 9	< 13.4	< 12.9	< 11	< 14.9	< 14.4	< 13.9	< 9.7
Total Nitrogen (mg/L) Average Monthly	< 6.9	< 8.4	< 4.5	< 9.2	< 9	< 13.9	< 13.4	< 11.7	< 15.4	< 14.9	< 14.4	< 10.2
Ammonia (mg/L) Average Monthly	0.76	< 0.1	< 0.17	< 0.1	< 0.2	< 0.1	< 0.24	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
TKN (mg/L) Average Monthly	< 2.5	< 0.5	< 0.5	< 1	< 0.5	0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
Total Phosphorus (mg/L) Average Monthly	0.11	< 0.11	< 0.3	< 0.1	0.11	0.16	0.16	0.29	< 0.1	0.13	< 0.1	0.19

Existing Effluent Limits and Monitoring Requirements

A table below summarizes effluent limits and monitoring requirements specified in the existing permit.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite as N	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Calculation
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	12	XXX	24	2/month	8-Hr Composite
Total Kjeldahl Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	1.0	XXX	2	2/month	8-Hr Composite

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 14' 0.24"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .05025
Longitude -77° 21' 15.09"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

CBOD5, NH3-N and Dissolved Oxygen

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD5, NH3-N and DO. DEP's technical guidance no. 391-2000-007 describes the technical methods contained in the model for conducting wasteload allocation analyses and for determining recommended limits for point source discharges. The model is utilized for this permit renewal and the output shows that existing limits are still appropriate for these parameters. No change is therefore recommended.

Total Residual Chlorine

Since chlorine is used for disinfection, DEP's water quality analysis for Total Residual Chlorine (TRC) was utilized to determine if existing TRC limits are still appropriate. The water quality model, TRC_CALC does not recommend the WQBEL for TRC; therefore, an existing average monthly BAT limit will remain unchanged in the permit. IMAX limit of 1.6 mg/L is obtained from the model.

Toxics

DEP's minor sewage facility permit application does not require sampling of toxic pollutants for facilities less than 0.1 MGD. No toxic pollutants have therefore been taken into consideration as pollutants of concern at this time.

Best Professional Judgment (BPJ) Limitations

Dissolved Oxygen

A minimum of 5.0 mg/L for DO is an existing effluent limit and is a current state water quality criterion found in 25 Pa. Code § 93.7(a). This effluent limit will remain unchanged for the upcoming permit renewal to ensure the protection of water quality standards. This approach is also consistent with DEP's SOP no. BPNPSM-PMT-033. This requirement has also been assigned to other facilities throughout the state.

Total Phosphorus

The facility will also continue to control Total Phosphorus effluent levels by average monthly and instantaneous maximum (IMAX) limits of 1.0 mg/L and 2.0 mg/L, respectively. This was previously developed based on the previous regional biologist's determination that phosphorus loadings from this facility need to be controlled during the growing season for any newer facilities on the Conodoguinet Creek watershed.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

E. Coli Monitoring

DEP's SOP no. BPNPSM-PMT-033 recommends a quarterly routine monitoring of E. Coli for all sewage facilities that have design flow less than 0.1 MGD but greater than 0.05 MGD. A quarterly monitoring for E. Coli will therefore be included in the permit.

Chesapeake Bay TMDL & TN/TP SOP Monitoring Requirement

The discharge is located within the Chesapeake Bay watershed and is considered under the Supplement to Phase III Watershed Implementation Plan (WIP) a Phase 5 facility designed to treat between 0.002 MGD and 0.2 MGD. The facility has been monitored for nutrients on a quarterly basis. DEP's SOP no. BPNPSM-PMT-033 recommends that a routine monitoring for Total Phosphorous and Total Nitrogen regardless for any sewage facilities. It is important to collect ample datasets for DEP to understand impacts of all point source discharges to the Chesapeake Bay watershed. It is therefore recommended to maintain existing nutrient monitoring requirements. Since the facility has been collecting monthly data and no permit violations have been identified, it is recommended that the monitoring frequency be changed from 2/month to 1/quarter for Total Nitrogen.

Monitoring Frequency and Sample Type

Unless stated otherwise in this fact sheet, all existing monitoring frequencies and sample types will remain unchanged in the permit and are consistent with recommended requirements specified in DEP's technical guidance no. 362-0400-001.

Class A Wild Trout Fishery

A Class A Wild Trout Fishery is not impacted by this discharge.

Anti-Degradation Requirements

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as permit requirements specified in the existing permit renewal in accordance with 40 CFR §122.44(l)(1).

Antibacksliding Requirements

Unless specified otherwise throughout this fact sheet, effluent limits for all pollutants of concern have been developed at least as stringent as effluent limits written in the existing permit renewal. This approach is consistent with 40 CFR §122.44(l)(1).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	Calculation
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	12	XXX	24	2/month	8-Hr Composite
TKN	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	1.0	XXX	2	2/month	8-Hr Composite
E. Coli (No. 100 mL)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10343	BLOSER CREEK	1.870	503.00	4.84	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH	Temp (°C)	Stream pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.100	0.00	0.77	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Country View	PA0084085	0.0503	0.0503	0.0503	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		12.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10343	BLOSER CREEK	0.000	448.00	5.60	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.89	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)			
		0.0000	0.0000	0.0000	0.000	0.00	7.00
Parameter Data							
Parameter Name		Disc Conc	Trib Conc	Stream Conc	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

