

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0084191  
APS ID 730999  
Authorization ID 1391341

**Applicant and Facility Information**

Applicant Name	<u>Peters Township Municipal Authority</u>	Facility Name	<u>Mercersburg Junction STP</u>
Applicant Address	<u>PO Box 19 5000 Steele Avenue</u> <u>Lemasters, PA 17231-0019</u>	Facility Address	<u>4360 Mercersburg Road</u> <u>Mercersburg, PA 17236</u>
Applicant Contact	<u>Forsyth Derek</u>	Facility Contact	<u>Forsyth Derek</u>
Applicant Phone	<u>(717) 328-3241</u>	Facility Phone	<u>(717) 977-1007</u>
Client ID	<u>273166</u>	Site ID	<u>451951</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Peters Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Franklin</u>
Date Application Received	<u>April 6, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>April 20, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Permit Renewal.</u>		

**Summary of Review**

Peters Township Municipal Authority (PTMA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on November 22, 2017 and became effective on December 1, 2017. The permit will expire on November 30, 2022.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted.

Sludge use and disposal description and location(s): Sludge is processed on-site prior to being sent to a landfill (Mt. View Reclamation) for ultimate disposal.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist	August 9, 2023
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	September 11, 2023
X		Maria D. Bebenek Maria D. Bebenek, P.E. / Program Manager	September 11, 2023

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	0.25
Latitude	39° 51' 30"	Longitude	-77° 53' 7"
Quad Name	Mercersburg	Quad Code	2022
Wastewater Description: Treated Sewage			
Receiving Waters	West Branch Conococheague Creek	Stream Code	59398
NHD Com ID	49469840	RMI	14.8
Drainage Area	124	Yield (cfs/mi <sup>2</sup> )	0.07
Q <sub>7-10</sub> Flow (cfs)	8.37	Q <sub>7-10</sub> Basis	USGS PA StreamStats
Elevation (ft)	521	Slope (ft/ft)	
Watershed No.	13-C	Chapter 93 Class.	TSF
Existing Use	None	Existing Use Qualifier	None
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	Hagerstown		
PWS Waters	Potomac River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	43

**Drainage Area**

The discharge is to the West Branch Conococheague Creek at RMI 14.8. A drainage area upstream of the point of discharge is estimated to be 124 mi<sup>2</sup> according to the USGS Stream Stats available at <https://streamstats.usgs.gov/ss/>.

**Stream Flow**

There is no USGS gauging station in the vicinity of the point of discharge. A Q<sub>7-10</sub> flow value of 8.37 cfs generated from USGS Stream Stats will be used in water quality modeling. This results in a low flow yield of 8.42 / 124 = 0.0675 cfs/sq.mi.

**West Branch Conococheague Creek**

25 Pa Code §93.9z classifies the West Branch Conococheague Creek (main stem, US 30 Bridge to PA-MD State Border) as trout stocking surface water. No special protection waters are impacted by this discharge. The discharge is located in a stream segment listed as attaining uses. No local TMDL has been taken into consideration during this review.

**Public Water Supply Intake**

The nearest downstream public water supply intake is the Hagerstown intake located on the Potomac River approximately 43 miles from the discharge. Considering the distance and nature, the discharge is not expected to significantly affect the water supply.

**Class A Wild Trout Streams**

The receiving stream is not a Class A Wild Trout stream; therefore no Class A Wild Trout Fishery is impacted by this discharge.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Mercersburg Junction STP				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.25
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.25	521	Not Overloaded	Aerobic Digestion	Landfills

The Mercersburg Junction STP owned and operated by PTMA is located at 4360 Mercersburg Road, Mercersburg, PA 17236. This facility only serves Peters Township and all sewer systems are 100% separated. This facility utilizes an extended aeration activated sludge treatment process consisting of aeration tanks (2), clarifiers (2), chlorine contact tank, and outfall structure(s) to the West Branch Conococheague Creek. An aerobic digester and belt filter press for solids handling process prior to being sent to a landfill. Sodium hypochlorite is used for disinfection. Alum and lime are used for phosphorous removal and pH control, respectively. There is no industrial/commercial user contributing industrial wastewater to the sewer system.

Compliance History	
<b>Summary of DMRs:</b>	A summary of the past 12-month DMR data is presented on the next page.
<b>Summary of Inspections:</b>	05/28/2020: Brandon Bettinger, DEP Water Quality Specialist, conducted an administrative inspection and found no issues at the time of inspection. 03/06/2020: Brandon Bettinger conducted a routine inspection and noticed that the facility failed to use an NIST thermometer and failed to collect samples on days when there is return from belt filter press. No violations were noted.
<b>Other Comments:</b>	There is currently no open violation associated with this facility or permittee.

Effluent Data

DMR Data for Outfall 001 (from May 1, 2021 to April 30, 2022)

Parameter	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21
Flow (MGD) Average Monthly	0.044	0.046	0.049	0.045	0.046	0.048	0.049	0.055	0.05	0.045	0.043	0.045
Flow (MGD) Daily Maximum	0.058	0.059	0.07	0.06	0.058	0.067	0.071	0.133	0.075	0.058	0.054	0.057
pH (S.U.) Minimum	6.7	6.6	6.6	6.6	6.5	6.7	6.6	6.6	6.8	7.1	7.0	6.9
pH (S.U.) Instantaneous Maximum	7.1	7.1	6.9	6.9	7.0	7.0	7.0	7.3	7.4	7.6	7.4	7.3
DO (mg/L) Minimum	5.4	6.2	6.8	7.0	6.7	6.2	5.9	5.8	5.5	5.0	5.2	5.6
TRC (mg/L) Average Monthly	0.3	0.4	0.3	0.5	0.4	0.3	0.3	0.4	0.3	0.3	0.3	0.3
TRC (mg/L) Instantaneous Maximum	0.4	0.6	0.6	1.3	0.6	0.4	0.5	0.7	0.5	0.5	0.3	0.4
CBOD5 (lbs/day) Average Monthly	< 0.9	< 0.9	< 1.0	< 0.8	< 0.9	< 0.9	< 0.9	< 1.0	1.0	< 1.0	< 1.0	< 0.8
CBOD5 (lbs/day) Weekly Average	< 1	1.0	< 1.0	< 1.0	1.0	< 1.0	< 1.0	1.0	2.0	2.0	1.0	0.9
CBOD5 (mg/L) Average Monthly	< 2.0	< 2.2	< 2.0	< 2.1	< 2.1	< 2.1	< 2.0	< 2.1	2.8	< 3.0	< 3.0	< 2.3
CBOD5 (mg/L) Weekly Average	2.0	3.0	2.0	2.0	2.5	2.1	< 2.0	2.1	3.7	3.8	3.7	2.8
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	184	142	174	139	148	151	113	154	181	173	122	150
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	239	160	261	151	191	275	175	215	255	230	138	168
BOD5 (mg/L) Raw Sewage Influent Average Monthly	415	340	355	351	343	314	256	316	353	396	329	439
TSS (lbs/day) Average Monthly	2.0	2.0	2.0	3.0	1.0	1.0	1.0	< 1.0	1.0	1.0	2.0	2.0
TSS (lbs/day) Raw Sewage Influent Average Monthly	64	50	75	89	46	80	64	170	173	150	137	127

**NPDES Permit Fact Sheet  
Mercersburg Junction STP**

**NPDES Permit No. PA0084191**

Parameter	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21
TSS (lbs/day) Raw Sewage Influent Daily Maximum	151	104	117	125	74	134	131	347	287	183	152	131
TSS (lbs/day) Weekly Average	2.0	3.0	3.0	8.0	2.0	3.0	2.0	3.0	2.0	2.0	3.0	2.0
TSS (mg/L) Average Monthly	3.6	4.0	3.5	8.0	2.9	3.1	2.6	< 2.3	2.8	3.0	4.3	5.3
TSS (mg/L) Raw Sewage Influent Average Monthly	139	123	163	237	108	169	142	337	328	347	372	375
TSS (mg/L) Weekly Average	4.5	8.5	6.0	23.5	3.5	6.0	4.0	4.0	4.5	5.0	7.0	6.0
Fecal Coliform (No./100 ml) Geometric Mean	7	< 3.0	< 3.0	< 1.0	< 1.0	< 2.0	4.0	< 5	< 2.0	< 2.0	< 2	< 1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	12	30	29.0	< 1.0	< 1.0	8.0	11.0	49	7.0	8.0	6	1.0
Total Nitrogen (lbs/day) Average Monthly	< 33	< 28	< 29.0	< 25	< 28	< 25	< 25.0	< 27	< 31	< 26	< 27	< 27
Total Nitrogen (mg/L) Average Monthly	< 74.13	< 65.97	< 60.24	< 30	< 63.42	< 55.62	< 59.43	< 54.63	< 60.22	< 60.46	< 72.39	< 79.55
Total Nitrogen (lbs) Total Monthly	< 985	< 860	< 817	< 770	< 853	< 764	< 785	< 799	< 946	< 812	< 804	< 835
Ammonia (lbs/day) Average Monthly	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.3	< 0.2	< 0.2	< 0.2
Ammonia (mg/L) Average Monthly	< 0.5	< 0.525	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
Total Phosphorus (lbs/day) Average Monthly	2.0	2.0	2.0	< 1.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
Total Phosphorus (mg/L) Average Monthly	4.9	4.53	3.84	< 3.18	4.32	3.86	3.61	3.39	3.52	3.93	4.92	5.12
Total Phosphorus (lbs) Total Monthly	65	59	52	< 41	58	53	48	49	55	53	55	54

**Existing Effluent Limitations and Monitoring Requirements**

The table below summarizes effluent limitations and monitoring requirements specified in the current NPDES permit renewal.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	52	83	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids	63	94	XXX	30.0	45.0	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Ammonia-Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Phosphorus (Total Load, lbs) (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (Total Load, lbs) (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

**Development of Effluent Limitations and Monitoring Requirements**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.25</u>
<b>Latitude</b> <u>39° 51' 30.00"</u>	<b>Longitude</b> <u>-77° 53' 7.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

*CBOD5, NH3-N and Dissolved Oxygen (DO)*

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD5, NH3-N and DO. DEP's technical guidance no. 391-2000-007 describes the technical methods contained in the model for conducting wasteload allocation analyses and for determining recommended limits for point source discharges. DEP recently updated this model (ver. 1.1) to include new ammonia criteria that has been approved by US EPA as part of the 2017 Triennial Review. The model was utilized, and the model output indicated that all existing requirements are still appropriate. Therefore, no changes are recommended.

*Total Residual Chlorine*

Since sodium hypochlorite is used for disinfection, Total Residual Chlorine (TRC) effluent levels must be regulated in accordance with 25 Pa Code §92a.48(b). DEP's TRC\_CALC worksheet is utilized to determine if the existing BAT TBEL of 0.5 mg/L is still appropriate. The worksheet indicates that existing limits of 0.5 mg/L (average monthly) and 1.6 mg/L (IMAX) are still protective of water quality.

*Toxics*

DEP's NPDES permit application for minor sewages (less than 1.0 MGD) requires samples of heavy metals including Total Copper, Total Lead, and Total Zinc when the facility receives industrial or commercial contributions. The application shows no sample results. The sample results for TDS and its constituents showed effluent levels of these pollutants are not of concern. Therefore, no toxic pollutants are determined to be pollutants of concern for this facility.

**Best Professional Judgment (BPJ) Limitations**

*Dissolved Oxygen*

A minimum of 5.0 mg/L for DO is an existing effluent limit and will remain unchanged in the draft permit as recommended by DEP's SOP. This requirement has also been assigned to other major sewage facilities in the region. 5.0 mg/L is taken directly from 25 Pa. Code § 93.7(a) and it is also determined to be appropriate according to water quality modeling.

*Total Phosphorus & Total Nitrogen*

DEP's SOP no. BPNPSM-PMT-033 recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, a routine monitoring for Total Phosphorus and Total Nitrogen is recommended. Since the receiving stream, West Branch Conococheague Creek is not impaired for nutrients, weekly sampling of Total Phosphorus and Total Nitrogen will provide ample data for the subsequent permit renewal.

**Additional Considerations**

*Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

*Influent BOD & TSS Monitoring*

As a result of negotiation with EPA, the existing influent monitoring reporting requirement for TSS and BOD5 will be maintained in the draft permit. This requirement has been consistently assigned to all municipal wastewater treatment facilities.

*Chesapeake Bay TMDL*

DEP's Phase II Watershed Implementation Plan (WIP) categorizes this facility as a phase 4 non-significant sewage facility that has a design flow less than 0.4 MGD but greater than 0.2 MGD. The WIP recommends monitoring and reporting for Total Nitrogen and Total Phosphorus throughout the permit term at a frequency no less than monthly. As mentioned above, monitoring of these pollutants will be written in the permit as recommended by DEP's SOP. Therefore, no additional requirements will be necessary.

*Total Dissolved Solids (TDS)*

TDS and its associated solids including Bromide, Chloride, and Sulfate have become statewide pollutants of concern. The requirement to monitor these pollutants must be considered under the criteria specified in 25 Pa. Code § 95.10 and the following January 23, 2014 DEP Central Office Directive:

*For point source discharges and upon issuance or reissuance of an individual NPDES permit:*

*-Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.*

The sample result shows that effluent contains a TDS concentration level of 598 mg/L and Bromide was non-detected. Accordingly, the requirement to monitor these pollutants is not necessary.

*E. Coli Monitoring*

DEP's SOP No. BCW-PMT-033 recommends under 25 Pa Code §92a.61 a routine monitoring for E. Coli in all new and reissued permits. Since the facility has now the annual average design flow of 0.25 MGD, a quarterly monitoring will be included in the permit.

*Monitoring Frequency and Sample Type*

Unless otherwise specified throughout this fact sheet, existing monitoring frequencies and sample types will remain unchanged in the permit. DEP noticed that the last permit renewal requires 1/month calculation for Total Nitrogen. It is DEP's intention that the facility would be required to collect samples for Total Nitrogen 1/week and then calculate the results 1/month. Therefore, DEP will include 1/week sampling for ammonia, nitrate-nitrite as N, and TKN and then 1/month calculation for Total Nitrogen. 1/week sampling requirement is the same requirement applied to Total Phosphorus which is consistent with DEP's technical guidance no. 362-0400-001.

*Mass Loading Limitations*

All effluent mass loading limits will be based on the formula: design flow x concentration limit x conversion factor of 8.34.

*Antidegradation Requirements*

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	52	83	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	63	94	XXX	30.0	45.0	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
E. Coli (no./100 mL)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab


Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

Attachments

1. StreamStats

## StreamStats Report

Region ID: PA  
 Workspace ID: PA20220616140454023000  
 Clicked Point (Latitude, Longitude): 39.85840, -77.88592  
 Time: 2022-06-16 10:05:15 -0400



Collapse All

### > Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	24.93	percent
DRNAREA	Area that drains to a point on a stream	124	square miles
PRECIP	Mean Annual Precipitation	40	inches
ROCKDEP	Depth to rock	4.4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.3	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	124	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	40	inches	35	50.4
STRDEN	Stream Density	2.3	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.4	feet	3.32	5.65
CARBON	Percent Carbonate	24.93	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	15.5	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	19.9	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	8.37	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	10.8	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	14.8	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

2. WQM 7.0 ver. 1.1

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
13C	59398	WEST BRANCH CONOCOCHIEAGUE	14.800	521.00	124.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	8.37	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Merc. Junction	PA0084191	0.2500	0.2500	0.2500	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
13C	59398	WEST BRANCH CONOCOCHIEAGUE	10.040	495.00	141.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	10.80	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
13C	59398	WEST BRANCH CONOCOHEAGUE CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
14.800	0.250	25.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
51.378	0.792	64.862	0.215	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
3.02	0.241	1.10	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.100	2.381	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
1.352	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.135	2.89	0.96	7.46
	0.270	2.78	0.84	7.08
	0.406	2.67	0.73	6.87
	0.541	2.56	0.63	6.78
	0.676	2.46	0.55	6.77
	0.811	2.36	0.48	6.81
	0.946	2.26	0.42	6.87
	1.082	2.17	0.36	6.96
	1.217	2.08	0.32	7.05
	1.352	2.00	0.27	7.15



**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
13C		59398				WEST BRANCH CONOCOHEAGUE CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
14.800	8.37	0.00	8.37	.3868	0.00103	.792	51.38	64.86	0.22	1.352	25.00	7.00
<b>Q1-10 Flow</b>												
14.800	5.36	0.00	5.36	.3868	0.00103	NA	NA	NA	0.17	1.712	25.00	7.00
<b>Q30-10 Flow</b>												
14.800	11.38	0.00	11.38	.3868	0.00103	NA	NA	NA	0.25	1.146	25.00	7.00

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
13C	59398	WEST BRANCH CONOCOCHIEAGUE CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
14.800	Merc. Junction	11.07	50	11.07	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
14.800	Merc. Junction	1.37	25	1.37	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
14.80	Merc. Junction	25	25	25	25	5	5	0	0

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
13C	59398	WEST BRANCH CONOCOCHIEGUE CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
14.800	Merc. Junction	PA0084191	0.250	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5

3. TRC\_Calc Spreadsheet

TRC\_CALC

1A	B	C	D	E	F	G
2	<b>TRC EVALUATION</b>					
3	Input appropriate values in B4:B8 and E4:E7					
4	8.37	= Qstream (cfs)		0.5	= CV Daily	
5	0.25	= Qdischarge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 6.923	1.3.2.iii	WLA_cfc = 6.742	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 2.580	5.1d	LTA_cfc = 3.919	
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.500	BAT/BPJ		
18			INST_MAX_LIMIT (mg/l) = 1.635			
	WLA_afc	$(.019/e^{-k^*AFC\_tc}) + [(AFC\_Yc^*Qs^*.019/Qd^*e^{-k^*AFC\_tc}) \dots + Xd + (AFC\_Yc^*Qs^*Xs/Qd)]^*(1-FOS/100)$				
	LTAMULT_afc	$EXP((0.5^*LN(cvh^*2+1))-2.326^*LN(cvh^*2+1)^0.5)$				
	LTA_afc	$wla\_afc^*LTAMULT\_afc$				
	WLA_cfc	$(.011/e^{-k^*CFC\_tc}) + [(CFC\_Yc^*Qs^*.011/Qd^*e^{-k^*CFC\_tc}) \dots + Xd + (CFC\_Yc^*Qs^*Xs/Qd)]^*(1-FOS/100)$				
	LTAMULT_cfc	$EXP((0.5^*LN(cvd^*2/no\_samples+1))-2.326^*LN(cvd^*2/no\_samples+1)^0.5)$				
	LTA_cfc	$wla\_cfc^*LTAMULT\_cfc$				
	AML_MULT	$EXP(2.326^*LN((cvd^*2/no\_samples+1)^0.5)-0.5^*LN(cvd^*2/no\_samples+1))$				
	AVG_MON_LIMIT	$MIN(BAT\_BPJ,MIN(LTA\_afc,LTA\_cfc)^*AML\_MULT)$				
	INST_MAX_LIMIT	$1.5^*(av\_mon\_limit/AML\_MULT)/LTAMULT\_afc$				