



Application Type
Facility Type
Major / Minor

Renewal
Industrial
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0084395
APS ID 275998
Authorization ID 1500853

Applicant and Facility Information

Applicant Name	<u>PA Department of Corrections</u>	Facility Name	<u>State Correctional Institution at Camp Hill</u>
Applicant Address	<u>2500 Lisburn Road PO Box 8837</u>	Facility Address	<u>2500 Lisburn Road</u>
	<u>Camp Hill, PA 17011-8005</u>		<u>Camp Hill, PA 17011-8005</u>
Applicant Contact	<u>Michael Gourley</u>	Facility Contact	<u>Michael Gourley</u>
Applicant Phone	<u>(717) 737-4531</u>	Facility Phone	<u>(717) 737-4531</u>
Client ID	<u>43607</u>	Site ID	<u>453669</u>
SIC Code	<u>9223</u>	Municipality	<u>Lower Allen Township</u>
SIC Description	<u>Public Admin. - Correctional Institutions</u>	County	<u>Cumberland</u>
Date Application Received	<u>September 24, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 9, 2024</u>	If No, Reason	<u> </u>
Purpose of Application	<u>NPDES Renewal..</u>		

Summary of Review

PA Department of Corrections (DOC) has applied to the PA Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on June 8, 2020 and became effective on July 1, 2020. The permit will expire on June 30, 2025.

Based on the review, it is recommended that the permit be drafted.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist	June 16, 2025
x		<i>Maria D. Bebenek</i> for Daniel W. Martin, P.E. / Environmental Engineer Manager	July 1, 2025
x		<i>Maria D. Bebenek</i> Maria D. Bebenek, P.E. / Program Manager	July 1, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.05
Latitude	40° 13' 15.00"	Longitude	-76° 55' 39.00"
Quad Name	Lemoyne	Quad Code	1730
Wastewater Description: Water Treatment Effluent			
Receiving Waters	Cedar Run (CWF, MF)	Stream Code	63604
NHD Com ID	133783548	RMI	1.92
Drainage Area	6.25 sq.mi.	Yield (cfs/mi ²)	
Q ₇₋₁₀ Flow (cfs)	2.63	Q ₇₋₁₀ Basis	
Elevation (ft)		Slope (ft/ft)	
Watershed No.	7-E	Chapter 93 Class.	CWF, MF
Existing Use	None	Existing Use Qualifier	None
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Impaired		
Cause(s) of Impairment	Siltation, Nutrients, Pathogens		
Source(s) of Impairment	Natural Sources, Source Unknown, Urban Runoff/Storm Sewers		
TMDL Status	Pending	Name	N/A
Nearest Downstream Public Water Supply Intake	PA American – West Short Regional		
PWS Waters	Yellow Breeches Creek	Flow at Intake (cfs)	68.3
PWS RMI	0.35	Distance from Outfall (mi)	5.5

Drainage Area

The discharge is to Cedar Run at RM 1.92. A drainage area upstream of the point of discharge is estimated to be 6.25 sq.mi. using USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

USGS StreamStats produced a Q₇₋₁₀ flow of 2.63 cfs at the point of discharge.

Cedar Run

Under 25 Pa Code §93.9o, Cedar Run is a tributary of Yellow Breeches Creek and is designated as cold water and migratory fishes. Yellow Breeches Creek at the confluence with Cedar Run is also designated as cold water and migratory fishes. No special protection water is therefore impacted by this discharge. DEP's latest integrated water quality report prepared in 2024 indicates that Cedar Run is impaired for nutrients as a result of stormwater runoff from urbanized areas and unknown source. The report also indicates that the stream is impaired for siltation as a result of natural sources. A development of a Total Maximum Daily Load (TMDL) is pending at this time as the TMDL is in fact required to be developed to address this impairment.

Public Water Supply Intake

The fact sheet developed for the last permit renewal indicates that the nearest downstream public water supply intake is PA American Water Co. located on Yellow Breeches Creek, approximately 5.5 miles from the discharge. Given the nature and quantity, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: State Correctional Institution at Camp Hill				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial	Primary Treatment	Sedimentation	No Disinfection	0.031
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.05	N/A	Not Overloaded	N/A	N/A

DOC currently utilizes a water treatment system for the correctional facility located in Lower Allen Township Cumberland County. The raw water source is Cedar Run which is withdrawn via two (2) pumps at a maximum rate of 530 GPM. A typical water production is between 0.5 to 0.65 MGD with the maximum design capacity of 0.764 MGD, according to the application. The discharge of filter backwash as well as settled solids from the water treatment system is to one of two (2) existing settling lagoons. The discharge occurs continuously for 2 hours per day at an average rate of 0.031 MGD with the maximum of 0.04 MGD. The design flow of 0.05 MGD has been consistently considered by DEP.

Compliance History	
Summary of DMRs:	A summary of past 12-month DMR data is presented on the next page.
Summary of Inspections:	11/9/2022: DEP conducted a routine inspection and no issues were found at the time of inspection.
Other Comments:	Since the last permit reissuance, the facility had two (2) violations; one in January 2024 (effluent violation for Total Manganese) and one in August 2024 (late DMR submission). DEP's database shows that there is no open violation identified by Clean Water Program but some open violations identified by Air Quality and Safe Drinking Water Program.

Effluent Data

DMR Data for Outfall 001 (from May 1, 2024 to April 30, 2025)

Parameter	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24
Flow (MGD) Average Monthly	0.021		0.032	0.032	0.029	0.029	0.029	0.029	0.029	0.029	0.029	0.029
Flow (MGD) Daily Maximum	0.028		0.025	0.032	0.029	0.029	0.029	0.029	0.029	0.029	0.029	0.030
pH (S.U.) Instantaneous Minimum	7.1		7.4	7.4	7.2	7.3	7.3	7.2	7.1	7.2	7.1	7.1
pH (S.U.) Instantaneous Maximum	7.8		7.9	7.9	7.8	8.0	7.9	7.6	7.6	7.8	7.8	7.7
TRC (mg/L) Average Monthly	0.25		0.37	0.40	0.46	0.23	0.011	0.13	0.07	0.08	0.1	0.11
TRC (mg/L) Instantaneous Maximum	0.88		0.59	0.66	0.61	0.46	0.024	0.35	0.13	0.25	0.27	0.26
TSS (mg/L) Average Monthly	< 5		5	< 5	< 5	5	< 5	6	7	5	< 5	13
TSS (mg/L) Daily Maximum	< 5		5	< 5.0	< 5	5.0	< 5	6	7	5	< 5	20
Total Copper (mg/L) Average Monthly	< 0.005		0.0053	0.017	< 0.005	0.005	< 0.005	0.0053	< 0.005	< 0.005	0.0069	0.005
Total Copper (mg/L) Daily Maximum	0.005		0.0056	0.028	< 0.005	0.005	< 0.005	0.0055	0.005	< 0.005	0.008	0.005
Total Iron (mg/L) Average Monthly	0.23		0.30	0.1	0.41	0.36	0.27	0.24	0.33	0.46	0.24	0.76
Total Iron (mg/L) Daily Maximum	0.29		0.32	0.4	0.49	0.43	0.28	0.24	0.35	0.68	0.24	0.94
Total Manganese (mg/L) Average Monthly	0.062		0.001	0.002	0.0101	0.0082	0.0058	0.0053	0.0072	0.0128	0.032	0.25
Total Manganese (mg/L) Daily Maximum	0.11		0.01	0.0089	0.012	0.013	0.0074	0.0072	0.0083	0.018	0.05	0.25

Existing Effluent Limits and Monitoring Requirements

A table below summarizes effluent limits and monitoring requirements specified in the current permit:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Calculation
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	75	2/month	24-Hr Composite
Copper, Total	XXX	XXX	XXX	Report	Report	XXX	2/month	24-Hr Composite
Iron, Total	XXX	XXX	XXX	2.0	4.0	5	2/month	24-Hr Composite
Manganese, Total	XXX	XXX	XXX	1.0	2.0	2.5	2/month	24-Hr Composite

Development of Effluent Limitations			
Outfall No.	001	Design Flow (MGD)	.05
Latitude	40° 13' 15.00"	Longitude	-76° 55' 38.00"
Wastewater Description: Water Treatment Effluent			

Technology-Based Limitations

The facility given the type of discharge generated is not subject to federal effluent limits and guidelines (ELGs). The facility is subject to the state effluent standards for industrial waste found in 25 Pa Code §§92a.48 and 95.2. Further, DEP generally uses recommended BPT effluent requirements expressed in DEP's technical guidance no. 362-2183-003 to develop effluent limits for water treatment plant wastes. These requirements are shown below:

Parameter	Monthly Average (mg/L)	Daily Maximum (mg/L)
TSS	30	60
Total Iron	2	4
Total Aluminum	4	8
Total Manganese	1	2
Flow	Monitor	
pH	6-9 at all times	
TRC	0.5	1.0

Total Aluminum was removed from the permit during the last permit renewal as requested by the permittee. The review at that time revealed that Total Aluminum has been consistently non-detected in both raw water and effluent and the facility does not utilize Alum. As a result, DEP agreed that Total Aluminum permit requirements were not needed. For this permit renewal however, it is recommended that Total Aluminum effluent limits be included in the permit. While the permittee did not provide effluent sample results for Total Aluminum, the raw water intake sample collection provided with the application shows that Total Aluminum is detected (i.e., 110 ug/L). This would demonstrate that once filter backwash occurs, effluent concentration for Total Aluminum will most likely be higher. Inclusion of heavy metals such as Total Aluminum, Total Manganese and Total Iron is a standard permitting practice applied by DEP for those water treatment facilities utilizing a filter backwash (see DEP's guidance no. 362-2183-003). If the data during the next permit renewal shows that Total Aluminum is consistently non-detected in effluent, DEP may revisit this requirement during the next permit renewal application review.

Given that the facility currently uses chlorine prior to filtration, TRC effluent limits were included in the last permit per 25 Pa Code §92a.48.

Water Quality-Based Limitations

WQM 7.0

CBOD5 and NH3-N are not pollutants of concern for the water treatment waste as the discharge of these pollutants is not resulting from the water treatment process. Therefore, WQM 7.0 modeling is not necessary and permit requirements for these pollutants are not recommended.

Total Residual Chlorine

DEP's TRC_CALC worksheet was utilized and indicated that the effluent limits of 0.5 mg/L (average monthly) and 1.6 mg/L (instantaneous maximum) will be appropriate for water quality protection.

Toxics

DEP utilizes a Toxics Management Spreadsheet (TMS) to facilitate calculations necessary for completing a reasonable potential analysis and determining WQBELs for toxic pollutants. The worksheet combines the functionality of DEP's previous water quality models including Toxics Screening Analysis worksheet and PENTOXSD. The TMS does not recommend any WQBELs for the upcoming permit renewal. The data collected during the permit term shows that Total Copper has been consistently low, almost non-detect. As TMS does not recommend any limits and monitoring requirements, it is recommended that the existing Total Copper monitoring requirement be removed from the permit.

Additional Considerations

Flow Monitoring

Flow monitoring will remain in the permit and is required by 40 CFR § 122.44(i)(1)(ii).

Chesapeake Bay TMDL

DEP's Supplement to Phase II Watershed Implementation Plan (WIP) indicates that monitoring and reporting of TN and TP are necessary for non-significant IW facilities throughout the permit term anytime the facility has the potential to introduce a net TN or TP increase to the load contained within the intake water used in processing. The facility does not use any chemical products prior to filtration that contain nitrogen or phosphorus and no nutrients are expected to be generated from the water treatment process. The requirement to monitor for TN and TP is therefore not needed.

Instantaneous Maximum Effluent Limitations

In general, instantaneous maximum effluent limitations (IMAX) are not necessary for any parameters that are required to be measured through the collection of composite samples. NPDES permits include IMAX limits for compliance purpose(s) only, allowing DEP to collect a grab sample at the time of inspection to determine compliance. Accordingly, these limits will remain unchanged in the draft permit.

Monitoring Frequency and Sample Type

All existing monitoring frequency and sample type will remain unchanged. A daily grab sampling requirement for TRC is recommended by DEP's technical guidance no. 362-0400-001. A semi-monthly 24-hour composite sampling requirement for Total Copper is recommended to correspond with the sample type and monitoring frequency assigned to other toxic pollutants.

Anti-Degradation Requirements

The effluent limits for this discharge have been developed to ensure the existing in-stream uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Anti-Backsliding Requirements

Unless stated otherwise in this fact sheet, permit requirements proposed in this fact sheet are at least as stringent as existing permit requirements.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Calculation
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
TSS	XXX	XXX	XXX	30	60	75	2/month	24-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5	2/month	24-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	2/month	24-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10	2/month	24-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Calculation
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
TSS	XXX	XXX	XXX	30	60	75	2/month	24-Hr Composite
Total Copper	XXX	XXX	XXX	Report	Report	XXX	2/month	24-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5	2/month	24-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	2/month	24-Hr Composite


Compliance Sampling Location: 

Other Comments: 

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

StreamStats Report

Region ID: PA
Workspace ID: PA20250616171022829000
Clicked Point (Latitude, Longitude): 40.22080, -76.92736
Time: 2025-06-16 13:10:54 -0400



[Collapse All](#)

» Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	81.14	percent
DRNAREA	Area that drains to a point on a stream	6.25	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	5.6	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.03	miles per square mile

General Disclaimers

Parameter values have been edited, computed flows may not apply.

» Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
CARBON	Percent Carbonate	81.14	percent	0	99
DRNAREA	Drainage Area	6.25	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
ROCKDEP	Depth to Rock	5.6	feet	3.32	5.65
STRDEN	Stream Density	1.03	miles per square mile	0.51	3.1

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	3.53	ft ³ /s	38	38
30 Day 2 Year Low Flow	3.73	ft ³ /s	33	33
7 Day 10 Year Low Flow	2.63	ft ³ /s	51	51
30 Day 10 Year Low Flow	2.72	ft ³ /s	46	46
90 Day 10 Year Low Flow	2.87	ft ³ /s	36	36

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1



Discharge Information

Instructions Discharge Stream

Facility: SCI-DOC Camp Hill

NPDES Permit No.: PA0084395

Outfall No.: 001

Evaluation Type Major Sewage / Industrial Waste

Wastewater Description: Filter Backwash

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.05	289	7						

	Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
				Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod
Group 1	Total Dissolved Solids (PWS)	mg/L	446								
	Chloride (PWS)	mg/L									
	Bromide	mg/L									
	Sulfate (PWS)	mg/L									
	Fluoride (PWS)	mg/L									
Group 2	Total Aluminum	µg/L									
	Total Antimony	µg/L	< 2								
	Total Arsenic	µg/L	< 3								
	Total Barium	µg/L	0.04								
	Total Beryllium	µg/L	< 1								
	Total Boron	µg/L	< 200								
	Total Cadmium	µg/L	< 0.2								
	Total Chromium (III)	µg/L	3.7								
	Hexavalent Chromium	µg/L	3								
	Total Cobalt	µg/L	< 1								
	Total Copper	µg/L	6.3								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L	< 10								
	Dissolved Iron	µg/L	< 20								
	Total Iron	µg/L	4.5								
	Total Lead	µg/L	< 1								
	Total Manganese	µg/L	0.086								
	Total Mercury	µg/L	0.00095								
	Total Nickel	µg/L	1.7								
	Total Phenols (Phenolics) (PWS)	µg/L	< 5								
	Total Selenium	µg/L	1.3								
	Total Silver	µg/L	< 0.5								
	Total Thallium	µg/L	< 2								
	Total Zinc	µg/L	1.8								
	Total Molybdenum	µg/L	1.1								
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								
	Carbon Tetrachloride	µg/L	<								



Toxics Management Spreadsheet
Version 1.4, May 2025

Stream / Surface Water Information

Instructions Discharge Stream

SCI-DOC Camp Hill , NPDES Permit No. PA0084395, Outfall 001

Receiving Surface Water Name: **Cedar Run**

No. Reaches to Model: 1

Statewide Criteria
Great Lakes Criteria
ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	063604	1.53	357	6.25			Yes
End of Reach 1	063604	0	317	12.6			Yes

Q_{r,0}

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity y (fps)	Travel Time (days)	Tributary	Stream	Analysis
Point of Discharge	1.53	0.3176									pH
End of Reach 1	0	0.3176									Hardness

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity y (fps)	Travel Time (days)	Tributary	Stream	Analysis
Point of Discharge	1.53										pH
End of Reach 1	0										Hardness



Model Results

Toxics Management Spreadsheet
Version 1.4, May 2025

SCI-DOC Camp Hill , NPDES Permit No. PA0084395, Outfall 001

All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min): 13.076

PMF: 1

Analysis Hardness (mg/l): 107.09

Analysis pH: 7.00

CFC

CCT (min): 13.076

PMF: 1

Analysis Hardness (mg/l): 107.09

Analysis pH: 7.00

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	1.100	1.100	29.329	
Total Arsenic	0	0	0	0	340	9,065	559,914	Chem Translator of 1 applied
Total Barium	0	0	0	0	21,000	21,000	21,000	
Total Boron	0	0	0	0	8,100	8,100	215,967	
Total Cadmium	0	0	0	0	2,152	2,29	61,0	Chem Translator of 0.941 applied
Total Chromium (III)	0	0	0	0	602,635	1,907	50,847	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0	0	0	16	16,3	434	Chem Translator of 0.982 applied
Total Cobalt	0	0	0	0	95	95,0	2,533	
Total Copper	0	0	0	0	14,335	14,9	398	Chem Translator of 0.96 applied
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	69,576	89,1	2,375	Chem Translator of 0.781 applied
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	1,400	1,65	43,9	Chem Translator of 0.85 applied
Total Nickel	0	0	0	0	496,166	497	13,256	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0	0	0	3,619	4,26	114	Chem Translator of 0.85 applied
Total Thallium	0	0	0	0	65	65,0	1,733	
Total Zinc	0	0	0	0	124,181	127	3,385	Chem Translator of 0.978 applied

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	

Model Results

6/16/2025 Page 5

Total Antimony	0	0	0	0	220	220	5,866	
Total Arsenic	0	0	0	0	150	150	3,999	Chem Translator of 1 applied
Total Barium	0	0	0	0	4,100	4,100	109,317	
Total Boron	0	0	0	0	1,600	1,600	42,660	
Total Cadmium	0	0	0	0	0.258	0.28	7.59	Chem Translator of 0.906 applied
Total Chromium (III)	0	0	0	0	78,390	91.2	2,430	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0	0	0	10	10.4	277	Chem Translator of 0.86 applied
Total Cobalt	0	0	0	0	19	19.0	507	Chem Translator of 0.962 applied
Total Copper	0	0	0	0	9,495	9.89	264	Chem Translator of 0.96 applied
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	1,500	1,500	39,994	WQC = 30 day average; PMF = 1
Total Lead	0	0	0	0	2,711	3.47	92.6	Chem Translator of 0.781 applied
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	0.770	0.91	24.2	Chem Translator of 0.85 applied
Total Nickel	0	0	0	0	55,109	55.3	1,474	Chem Translator of 0.937 applied
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	4,600	4,99	133	Chem Translator of 0.922 applied
Total Silver	0	0	0	0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0	0	0	13	13.0	347	
Total Zinc	0	0	0	0	125,197	127	3,385	Chem Translator of 0.966 applied

THH CCT (min): 13.076

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc. (µg/L)	Stream CV	Trb Conc (µg/L)	Rate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	500,000	500,000	N/A	
Total Antimony	0	0	0	0	5.6	5.6	149	
Total Arsenic	0	0	0	0	10	10.0	267	
Total Barium	0	0	0	0	2,400	2,400	63,990	
Total Boron	0	0	0	0	3,100	3,100	82,654	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A	
Total Cobalt	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	
Dissolved Iron	0	0	0	0	300	300	7,999	
Total Iron	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Manganese	0	0	0	0	1,000	1,000	26,663	
Total Mercury	0	0	0	0	0.050	0.05	1.33	
Total Nickel	0	0	0	0	610	610	16,264	
Total Phenols (Phenolics) (PWS)	0	0	0	0	5	5.0	N/A	
Total Selenium	0	0	0	0	N/A	N/A	N/A	
Total Silver	0	0	0	0	N/A	N/A	N/A	
Total Thallium	0	0	0	0	0.24	0.24	6.4	
Total Zinc	0	0	0	0	N/A	N/A	N/A	

Model Results

6/16/2025

Page 6

CRL	CCT (min):	4.017	PMF:	<input type="checkbox"/> 1	Analysis Hardness (mg/l):	<input type="checkbox"/> N/A	Analysis pH:	<input type="checkbox"/> N/A
Total Dissolved Solids (PWS)	Stream Conc (mg/L)	0	Stream CV	0	WQC Conc (µg/L)	0	WQ Obj (µg/L)	WLA (µg/L)
Total Antimony	0	0			Fate Coef	0		Comments
Total Arsenic	0	0			WQC Coef	0	N/A	N/A
Total Barium	0	0			WQC Coef	0	N/A	N/A
Total Boron	0	0			WQC Coef	0	N/A	N/A
Total Cadmium	0	0			WQC Coef	0	N/A	N/A
Total Chromium (III)	0	0			WQC Coef	0	N/A	N/A
Hexavalent Chromium	0	0			WQC Coef	0	N/A	N/A
Total Cobalt	0	0			WQC Coef	0	N/A	N/A
Total Copper	0	0			WQC Coef	0	N/A	N/A
Dissolved Iron	0	0			WQC Coef	0	N/A	N/A
Total Iron	0	0			WQC Coef	0	N/A	N/A
Total Lead	0	0			WQC Coef	0	N/A	N/A
Total Manganese	0	0			WQC Coef	0	N/A	N/A
Total Mercury	0	0			WQC Coef	0	N/A	N/A
Total Nickel	0	0			WQC Coef	0	N/A	N/A
Total Phenols (Phenolics) (PWS)	0	0			WQC Coef	0	N/A	N/A
Total Selenium	0	0			WQC Coef	0	N/A	N/A
Total Silver	0	0			WQC Coef	0	N/A	N/A
Total Thallium	0	0			WQC Coef	0	N/A	N/A
Total Zinc	0	0			WQC Coef	0	N/A	N/A

7 Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Concentration Limits				Governing WQBEL Basis	WQBEL Basis	Comments
	Mass Limits	MDL (lbs/day)	AML	MDL			
Total Dissolved Solids (PWS)	N/A	N/A					PWS Not Applicable
Total Antimony	N/A	N/A					Discharge Conc < TQL
Total Arsenic	N/A	N/A					Discharge Conc < TQL
Total Barium	63,990	µg/L					Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A					No WQS
Other Results							6/1/16/2025

7 Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g. <= Target QL).

Total Boron	N/A	N/A	Discharge Conc < TOL
Total Cadmium	N/A	N/A	Discharge Conc < TOL
Total Chromium (III)	2,430	µg/L	Discharge Conc ≤ 10% WQBEL
Hexavalent Chromium	277	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cobalt	507	µg/L	Discharge Conc < TOL
Total Copper	255	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	7,999	µg/L	Discharge Conc < TOL
Total Iron	39,994	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	92.6	µg/L	Discharge Conc < TOL
Total Manganese	26,663	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	1.33	µg/L	Discharge Conc ≤ 10% WQBEL
Total Nickel	1,474	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	Discharge Conc < TOL
Total Selenium	133	µg/L	Discharge Conc ≤ 10% WQBEL
Total Silver	72.8	µg/L	Discharge Conc ≤ 10% WQBEL
Total Thallium	6.4	µg/L	Discharge Conc < TOL
Total Zinc	2,170	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS