

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0084514  
APS ID 3678  
Authorization ID 1271466

**Applicant and Facility Information**

Applicant Name	<u>Shade Gap Area Joint Municipal Authority Huntingdon County</u>	Facility Name	<u>Shade Gap STP</u>
Applicant Address	<u>PO Box 185</u> <u>Shade Gap, PA 17255-0185</u>	Facility Address	<u>22136 Croghan Pike</u> <u>Shade Gap, PA 17255-0185</u>
Applicant Contact	<u>Rory Myers</u>	Facility Contact	<u>David Hockenberry</u>
Applicant Phone	<u>(814) 259-3287</u>	Facility Phone	<u>(814) 259-3892</u>
Client ID	<u>64599</u>	Site ID	<u>449751</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Shade Gap Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Huntingdon</u>
Date Application Received	<u>April 30, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 1, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit Renewal.</u>		

**Summary of Review**

Shade Gap Area Joint Municipal Authority has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on October 17, 2014 and became effective on November 1, 2014. The permit expired on October 31, 2019 but the terms and conditions of the permit have been extended since that time.

Shade Gap Area Joint Municipal Authority owns, operates, and maintains the wastewater treatment plant located in Shade Gap Borough, Dublin Township, Huntingdon County. The aeration secondary treatment plant discharges treated municipal wastewater to Shade Creek, which is classified for Trout Stocking Fishes (TSF). The collection system has 30% sewers from Shade Gap Borough and 70% sewers from Dublin Township. The facility has a design average annual flow of 0.065 MGD. The hydraulic design capacity is 0.163 MGD.

WQM Part II No. 3192406 original was issued on November 25, 1992.

Changes from the previous permit: Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		/s/ Hilary H. Le / Environmental Engineering Specialist	January 21, 2020
X		/s/ Daniel W. Martin, P.E. / Environmental Engineer Manager	March 26, 2020
X		/s/ Maria D. Bebenek, P.E. / Clean Water Program Manager	April 07, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.065
Latitude	40° 11' 15.07"	Longitude	-77° 51' 20.53"
Quad Name	Shade Gap	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Shade Creek (TSF)	Stream Code	12806
NHD Com ID	66211959	RMI	4.6 miles
Drainage Area	19.6 mi. <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	See comments below
Q <sub>7-10</sub> Flow (cfs)	See comments below	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	880.0	Slope (ft/ft)	
Watershed No.	12-C	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	Mifflintown Borough Municipal Authority, Juniata County		
PWS Waters	Juniata River	Flow at Intake (cfs)	
PWS RMI	34.4 miles	Distance from Outfall (mi)	Approximate 64 miles

Changes Since Last Permit Issuance: none

**Drainage Area**

The discharge is to Toms Creek at RMI 4.6 miles. A drainage area upstream of the discharge is estimated to be 19.6 mi.<sup>2</sup>, according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

**Stream Flow**

There is no gage station on Shade Creek to accurately determine Q<sub>7-10</sub> flow. Therefore, Streamflow will be correlated with past streamflow records taken from the nearby USGS gage station on the Standing Stone Creek, Huntingdon county. The Q<sub>7-10</sub> is 6.85 cfs and the drainage area is 133 mi.<sup>2</sup> (according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>) which results in a Q<sub>7-10</sub> low flow yield of 0.05 cfs/mi.<sup>2</sup>. This information is used to obtain a chronic or 30-day (Q<sub>30-10</sub>), and an acute or 1-day (Q<sub>1-10</sub>) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned} \text{Low Flow Yield} &= 6.85 \text{ cfs} / 133 \text{ mi.}^2 \approx 0.05 \text{ cfs/mi.}^2 \\ \text{Q}_{7-10} \text{ discharge} &= 0.05 \text{ cfs/mi.}^2 \times \text{D.A} = 0.05 \text{ cfs/mi.}^2 \times 19.6 \text{ mi.}^2 = 1.0 \text{ cfs} \\ \text{Q}_{30-10} &= 1.36 * 1.0 \text{ cfs} \approx 1.36 \text{ cfs} \\ \text{Q}_{1-10} &= 0.64 * 1.0 \text{ cfs} \approx 0.64 \text{ cfs} \end{aligned}$$

The resulting dilution ratio (under Q<sub>7-10</sub> conditions) is: Q<sub>stream</sub> / Q<sub>discharge</sub> = 1.00 cfs / [0.065 MGD \* (1.55 cfs/MGD)] = 9.9:1

**Public Water Supply**

The closest water supply intake located downstream from the discharge is the Mifflintown Borough Municipal Authority on Juniata River located approximately 64 miles downstream. Due to dilution, this discharge is not expected to have any impact on the intake.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Shade Gap Area STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
3192406		11/25/1992		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Hypochlorite	0.065
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.163	135	Not Overloaded	Drying	Combination of methods

Changes Since Last Permit Issuance: none

The treatment plant consists:

A wet well/comminutor/bar screen, equalization tank, 2 aeration tanks, 2 settling tanks, 2 chlorine contact tanks, post aeration, sludge digester, 3 reed beds, 3 blowers, and discharge (outfall 001).

Compliance History	
<b>Summary of DMRs:</b>	DMR Data for Outfall 001 from December 1, 2018 to November 30, 2019 are summarized in the Table below (Pages # 5 & 6).
<b>Summary of Inspections:</b>	<p>11/30/2016: Mr. Clark, DEP WQS, conducted a routine compliance inspection. There were no violations noted during inspection. The field test results were within permitted limits.</p> <p>11/28/2017: Mr. Clark, DEP WQS, conducted a routine compliance inspection. There were no violations noted during inspection. The field test results were within permitted limits.</p> <p>11/27/2018: Mr. Clark, DEP WQS, conducted a compliance inspection. There were recommendations such as: post valid operator certification, replace expired #10 pH buffer, keep maintenance and repair log up to date, and report sludge accepted at the plant. Field tests results were within permitted limits.</p> <p>11/27/2019: Mr. Clark, DEP WQS, conducted a routine compliance inspection. There were no violations noted during inspection. The field test results were within permitted limits.</p>
<b>Other Comments:</b>	There were no open violations against facility or permittee.

Other Comments:

The table below summarizes the influent/effluent testing results submitted along with the application.

<i>Influent Testing Results</i>			<i>Effluent Testing Results</i>		
<b>Parameter</b>	<b>Min/Max Value</b>	<b>Average Value</b>	<b>Parameter</b>	<b>Min/Max Value</b>	<b>Average Value</b>
BOD <sub>5</sub> (mg/L)	87.9 mg/L	87.9 mg/L	pH (minimum)	6.9 S.U.	
BOD <sub>5</sub> (lbs/day)	7.18 lbs/day	7.18 lbs/day	pH (maximum)	8.0 S.U.	
TSS (mg/L)	87.0 mg/L	87.0 mg/L	D.O (minimum)	5.1 mg/L	8.2 mg/L
TSS (lbs/day)	7.11 lbs/day	7.11 lbs/day	TRC	1.60 mg/L	0.39 mg/L
TN (mg/L)	< 35.86 mg/L	< 35.83 mg/L	Fecal Coliform	9678.4 No./100mL	< 26.85 No./100mL
TN (lbs/day)	2.93 lbs/day	2.93 lbs/day	CBOD <sub>5</sub>	11.0 mg/L	< 3.94 mg/L
TP (mg/L)	3.68 mg/L	3.68 mg/L	TSS	22.0 mg/L	< 3.74 mg/L
TP (lbs/day)	0.30 lbs/day	0.30 lbs/day	NH <sub>3</sub> -N	< 0.10 mg/L	< 0.10 mg/L
NH <sub>3</sub> -N (mg/L)	4.42 mg/L	4.42 mg/L	TN	< 60.27 mg/L	< 14.09 mg/L
NH <sub>3</sub> -N (lbs/day)	0.36 lbs/day	0.36 lbs/day	TP	7.32 mg/L	2.76 mg/L
TDS (mg/L)	648 mg/L	648 mg/L	Temp	78.8 F	58.3 F
TDS (lbs/day)	52.96 lbs/day	52.96 lbs/day	TKN	14.46 mg/L	< 2.11 mg/L
Fecal Coliform	5,172,000 No./100 mL	4,172,00 No./100 mL	NO <sub>2</sub> -N + NO <sub>3</sub> -N	< 59.27 mg/L	< 11.98 mg/L
TKN	34.50 mg/L	34.50 mg/L	TDS	696 mg/L	568 mg/L
NO <sub>2</sub> -N + NO <sub>3</sub> -N	< 1.36 mg/L	< 1.36 mg/L	Chloride	231 mg/L	182 mg/L
			Bromide	< 0.40 mg/L	< 0.40 mg/L
			Sulfate	57.1 mg/L	48.3 mg/L
			Oil and Grease	< 5.15 mg/L	< 5.12 mg/L
			Total Copper	0.012 mg/L	0.011 mg/L
			Total Lead	< 0.008 mg/L	< 0.008 mg/L
			Total Zinc	0.064 mg/L	0.063 mg/L

Compliance History

DMR Data for Outfall 001 (from December 1, 2018 to November 30, 2019)

Parameter	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18
Flow (MGD) Average Monthly	0.0074	0.0104	0.0135	0.0103								
Flow (MGD) Daily Maximum	0.0177	0.0194	0.0188	0.0197								
pH (S.U.) Minimum	7.0	6.8	7.0	6.7								
pH (S.U.) Maximum	7.3	7.5	7.3	7.3								
DO (mg/L) Minimum	6.9	6.4	6.1	5.6								
TRC (mg/L) Average Monthly	0.36	0.41	0.3	0.4								
TRC (mg/L) Instantaneous Maximum	1.34	1.11	0.7	0.74								
CBOD5 (lbs/day) Average Monthly	< 0.3	< 0.4	< 0.5	< 0.4								
CBOD5 (lbs/day) Weekly Average	0.3	< 0.4	< 0.5	0.6								
CBOD5 (mg/L) Average Monthly	< 3.9	< 3.0	< 3.0	< 4.5								
CBOD5 (mg/L) Weekly Average	4.8	< 3.0	< 3.0	6.0								
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	12	7.36	25	14.0								
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	17	12.38	41	17.0								
BOD5 (mg/L) Raw Sewage Influent Average Monthly	187	78.3	163.7	134.0								
TSS (lbs/day) Average Monthly	< 0.2	< 0.45	< 0.3	0.2								
TSS (lbs/day) Raw Sewage Influent Average Monthly	6.0	10.79	18	32.0								
TSS (lbs/day) Raw Sewage Influent Daily Maximum	6.0	19.75	27	42.0								

**NPDES Permit Fact Sheet**

**NPDES Permit No. PA0084514**

**Shade Gap STP**

TSS (lbs/day) Weekly Average	0.2	0.72	0.3	0.3								
TSS (mg/L) Average Monthly	< 2.0	< 3.50	< 1.8	2.3								
TSS (mg/L) Raw Sewage Influent Average Monthly	82.0	99.00	115	288.0								
TSS (mg/L) Weekly Average	2.4	5.40	2.0	2.6								
Fecal Coliform (CFU/100 ml) Geometric Mean	< 6.0	12.81	< 4.0	< 4.0								
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 10.0	16.40	< 4.0	< 4.0								
Nitrate-Nitrite (mg/L) Average Quarterly			< 32.0									
Total Nitrogen (mg/L) Average Quarterly			< 33.0									
TKN (mg/L) Average Quarterly			< 1.0									
Total Phosphorus (mg/L) Average Quarterly			4.32									

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.065</u>
<b>Latitude</b> <u>40° 11' 9.34"</u>	<b>Longitude</b> <u>-77° 51' 46.30"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

**Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>):**

The attached computer printout of the WQM 7.0 stream model indicates that a monthly average limit of 25 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing limits of 25 mg/L monthly average (AML), 40mg/l average weekly limit (AWL), and 50 mg/L instantaneous maximum will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 25 \text{ mg/L} \times 0.065 \text{ MGD} \times 8.34 = 13.6 \text{ (14.0) lbs/day} \\ \text{Average weekly mass limit: } & 40 \text{ mg/L} \times 0.065 \text{ MGD} \times 8.34 = 21.7 \text{ (22.0) lbs/day} \end{aligned}$$

**Total Suspended Solids (TSS):**

The existing technology-based limits of 30 mg/L average monthly, 45 mg/L average weekly, and 60 mg/L instantaneous maximum will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 30 \text{ mg/L} \times 0.065 \text{ MGD} \times 8.34 = 16.3 \text{ (16.0) lbs/day} \\ \text{Average weekly mass limit: } & 45 \text{ mg/L} \times 0.065 \text{ MGD} \times 8.34 = 24.4 \text{ (24.0) lbs/day} \end{aligned}$$

**Ammonia (NH<sub>3</sub>-N):**

NH<sub>3</sub>N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached WQM 7.0 computer model of the stream:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	20°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	25°C	(Default for CWF)
*	Background NH <sub>3</sub> -N	=	0 mg/L	(Default)

The attached computer printout of the WQM 7.0 stream model indicates that no limitation on NH<sub>3</sub> as a monthly average is necessary to protect the aquatic life from toxicity effects

**Dissolved Oxygen (DO):**

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

**pH:**

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa Code § 95.2(1).

**Fecal Coliform:**

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

**Total Residual Chlorine (TRC):**

Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), the facility's discharge must meet a monthly average limit of 0.5 mg/L and an instantaneous maximum limit of 1.6 mg/L. These limits are the same as those in the existing permit. The facility has been meeting the limits consistently.

**Chesapeake Bay Strategy:**

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases I, II, and III) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase IV (0.2 -0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase V (below 0.2 MGD) will monitor during current permit renewal once a year. However, any facility in Phases IV and V that undergoes expansion is subjected to cap load right away. This plant is classified as a phase V, will be required to monitor and report for Total Phosphorus, Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, and Total Nitrogen.

Additionally, according to SOP for establishing effluent limitation for individual sewage, monitoring frequency for nutrients should be equivalent to conventional pollutants in Table 6-3 of DEP's *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001) ("Permit Writer's Manual") where the facility discharges to nutrient-impaired waters, or a lesser frequency for discharges to waters not impaired for nutrients. Quarterly monitoring frequency is required for this discharge since the receiving stream is not nutrient impaired. These requirements will remain in the proposed permit.

**Influent BOD<sub>5</sub> and TSS Monitoring:**

The permit will include influent BOD<sub>5</sub> and TSS monitoring at the same frequency as is done for effluent in order to implement 25 Pa. Code § 94.12 and assess percent removal requirements, per DEP policy.

**Biosolids Management:**

Digested Sludge is sent out periodically to the drying beds.

**Stormwater:**

There is no stormwater outfall associated with this facility.

**Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**303d Listed Streams:**

The discharge is not located on a 303d listed stream segment. The stream segment that receive the discharge is listed as attaining its used for aquatic life and fish consumption.

**Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.



*Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the proposed permit per 40 CFR § 122.44(i)(1)(ii).

*Monitoring Frequency and Sample Type*

The facility currently is required to collect daily effluent grab samples for D.O., TRC, and pH; two per month effluent 8-hr composite samples of CBOD<sub>5</sub>, and TSS; two per month effluent grab samples of Fecal Coliform; one quarter effluent 8-hr composite samples of Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, and TP; and one quarter effluent calculation samples of TN. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the existing monitoring frequencies will remain the same as those specified in the proposed permit.

**WQM 7.0**

Node 1: Outfall 001 on Shade's Creek (12806)

Elevation: 880 ft (USGS National Map Viewer)  
Drainage Area: 19.6 mi.<sup>2</sup> (USGS PA StreamStats)  
River Mile Index: 4.60 (PA DEP eMapPA)  
Low Flow Yield: 0.05 cfs/mi.<sup>2</sup>  
Discharge Flow: 0.065 MGD (NPDES Application)

Node 2: Just before confluence with Craig Run to Shade Creek

Elevation: 812 ft (USGS National Map Viewer)  
Drainage Area: 20.3 mi.<sup>2</sup> (USGS PA StreamStats)  
River Mile Index: 3.23 (PA DEP eMapPA)  
Low Flow Yield: 0.05 cfs/mi.<sup>2</sup>  
Discharge Flow: 0.000 MGD

Attachment is WQM 7.0 data.



Shade Gap WQM  
7.0 data.pdf

TRC results

<b>TRC EVALUATION</b>					
Input appropriate values in A3:A9 and D3:D9					
1	= Q stream (cfs)	0.5	= CV Daily		
0.065	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)		
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 3.191		1.3.2.iii	WLA_cfc = 3.104
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 1.189		5.1d	LTA_cfc = 1.804
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				

**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD <sub>5</sub>	14	22 Wkly Avg	XXX	25	40	50	2/month	8-Hr Composite
Total Suspended Solids	16	24 Wkly Avg	XXX	30	45	60	2/month	8-Hr Composite
BOD <sub>5</sub> Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Nitrate-Nitrite as N	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Kjeldahl Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Calculation

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD <sub>5</sub>	14.0	22.0 Wkly Avg	XXX	25.0	40.0	50.0	2/month	8-Hr Composite
TSS	16.0	24.0 Wkly Avg	XXX	30.0	45.0	60.0	2/month	8-Hr Composite
BOD <sub>5</sub> Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Nitrate-Nitrite as N	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
TKN	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Calculation

Compliance Sampling Location:     

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: No. BCW-PMT-002, revised January 6, 2020
<input type="checkbox"/>	Other: [redacted]