

Application Type Renewal  
Facility Type Industrial  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. PA0084638  
APS ID 16694  
Authorization ID 1401645

**Applicant and Facility Information**

Applicant Name	<u>Boyertown Borough</u>	Facility Name	<u>Boyertown Borough Water System</u>
Applicant Address	<u>100 S. Washington Street</u> <u>Boyertown, PA 19512-1521</u>	Facility Address	<u>1 Grandview Road</u> <u>Boyertown, PA 19512-1599</u>
Applicant Contact	<u>Patricia Loder</u>	Facility Contact	<u>Ralph Schoenly</u>
Applicant Phone	<u>(610) 369-3031</u>	Facility Phone	<u>(610) 369-3041</u>
Client ID	<u>28598</u>	Site ID	<u>866</u>
SIC Code	<u>4952</u>	Municipality	<u>Earl Township</u>
SIC Description	<u>Trans. &amp; Utilities - Water Supply</u>	County	<u>Berks</u>
Date Application Received	<u>June 30, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>July 1, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit Renewal.</u>		

**Summary of Review**

Spotts, Stevens and McCoy, on behalf of the Boyertown Borough Water System (Authority/Permittee), applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The permit was reissued on December 21, 2017 and became effective on January 1, 2018. The permit expired on December 31, 2022 but the terms and conditions of the permit have been extended since that time.

The facility is a minor industrial waste permit without Effluent Limitation Guideline (ELG). The discharge average design flow and hydraulic design capacity is 0.04 MGD, comprised mostly of filter backwash.

No WQM permit is shown in DEP's eFACTs database or reported in the permit application.

Delaware River Basin Commission

As per standard procedure, a copy of the draft permit will also be forwarded to the Delaware River Basin Commission (DRBC). Ironstone Creek is within the DE River watershed. The relevant standard Part C Condition will also be added in the permit: "This discharge may be subject to other DRBC requirements".

Changes from the previous permit: NA

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	December 1, 2023
X		<i>Maria D. Bebenek for Danial W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	December 8, 2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.04</u>
Latitude	<u>40° 20' 25.28"</u>	Longitude	<u>-75° 40' 52.74"</u>
Quad Name	<u>Boyertown</u>	Quad Code	<u></u>
Wastewater Description:	<u>Filter backwash, chlorine analyzer wastewater, floor drains, settling tank and flocculator drains</u>		
Receiving Waters	<u>Unnamed Tributary to Ironstone Creek</u>	Stream Code	<u>01664</u>
NHD Com ID	<u>25964968</u>	RMI	<u>1.5</u>
Drainage Area	<u>0.44 mi.<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>See comments below</u>
Q <sub>7-10</sub> Flow (cfs)	<u>See comments below</u>	Q <sub>7-10</sub> Basis	<u>See comments below</u>
Elevation (ft)	<u>540 (est'd)</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>3-D</u>	Chapter 93 Class.	<u>TSF, MF</u>
Existing Use	<u>CWF (Cold Water Fishes)</u>	Existing Use Qualifier	<u>Coldwater Community</u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s),</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u>None</u>	Name	<u></u>
Nearest Downstream Public Water Supply Intake	<u>North Coventry Township Water Authority, Chester County</u>		
PWS Waters	<u>Schuylkill River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>Approximate 11.2 miles</u>

Changes Since Last Permit Issuance:

**Drainage Area**

The discharge is to UNT to Ironstone at RMI 1.50 miles. A drainage area upstream of the discharge is estimated to be 0.44 mi.<sup>2</sup>, according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

**Streamflow**

There is a category B-1 High Hazard Dam at Boyertown Reservoir just upstream of this discharge point, the PA Stream Stats Q<sub>7-10</sub> could not be relied upon. The nearest USGS Streamgage is 01471980 in Pottstown, PA which is approximately 8.1 miles downstream of the discharge point hence is not representative. Moreover, stream flow data collected from USGS StreamStats indicated some parameters are outside of the recommended range for regression analysis to calculate low flows. The drainage area was found to be 85.5 mi<sup>2</sup> at the gage, Q<sub>7-10</sub>, and Q<sub>30-10</sub> values at this gage are 22.9 cfs, and 25.7 cfs. As a result, low flows were estimated using the Low-Flow Yield approach as follows:

$$\begin{aligned}
 \text{Yield} &= 22.9 \text{ cfs}/85.5 \text{ mi}^2 = 0.27 \text{ cfs}/\text{mi}^2 \\
 Q_{7-10} &= 0.27 \text{ cfs}/\text{mi}^2 * 0.44 \text{ mi}^2 = 0.12 \text{ cfs} \\
 Q_{30-10} &= 0.12 \text{ cfs} * 1.36 = 0.16 \text{ cfs} \\
 Q_{1-10} &= 0.12 \text{ cfs} * 0.64 = 0.08 \text{ cfs}
 \end{aligned}$$

**Receiving Water Characteristics**

Under 25 Pa Code §93.9f, Trib. 01664 to Ironstone Creek is designated as Trout Stocking Fishes and Migratory Fishes (TSF & MF). The discharge is located within a stream segment listed as attaining uses.

**Water Supply Intake**

The nearest downstream public water supply intake is North Coventry Township Water Authority located on the Schuylkill River, in Chester County, approximately 11.2 miles from the point of discharge. Based on the dilution and nature of discharge, the discharge is not expected to impact the water supply intake.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Boyertown Boro/ lw				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
None in database		-		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Industrial	Physical (Industrial Waste), Physical (Industrial Waste)	Filtration, Flocculation	Chlorine With Dechlorination	0.04
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.04		Not Overloaded	Concentration	Land Application

Changes Since Last Permit Issuance: none

The plant has a rated capacity of 0.79 MGD. The unit processes include aeration basin, rapid mixer and flocculation tanks, sedimentation, multimedia filters, a clear well, and two lagoons. The discharge is filter backwash, chlorine analyzer wastewater, floor drains, settling tank and flocculator drains.

Two sedimentation basins in series have been provided for sludge and filter backwash.

**Chemicals:**

Powdered activated carbon is used for taste and odor control. DeIPAC 2020 is used for coagulation. Soda ash is used for pH adjustment/corrosion control. Chlorine (gaseous) is used for disinfection. Ammonia (gaseous) is used for chloramine formation. Sodium Thiosulfate is used for dechlorination.

Compliance History	
<b>Summary of DMRs:</b>	A summary of past 12-month DMRs is presented on next pages.
<b>Summary of Inspections:</b>	<b>9/8/2020:</b> Ms. Tomtishen, DEP's WQS, conducted a compliance evaluation inspection. Recommendations were please update contact information in onsite Emergency Response Plan, including DEP's 24-hour ER Number 1-800-541-2050, and maintain hard copies of laboratory sample results and chain of custody forms with monthly DMRs for minimum of 3 years in accordance with Part A.III.A.2 of your NPDES permit. There were no violations identified during inspection. The field test results were within permit limits.
<b>Other Comments:</b>	There are currently no open violations associated with the permittee or the facility.

**Other Comments:**

The DEP Inspector's sample on 11/19/2020 results are shown below:

Parameter	Units	10/19/2020
pH	s.u.	6.91
D.O.	mg/L	-
TRC	mg/L	0.15
TSS	mg/L	< 5.0
Temperature	°C	23.0
Total Aluminum	ug/L	370.0
Total Iron	ug/L	< 100.0
Total Manganese	ug/L	138.0

Compliance History

DMR Data for Outfall 001 (from October 1, 2022 to September 30, 2023)

Parameter	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22
Flow (MGD) Average Monthly	0.027	0.051	0.057	0.052	0.046	0.044	0.034	0.031	0.034	0.037	0.035	0.039
Flow (MGD) Daily Maximum	0.070	0.076	0.080	0.096	0.065	0.109	0.041	0.039	0.045	0.058	0.083	0.062
pH (S.U.) Minimum	6.6	6.8	7.0	6.9	6.8	6.9	6.7	6.7	6.9	7.0	6.9	6.7
pH (S.U.) IMAX	7.7	8.6	7.8	7.7	7.8	7.9	7.9	8.0	7.8	7.7	8.4	7.4
TRC (mg/L) Average Monthly	0.15	0.14	0.14	0.12	0.06	0.07	0.09	0.16	0.16	0.13	0.08	0.06
TRC (mg/L) IMAX	0.31	0.37	0.38	0.26	0.20	0.23	0.27	0.35	0.42	0.41	0.29	0.18
TSS (lbs/day) Average Monthly	1.45	0.92	1.63	1.14	1.04	0.41	0.72	0.79	0.45	0.48	0.44	1.09
TSS (lbs/day) Daily Maximum	2.62	1.79	3.85	3.14	2.75	0.61	1.85	1.24	0.85	0.61	0.50	2.13
TSS (mg/L) Average Monthly	4.8	2.0	3.5	2.5	2.4	1.3	2.5	3.0	1.6	1.8	1.6	2.8
TSS (mg/L) Daily Maximum	7.0	4.0	9.0	7.0	6.0	2.0	6.0	5.0	3.0	3.0	2.0	5.0
Total Aluminum (lbs/day) Average Monthly	0.10	0.18	0.22	0.20	0.23	0.11	0.08	0.07	0.10	0.13	0.13	0.15
Total Aluminum (lbs/day) Daily Maximum	0.19	0.22	0.30	0.32	0.31	0.19	0.09	0.09	0.14	0.17	0.37	0.23
Total Aluminum (mg/L) Average Monthly	0.33	0.41	0.44	0.42	0.55	0.34	0.29	0.26	0.37	0.41	0.41	0.40
Total Aluminum (mg/L) Daily Maximum	0.43	0.57	0.53	0.55	0.72	0.49	0.30	0.34	0.54	0.57	1.01	0.51
Total Iron (lbs/day) Average Monthly	0.03	0.02	0.05	0.02	0.07	0.01	0.01	0.01	0.03	0.03	0.01	0.05
Total Iron (lbs/day) Daily Maximum	0.05	0.03	0.07	0.03	0.29	0.02	0.01	0.02	0.03	0.05	0.01	0.09
Total Iron (mg/L) Average Monthly	0.12	0.05	0.09	0.05	0.17	0.04	0.02	0.04	0.09	0.10	0.03	0.12

**NPDES Permit Fact Sheet  
Boyertown Borough Water System**

**NPDES Permit No. PA0084638**

Total Iron (mg/L) Daily Maximum	0.14	0.07	0.12	0.06	0.67	0.05	0.03	0.07	0.12	0.15	0.04	0.21
Total Manganese (lbs/day) Average Monthly	0.06	0.14	0.21	0.22	0.06	0.02	0.02	0.08	0.02	0.02	0.03	0.03
Total Manganese (lbs/day) Daily Maximum	0.09	0.19	0.33	0.24	0.09	0.02	0.02	0.14	0.02	0.03	0.05	0.03
Total Manganese (mg/L) Average Monthly	0.23	0.32	0.44	0.48	0.14	0.07	0.08	0.29	0.06	0.06	0.08	0.07
Total Manganese (mg/L) Daily Maximum	0.33	0.42	0.77	0.66	0.21	0.08	0.09	0.56	0.08	0.08	0.12	0.08

Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	0.04
Latitude	40° 20' 25.28"	Longitude	-75° 40' 52.74"
Wastewater Description: Water Treatment Effluent			

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation	State Developed TBEL
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)	DEP Technical Guidance Document 362-2183-003
	60	Daily Maximum	133.102(b)(2)	92a.47(a)(2)	
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)	DEP Technical Guidance Document 362-2183-003
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)	DEP Technical Guidance Document 362-2183-003
Total Iron	2	Average Monthly			DEP Technical Guidance Document 362-2183-003
	4	Daily Maximum			DEP Technical Guidance Document 362-2183-003
Total Aluminum	4	Average Monthly			DEP Technical Guidance Document 362-2183-003
	8	Daily Maximum			DEP Technical Guidance Document 362-2183-003
Total Manganese	1	Average Monthly			DEP Technical Guidance Document 362-2183-003
	2	Daily Maximum			DEP Technical Guidance Document 362-2183-003

**Water Quality-Based Limitations**

**pH:**  
The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

**Total Residual Chlorine (TRC):**  
Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department’s May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), the facility’s discharge must meet a monthly average limit of 0.29 (0.3) mg/L and an instantaneous maximum limit of 0.96 (0.9) mg/L for a design flow of 0.04 MGD. The existing limit of 0.3 mg/L AML & 0.9 mg/L IMAX will remain in the proposed permit. Minimum monitoring frequency will be 1/day.

TRC EVALUATION			
Input appropriate values in A3:A9 and D3:D9			
0.12	= Q stream (cfs)	0.5	= CV Daily
0.04	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)
Source	Reference	AFC Calculations	Reference CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.638	1.3.2.iii WLA_cfc = 0.614
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.238	5.1d LTA_cfc = 0.357
Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.292	
		INST MAX LIMIT (mg/l) = 0.956	
WLA_afc	(.019/e <sup>-k*AFC_tc</sup> ) + [(AFC_Yc*Qs*.019/Qd*e <sup>-k*AFC_tc</sup> )]... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)		
LTAMULT_afc	EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)		
LTA_afc	wla_afc*LTAMULT_afc		
WLA_cfc	(.011/e <sup>-k*CFC_tc</sup> ) + [(CFC_Yc*Qs*.011/Qd*e <sup>-k*CFC_tc</sup> )]... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)		
LTAMULT_cfc	EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)		
LTA_cfc	wla_cfc*LTAMULT_cfc		
AML MULT	EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))		
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)		
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)		

**Total Suspended Solids (TSS):**

The existing limits of 30.0 mg/L average monthly, 60.0 mg/L weekly average, and 75.0 mg/L IMAX will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations below these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 30.0 \text{ mg/L} \times 0.04 \text{ MGD} \times 8.34 = 10.0 \text{ lbs/day} \\ \text{Average weekly mass limit: } & 60.0 \text{ mg/L} \times 0.04 \text{ MGD} \times 8.34 = 20.0 \text{ lbs/day} \end{aligned}$$

**TDS Baseline:**

State regulations have requirements for significant increases from 2010 TDS loads. Fact Sheets are documenting the existing TDS loads at facilities as baselines which can be used to calculate future load 'increases'. Chapter 95.10(a)(1) states that "existing mass loads" will be considered maximum daily discharge loads of TDS...that were authorized by the Department prior to August 21, 2010. This facility's 2022 NPDES permit application indicated a maximum TDS effluent concentration of 134.0 mg/L, based on three effluent samples. The resulting TDS load would be 44.7 (45.0) lbs/day: 134.0 mg/l TDS x 0.04 MGD x 8.34 c.f.

**Stormwater:**

The renewal application also indicates that there are no stormwater outfalls or outfalls with combined stormwater and industrial wastewater. No stormwater outfall annual inspection or stormwater sampling requirements are applicable.

**Nutrients:**

Their application did not show nutrient concentrations in their discharge at levels of concern. Based on three effluent samples, the maximum concentrations were as follows: 0.44 mg/L for NO<sub>3</sub>-NO<sub>2</sub>, <0.5 mg/L for TKN, <0.06 mg/L for Ammonia, and <0.01 mg/L for Total Phosphorus. No monitoring requirement has therefore been added.

**Chemical Additives:**

The application did not show any "chemical additives" in use, as defined by the application instructions and DEP's Standard Operating Procedure (SOP) for Chemical Additives.

**Anti-Backsliding:**

No limits in this renewal permit are less stringent than in the previous permit. Federal and State regulations which prohibit back-sliding (with some exceptions) are therefore satisfied.

**Antidegradation:**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No Exceptional Value (EV) waters are impacted by this discharge. At this time, the downstream water has not been designated a High Quality (HQ) water. If it becomes a HQ water, after appropriate assessment and a public comment period, this facility's existing discharge will be "grandfathered", but it would have to satisfy the requirements at 25 PA Code Chapter 94c for any future proposed increases in flow or pollutant loads. These requirements include evaluating non-discharge alternatives or demonstrating that the discharge will maintain and protect the existing quality of the receiving surface water or obtaining a Social or Economic Justification (SEJ).

The discharge is into Trib. 01664 to Ironstone Creek which Ironstone Creek has been listed by the PA Fish and Boat Commission as under consideration for designation as a Class A Wild Trout Water. If that happens, the downstream receiving water would become a "High-Quality" water. Loads from existing dischargers would be "grandfathered" but any increased loading would be subject to DEP's antidegradation policies and regulations.

**Additional Considerations:**

Because the downstream receiving water is designated as Natural Trout Reproduction, the Dissolved Oxygen (D.O.) water quality criteria for certain months is higher than for other CWF waters: 8.0 mg/L during October-May. This discharge is not high in organic content and is not expected to interfere with this designation. The renewal 2022 application indicated <2.0 mg/L for BOD<sub>5</sub> and <2.5 mg/L for COD, based on three effluent samples. The DEP inspector sampled for D.O. at least once with a result of 10.6 mg/L. No limit or monitoring requirement has therefore been imposed for D.O.

**Flow Monitoring:**

Flow monitoring will remain in the proposed permit and is required by 40 CFR § 122.44(i)(1)(ii).

**Other:**

WQBELs are developed based on the designated and existing use of the particular receiving water, Water Quality Standards including water quality criteria [25 Pa Code Chapter 93 and 96], and an analysis of the reasonable potential to cause an in-stream exceedance of water quality criteria.

DEP uses:

1) The WQM 7.0 model, when applicable.

Because this discharge has very low **Ammonia** concentrations and **CBOD<sub>5</sub>** concentrations per their application and as would be expected from such operations, the WQM 7.0 model would not normally be run, consistent with DEP Standard Operating Procedures for Individual Industrial NPDES Permits. No permit limit or monitoring requirement is proposed for Ammonia and CBOD<sub>5</sub> or BOD<sub>5</sub>.

2) The Toxics Management Spreadsheet/model (TMS), when applicable.

The following input data were used for Toxic Management Spreadsheet (TMS) Analysis:

- Discharge pH = 7.38 (6.96 + 7.8 = 7.38) (Renewal Application)
- Stream pH = 7.0 (Default)
- Discharge Hardness = 39.3 mg/L (Renewal Application)
- Stream Hardness = 100 mg/L (Default)

Node 1: Outfall 001 at Trib. 01664 to Ironstone Creek (01664)  
 Elevation: 540.00 ft (USGS National Map)  
 Drainage Area: 0.44 mi<sup>2</sup> (USGS StreamStats)  
 River Mile Index: 1.50 (PA DEP eMapPA)  
 Low Flow Yield: 0.27 cfs/mi<sup>2</sup>  
 Discharge Flow: 0.04 MGD

Node 2: At the confluence to Ironstone Creek (01658)  
 Elevation: 380.00 ft (USGS National Map)  
 Drainage Area: 0.71 mi<sup>2</sup> (USGS StreamStats)  
 River Mile Index: 0.001 (PA DEP eMapPA)  
 Low Flow Yield: 0.27 cfs/mi<sup>2</sup>  
 Discharge Flow: 0.00 MGD

This data was analyzed based on the guidelines found in DEP's Water Quality Toxics Management Strategy (Document No. 361-0100-003) and DEP's SOP No. BPNPSM-PMT-033. Spreadsheet results are attached to this fact sheet. The Toxics Management Spreadsheet uses the following logic:



- a. Establish average monthly and IMAX limits in the draft permit where the maximum reported concentration exceeds 50% of the WQBEL.
- b. For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25%-50% of the WQBEL.
- c. For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10%-50% of the WQBEL.

DEP's Toxics Management spreadsheet was utilized to perform a reasonable potential analysis and develop water quality effluent limits for toxic pollutants. Summarized information are in the Table below.

Parameter	Calculated WQBEL (units)	Model	Comments	Recommended
Total Aluminum	1,404 ug/L (1.404 mg/L)	TMS	Discharge Concentration less than or equal 10% WQBEL	Not needed
Total Iron	4,380 ug/L (4.380 mg/L)	TMS	Discharge Concentration less than Target QL	Not needed
Total Manganese	2,920 ug/L (2.920 mg/L)	TMS	Discharge Concentration less than or equal 10% WQBEL	Not needed

The TMS analysis results limits of Total Aluminum, Total Iron, and Total Manganese shown in the Table above, which are higher than the existing limits requirements; therefore, the existing limits of these pollutants are more stringent and will remain in the proposed permit.





USGS StreamStats  
science for a changing world

SELECT A STATE / REGION  
Pennsylvania

IDENTIFY A STUDY AREA  
Basin Delineated

SELECT SCENARIOS

**BUILD A REPORT** Report Built

**Step 1:** You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS  
Accessibility FOIA Privacy Policy & Notices

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	7.9998	degrees
DRNAREA	Area that drains to a point on a stream	0.44	square miles
ROCKDEP	Depth to rock	5	feet
URBAN	Percentage of basin with urban development	0.235	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]


Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.44	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	7.9998	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5	feet	4.13	5.21
URBAN	Percent Urban	0.235	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.212	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.241	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.108	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.129	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.157	ft <sup>3</sup> /s



USGS StreamStats  
science for a changing world

SELECT A STATE / REGION  
Pennsylvania

IDENTIFY A STUDY AREA  
Basin Delineated

SELECT SCENARIOS

**BUILD A REPORT** Report Built

**Step 1:** You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS  
Accessibility FOIA Privacy Policy & Notices

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	8.2572	degrees
DRNAREA	Area that drains to a point on a stream	0.71	square miles
ROCKDEP	Depth to rock	5	feet
URBAN	Percentage of basin with urban development	0.1472	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]


Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.71	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	8.2572	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5	feet	4.13	5.21
URBAN	Percent Urban	0.1472	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.356	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.401	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.189	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.221	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.262	ft <sup>3</sup> /s



USGS StreamStats  
 science for a changing world

SELECT A STATE / REGION  
 Pennsylvania

IDENTIFY A STUDY AREA  
 Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button.

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS  
 Accessibility FOIA Privacy Policy & Notices

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	6.446	degrees
DRNAREA	Area that drains to a point on a stream	85.5	square miles
ROCKDEP	Depth to rock	5.1	feet
URBAN	Percentage of basin with urban development	2.2204	percent

> Low-Flow Statistics

Low-Flow Statistics Parameters [99.9 Percent (85.4 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	85.5	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	6.446	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.1	feet	4.13	5.21
URBAN	Percent Urban	2.2204	percent	0	89

Low-Flow Statistics Disclaimers [99.9 Percent (85.4 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [99.9 Percent (85.4 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	36.8	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	41.8	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	22.9	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	25.7	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	31.1	ft <sup>3</sup> /s

Low-Flow Statistics Citations

processor Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Displaying simplified Basin. See FAQ for more information.

NPDES Permit Fact Sheet  
Boyetown Borough Water System

NPDES Permit No. PA0084638



Toxic Management Spreadsheet  
Version 1.4, May 2023

Discharge Information

Instructions Discharge Stream

Facility: Boyertown Borough NPDES Permit No.: PA0084638 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Trib 01884 to Ironstone Creek

Design Flow (MGD)*	Hardness (mg/l)*	pH (8U)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	G <sub>10</sub>	G <sub>5</sub>
0.04	39.3	7.38						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod
<b>Group 1</b>										
Total Dissolved Solids (PWS)	mg/L	134								
Chloride (PWS)	mg/L	28.2								
Bromide	mg/L	< 0.1								
Sulfate (PWS)	mg/L	15								
Fluoride (PWS)	mg/L	< 1								
<b>Group 2</b>										
Total Aluminum	ug/L	1.27								
Total Arsenic	ug/L	< 0.003								
Total Barium	ug/L	< 0.001								
Total Beryllium	ug/L	< 0.001								
Total Boron	ug/L	< 0.2								
Total Cadmium	ug/L	< 0.0001								
Total Chromium (III)	ug/L	< 0.001								
Hexavalent Chromium	ug/L	< 0.00025								
Total Cobalt	ug/L	< 0.005								
Total Copper	ug/L	< 0.001								
Free Cyanide	ug/L	< 0.01								
Total Cyanide	ug/L	< 0.02								
Dissolved Iron	ug/L	< 0.33								
Total Iron	ug/L	< 0.002								
Total Lead	ug/L	< 0.002								
Total Manganese	ug/L	< 0.879								
Total Mercury	ug/L	< 0.0002								
Total Nickel	ug/L	< 0.001								
Total Phenols (Phenolics) (PWS)	ug/L	< 0.004								
Total Selenium	ug/L	< 0.001								
Total Silver	ug/L	< 0.0002								
Total Thallium	ug/L	< 0.005								
Total Zinc	ug/L	< 0.003								
Total Molybdenum	ug/L	< 0.003								
Acrolein	ug/L	< 0.001								
Acrylamide	ug/L	< 0.001								
Acrylonitrile	ug/L	< 0.001								
Benzene	ug/L	< 0.001								
Bromoform	ug/L	< 0.001								

Carbon Tetrachloride	ug/L	< 0.001								
Chlorobenzene	ug/L	< 0.001								
Chlorodibromomethane	ug/L	< 0.001								
Chloroethane	ug/L	< 0.001								
2-Chloroethyl Vinyl Ether	ug/L	< 0.001								
Chloroform	ug/L	< 0.001								
Dichlorobromomethane	ug/L	< 0.001								
1,1-Dichloroethane	ug/L	< 0.001								
1,2-Dichloroethane	ug/L	< 0.001								
1,1,2-Dichloroethylene	ug/L	< 0.001								
1,2-Dichloropropane	ug/L	< 0.001								
1,3-Dichloropropylene	ug/L	< 0.001								
1,4-Dioxane	ug/L	< 0.001								
Ethylbenzene	ug/L	< 0.001								
Methyl Bromide	ug/L	< 0.001								
Methyl Chloride	ug/L	< 0.001								
Methylene Chloride	ug/L	< 0.001								
1,1,2,2-Tetrachloroethane	ug/L	< 0.001								
Tetrachloroethylene	ug/L	< 0.001								
Toluene	ug/L	< 0.001								
1,2-Di(2-chloroethyl)ethane	ug/L	< 0.001								
1,1,1-Trichloroethane	ug/L	< 0.001								
1,1,2-Trichloroethane	ug/L	< 0.001								
Trichloroethylene	ug/L	< 0.001								
Vinyl Chloride	ug/L	< 0.001								
2-Chlorophenol	ug/L	< 0.001								
2,4-Dichlorophenol	ug/L	< 0.001								
2,4-Dimethylphenol	ug/L	< 0.001								
4,6-Dinitro-o-Cresol	ug/L	< 0.001								
2,4-Dinitrophenol	ug/L	< 0.001								
2-Nitrophenol	ug/L	< 0.001								
4-Nitrophenol	ug/L	< 0.001								
p-Chloro-o-Cresol	ug/L	< 0.001								
Para-chlorophenol	ug/L	< 0.001								
Phenol	ug/L	< 0.001								
2,4,6-Trichlorophenol	ug/L	< 0.001								
Acenaphthene	ug/L	< 0.001								
Acenaphthylene	ug/L	< 0.001								
Anthracene	ug/L	< 0.001								
Benzo(a)Anthracene	ug/L	< 0.001								
Benzo(a)Pyrene	ug/L	< 0.001								
3,4-Benzofluoranthene	ug/L	< 0.001								
Benzo(g)Perylene	ug/L	< 0.001								
Benzo(k)Fluoranthene	ug/L	< 0.001								
Benzo(b)Fluoranthene	ug/L	< 0.001								
Benzo(e)Perylene	ug/L	< 0.001								
Benzo(i)Perylene	ug/L	< 0.001								
Benzo(j)Fluoranthene	ug/L	< 0.001								
Benzo(k)Fluoranthene	ug/L	< 0.001								
Benzo(l)Acenaphthylene	ug/L	< 0.001								
Benzo(m)Perylene	ug/L	< 0.001								
Benzo(n)Fluoranthene	ug/L	< 0.001								
Benzo(o)Fluoranthene	ug/L	< 0.001								
Benzo(p)Fluoranthene	ug/L	< 0.001								
Benzo(q)Fluoranthene	ug/L	< 0.001								
Benzo(r)Fluoranthene	ug/L	< 0.001								
Benzo(s)Fluoranthene	ug/L	< 0.001								
Benzo(s)Indene	ug/L	< 0.001								
Benzo(t)Fluoranthene	ug/L	< 0.001								
Benzo(u)Fluoranthene	ug/L	< 0.001								
Benzo(v)Fluoranthene	ug/L	< 0.001								
Benzo(w)Fluoranthene	ug/L	< 0.001								
Benzo(x)Fluoranthene	ug/L	< 0.001								
Benzo(y)Fluoranthene	ug/L	< 0.001								
Benzo(z)Fluoranthene	ug/L	< 0.001								
1,2-Dichlorobenzene	ug/L	< 0.001								
1,3-Dichlorobenzene	ug/L	< 0.001								
1,4-Dichlorobenzene	ug/L	< 0.001								
3,3-Dichlorobenzidine	ug/L	< 0.001								
Diethyl Phthalate	ug/L	< 0.001								
Dimethyl Phthalate	ug/L	< 0.001								
Di-n-Butyl Phthalate	ug/L	< 0.001								
2,4-Dinitrotoluene	ug/L	< 0.001								





Toxic Management Spreadsheet  
Version 1.4, May 2023

Model Results

Boyerstown Borough, NPDES Permit No. PA0084683, Outfall 001

Instructions Results RETURN TO INPUTS SAVE AS PDF PRINT  All  Inputs  Results  Limits

Hydrodynamics

Wasteload Allocations

AFC OCT (min): 0.303 PMF: 1 Analysis Hardness (mg/l): 79.211 Analysis pH: 7.10

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	750	750	2,190	
Total Antimony	0	0	0	0	1,100	1,100	3,212	
Total Arsenic	0	0	0	0	340	340	993	Chem Translator of 1 applied
Total Barium	0	0	0	0	21,000	21,000	61,317	
Total Boron	0	0	0	0	8,100	8,100	23,651	
Total Cadmium	0	0	0	0	1,605	1,68	4,91	Chem Translator of 0.954 applied
Total Chromium (III)	0	0	0	0	470.761	1,490	4,350	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0	0	0	16	16.3	47.6	Chem Translator of 0.982 applied
Total Cobalt	0	0	0	0	95	95.0	277	
Total Copper	0	0	0	0	10,790	11.2	32.8	Chem Translator of 0.96 applied
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	50,063	60.7	177	Chem Translator of 0.825 applied
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	1,400	1.65	4.81	Chem Translator of 0.85 applied
Total Nickel	0	0	0	0	384.448	385	1,125	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0	0	0	2,154	2.53	7.4	Chem Translator of 0.85 applied
Total Thallium	0	0	0	0	65	65.0	190	
Total Zinc	0	0	0	0	96,183	98.3	287	Chem Translator of 0.978 applied

Model Results

11/29/2023

Page 5

CFC OCT (min): 0.303 PMF: 1 Analysis Hardness (mg/l): 79.211 Analysis pH: 7.10

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	220	220	642	
Total Arsenic	0	0	0	0	150	150	438	Chem Translator of 1 applied
Total Barium	0	0	0	0	4,100	4,100	11,971	
Total Boron	0	0	0	0	1,600	1,600	4,672	
Total Cadmium	0	0	0	0	0.209	0.23	0.66	Chem Translator of 0.919 applied
Total Chromium (III)	0	0	0	0	61.236	71.2	208	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0	0	0	10	10.4	30.4	Chem Translator of 0.962 applied
Total Cobalt	0	0	0	0	19	19.0	55.5	
Total Copper	0	0	0	0	7,339	7.64	22.3	Chem Translator of 0.96 applied
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	1,500	1,500	4,380	WQC = 30 day average; PMF = 1
Total Lead	0	0	0	0	1,951	2.36	6.9	Chem Translator of 0.825 applied
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	0,770	0.91	2.65	Chem Translator of 0.85 applied
Total Nickel	0	0	0	0	42,700	42.8	125	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	4,800	4.99	14.6	Chem Translator of 0.922 applied
Total Silver	0	0	0	0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0	0	0	13	13.0	38.0	
Total Zinc	0	0	0	0	96,970	98.3	287	Chem Translator of 0.986 applied

THH OCT (min): 0.303 PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	500,000	500,000	N/A	
Chloride (PWS)	0	0	0	0	250,000	250,000	N/A	
Sulfate (PWS)	0	0	0	0	250,000	250,000	N/A	
Fluoride (PWS)	0	0	0	0	2,000	2,000	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	5.6	5.6	16.4	
Total Arsenic	0	0	0	0	10	10.0	29.2	
Total Barium	0	0	0	0	2,400	2,400	7,008	
Total Boron	0	0	0	0	3,100	3,100	9,052	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	

Model Results

11/29/2023

Page 6

Hexavalent Chromium	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	N/A	N/A	N/A
Dissolved Iron	0	0	0	300	300	876
Total Iron	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	1,000	1,000	2,920
Total Mercury	0	0	0	0.050	0.05	0.15
Total Nickel	0	0	0	610	610	1,781
Total Phenols (Phenolics) (PWS)	0	0	0	5	5.0	N/A
Total Selenium	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0.24	0.24	0.7
Total Zinc	0	0	0	N/A	N/A	N/A

CRL      OCT (min):       PMP:       Analysis Hardness (mg/l):       Analysis pH:

Pollutants	Stream Conc (ug/L)	Stream CV	Trib Conc (ug/L)	Fate Coef	WQC (ug/L)	WQ Obj (ug/L)	WLA (ug/L)	Comments
Total Dissolved Solids (FWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	N/A	N/A	N/A	
Total Arsenic	0	0	0	0	N/A	N/A	N/A	
Total Barium	0	0	0	0	N/A	N/A	N/A	
Total Boron	0	0	0	0	N/A	N/A	N/A	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A	
Total Cobalt	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	N/A	N/A	N/A	
Total Nickel	0	0	0	0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	N/A	
Total Silver	0	0	0	0	N/A	N/A	N/A	
Total Thallium	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits			Units	Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX				

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (FWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	1,404	ug/L	Discharge Conc <= 10% WQBEL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	7,008	ug/L	Discharge Conc <= 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	4,672	ug/L	Discharge Conc < TQL
Total Cadmium	0.66	ug/L	Discharge Conc < TQL
Total Chromium (III)	208	ug/L	Discharge Conc < TQL
Hexavalent Chromium	30.4	ug/L	Discharge Conc < TQL
Total Cobalt	55.5	ug/L	Discharge Conc < TQL
Total Copper	21.0	ug/L	Discharge Conc < TQL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	876	ug/L	Discharge Conc < TQL
Total Iron	4,380	ug/L	Discharge Conc < TQL
Total Lead	6.9	ug/L	Discharge Conc < TQL
Total Manganese	2,920	ug/L	Discharge Conc <= 10% WQBEL
Total Mercury	0.15	ug/L	Discharge Conc < TQL
Total Nickel	125	ug/L	Discharge Conc < TQL
Total Phenols (Phenolics) (PWS)		ug/L	Discharge Conc < TQL
Total Selenium	14.6	ug/L	Discharge Conc < TQL
Total Silver	4.74	ug/L	Discharge Conc < TQL
Total Thallium	0.7	ug/L	Discharge Conc < TQL
Total Zinc	184	ug/L	Discharge Conc < TQL
Total Molybdenum	N/A	N/A	No WQS

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/day	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/day	Grab
TRC	XXX	XXX	XXX	0.3	XXX	0.9	1/day	Grab
TSS	10	20	XXX	30.0	60.0	75	1/week	24-Hr Composite
Total Aluminum	0.4	0.7	XXX	1.3	2.1	3.3	1/week	24-Hr Composite
Total Iron	0.7	1.3	XXX	2.0	4.0	5	1/week	24-Hr Composite
Total Manganese	0.3	0.7	XXX	1.0	2.0	2.5	1/week	24-Hr Composite



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/day	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
TRC	XXX	XXX	XXX	0.3	XXX	0.9	1/day	Grab
TSS	10.0	20.0	XXX	30.0	60.0	75.0	1/week	24-Hr Composite
Total Aluminum	0.4	0.7	XXX	1.3	2.1	3.3	1/week	24-Hr Composite
Total Iron	0.7	1.3	XXX	2.0	4.0	5.0	1/week	24-Hr Composite
Total Manganese	0.3	0.7	XXX	1.0	2.0	2.5	1/week	24-Hr Composite

Compliance Sampling Location:     

Other Comments:

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input checked="" type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]