



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0084646

APS ID

278297

Authorization ID

1495603

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Applicant and Facility Information

Applicant Name	Southern Fulton School District	Facility Name	Southern Fulton Elementary School
Applicant Address	3072 Great Cove Road, Suite 100 Warfordsburg, PA 17267-8530	Facility Address	3072 Great Cove Road Warfordsburg, PA 17267-8530
Applicant Contact	James Will	Facility Contact	James Will
Applicant Phone	(717) 830-6690	Facility Phone	(717) 830-6690
Client ID	44393	Site ID	2355
Ch 94 Load Status	Not Overloaded	Municipality	Bethel Township
Connection Status		County	Fulton
Date Application Received	August 14, 2024	EPA Waived?	Yes
Date Application Accepted	August 16, 2024	If No, Reason	
Purpose of Application	NPDES permit renewal.		

Summary of Review

Southern Fulton School District has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on January 28, 2020, and became effective on February 1, 2020. The permit expired on January 31, 2025.

The annual average design flow and hydraulic flow is 0.01 MGD. The discharge is to UNT to White Oak Run.

Sludge use and disposal description and location(s): N/A because sludge is hauling by County Septic contractor.

Changes from the previous permit: The E. Coli monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	December 24, 2024
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	January 27, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.01
Latitude	39° 47' 42.90"	Longitude	-78° 11' 21.04"
Quad Name	Needmore	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	UNT to White Oak Run (TSF)	Stream Code	60898
NHD Com ID	49477866	RMI	0.09 mile
Drainage Area	0.8 mi. ²	Yield (cfs/mi ²)	See comments below
Q ₇₋₁₀ Flow (cfs)	See comments below	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)		Slope (ft/ft)	
Watershed No.	13-B	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	R.C. Wilson Water Treatment Plant near Williamsport, MD		
PWS Waters	Potomac River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	Approximate 23.0 miles

Drainage Area

The discharge is to Unnamed Tributary to White Oak Run at RMI 0.09 mile. A drainage area upstream of the discharge is estimated to be 0.8 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, the discharge point on Unnamed Tributary to White Oak Run has a Q₇₋₁₀ of 0.00502 cfs and a drainage area of 0.8 mi.² (resulting in a low flow yield of 0.00628 cfs/mi.²). However, the drainage area at the discharge point is well below the minimum value for the regression equations used. Therefore, the entire White Oak Run watershed was chosen as an appropriate representative drainage area. The Q₇₋₁₀ at the exit point of this watershed is 0.034 cfs and the drainage area is 3.38 mi.² which results in a Q₇₋₁₀ low flow yield of 0.01 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the point of first use as follows (Guidance No. 391-2000-023):

$$\text{Low Flow Yield} = 0.034 \text{ cfs} / 3.38 \text{ mi.}^2 \approx 0.01 \text{ cfs/mi.}^2$$

$$Q_{7-10} = 0.01 \text{ cfs/mi.}^2 * 0.8 \text{ mi.}^2 \approx 0.008 \text{ cfs}$$

$$Q_{30-10} = 1.36 * 0.008 \text{ cfs} \approx 0.011 \text{ cfs}$$

$$Q_{1-10} = 0.64 * 0.008 \text{ cfs} \approx 0.005 \text{ cfs}$$

The resulting Q₇₋₁₀ dilution ratio is: Q_{stream} / Q_{discharge} = 0.008 cfs / [0.01 MGD * (1.55 cfs/MGD)] = 0.52:1

Unnamed Tributary to White Oak Run to Little Tonoloway Creek

25 Pa. Code 93.9z classifies Little Tonoloway Creek as Trout Stocking Fishes (TSF) surface water. Based on the 2024 Integrated Report, Little Tonoloway Creek, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Potable Water Supply Intake

The nearest downstream public water supply intake is the R.C. Wilson Water Treatment Plant near Williamsport, MD intake on the Potomac River, approximately 23.0 miles from the point of discharge. eMapPA confirms that there are still no public water supplies downstream of this facility prior to the PA-MD border (over nine miles of stream). Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Southern Fulton Elementary				
WQM Permit No.	Issuance Date			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration With Solids Removal	Gas Chlorine	0.01
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.01		Not Overloaded	Aerobic Digestion	Combination of methods

Changes Since Last Permit Issuance: none

Other Comments:

The WWTP train is as follows:

Comminutor / Bar Screen (1) ⇒ EQ Tank (1) ⇒ Aeration Tank (1) ⇒ Settling Tank (1) ⇒ Sand Filters (2) ⇒ Chlorine Contact Tank (with liquid feed) (1) ⇒ De-chlorination System (with tablet feed) (1) ⇒ Discharge

The system incorporates chemical addition in the form of liquid chlorine (for disinfection), sodium bisulfite tablets (for de-chlorination), and sodium carbonate dry (for pH control). A sludge holding tank is used for solids storage.

Compliance History	
Summary of DMRs:	A summary of past 12-month DMRs is presented on the next pages.
Summary of Inspections:	<p>4/30/2024: Mr. Clark, DEP WQS, conducted a compliance evaluation inspection. There was no discharge during the inspection and no samples were taken. There were no violations during inspection. The field test results were within the permit limits. There were recommendations: submit the appropriate paperwork to change the permissions for eDMR, obtain copies of sludge hauler receipts for past five years, contact DEP permits engineer about flow meter chart recorder, and NPDES permit renewal application is due by August 4, 2024.</p> <p>4/3/2023: Mr. Clark, DEP WQS, conducted a compliance evaluation inspection. The effluent was clear. There were no violations during inspection. There were recommendations: remove weeds from both sand beds and rake sand as part of routine plant maintenance, have the flow meter calibrated and chart recorder repaired, record all individual grab times for composite sample, place NIST traceable thermometer in storage fridge, submit a sludge disposal supplemental form with the February 2023 DMR, submit a change of Operator form through the DEP website, and install new floats in EQ tank.</p>
Other Comments:	There are no open violations against permittee or facility.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from November 1, 2023 to October 31, 2024)

Parameter	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23
Flow (MGD) Average Monthly	0.00347	0.00448	0.00359		0.00092	0.00393	0.00285	0.0003	0.0017	0.00205	0.00217	0.00251
Flow (MGD) Daily Maximum	0.00543	0.00898	0.0077		0.00855	0.00846	0.00498	0.0007	0.00342	0.00420	0.00387	0.0069
pH (S.U.) Instantaneous Minimum	7.12	6.85	5.6		7.02	7.12	6.93	6.81	6.79	6.89	6.90	6.86
pH (S.U.) Instantaneous Maximum	7.75	8.15	7.59		7.38	7.69	8.01	7.62	7.46	7.56	7.48	7.58
DO (mg/L) Instantaneous Minimum	8.71	8.28	6.21		7.23	8.36	8.26	7.32	8.29	9.14	5.9	5.24
TRC (mg/L) Average Monthly	0.01	0.01	0.02		0.01	0.01	0.02	0.01	0.0002	0.0003	0.0003	0.0003
TRC (mg/L) Instantaneous Maximum	0.02	0.02	0.02		0.02	0.02	0.06	0.02	0.0003	0.0004	0.0005	0.007
CBOD5 (mg/L) Average Monthly	41.0	39	69		96.0	78.0	36.0	59.0	4.0	42.0	< 3.0	3.0
TSS (mg/L) Average Monthly	4.0	12.0	8.0		11.0	7.0	14.0	12.0	8.0	5.0	2.0	< 2.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 1.0	< 1.0		< 1.0	< 1.0	< 7	< 5.0	161	< 10	< 2.0	< 1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1.0	< 1.0	< 1.0		< 1.0	< 1.0	52	22	206	92	3.0	< 1.0
Nitrate-Nitrite (lbs/day) Total Annual											240	
Nitrate-Nitrite (mg/L) Annual Average											48.7	
Total Nitrogen (lbs/day) Total Annual											< 245	
Total Nitrogen (mg/L) Annual Average											< 49.7	

NPDES Permit Fact Sheet**Southern Fulton Elementary School****NPDES Permit No. PA0084646**

Ammonia (mg/L)	< 1.0	< 3.0	< 1.0		< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 3.0	< 1.0
Average Monthly	< 1.0	< 3.0	< 1.0		< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 3.0	< 1.0
TKN (lbs/day)										< 5	
Total Annual										< 1.0	
TKN (mg/L)											
Annual Average											
Total Phosphorus (lbs/day)										6	
Total Annual											
Total Phosphorus (mg/L)											
Annual Average										1.12	

Existing Effluent Limitations and Monitoring Requirements

Outfall 001.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Total Annual	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.04	XXX	0.13	1/day	Grab
CBOD ₅	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	8-Hr Composite
Nitrate-Nitrite	XXX	Report	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Nitrogen	XXX	Report	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
TKN	XXX	Report	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Phosphorus	XXX	Report	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Development of Effluent Limitations

Outfall No. 001
 Latitude 39° 47' 42.90"
 Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.01
 Longitude -78° 11' 21.04"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

Water Quality-Based Limitations**Ammonia (NH₃-N):**

NH₃-N calculations were first based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

- Discharge pH = 7.0 (Default)
- Discharge Temperature = 20°C (Estimated)
- Stream pH = 7.0 (Default)
- Stream Temperature = 20°C (Estimated for shaded TSF)
- Background NH₃-N = 0 (Default)

Analysis Results WQM 7.0

Hydrodynamics		NH3-N Allocations		D.O. Allocations		D.O. Simulation		Effluent Limitations			
RMI	Discharge Name	Permit Number Disc Flow (mgd)									
0.09	Southern Fulton	PA.0084646 0.0100									
		Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)						
		CBOD5	25	6.42	5						
		NH3-N	3.21								
		Dissolved Oxygen									
Record: 1 of 1 < Back Next > No Filter Search											
Print		< Back		Next >		Archive		Cancel			

The model input data and results are attached. The printout of the WQM 7.0 output indicates that at a discharge of 0.010 MGD, limits of 3.21 (3.0) mg/L NH₃-N as a monthly average and 6.42 (6.0) mg/L NH₃-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects for summer, to calculate winter limits based on a typical multiplier of 3.0 used by DEP. Therefore, the existing limits of 3.0 mg/L NH₃-N monthly average and 6.0 mg/L NH₃-N instantaneous maximum for summer are same and will place in the proposed permit. The facility's recent DMRs indicate that the facility has been consistently achieving concentrations below these limits.

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached printout of the WQM 7.0 model indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations well below this limit.

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

Total Suspended Solids (TSS):

The existing limits of 30.0 mg/L average monthly and 60.0 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations well under these limits.

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(2).

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Chesapeake Bay Strategy:

The discharge of TN and TP from this facility is consistent with and covered under the Chesapeake Bay TMDL aggregate WLA for non-significant wastewater discharges.

This facility falls in Phase V of Pennsylvania's Chesapeake Bay Tributary Strategy Point Source Implementation Plan. At this time, the Department is not requiring a total maximum annual phosphorus or nitrogen loading cap.

The Supplement to Phase II Watershed Implementation Plan states the following:

"For Phase V sewage facilities with individual permits (average annual design flow on August 29, 2005 > 0.002 MGD and < 0.2 MGD), DEP will issue individual permits with monitoring and reporting for TN and TP throughout the permit term at a frequency no less than annually, unless 1) the facility has already conducted at least two years of nutrient monitoring and 2) a summary of the monitoring results are included in the next permit's fact sheet. If, however, Phase V facilities choose to expand, the renewed or amended permits will contain Cap Loads based on the lesser of a) existing TN/TP concentrations at existing average annual flow or b) 7,306 lbs/yr TN and 974 lbs/yr TP."

A 1/year "Monitor & Report" requirement for TN and TP will remain in the proposed permit.

Total Residual Chlorine (TRC):

Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003, Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), the facility's discharge must meet a monthly average limit of 0.08 mg/L and an instantaneous maximum limit of 0.28 mg/L. Therefore, the existing TRC limits of 0.04 mg/L monthly average and 0.13 mg/L instantaneous maximum are more stringent and will remain in the proposed permit.

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.008	= Q stream (cfs)			
0.01	= Q discharge (MGD)			
30	= no. samples			
0.3	= Chlorine Demand of Stream			
0	= Chlorine Demand of Discharge			
0.5	= BAT/BPJ Value			
0	= % Factor of Safety (FOS)			
0.5	= CV Daily			
0.5	= CV Hourly			
1	= AFC_Partial Mix Factor			
1	= CFC_Partial Mix Factor			
15	= AFC_Criteria Compliance Time (min)			
720	= CFC_Criteria Compliance Time (min)			
	=Decay Coefficient (K)			
Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.184	1.3.2.iii	WLA_cfc = 0.172
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc= 0.069	5.1d	LTA_cfc = 0.100
Source		Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.084		
		INST MAX LIMIT (mg/l) = 0.276		
WLA_afc		(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)		
LTAMULT_afc		EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)		
LTA_afc		wla_afc*LTAMULT_afc		
WLA_cfc		(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)		
LTAMULT_cfc		EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)		
LTA_cfc		wla_cfc*LTAMULT_cfc		
AML MULT		EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))		
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)		
INST MAX LIMIT		1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)		

Toxic:

This is a minor sewage facility receiving domestic wastewater only and the current application does not require sampling of toxic pollutants (or heavy metals) for those facilities with design flows less than 0.1 MGD. Therefore, no reasonable potential analysis for toxic pollutants has been performed for this permit renewal.

Antidegradation (93.4)

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303d LISTED STREAMS

This discharge is not located on a 303d listed stream segment.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the proposed permit per 40 CFR § 122.44(i)(1)(ii).

Southern Fulton Elementary School*Monitoring Frequency and Sample Type*

The facility currently is required to collect daily effluent grab samples for D.O., pH; and total residual chlorine; two-month effluent 8-hr composite samples of CBOD₅, and TSS; two-month effluent grab samples of fecal coliform; two-month influent 8-hr composite sample of ammonia-nitrogen; annually effluent 8-hr composite samples of TP, nitrate-nitrite as N, and total Kjeldahl Nitrogen; and annually effluent calculation samples of TN. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the existing monitoring frequencies will remain the same as those specified in the proposed permit.

WQM 7.0 Data:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	20°C	(Estimated)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	20°C	(Estimated for shaded TSF)
*	Background NH ₃ -N	=	0	(Default)


There are no upstream discharges. Hence, the two nodes were used:

Node 1: Outfall 001 on UNT White Oak Run (60898)

Elevation: 630 ft (USGS National Map Viewer)
 Drainage Area: 0.80 mi.² (USGS PA StreamStats)
 River Mile Index: 0.09 mile (PA DEP eMapPA)
 Low Flow Yield: 0.01 cfs/mi.²
 Discharge Flow: 0.010 MGD

Node 2: Just before confluence with White Oak Run

Elevation: 615 ft (USGS National Map Viewer)
 Drainage Area: 0.81 mi.² (USGS PA StreamStats)
 River Mile Index: 0.001 mile (PA DEP eMapPA)
 Low Flow Yield: 0.01 cfs/mi.²
 Discharge Flow: 0.000 MGD



NPDES Permit Fact Sheet
Southern Fulton Elementary School

NPDES Permit No. PA0084646

USGS StreamStats
science for a changing world

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

>Show Basin Characteristics

Select available reports to display:

Basin Characteristics Report
 Scenario Flow Reports

Open Report

POWERED BY **WIM**

USGS Home Contact USGS Search USGS
Accessibility FOIA Privacy Policy & Notice

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]


Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.8	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	37	inches	35	50.4
STRDEN	Stream Density	1.65	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	3	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0216	ft ³ /s
30 Day 2 Year Low Flow	0.0372	ft ³ /s
7 Day 10 Year Low Flow	0.00502	ft ³ /s
30 Day 10 Year Low Flow	0.00946	ft ³ /s
90 Day 10 Year Low Flow	0.0229	ft ³ /s



USGS StreamStats
science for a changing world

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

>Show Basin Characteristics

Select available reports to display:

Basin Characteristics Report
 Scenario Flow Reports

Open Report

POWERED BY **WIM**

USGS Home Contact USGS Search USGS
Accessibility FOIA Privacy Policy & Notice

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]


Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.81	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	37	inches	35	50.4
STRDEN	Stream Density	1.75	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	3	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0208	ft ³ /s
30 Day 2 Year Low Flow	0.0358	ft ³ /s
7 Day 10 Year Low Flow	0.0048	ft ³ /s
30 Day 10 Year Low Flow	0.00907	ft ³ /s
90 Day 10 Year Low Flow	0.0219	ft ³ /s



StreamStats

IDENTIFY A STUDY AREA

Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	3.38	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	37	inches	35	50.4
STRDEN	Stream Density	2.51	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	3.4	feet	3.32	5.65
CARBON	Percent Carbonate	16.74	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.113	ft^3/s
30 Day 2 Year Low Flow	0.178	ft^3/s
7 Day 10 Year Low Flow	0.034	ft^3/s
30 Day 10 Year Low Flow	0.0569	ft^3/s
90 Day 10 Year Low Flow	0.112	ft^3/s

Layers

Base Maps

Application Layers

National Layers

PA Map Layers

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RML	Discharge Name	Permit Number	Disc Flow (mgd)
0.09	Southern Fulton	PA0084646	0.0100

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	3.21	6.42	
Dissolved Oxygen			5

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

NPDES Permit Fact Sheet
Southern Fulton Elementary School

NPDES Permit No. PA0084646

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name
13B	66999	Trb 66999 to White Oak Run

RM#	Name	Permit Number	Disc. Flow (mg/s)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)	
0.090	Southern Fulton	PA0084646	0.010	CBOD5	25	NH3N	3.21	6.42
				Dissolved Oxygen	5			

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
13B	66999	Trb 66999 to White Oak Run

NHS-N Acute Allocations

RM#	Discharge Name	Baseline Capacity (mg/s)	Baseline WLA (mg/s)	Multiple Critical (mg/s)	Multiple WLA (mg/s)	Critical Reach	Percent Reduction
0.090	Southern Fulton	16.76	22.31	16.76	22.31	0	0

NHS-N Chronic Allocations

RM#	Discharge Name	Baseline Capacity (mg/s)	Baseline WLA (mg/s)	Multiple Critical (mg/s)	Multiple WLA (mg/s)	Critical Reach	Percent Reduction
0.090	Southern Fulton	1.69	3.21	1.69	3.21	0	0

Dissolved Oxygen Allocations

RM#	Discharge Name	CBOD5 (mg/s)	Baseline Capacity (mg/s)	Baseline WLA (mg/s)	Multiple Critical (mg/s)	Multiple WLA (mg/s)	Critical Reach	Percent Reduction
0.090	Southern Fulton	25	3.21	3.21	5	5	0	0

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name
13B	66999	Trb 66999 to White Oak Run

RM#	Total Discharge Flow (mg/s)	Analysis Temperature (°C)	Analysis pH
0.090	0.010	20.000	7.000
Reach Velocity (ft/s)	0.279	Reach W/Ratio	Reach Velocity (ft/s)
Reach DO (mg/L)	17.16	Reach DO-N (mg/L)	Reach DO-N (mg/L)
Reach DO (mg/L)	6.105	Reach K (1/day)	Reach DO Goal (mg/L)
Reach Travel Time (days)	0.173	K/Equation	Overall

Subreach Results

Travel Time (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
0.017	16.76	2.08	6.48
0.035	16.33	2.07	6.74
0.053	15.93	2.01	6.93
0.069	15.54	2.02	7.08
0.086	15.16	1.99	7.19
0.104	14.79	1.97	7.27
0.121	14.43	1.95	7.35
0.138	14.08	1.92	7.41
0.155	13.73	1.90	7.46
0.173	13.40	1.88	7.51

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameter	Value	Notes
WLA Method	SLMR	Use Inputted W/LA Ratio
Q1-10Q7-10 Ratio	0.64	Use Inputted Reach Travel Times
Q30-10Q7-10 Ratio	1.36	Temperature Adjust K
D.O. Saturation	90.0%	Use Balanced Technology
D.O. Goal	5	

NPDES Permit Fact Sheet
Southern Fulton Elementary School

NPDES Permit No. PA0084646

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code		Stream Name									
13B	60098	Trib 60098 to W. Oak Run											
RM	Stream Flow	Net With	Disch.	Reach Depth	Width	W.D.	Velocity	Reach Temp	Analysis	pH			
(cfs)	(cfs)	(cfs)	(cfs)	(ft)	(ft)	(ft/s)	(ft/s)	(deg)	(°C)				
Q7-10 Flow	0.00	0.01	0.0155	0.03182	.279	2.67	9.54	0.03	0.173	20.00	7.00		
Q1-10 Flow	0.00	0.01	0.0155	0.03182	NA	NA	NA	0.03	0.166	20.00	7.00		
Q30-10 Flow	0.00	0.01	0.0155	0.03182	NA	NA	NA	0.03	0.163	20.00	7.00		

rptGeneral

Input Data WQM 7.0

SWP Basin		Stream Code		Stream Name									
13B	60098	Trib 60098 to White Oak Run											
RM	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC								
(ft)	(sq mi)	(ft)	(%)	(mgd)									
0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rich Trav. Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tributary Temp	pH	Stream Temp	pH
(cfs)	(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft/s)	(ft)	(ft)	(°C)		(°C)	
Q7-10	0.010	0.00	0.00	0.0000	0.00	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10	0.00	0.00	0.00	0.0000	0.00	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.0000	0.00	0.0	0.00	0.00	20.00	7.00	0.00	0.00

Discharge Data

Name	Permit Number	Existing Disch. Flow (mgd)	Permitted Disch. Flow (mgd)	Design Disch. Flow (mgd)	Reserve Factor	Disc. Temp (°C)	Disc. pH
Southern Fulton	PA0084646	0.0100	0.0100	0.0100	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Rate Coef. (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	0.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Monday, December 23, 2024

Version 1.1

Page 1 of 1

rptGeneral

Input Data WQM 7.0

SWP Basin		Stream Code		Stream Name									
13B	60098	Trib 60098 to White Oak Run											
RM	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC								
(ft)	(sq mi)	(ft)	(%)	(mgd)									
0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rich Trav. Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tributary Temp	pH	Stream Temp	pH
(cfs)	(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft/s)	(ft)	(ft)	(°C)		(°C)	
Q7-10	0.010	0.00	0.00	0.0000	0.00	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10	0.00	0.00	0.00	0.0000	0.00	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.0000	0.00	0.0	0.00	0.00	20.00	7.00	0.00	0.00

Discharge Data

Name	Permit Number	Existing Disc. Flow (mgd)	Permitted Disc. Flow (mgd)	Design Disc. Flow (mgd)	Reserve Factor	Disc. Temp (°C)	Disc. pH
Southern Fulton	PA0084646	0.0000	0.0000	0.0000	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Rate Coef. (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	0.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Monday, December 23, 2024

Version 1.1

Page 2 of 2

Page: 14 2 No Filter

14

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.04	XXX	0.13	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	8-Hr Composite
TKN	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Nitrate-Nitrite	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Nitrogen	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Compliance Sampling Location:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]