

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

**PA0084794**

APS ID

**780245**

Authorization ID

**1478492**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<u>The York Water Co.</u>	Facility Name	<u>Asbury Pointe Res Development</u>
Applicant Address	<u>PO Box 15089 130 E Market Street</u>	Facility Address	<u>305 Riverview Road</u>
	<u>York, PA 17405-7089</u>		<u>Mount Wolf, PA 17347</u>
Applicant Contact	<u>Matthew Scarpato</u>	Facility Contact	<u>Vaughn Wenger</u>
Applicant Phone	<u>(717) 718-2977</u>	Facility Phone	<u>(717) 845-3601</u>
Client ID	<u>69800</u>	Site ID	<u>452614</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>East Manchester Township</u>
Connection Status		County	<u>York</u>
Date Application Received	<u>March 26, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>April 3, 2024</u>	If No, Reason	
Purpose of Application	<u>Renewal of existing NPDES Permit</u>		

**Summary of Review**

The York Water Company has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit for the Asbury Pointe STP. The permit was last reissued on September 27, 2019 with an effective date of October 1, 2019. The permit expired on September 30, 2024, but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days. A file review of documents associated with the discharge or permittee may be available at the PA DEP southcentral regional office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file reviews, contact the SCRO file review coordinator at 717.705.4700.

Sludge use and disposal description and location(s): Smith Disposal Facility and Berstine Farm (Adams County)

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Aaron Baar</i> Aaron Baar / Project Manager	March 28, 2025
X		<i>Daniel W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	April 2, 2025

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.0784
Latitude	40° 3' 20.22"	Longitude	-76° 38' 40.45"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Codorus Creek (WWF)	Stream Code	08032
NHD Com ID	57465175	RMI	0.53
Drainage Area	278 sq. mi.	Yield (cfs/mi <sup>2</sup> )	2.007
Q <sub>7-10</sub> Flow (cfs)	37.2	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	245.02	Slope (ft/ft)	
Watershed No.	7-H	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	CAUSE UNKNOWN, FLOW REGIME MODIFICATION, TOXICITY URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS		
Source(s) of Impairment			
TMDL Status	Name		
Background/Ambient Data		Data Source	
pH (SU)	7.0	Default	
Temperature (°C)	25.0	WWF Default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake	Wrightsville Water Supply Co.		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	28.51	Distance from Outfall (mi)	~8 mi.

**Drainage Area**

The discharge is to Codorus Creek at RMI 0.53. A drainage area upstream of the discharge point is determined to be 278 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

**Stream Flow**

According to StreamStats, the watershed has a Q<sub>7-10</sub> of 37.2 cfs. This information was used to obtain a LFY, a chronic 30-day (Q<sub>30-10</sub>) and acute (Q<sub>1-10</sub>) exposure stream flows for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned}
 Q_{7-10} &= 37.2 \text{ cfs} \\
 Q_{30-10} &= 1.36 * 37.2 \text{ cfs} = 50.592 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 37.2 \text{ cfs} = 23.808 \text{ cfs} \\
 \text{LFY} &= 37.2 \text{ cfs} / 1.63 \text{ mi}^2 = 2.007 \text{ cfs/mi}^2
 \end{aligned}$$

**Codorus Creek**

25 Pa Code §93.9 classifies the receiving water, Codorus Creek, with a WWF existing use designation. No special protection waters are impacted by this discharge. The discharge is in a stream segment listed as impaired for aquatic life due to urban runoff/storm sewers (source unknown) and flow regime modification. The receiving stream segment is also listed as impaired for recreational uses due to pathogens (source unknown) in the 2024 Integrated

Report. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

*Local Watershed Total Maximum Daily Loads (TMDLs)*

According to PA's 2024 Integrated Water Quality Monitoring and Assessment Report, Codorus Creek in the vicinity of the point of discharge is listed as impaired for aquatic life due to flow regime modification with a Category 4c designation, indicating that the waters are impaired for one or more uses not needing a TMDL because the impairment is not caused by a pollutant. The water way is listed as impaired for aquatic life due to siltation with a Category 5 designation, indicating that the waters are impaired for one or more uses by a pollutant that requires the development of a TMDL. The water way is listed as impaired for recreation with a Category 5 classification, indicating that the waters are impaired for one or more uses by a pollutant that requires the development of a TMDL. No local watershed TMDL has therefore been taken into consideration during this review.

*Public Water Supply Intake*

The nearest downstream public water supply intake is the Wrightsville Water Supply Co. intake located on the Susquehanna River approximately 8 miles from the discharge. Considering the distance and nature, the discharge is not expected to significantly affect the water supply.

*Class A Wild Trout Streams*

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Asbury Pointe				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6791410 T-1		6/13/2012		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.0784
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0784	170	Not Overloaded	Aerobic Digestion	Other WWTP

The York Water Company owns and operates the Asbury Pointe sanitary wastewater treatment facility located in East Manchester Township, York County. The facility serves only the Asbury Pointe development, all wastes are residential in nature, and all sewer systems are 100% separated. Having both annual average design flow and hydraulic design capacity of 0.0784 MGD, this facility consists of a single influent comminutor, a flow splitter that divides flow between trains, six aeration tanks (per train), three secondary clarifiers (per train), one chlorine contact tank (per train), one polishing clarifier (per train), one post-aeration tank (per train) and the outfall (i.e., Outfall 001). Calcium hypochlorite (disinfection) is introduced via erosion chlorinators between the secondary clarifiers and the chlorine contact tank on each train. Soda ash (pH control) and poly-aluminum chloride (settling) are also utilized at the facility. Solids are treated onsite in two aerobic sludge digesters before being hauled offsite for disposal.

Note: The application incorrectly estimates the design annual average flow of the facility as 0.065 mgd.

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	DMR results for the past year are presented below.
<b>Summary of Inspections:</b>	<p>Since the last renewal of the facility's NPDES permit, the following inspections have been logged:</p> <p>March 5, 2020: A CEI was conducted by Austen Randecker. No violations were noted. Observations from the site visit were recorded.</p> <p>May 7, 2020: An administrative inspection was conducted by Austen Randecker via phone due to COVID19. No violations were noted.</p> <p>October 17, 2024: A CEI was conducted by Shawn Lesitsky. No violations were noted. Observations from the site visit were recorded.</p>

Other Comments: As of March 28, 2025, there are no open violations associated with this permittee.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

Compliance History

DMR Data for Outfall 001 (from February 1, 2024 to January 31, 2025)

Parameter	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24
Flow (MGD) Average Monthly	0.015	0.016	0.016	0.016	0.016	0.016	0.016	0.015	0.016	0.017	0.016	0.015
Flow (MGD) Daily Maximum	0.021	0.021	0.022	0.021	0.023	0.020	0.020	0.019	0.022	0.042	0.029	0.020
pH (S.U.) Instantaneous Minimum	6.78	6.60	7.11	7.04	6.91	6.56	6.43	6.75	6.07	6.13	6.05	6.88
pH (S.U.) Instantaneous Maximum	7.99	7.91	8.03	7.97	8.15	8.19	8.03	7.96	8.06	7.96	8.07	7.98
DO (mg/L) Instantaneous Minimum	7.62	7.62	8.67	8.68	8.04	6.9	7.76	7.84	7.62	8.79	9.37	9.57
TRC (mg/L) Average Monthly	0.20	0.21	0.21	0.21	0.16	0.18	0.18	0.23	0.14	0.16	0.15	0.18
TRC (mg/L) Instantaneous Maximum	0.74	0.74	0.57	0.47	0.45	0.54	0.48	0.56	0.47	0.80	0.34	0.78
CBOD5 (mg/L) Average Monthly	4.7	< 3.4	< 2.5	< 3.0	< 3.3	< 2.4	< 3.2	< 2.7	3.8	8.1	5.6	4.1
CBOD5 (mg/L) Instantaneous Maximum	5.9	4.4	2.5	3.5	4.1	< 2.4	4.0	3.0	3.8	8.7	6.4	4.9
TSS (mg/L) Average Monthly	7.5	11.0	9.0	17.0	14.0	11.0	21.5	6.5	3.5	9.0	16.5	4.5
TSS (mg/L) Instantaneous Maximum	11.0	13.0	15	17.0	17.0	12.0	23.0	9.0	4.0	11.0	17.0	6.0
Fecal Coliform (No./100 ml) Geometric Mean	385	296	158	311	128	133	64	18	270	141	219	21
Fecal Coliform (No./100 ml) Instantaneous Maximum	649	308	172	980	276	205	78	26	613	291	365	23
Nitrate-Nitrite (mg/L) Average Monthly	34.5	37.5	40.5	37.5	39.0	40.0	34.5	36.5	31.5	22.6	39.0	9.1

NPDES Permit Fact Sheet  
Asbury Pointe Res Development

NPDES Permit No. PA0084794

Nitrate-Nitrite (lbs)											
Total Monthly	129	135	158	151.0	146	170	152	137	114	136	144
Total Nitrogen (mg/L)											
Average Monthly	< 35.25	< 38.70	< 41.00	< 38.95	< 40.40	< 41.5	< 35.00	< 37.0	< 35.5	< 26.8	< 43
Total Nitrogen (lbs)											
Total Monthly	< 132.5	< 138.7	< 159.9	< 156.6	< 151.2	< 176.5	< 153.9	< 138.9	< 128.5	< 171.9	< 159
Total Nitrogen (lbs)											
Total Annual					1540						
Ammonia (lbs/day)											
Average Monthly	< 0.02	< 0.01	< 0.02	< 0.01	< 0.01	< 0.05	< 0.02	< 0.01	< 0.01	0.71	< 0.02
Ammonia (mg/L)											
Average Monthly	< 0.2	< 0.1	< 0.1	< 0.1	< 0.1	< 0.4	< 0.1	< 0.1	< 0.1	2.1	< 0.1
Ammonia (lbs)											
Total Monthly	< 0.6	< 0.3	< 0.5	< 0.3	< 0.3	< 1.6	< 0.5	< 0.3	< 0.3	21.3	< 0.5
Ammonia (lbs)											
Total Annual					117						
TKN (mg/L)											
Average Monthly	< 0.8	< 1.2	< 0.5	< 1.5	< 1.4	< 1.5	< 0.5	< 0.5	< 4.0	< 4.3	< 4.0
TKN (lbs)											
Total Monthly	< 3	< 4	< 2	< 6	< 5	< 6	< 2	< 2	< 14	< 36	< 15
Total Phosphorus (lbs/day)											
Average Monthly	0.5	0.4	0.5	0.5	0.6	0.7	0.6	0.6	0.6	0.9	0.4
Total Phosphorus (mg/L)											
Average Monthly	3.5	3.7	3.9	4.1	4.6	5.0	4.3	5.0	5.5	4.4	3.9
Total Phosphorus (lbs)											
Total Monthly	13.95	13.18	14.85	16.12	17.25	20.93	18.76	18.75	20.00	27.75	13.64
Total Phosphorus (lbs)											
Total Annual					200						

Compliance History

Effluent Violations for Outfall 001, from: March 1, 2024 To: January 31, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	05/31/24	Geo Mean	270	No./100 ml	200	No./100 ml

Other Comments: The cause of the violation is listed in the DMR as unknown. TRC for most days in May 2024 were only recorded as 0.1 mg/L – significantly lower than normal.

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	.0784	
Latitude	40° 3' 20.62"	Longitude	-76° 38' 41.61"	
Wastewater Description:	Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

### Water Quality-Based Limitations

#### *CBOD<sub>5</sub>, NH<sub>3</sub>-N and Dissolved Oxygen (DO)*

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD<sub>5</sub>, NH<sub>3</sub>-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges.

The model was utilized, and the model output indicated that existing WQBEL for CBOD<sub>5</sub> and ammonia are still appropriate and protective of water quality.

A minimum of 5.0 mg/L for DO is an existing effluent limit and will remain unchanged in the draft permit as recommended by DEP's SOP. This requirement has also been assigned to other sewage facilities in the region. 5.0 mg/L is taken directly from 25 Pa. Code § 93.7(a) and it is also determined to be appropriate according to water quality modeling.

#### *Total Residual Chlorine*

Since chlorine is used for disinfection, Total Residual Chlorine (TRC) effluent levels must be regulated in accordance with 25 Pa Code §92a.48(b). DEP's TRC\_CALC worksheet is utilized to determine if the existing BAT TBEL is still appropriate. The worksheet indicates that the existing limits of 0.5 mg/L (average monthly) and 1.0 mg/L (IMAX) are still protective of water quality.

#### *Toxics*

DEP's NPDES permit application for minor sewages (less than 0.1 MGD) does not require sampling for heavy metals including Total Copper, Total Lead, and Total Zinc.

### **Best Professional Judgment (BPJ) Limitations**

#### *Total Phosphorus & Total Nitrogen*

DEP's SOP no. BPNPSM-PMT-033 recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, routine monitoring for TKN, Nitrate-Nitrite, Total Nitrogen and Total Phosphorus are recommended to be continued in this permit renewal twice monthly.

### **Additional Considerations**

#### *Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

#### *E. Coli Monitoring*

In conformity with the Department's *Establishing Effluent Limitations for Individual Sewage Permits* (SOP No. BCW-PMT-033) and as authorized by § 92a.61 of the PA Code, quarterly E. Coli monitoring has been proposed in this permit. The collection method will be via grab sample.

#### *Chesapeake Bay TMDL*

The Department formulated a strategy in April 2007, to comply with the EPA's and Chesapeake Bay Foundation's requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011, Phase 2 in March 2012 and Phase 3 in December 2019. In accordance with the Phase 3 WIP, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 3 WIP categorizes this facility as a phase 5 non-significant sewage facility that has a design flow less than 0.2 MGD but greater than 0.002 MGD. The WIP recommends monitoring and reporting for Total Nitrogen and Total Phosphorus throughout the permit term at a frequency no less than annual. As discussed previously, continued twice monthly testing of these pollutants is proposed in this permit.

#### *Monitoring Frequency and Sample Type*

Unless discussed otherwise above, the permit's monitoring frequency and sample type for all parameters will remain unchanged from the last permit renewal.

#### *Antidegradation Requirements*

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

#### *Anti-backsliding Requirement*

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal. This approach is in accordance with 40 CFR §122.44(l)(1).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Total Nitrogen (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

Compliance Sampling Location: Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Ammonia May 1 - Oct 31	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]




## StreamStats Report

Region ID: PA

Workspace ID: PA20250328112944988000

Clicked Point (Latitude, Longitude): 40.05600, -76.64447

Time: 2025-03-28 07:30:10 -0400



Collapse All

### » Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	5.7348	degrees
DRNAREA	Area that drains to a point on a stream	278	square miles
ROCKDEP	Depth to rock	4.4	feet
URBAN	Percentage of basin with urban development	10.842	percent

### » Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	5.7348	degrees	1.7	6.4
DRNAREA	Drainage Area	278	square miles	4.78	1150
ROCKDEP	Depth to Rock	4.4	feet	4.13	5.21
URBAN	Percent Urban	10.842	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	65.1	ft <sup>3</sup> /s	46	46
30 Day 2 Year Low Flow	81.9	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	37.2	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	46.6	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	64.1	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


## StreamStats Report

Region ID: PA

Workspace ID: PA20250328113735368000

Clicked Point (Latitude, Longitude): 40.06208, -76.64007

Time: 2025-03-28 07:38:03 -0400



+ Collapse All

### » Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	5.7332	degrees
DRNAREA	Area that drains to a point on a stream	278	square miles
ROCKDEP	Depth to rock	4.4	feet
URBAN	Percentage of basin with urban development	10.8354	percent

### » Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	5.7332	degrees	1.7	6.4
DRNAREA	Drainage Area	278	square miles	4.78	1150
ROCKDEP	Depth to Rock	4.4	feet	4.13	5.21
URBAN	Percent Urban	10.8354	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	65.1	ft <sup>3</sup> /s	46	46
30 Day 2 Year Low Flow	81.9	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	37.1	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	46.5	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	64.1	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.


USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1



**WQM 7.0 Effluent Limits**

<b>SWP Basin</b>		<b>Stream Code</b>	<b>Stream Name</b>				
07H		8032	CODORUS CREEK				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.530	Ashbury Pointe	PA0084794	0.078	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07H	8032	CODORUS CREEK					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.530	Ashbury Pointe	11.07	50	11.07	50	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.530	Ashbury Pointe	1.37	25	1.37	25	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
0.53	Ashbury Pointe	25	25	25	25	5	5
						0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07H	8032	CODORUS CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>		<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
0.530	0.078		25.000	7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>		<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
104.894	1.006		104.225	0.354
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>		<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.07	0.054		0.08	1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>		<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.232	0.366		Tsivoglou	6
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.091	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.009	2.07	0.08	7.54
	0.018	2.07	0.08	7.54
	0.027	2.07	0.08	7.54
	0.037	2.07	0.08	7.54
	0.046	2.07	0.08	7.54
	0.055	2.07	0.08	7.54
	0.064	2.07	0.08	7.54
	0.073	2.06	0.08	7.54
	0.082	2.06	0.07	7.54
	0.091	2.06	0.07	7.54

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
07H			8032			CODORUS CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.530	37.20	0.00	37.20	.1213	0.00020	1.006	104.89	104.23	0.35	0.091	25.00	7.00
<b>Q1-10 Flow</b>												
0.530	23.81	0.00	23.81	.1213	0.00020	NA	NA	NA	0.28	0.117	25.00	7.00
<b>Q30-10 Flow</b>												
0.530	50.59	0.00	50.59	.1213	0.00020	NA	NA	NA	0.42	0.077	25.00	7.00

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
07H	8032 CODORUS CREEK				0.530	245.02	278.00	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH	
Q7-10	0.000	0.00	37.20	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
<b>Discharge Data</b>												
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
	Ashbury Pointe	PA0084794	0.0784	0.0784	0.0784	0.000	25.00	7.00				
<b>Parameter Data</b>												
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)							
	CBOD5	25.00	2.00	0.00	1.50							
	Dissolved Oxygen	5.00	8.24	0.00	0.00							
	NH3-N	25.00	0.00	0.00	0.70							

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC			
07H	8032 CODORUS CREEK				0.001	244.47	278.01	0.00000	0.00	<input checked="" type="checkbox"/>			
<b>Stream Data</b>													
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH		
Q7-10	0.000	0.00	37.10	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00		
Q1-10		0.00	0.00	0.000	0.000								
Q30-10		0.00	0.00	0.000	0.000								
<b>Discharge Data</b>													
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH						
		0.0000	0.0000	0.0000	0.000	0.00	7.00						
<b>Parameter Data</b>													
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)								
CBOD5		25.00	2.00	0.00	1.50								
Dissolved Oxygen		3.00	8.24	0.00	0.00								
NH3-N		25.00	0.00	0.00	0.70								

TRC\_CALC

1A	B	C	D	E	F	G
<b>TRC EVALUATION</b>						
Input appropriate values in B4:B8 and E4:E7						
4	37.2	= Q stream (cfs)		0.5	= CV Daily	
5	0.0748	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 102.570	1.3.2.iii	WLA_cfc = 99.991	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 38.220	5.1d	LTA_cfc = 58.130	
14	Source					
15	Effluent Limit Calculations					
16	PENTOXSD TRG	5.1f	AML MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ		
18			INST MAX LIMIT (mg/l) = 1.635			
<p>WLA_afc      <math>(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)</math></p> <p>LTAMULT_afc    <math>EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)</math></p> <p>LTA_afc        <math>wla_afc*LTAMULT_afc</math></p> <p>WLA_cfc        <math>(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)</math></p> <p>LTAMULT_cfc    <math>EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)</math></p> <p>LTA_cfc        <math>wla_cfc*LTAMULT_cfc</math></p> <p>AML MULT        <math>EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))</math></p> <p>AVG MON LIMIT   <math>MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)</math></p> <p>INST MAX LIMIT   <math>1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)</math></p>						