



Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

Application No. PA0084964
APS ID 43490
Authorization ID 1518433

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

| | | | |
|---------------------------|--------------------------------------|------------------|-------------------------------|
| Applicant Name | <u>Bethel Township Fulton County</u> | Facility Name | <u>Bethel Township STP</u> |
| Applicant Address | <u>PO Box 239</u> | Facility Address | <u>283 Pigeon Cove Road</u> |
| | <u>Warfordsburg, PA 17267-0239</u> | | <u>Warfordsburg, PA 17267</u> |
| Applicant Contact | <u>Michael Crunkleton</u> | Facility Contact | <u>Michael Crunkleton</u> |
| Applicant Phone | <u>(301) 988-7361</u> | Facility Phone | <u>(301) 988-7361</u> |
| Client ID | <u>74499</u> | Site ID | <u>246347</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Bethel Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Fulton</u> |
| Date Application Received | <u>March 5, 2025</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>March 6, 2025</u> | If No, Reason | |
| Purpose of Application | <u>NPDES Permit Renewal.</u> | | |

Summary of Review

Bethel Township Sewer Authority has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The permit was issued on July 9, 2020, and became effective on August 1, 2020. The permit authorized discharge of treated sewage from the existing wastewater treatment plant (WWTP) located in Bethel Township, Fulton County to Little Tonoloway Creek. The existing permit expiration date is July 31, 2025.

The discharge design flow is 0.048 MGD. This facility is owned, operated by Bethel Township, and serves the Warfordsburg area of Bethel Township.

WQM No. 299340 95-1 amendment was issued on September 27, 1995.

Sludge use and disposal description and location(s): N/A because sludge is hauled by facility's contractor.

Changes from the previous permit: The E. Coli monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

| Approve | Deny | Signatures | Date |
|---------|------|---|---------------|
| X | | Hilaryle Hilary H. Le / Environmental Engineering Specialist | June 13, 2025 |
| X | | Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager | July 3, 2025 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|-------------------------|-----------------|-------------------|-----------------|
| Outfall No. | 001 | Design Flow (MGD) | 0.048 |
| Latitude | 39° 45' 9.43" | Longitude | -78° 10' 48.93" |
| Quad Name | Needmore | Quad Code | |
| Wastewater Description: | Sewage Effluent | | |

| | | | |
|------------------------------|------------------------------|------------------------------|--------------------|
| Receiving Waters | Little Tonoloway Creek (TSF) | Stream Code | 60871 |
| NHD Com ID | 49477840 | RMI | 2.9 miles |
| Drainage Area | 49.9 mi. ² | Yield (cfs/mi ²) | See comments below |
| Q ₇₋₁₀ Flow (cfs) | See comments below | Q ₇₋₁₀ Basis | USGS StreamStats |
| Elevation (ft) | 484.25 | Slope (ft/ft) | |
| Watershed No. | 13-B | Chapter 93 Class. | TSF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Attaining Use(s) | | |
| Cause(s) of Impairment | | | |
| Source(s) of Impairment | | | |
| TMDL Status | | Name | |

| | | | |
|---|---|----------------------------|------------------------|
| Nearest Downstream Public Water Supply Intake | R.C. Wilson Water Treatment Plant near Williamsport, MD | | |
| PWS Waters | Potomac River | Flow at Intake (cfs) | |
| PWS RMI | | Distance from Outfall (mi) | Approximate 20.0 miles |

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Little Tonoloway Creek at RMI 2.9 miles. A drainage area upstream of the discharge is estimated to be 49.9 mi.², according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

There are no nearby stream gages with low flow data that have extensive or recent periods of record. Since USGS PA StreamStats estimated the drainage area that is below the minimum value allowed by USGS's regression equations, the USGS StreamStats on Tonoloway Creek at the PA/MD border will be used to calculate the Q₇₋₁₀ at the point of discharge using a low flow yield method. The Q₇₋₁₀ here is 1.67 cfs and the drainage area is 112 mi.² which results in a Q₇₋₁₀ low flow yield of 0.015 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned} \text{Low Flow Yield} &= Q_{7-10\text{gage}} / \text{Drainage Area}_{\text{gage}} = 1.67 \text{ cfs} / 112 \text{ mi.}^2 = 0.015 \text{ cfs/mi.}^2 \\ Q_{7-10\text{discharge}} &= 0.015 \text{ cfs/mi.}^2 * \text{Drainage Area}_{\text{discharge}} = 0.015 \text{ cfs/mi.}^2 * 49.9 \text{ mi.}^2 = 0.75 \text{ cfs} \\ Q_{30-10} &= 1.36 * Q_{7-10\text{discharge}} = 1.36 * 0.75 \text{ cfs} = 1.02 \text{ cfs} \\ Q_{1-10} &= 0.64 * Q_{7-10\text{discharge}} = 0.64 * 0.75 \text{ cfs} = 0.48 \text{ cfs} \end{aligned}$$

Little Tonoloway Creek

25 Pa Code § 93.9z classifies Little Tonoloway Creek as trout stocking fishes (TSF) surface water. Based on the 2024 Integrated Report, Little Tonoloway Creek, (Assessment ID 2714), is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Potable Water Supply Intake

The nearest downstream public water supply intake is the R.C. Wilson Water Treatment Plant near Williamsport, MD intake on the Potomac River, approximately 20 miles from the point of discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

| Treatment Facility Summary | | | | |
|---|-----------------------------------|---------------------|------------------------------|-------------------------------|
| Treatment Facility Name: Bethel Township STP | | | | |
| WQM Permit No. | Issuance Date | | | |
| 299340 95-1 | 9/27/1995 | | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Extended Aeration | Chlorine With Dechlorination | 0.048 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.048 | 85 | Not Overloaded | Aerobic Digestion | Combination of methods |

Changes Since Last Permit Issuance:

Other Comments:

The treatment process consists of a pump station/wet well (1), comminutor (1), bar screen (1), equitization tanks (3), aeration tanks (8), clarifiers/settling tanks (2), chlorine contact tank (1), dichlorination tank (1), sludge holding tanks (2), discharge (outfall).

Calcium Hypochlorite is used for disinfection.

Industrial/Commercial Users:

The permit application indicated there is no industrial/commercial contributor to the treatment plant.

Biosolids:

Liquid Biosolids are hauled off site by facility's contractor.

| Compliance History | |
|--------------------------------|--|
| Summary of DMRs: | DMRs reported last 12 months are summarized in next page. |
| Summary of Inspections: | <p>12/27/2024: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. There were no violations noted during inspection. The field sample test results were within the permit limits. Recommendations were to repair or replace overflow weirs in clarifier tank and check & adjust clarifier skimmers as needed.</p> <p>6/7/2023: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. There were no violations noted during inspection. The field sample test results were within the permit limits. Recommendations were to obtain a copy of the April 2022 sludge hauling receipt and file with other sludge records, check and adjust clarifier skimmers as needed, and obtain a thermometer for storage refrigerator.</p> |
| Other Comments: | There are currently no open violations associated with the permittee or the facility. |

Other Comments: 

Compliance History

DMR Data for Outfall 001 (from May 1, 2024 to April 30, 2025)

| Parameter | APR-25 | MAR-25 | FEB-25 | JAN-25 | DEC-24 | NOV-24 | OCT-24 | SEP-24 | AUG-24 | JUL-24 | JUN-24 | MAY-24 |
|--|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Flow (MGD) Average Monthly | 0.00828 0 | 0.01015 5 | 0.01185 4 | 0.01039 4 | 0.00828 4 | 0.00511 7 | 0.00538 4 | 0.00485 7 | 0.00899 7 | 0.00404 2 | 0.00498 0 | 0.00762 6 |
| Flow (MGD) Daily Maximum | 0.0128 | 0.01370 0 | 0.01610 0 | 0.02150 0 | 0.0165 | 0.01210 0 | 0.0108 | 0.00960 0 | 0.04690 0 | 0.0078 | 0.0099 | 0.03180 0 |
| pH (S.U.) Daily Minimum | 7.0 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 | 7.2 | 6.9 | 7.1 | 6.9 | 7.1 | 7.0 |
| pH (S.U.) Instantaneous Maximum | 8.0 | 7.7 | 7.7 | 7.6 | 7.8 | 7.9 | 8.4 | 7.6 | 7.9 | 7.7 | 8.0 | 7.9 |
| DO (mg/L) Daily Minimum | 8.1 | 9.1 | 10.1 | 10.2 | 8.3 | 8.9 | 7.9 | 8.7 | 7.8 | 8.3 | 8.3 | 8.7 |
| TRC (mg/L) Average Monthly | 0.03 | 0.04 | 0.05 | 0.05 | 0.06 | 0.05 | 0.04 | 0.04 | 0.03 | 0.03 | 0.03 | 0.04 |
| TRC (mg/L) Instantaneous Maximum | 0.08 | 0.15 | 0.14 | 0.21 | 0.19 | 0.17 | 0.13 | 0.20 | 0.11 | 0.20 | 0.16 | 0.21 |
| CBOD5 (lbs/day) Average Monthly | 0.20 | 0.44 | 0.32 | 0.37 | 0.45 | 0.21 | 0.14 | 0.155 | 0.08 | 0.008 | 0.13 | 0.26 |
| CBOD5 (lbs/day) Weekly Average | 0.21 | 0.63 | 0.32 | 0.54 | 0.67 | 0.28 | 0.20 | 0.17 | 0.127 | 0.009 | 0.13 | 0.34 |
| CBOD5 (mg/L) Average Monthly | 3.0 | 5.1 | 3.0 | 3.4 | 3.9 | 3.0 | 3.0 | 3.0 | 3.0 | 3.9 | 3.0 | 4.7 |
| CBOD5 (mg/L) Weekly Average | 3.0 | 7.1 | 3.0 | 3.8 | 4.9 | 3.0 | 3.0 | 3.0 | 3.0 | 4.8 | 3.0 | 6.3 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 15.3 | 19.9 | 21.4 | 8.9 | 21.6 | 16.6 | 11.0 | 13.1 | 5.5 | 4.8 | 10.5 | 12.1 |
| BOD5 (lbs/day) Raw Sewage Influent Daily Maximum | 18.3 | 23.4 | 25.5 | 14.0 | 26.8 | 24.7 | 12.1 | 15.9 | 8.6 | 5.4 | 10.6 | 13.6 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 238.5 | 233.5 | 199.5 | 103.9 | 209.5 | 231.5 | 310.5 | 250.5 | 198 | 226 | 241.5 | 212.0 |
| TSS (lbs/day) Average Monthly | 0.375 | 0.46 | 0.44 | 0.51 | 0.44 | 0.27 | 0.43 | 0.24 | 0.07 | 0.06 | 0.38 | 0.12 |
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 20.5 | 29.6 | 22.1 | 10.9 | 26 | 25.3 | 13.2 | 11.7 | 8.6 | 4.5 | 16.2 | 13.5 |

NPDES Permit Fact Sheet
Bethel Township STP

NPDES Permit No. PA0084964

| | | | | | | | | | | | | |
|---|-------|-------|-------|-------|-------|-------|-------|--------|-------|-------|-------|-------|
| TSS (lbs/day) Raw Sewage Influent Daily Maximum | 20.7 | 40.1 | 26.0 | 16.4 | 31.4 | 34.6 | 13.4 | 12.3 | 13.6 | 6.2 | 17.5 | 15.1 |
| TSS (lbs/day) Weekly Average | 0.43 | 0.46 | 0.68 | 0.71 | 0.44 | 0.30 | 0.78 | 0.29 | 0.11 | 0.09 | 0.315 | 0.15 |
| TSS (mg/L) Average Monthly | 5.8 | 5.4 | 4.0 | 5.0 | 4.6 | 4.4 | 7.6 | 4.6 | 4.4 | 2.8 | 3.8 | 2.2 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 315.5 | 356 | 206.0 | 129.5 | 254 | 371 | 397.5 | 226 | 306 | 203 | 374 | 234 |
| TSS (mg/L) Weekly Average | 6.4 | 5.6 | 6.4 | 6.0 | 6.0 | 5.6 | 12.0 | 5.2 | 5.6 | 4.0 | 6.0 | 2.8 |
| Fecal Coliform (No./100 ml) Geometric Mean | 230 | 135 | 418 | 128 | 84 | 41 | 103 | 443 | 355 | 214 | 21 | 13 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 1102 | 174 | 646 | 156 | 96 | 140 | 125 | 626 | 818 | 436 | 57 | 21 |
| Nitrate-Nitrite (mg/L) Average Monthly | 24.89 | 29.40 | 28.95 | 29.26 | 51.89 | 39.04 | 26.12 | 40.80 | 57.91 | 54.44 | 47.06 | 20.96 |
| Total Nitrogen (mg/L) Average Monthly | 25.39 | 29.99 | 29.45 | 29.76 | 52.39 | 39.54 | 26.62 | 41.30 | 58.41 | 54.94 | 47.46 | 21.46 |
| Ammonia (lbs/day) Average Monthly | 0.004 | 0.09 | 0.059 | 0.011 | 0.011 | 0.017 | 0.005 | 0.0055 | 0.003 | 0.002 | 0.004 | 0.006 |
| Ammonia (mg/L) Average Monthly | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.34 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 |
| TKN (mg/L) Average Monthly | 0.50 | 0.5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.5 | 0.50 | 0.50 | 0.50 | 0.50 | 0.50 |
| Total Phosphorus (mg/L) Average Monthly | 4.83 | 4.01 | 4.22 | 4.13 | 6.51 | 6.91 | 6.5 | 7.04 | 9.36 | 9.80 | 8.15 | 4.86 |

Existing Effluent Limitations and Monitoring Requirements

Outfall 001.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|-------------------|----------------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| D.O. | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD ₅ | 10.0 | 16.0 Wkly Avg | XXX | 25.0 | 40.0 | 50.0 | 2/month | 8-Hr Composite |
| TSS | 12.0 | 18.0 Wkly Avg | XXX | 30.0 | 45.0 | 60.0 | 2/month | 8-Hr Composite |
| BOD ₅ Raw Sewage Influent | Report | Report | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| TSS Raw Sewage Influent | Report | Report | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 2/month | Grab |
| Ammonia | 5.8 | XXX | XXX | 14.5 | XXX | 40.0 | 2/month | 8-Hr Composite |
| Nitrate-Nitrite | XXX | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| TKN | XXX | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | XXX | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 45' 9.43"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.048
Longitude -78° 10' 48.93"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Comments: [redacted]

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃-N calculations were first based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

Discharge pH = 7.0 (Default)
Discharge Temperature = 20°C (Default)
Stream pH = 7.0 (Default)
Stream Temperature = 20°C (Default)
Background NH₃-N = 0 (Default)

Analysis Results WQM 7.0

| Hydrodynamics | NH ₃ -N Allocations | D.O. Allocations | D.O. Simulation | Effluent Limitations |
|---|--------------------------------|--------------------------------------|-------------------------------|-------------------------------|
| RMI | Discharge Name | Permit Number | Disc Flow (mgd) | |
| 2.90 | Bethel Twp | PA0084964 | 0.0480 | |
| | Parameter | Effluent Limit 30 Day Average (mg/L) | Effluent Limit Maximum (mg/L) | Effluent Limit Minimum (mg/L) |
| | CBOD ₅ | 25 | 50 | |
| | NH ₃ -N | 25 | | |
| | Dissolved Oxygen | | | 5 |
| Record: 1 of 1 < Back Next > No Filter Search | | | | |
| Print | | < Back | | Next > Archive Cancel |

The printout of the WQM 7.0 output indicates that at a discharge of 0.048 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 25.0 mg/L NH₃-N as average monthly (AML) and 50.0 mg/L NH₃-N instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects. However, the more stringent in existing limits of 14.5 mg/L AML and 40.0 mg/L IMAX will remain in the proposed permit due to anti-backsliding requirements. Additionally, past DMRs and inspection reports show that the facility has been consistently achieving concentrations under these limits. Mass limits are calculated as follows:

$$\text{Mass based AML (lbs/day)} = 14.5 \text{ (mg/L)} \times 0.048 \text{ (MG/day)} \times 8.34 \text{ (lbs/MG)(L/mg)} = 5.80 \text{ lbs/day}$$

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing limits of 25.0 mg/L average monthly (AML), 40.0 mg/L average weekly limit (AWL), and 50.0 mg/L instantaneous maximum (IMAX) will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\text{Mass based AML (lbs/day)} = 25.0 \text{ (mg/L)} \times 0.048 \text{ (MG/day)} \times 8.34 \text{ (lbs/MG)(L/mg)} = 10.01 \text{ lbs/day}$$

$$\text{Mass based AWL (lbs/day)} = 40.0 \text{ (mg/L)} \times 0.048 \text{ (MG/day)} \times 8.34 \text{ (lbs/MG)(L/mg)} = 16.01 \text{ lbs/day}$$

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

Total Suspended Solids (TSS):

There is no water quality criterion for TSS. A limit of 30.0 mg/L AML and 60.0 mg/L IMAX will be required based on the minimum level of effluent quality attainable by secondary treatment as defined in 40 CFR 133.102b(1) and 25 Pa. Code § 92a.47(a)(1), and an AWL of 45.0 mg/L per 40 CFR 133.102(b)(2) and 25 Pa. Code § 92a.47(a)(2). Mass limits are calculated as follows:

$$\text{Mass based AML (lbs/day)} = 30.0 \text{ (mg/L)} \times 0.048 \text{ (MG/day)} \times 8.34 \text{ (lbs/MG)(L/mg)} = 12.0 \text{ lbs/day}$$

$$\text{Mass based AWL (lbs/day)} = 45.0 \text{ (mg/L)} \times 0.048 \text{ (MG/day)} \times 8.34 \text{ (lbs/MG)(L/mg)} = 18.0 \text{ lbs/day}$$

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(2).

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Influent BOD₅ and TSS Monitoring:

The permit will include influent BOD₅ and TSS monitoring at the same frequency as is done for effluent in order to implement Chapter 94.12 and assess percent removal requirements, per DEP policy.

Biosolids Management:

According to the permit renewal application submitted on March 5, 2025; the total sewage sludge/biosolids production within the facility for the previous year was approximately 1.2 dry tons. These sewage sludge/biosolids production were hauled by Glenn Smith Septic Hauler to Washington Township, MD WWTP. Since the facility is located in Maryland, there is no PADEP-issued permit associated with this plant.

Total Residual Chlorine (TRC):

The attached computer printout utilizes the equations and calculations as presented in the Department's 2003 Implementation Guidance for Total Residual Chlorine, dated 11/15/94 (ID No. 391-2000-015) for developing chlorine limitations. The attached printout indicates that an average monthly water quality limit of 0.5 mg/L and 1.6 mg/L max daily would be needed to prevent toxicity concerns. This is consistent with the existing permit. The treatment facility is meeting this limit.

TRC EVALUATION

Input appropriate values in A3:A9 and D3:D9

| | | | |
|-------|--------------------------------|-----|--------------------------------------|
| 0.75 | = Q stream (cfs) | 0.5 | = CV Daily |
| 0.048 | = Q discharge (MGD) | 0.5 | = CV Hourly |
| 30 | = no. samples | 1 | = AFC_Partial Mix Factor |
| 0.3 | = Chlorine Demand of Stream | 1 | = CFC_Partial Mix Factor |
| 0 | = Chlorine Demand of Discharge | 15 | = AFC_Criteria Compliance Time (min) |
| 0.5 | = BAT/BPJ Value | 720 | = CFC_Criteria Compliance Time (min) |
| 0 | = % Factor of Safety (FOS) | | =Decay Coefficient (K) |

| Source | Reference | AFC Calculations | Reference | CFC Calculations |
|--------------|-----------|---------------------|-----------|---------------------|
| TRC | 1.3.2.iii | WLA_afc = 3.241 | 1.3.2.iii | WLA_cfc = 3.152 |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | 5.1c | LTAMULT_cfc = 0.581 |
| PENTOXSD TRG | 5.1b | LTA_afc= 1.208 | 5.1d | LTA_cfc = 1.833 |

| Source | Effluent Limit Calculations | | |
|--------------|-----------------------------|-------------------------------|---------|
| PENTOXSD TRG | 5.1f | AML MULT = 1.231 | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | BAT/BPJ |
| | | INST MAX LIMIT (mg/l) = 1.635 | |

| | |
|----------------|--|
| WLA_afc | $(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$ |
| LTAMULT_afc | $EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$ |
| LTA_afc | wla_afc*LTAMULT_afc |
| WLA_cfc | $(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$ |
| LTAMULT_cfc | $EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$ |
| LTA_cfc | wla_cfc*LTAMULT_cfc |
| AML MULT | $EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$ |
| AVG MON LIMIT | MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT) |
| INST MAX LIMIT | $1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$ |

Chesapeake Bay Strategy:

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6.0 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase 4 (0.2 -0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase 5 (below 0.2 MGD) will monitor during current permit renewal once a year unless two years of monitoring were completed and documented. Any facility in Phases 4 and 5 that undergoes expansion is subjected to cap load right away. This plant is classified as a phase 5 and will be required to monitor and report Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, Total Phosphorus, and Total Nitrogen. The one per month monitoring and report requirements for these parameters will remain in the proposed permit.

Toxics:

This is a minor sewage facility receiving domestic wastewater only and the current application does not require sampling of toxic pollutants (or heavy metals) for those facilities with design flows less than 0.1 MGD. Therefore, no reasonable potential analysis for toxic pollutants has been performed for this permit renewal.

Stormwater:

There are no known stormwater outfalls associated with this facility.

Since the Chapter 93 classification of this stream is Trout Stocking Fishes (TSF), anti-degradation requirements do not apply. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303d Listed Streams:

The discharge is not located on a 303d listed stream segment.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the proposed permit per 40 CFR § 122.44(i)(1)(ii).

Monitoring Frequency and Sample Type

The facility currently is required to collect daily effluent grab samples for D.O., pH, and TRC; two-month effluent 8-hr composite samples of CBOD₅, TSS, and Ammonia-Nitrogen; two-month effluent grab samples of fecal coliform; two-month influent 8-hr composite sample of BOD₅ and TSS; one per month effluent 8-hr composite samples of Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, and TP; and one per month effluent calculation samples of TN. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the existing monitoring frequencies will remain the same as those specified in the proposed permit.

WQM 7.0 :

| | | | |
|-------------------------------|---|------|-----------|
| Discharge pH | = | 7.0 | (Default) |
| Discharge Temperature | = | 20°C | (Default) |
| Stream pH | = | 7.0 | (Default) |
| Stream Temperature | = | 20°C | (Default) |
| Background NH ₃ -N | = | 0 | (Default) |

Node 1: Little Tonoloway Creek (stream code 60871)

| | |
|-------------------|---|
| Elevation: | 484.25 ft (USGS National Map Viewer) |
| Drainage Area: | 49.9 mi. ² (USGS PA StreamStats) |
| River Mile Index: | 2.90 miles (PA DEP eMapPA) |
| Low Flow Yield: | 0.015 cfs/mi. ² |
| Discharge Flow: | 0.048 MGD (NPDES PA0084964) |

Node 2: Just before Trib 60876 to Little Tonoloway Creek

| | |
|-------------------|--|
| Elevation: | 476.64 ft (USGS National Map Viewer) |
| Drainage Area: | 51.00 mi. ² (USGS PA StreamStats) |
| River Mile Index: | 2.39 mile (PA DEP eMapPA) |
| Low Flow Yield: | 0.015 cfs/mi. ² |
| Discharge Flow: | 0.00 MGD |

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

| RMI | Discharge Name | Permit Number | Disc Flow (mgd) |
|------|----------------|---------------|-----------------|
| 2.90 | Bethel Twp | PA0084964 | 0.0480 |

| Parameter | Effluent Limit 30 Day Average (mg/L) | Effluent Limit Maximum (mg/L) | Effluent Limit Minimum (mg/L) |
|------------------|--------------------------------------|-------------------------------|-------------------------------|
| CBOD5 | 25 | | |
| NH3-N | 25 | 50 | |
| Dissolved Oxygen | | | 5 |

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

rptEffLimits

WQM 7.0 Effluent Limits

| SWP Basin | | Stream Code | | Stream Name | | | |
|-----------|------------|-------------------------|-----------------|------------------|-------------------------------|---------------------------|---------------------------|
| 13B | 66071 | LITTLE TONOGLOWAY CREEK | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Eff. Limit 30-day Ave. (mg/L) | Eff. Limit Maximum (mg/L) | Eff. Limit Minimum (mg/L) |
| 2.900 | Bethel Twp | PA0084964 | 0.048 | CBOD5 | 25 | | |
| | | | | NH3-N | 25 | 50 | |
| | | | | Dissolved Oxygen | | | 5 |

rpt_WLA

WQM 7.0 Wasteload Allocations

| SWP Basin | | Stream Code | | Stream Name | | | |
|------------------------------|----------------|---------------------------|--------------------|---------------------------|--------------------|-------------------|-------------------|
| 13B | 66071 | LITTLE TONOGLOWAY CREEK | | | | | |
| NH3-N Acute Allocations | | | | | | | |
| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mgd) | Multiple Criterion (mg/L) | Multiple WLA (mgd) | Critical Reach | Percent Reduction |
| 2.900 | Bethel Twp | 16.76 | 50 | 16.76 | 50 | 0 | 0 |
| NH3-N Chronic Allocations | | | | | | | |
| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mgd) | Multiple Criterion (mg/L) | Multiple WLA (mgd) | Critical Reach | Percent Reduction |
| 2.900 | Bethel Twp | 1.69 | 25 | 1.69 | 25 | 0 | 0 |
| Dissolved Oxygen Allocations | | | | | | | |
| RMI | Discharge Name | CBOD5 | NH3-N | Dissolved Oxygen | Critical Reach | Percent Reduction | |
| 2.90 | Bethel Twp | 25 | 25 | 25 | 5 | 0 | |

Thursday, June 12, 2025 Version 1.1 Page 1 of 1

Thursday, June 12, 2025 Version 1.1 Page 1 of 1

Page: 1 of 1 No Filter Page: 1 of 1 No Filter

NPDES Permit Fact Sheet
Bethel Township STP

NPDES Permit No. PA0084964

rptDOSim

WQM 7.0 D.O. Simulation

| SWP Basin | Stream Code | Stream Name |
|-----------|-------------|------------------------|
| 13B | 600871 | LITTLE TONOLOWAY CREEK |

| RM# | Total Discharge Flow (mgd) | Analysis Temperature (°C) | Analysis pH |
|-------------------------|----------------------------|---------------------------|--------------------|
| 2.900 | 0.018 | 20.000 | 7.000 |
| Reach Length (ft) | Reach Kc (1/day) | Reach Kd (1/day) | Reach Ks (1/day) |
| 18,556 | 0.054 | 36.377 | 0.076 |
| Reach CBOD5 (mg/L) | Reach Kt (1/day) | Reach NH3-N (mg/L) | Reach NO3-N (mg/L) |
| 4.08 | 0.713 | 2.26 | 0.700 |
| Reach DO (mg/L) | Reach Kt (1/day) | Reach DO Goal (mg/L) | |
| 7.000 | 11.513 | 5 | |
| Reach T100 (Time, days) | Reach T100 (Time, days) | Reach T100 (Time, days) | |
| 0.419 | | | |

| Time/Time | Reach CBOD5 (mg/L) | Reach NH3-N (mg/L) | D.O. (mg/L) |
|-----------|--------------------|--------------------|-------------|
| (days) | (mg/L) | (mg/L) | (mg/L) |
| 0.013 | 3.06 | 2.19 | 8.03 |
| 0.084 | 3.06 | 2.13 | 8.10 |
| 0.126 | 3.70 | 2.07 | 8.15 |
| 0.168 | 3.42 | 2.01 | 8.19 |
| 0.209 | 3.39 | 1.95 | 8.22 |
| 0.250 | 3.41 | 1.89 | 8.26 |
| 0.292 | 3.28 | 1.81 | 8.24 |
| 0.333 | 3.21 | 1.78 | 8.24 |
| 0.377 | 3.12 | 1.73 | 8.24 |
| 0.419 | 3.02 | 1.68 | 8.24 |

Thursday, June 12, 2025 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

| Parameters | Value | Notes |
|--------------------|--------|------------------------------------|
| WIA Method | EMPR | Use Inputted Q1=10 and Q30=10 Flow |
| Q1=10/Q7=10 Ratio | 0.64 | Use Inputted WIA Ratio |
| Q30=10/Q7=10 Ratio | 1.36 | Use Inputted Reach Travel Times |
| D.O. Saturation | 90.00% | Temperature Adjust Kt |
| D.O. Goal | 5 | Balanced Technology |

Thursday, June 12, 2025 Version 1.1 Page 1 of 1

rptHydro

WQM 7.0 Hydrodynamic Outputs

| SWP Basin | Stream Code | Stream Name |
|-----------|-------------|------------------------|
| 13B | 600871 | LITTLE TONOLOWAY CREEK |

| RM# | Stream Flow (cfs) | PWS With Stream Flow (cfs) | Net Discharge Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | WD Ratio | Velocity (ft/s) | Reach Trav Time (hr) | Analysis Temp (°C) | Analysis pH | | |
|--------------------|-------------------|----------------------------|--------------------------|---------------------|------------|------------|----------|-----------------|----------------------|--------------------|-------------|-------|------|
| Q7-10 Flow | 2900 | 0.75 | 0.75 | .0743 | 0.00277 | 254 | 19.99 | 35.38 | 0.08 | 0.419 | 20.00 | 7.00 | |
| Q1-10 Flow | 2900 | 0.18 | 0.00 | 0.46 | .0743 | 0.00277 | NA | NA | NA | 0.00 | 0.523 | 20.00 | 7.00 |
| Q30-10 Flow | 2900 | 1.02 | 0.00 | 1.02 | .0743 | 0.00277 | NA | NA | NA | 0.09 | 0.367 | 20.00 | 7.00 |

Thursday, June 12, 2025 Version 1.1 Page 1 of 1

rptGeneral

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RM# | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|------------------------|--------------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 13B | 600871 | LITTLE TONOLOWAY CREEK | 2.900 | 164.25 | 49.80 | 0.000000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trb Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (ft/s) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary pH | Stream pH |
|--------------|-------|----------------|-------------------|----------------------|---------------------|----------|----------------|----------------|--------------|-----------|
| Q1-10 | 0.015 | 0.00 | 0.00 | 0.000 | 0.0 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 |
| Q1-10 | 0.00 | 0.00 | 0.00 | 0.000 | 0.0 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 |
| Q30-10 | 0.00 | 0.00 | 0.00 | 0.000 | 0.0 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 |

Discharge Data

| Name | Permit Number | Existing Discharge (mgd) | Permitted Design Discharge (mgd) | Design Discharge (mgd) | Release Factor | Disc Temp (°C) | Disc pH |
|-------------|---------------|--------------------------|----------------------------------|------------------------|----------------|----------------|---------|
| Bethel Trig | PA0084964 | 0.000 | 0.000 | 0.000 | 20.00 | 7.00 | |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trb Conc (mg/L) | Stream Conc (mg/L) | Flow Coef (1/day) |
|------------------|------------------|-----------------|--------------------|-------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Thursday, June 12, 2025 Version 1.1 Page 1 of 2

Page: 1

Page: 1

NPDES Permit Fact Sheet
Bethel Township STP

NPDES Permit No. PA0084964

rptGeneral

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RM | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|------------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 128 | 608F1 | LITTLE TONOLOWAY CREEK | 2.380 | 476.64 | 51.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib. Flow | Stream Flow | Rich Trav. Time | Rich Velocity | WD Ratio | Rich Width | Rich Depth | Tributary Temp | Stream pH |
|--------------|-------|------------|-------------|-----------------|---------------|----------|------------|------------|----------------|-----------|
| | (cfm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | (°C) |
| QT40 | 0.015 | 0.00 | 0.00 | 0.0000 | 0.00 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 |
| Q140 | 0.00 | 0.00 | 0.00 | 0.0000 | 0.00 | | | | | |
| Q30-10 | 0.00 | 0.00 | 0.00 | 0.0000 | 0.00 | | | | | |

Discharge Data

| Name | Permit Number | Existing Dis. Flow (mgd) | Permitted Design Dis. Flow (mgd) | Design Flow (mgd) | Reserve Factor | Disc. Temp (°C) | Disc. pH |
|------------|---------------|--------------------------|----------------------------------|-------------------|----------------|-----------------|----------|
| Bethel Twp | PA0084964 | 0.0000 | 0.0000 | 0.0000 | 0.000 | 20.00 | 7.00 |

Parameter Data

| Parameter Name | Disc. Conc. (mg/L) | Tab. Conc. (mg/L) | Stream Conc. (mg/L) | Fate Coef. (1/day) |
|------------------|--------------------|-------------------|---------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH4-N | 25.00 | 0.00 | 0.00 | 0.70 |

Thursday, June 12, 2025 Version 1.1 Page 2 of 2



Page: 14 <input

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|-------------------|----------------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| D.O. | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD ₅ | 10.0 | 16.0 | XXX | 25.0 | 40.0 | 50.0 | 2/month | 8-Hr Composite |
| BOD ₅ Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| TSS | 12.0 | 18.0 | XXX | 30.0 | 45.0 | 60.0 | 2/month | 8-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 2/month | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/year | Grab |
| Ammonia | 5.8 | XXX | XXX | 14.5 | XXX | 40.0 | 2/month | 8-Hr Composite |
| Nitrate-Nitrite | XXX | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| TKN | XXX | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | XXX | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |



NPDES Permit Fact Sheet

Bethel Township STP

NPDES Permit No. PA0084964

USGS StreamStats

Basin Characteristics can be edited here

| Parameter | Value |
|-----------|-------|
| DRNAREA | 51 |
| PRECIP | 37 |
| STRDEN | 2.62 |
| ROCKDEP | 3.6 |
| CARBON | 5.4 |

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports
- Hydrologic Features Report

[Open Report](#)

POWERED BY [WIM](#)

USGS Home | Contact USGS | Search USGS | Accessibility | FOIA | Privacy | Policy & Notices

Zoom Map S Lat: 38.500000 N Long: -77.500000 2 Km 5 Km

Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|-------|-----------------------|
| CARBON | Percentage of area of carbonate rock | 5.4 | percent |
| DRNAREA | Area that drains to a point on a stream | 51 | square miles |
| PRECIP | Mean Annual Precipitation | 37 | inches |
| ROCKDEP | Depth to rock | 3.6 | feet |
| STRDEN | Stream Density -- total length of streams divided by drainage area | 2.62 | miles per square mile |

Low-Flow Statistics


Low-Flow Statistics Parameters [Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| CARBON | Percent Carbonate | 5.4 | percent | 0 | 99 |
| DRNAREA | Drainage Area | 51 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 37 | inches | 35 | 50.4 |
| ROCKDEP | Depth to Rock | 3.6 | feet | 3.32 | 5.65 |
| STRDEN | Stream Density | 2.62 | miles per square mile | 0.51 | 3.1 |

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

| Statistic | Value | Unit | SE | ASEp |
|-------------------------|-------|--------------------|----|------|
| 7 Day 2 Year Low Flow | 2.08 | ft ³ /s | 38 | 38 |
| 30 Day 2 Year Low Flow | 3.13 | ft ³ /s | 33 | 33 |
| 7 Day 10 Year Low Flow | 0.763 | ft ³ /s | 51 | 51 |
| 30 Day 10 Year Low Flow | 1.2 | ft ³ /s | 46 | 46 |
| 90 Day 10 Year Low Flow | 2.2 | ft ³ /s | 36 | 36 |



USGS StreamStats

Basin Characteristics can be edited here

| Parameter | Value |
|-----------|-------|
| DRNAREA | 112 |
| PRECIP | 37 |
| STRDEN | 2.84 |
| ROCKDEP | 3.6 |
| CARBON | 2.52 |

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports
- Hydrologic Features Report

[Open Report](#)

POWERED BY [WIM](#)

USGS Home | Contact USGS | Search USGS | Accessibility | FOIA | Privacy | Policy & Notices

Zoom Map S Lat: 38.500000 N Long: -77.500000 2 Km 5 Km

Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|-------|-----------------------|
| CARBON | Percentage of area of carbonate rock | 2.52 | percent |
| DRNAREA | Area that drains to a point on a stream | 112 | square miles |
| PRECIP | Mean Annual Precipitation | 37 | inches |
| ROCKDEP | Depth to rock | 3.6 | feet |
| STRDEN | Stream Density -- total length of streams divided by drainage area | 2.84 | miles per square mile |

Low-Flow Statistics


Low-Flow Statistics Parameters [Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| CARBON | Percent Carbonate | 2.52 | percent | 0 | 99 |
| DRNAREA | Drainage Area | 112 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 37 | inches | 35 | 50.4 |
| ROCKDEP | Depth to Rock | 3.6 | feet | 3.32 | 5.65 |
| STRDEN | Stream Density | 2.84 | miles per square mile | 0.51 | 3.1 |

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

| Statistic | Value | Unit | SE | ASEp |
|-------------------------|-------|--------------------|----|------|
| 7 Day 2 Year Low Flow | 4.43 | ft ³ /s | 38 | 38 |
| 30 Day 2 Year Low Flow | 6.64 | ft ³ /s | 33 | 33 |
| 7 Day 10 Year Low Flow | 1.67 | ft ³ /s | 51 | 51 |
| 30 Day 10 Year Low Flow | 2.62 | ft ³ /s | 46 | 46 |
| 90 Day 10 Year Low Flow | 4.76 | ft ³ /s | 36 | 36 |



| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [REDACTED]) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input checked="" type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input checked="" type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input checked="" type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input checked="" type="checkbox"/> | SOP: BCW-PMT-033 |
| <input type="checkbox"/> | Other: [REDACTED] |