

Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0085014  
APS ID 72  
Authorization ID 1463518

**Applicant and Facility Information**

Applicant Name	<u>Conestoga Township</u>	Facility Name	<u>Conestoga Township Colemanville STP</u>
Applicant Address	<u>3959 Main Street</u>	Facility Address	<u>Fox Hollow Road</u>
	<u>Conestoga, PA 17516-9616</u>		<u>Colemanville, PA 17516</u>
Applicant Contact	<u>Brandi Tomasetti</u>	Facility Contact	<u>Duane Himes</u>
Applicant Phone	<u>(717) 872-4301</u>	Facility Phone	<u>(717) 278-6562</u>
Client ID	<u>64902</u>	Site ID	<u>449450</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Conestoga Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lancaster</u>
Date Application Received	<u>November 30, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 5, 2023</u>	If No, Reason	
Purpose of Application	<u>NPDES Renewal.</u>		

**Summary of Review**

Conestoga Township has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The existing permit was issued May 21, 2019, and became effective on June 1, 2019, authorizing discharge of treated sewage from the facility into Pequea Creek. The existing permit expiration date was May 31, 2024, and the permit has been administratively extended since that time.

Per the previous fact sheet, the WWTP was designed to serve approximately ten homes built on the steep slope of a hillside on the edge of a floodplain flat of the Pequea Creek. The facility was constructed to include a septic tank, lined sand filter, and a chlorine tank. The ten homes were split into groups of five. Each group flows to two septic tanks and then to a common dosing pump. The dosing pump alternately doses to the two lined sand mounds, each with a design capacity of 2,000 gallons per day (gpd). The wastewater flows through an erosion chlorinator and tank before discharging to Pequea Creek. The system is built on the flood flat but was designed to be watertight and flood-proof.

Changes in this renewal: E. Coli monitoring has been added to the permit.

Sludge use and disposal description and location(s): Sludge holding tank with offsite disposal.

Supplemental information for this facility is provided at the end of this fact sheet.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	September 20, 2024
X		Maria D. Bebeneck for Daniel W. Martin, P.E. / Environmental Engineer Manager	October 1, 2024

#### Summary of Review

day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.004
Latitude	39° 53' 58"	Longitude	76° 20' 41"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Pequea Creek	Stream Code	7450
NHD Com ID	57468119	RMI	2.36
Drainage Area	152 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.173
Q <sub>7-10</sub> Flow (cfs)	26.3	Q <sub>7-10</sub> Basis	USGS PA StreamStats
Elevation (ft)	183	Slope (ft/ft)	
Watershed No.	7-K	Chapter 93 Class.	WWF, MF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	Habitat Alterations, Siltation, Pathogens		
Source(s) of Impairment	Habitat Modification – Other Than Hydromodification, Agriculture, Source Unknown		
TMDL Status	N/A	Name	N/A
Nearest Downstream Public Water Supply Intake	PPL Holtwood Power Plant		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	7.5

Changes Since Last Permit Issuance: USGS PA StreamStats provided a drainage area of 153 mi<sup>2</sup> and a Q<sub>7-10</sub> flow of 26.3 cfs at the point of discharge.

Other Comments: None

Treatment Facility Summary				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sand Mound	Tablet Chlorination	0.004
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.004	10	Not Overloaded	Sludge Hauling	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The treatment process consists of septic tanks, dosing pumps, sand mounds, tablet chlorinator, and Outfall 001 to Pequea Creek

Compliance History	
<b>Summary of DMRs:</b>	A summary of past DMR effluent data is presented on the next page of this fact sheet.
<b>Summary of Inspections:</b>	8/28/2023: A routine inspection was conducted. No signs of leakage were noted at the sand mounds during the inspection. No other issues were noted at the WWTP.

Other Comments: There are currently no open violations associated with the Applicant

Compliance History

DMR Data for Outfall 001 (from August 1, 2023 to July 31, 2024)

Parameter	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23
Flow (MGD) Average Monthly					0.003	0.003	0.003			0.003		
Flow (MGD) Daily Maximum					0.003	0.003	0.003			0.003		
pH (S.U.) Instantaneous Minimum					6.00	6.15	6.23			6.4		
pH (S.U.) Instantaneous Maximum					7.10	7.13	7.2			6.8		
TRC (mg/L) Average Monthly					< 0.5	0.74	< 0.3			0.12		
TRC (mg/L) Instantaneous Maximum					0.5	1.9	0.5			0.5		
CBOD5 (lbs/day) Average Monthly					< 0.05	0.05	0.1			< 0.05		
CBOD5 (lbs/day) Weekly Average					< 0.05	0.05	0.2			< 0.05		
CBOD5 (mg/L) Average Monthly					< 2.0	< 0.2	5.0			< 2.0		
CBOD5 (mg/L) Weekly Average					< 2.0	< 0.2	6.0			< 2.0		
TSS (lbs/day) Average Monthly					< 1.0	< 0.05	< 0.1			0.1		
TSS (lbs/day) Weekly Average					< 1.0	< 0.05	0.2			0.1		
TSS (mg/L) Average Monthly					< 2.0	< 0.2	< 5.0			5.0		
TSS (mg/L) Weekly Average					< 2.0	< 0.2	9.0			5.0		
Fecal Coliform (No./100 ml) Geometric Mean					< 1.0	< 1.0	235			< 1		
Fecal Coliform (No./100 ml) Instantaneous Maximum					< 1.0	< 1.0	2419.6			< 1		

NPDES Permit Fact Sheet  
Conestoga Township Colemanville STP

NPDES Permit No. PA0085014

Nitrate-Nitrite (mg/L) Average Quarterly					< 10.14			< 35.5					
Total Nitrogen (mg/L) Average Quarterly					< 17.07			< 37.24					
Ammonia (mg/L) Average Quarterly					5.1			< 0.5					
TKN (mg/L) Average Quarterly					6.66			1.74					
Total Phosphorus (mg/L) Average Quarterly					1.875			3.163					

Compliance History

Effluent Violations for Outfall 001, from: September 1, 2023 To: July 31, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	02/29/24	Avg Mo	0.74	mg/L	.5	mg/L
TRC	02/29/24	IMAX	1.9	mg/L	1.6	mg/L

**Existing Effluent Limitations and Monitoring Requirements**

**Outfall 001**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	0.8	1.2	XXX	25	37	50	1/month	Grab
Total Suspended Solids	1.0	1.5	XXX	30	45	60	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
Total Kjeldahl Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
Nitrate-Nitrite as N	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Calculation
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 39° 53' 58.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .004  
Longitude 76° 20' 41"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

CBOD<sub>5</sub>, NH<sub>3</sub>-N

Pursuant to 40 CFR § 122.44(d)(1)(i), more stringent requirements should be considered when pollutants are discharged at the levels which have the reasonable potential to cause or contribute to excursions above water quality standards.

WQM 7.0 ver. 1.1b is a water quality model designed to assist DEP in determining appropriate water quality based effluent limits (WQBELs) for carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), ammonia (NH<sub>3</sub>-N) and dissolved oxygen (D.O.). DEP's Technical Guidance No. 391-2000-007 provides the technical methods contained in WQM 7.0 for determining wasteload allocations and for determining recommended NPDES effluent limits for point source discharges. The model was utilized for this permit renewal. The model output indicated a CBOD<sub>5</sub> average monthly limit of 25 mg/l, an NH<sub>3</sub>-N average monthly limit of 25 mg/l, and a D.O. minimum limit of 5.0 mg/l were protective of water quality. The flow data used to run the model was acquired from USGS PA StreamStats and is included as an attachment. The CBOD<sub>5</sub> limit is the same as the existing permit limit, which will remain in the permit. Per DEP's SOP No. BCW-PMT-033, for existing facilities, if WQM modeling results indicate that an average monthly limit of 25 mg/l is acceptable, a year round monitoring requirement for ammonia-nitrogen should be established. This is consistent with the existing permit limit.

There are no industrial/commercial users contributing industrial wastewater to the system and Conestoga Township does not currently have an EPA-approved pretreatment program. Accordingly, evaluating reasonable potential of toxic pollutants is not necessary as effluent levels of toxic pollutants are expected to be insignificant.

**Additional Considerations**

Chesapeake Bay Total Maximum Daily Load (TMDL)

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the *Pennsylvania Chesapeake Watershed Implementation Plan* (WIP), dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a *Phase 2 Watershed Implementation Plan Wastewater Supplement* (Phase 2 Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. A new update to the WIP was published as the Phase 3 WIP in August 2019. As

part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on December 17, 2019, and is the basis for the development of any Chesapeake Bay related permit parameters. Sewage discharges have been prioritized based on their design flow to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual Cap Loads based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. For Phase 4 and 5 facilities, Cap Loads are not currently being implemented for renewed or amended permits for facilities that do not increase design flow.

This facility is considered a Phase 5 non-significant facility with a design flow less than 0.2 MGD but greater than 0.002 MGD. According to the Phase 3 WIP, TN and TP monitoring is recommended for this facility, which is consistent with the existing permit. DEP's SOP No. BPNPSM-PMT-033 states that a lesser sampling frequency for TN and TP can be used for discharges to waters not impaired for nutrients. As this receiving stream does not have an impairment for nutrients, a sampling frequency of 1/quarter will be included in the effluent limitations for TN and TP.

#### Fecal Coliform

PA Code § 92a.47.(a)(4) requires a monthly average limit of 200/100 mL as a geometric mean and an instantaneous maximum limit not greater than 1,000/100 mL from May through September for fecal coliform. PA Code § 92a.47.(a)(5) requires a monthly average limit of 2,000/100 mL as a geometric mean and an instantaneous maximum limit not greater than 10,000/100 mL from October through April for fecal coliform. This is consistent with the existing permit limits.

#### E. Coli

PA Code § 92a.61 requires IMAX reporting of E. Coli. Per DEP's SOP No. BCW-PMT-033, sewage dischargers with a design flow of 0.002 – 0.05 mgd will include E. Coli monitoring with a frequency of 1/year. This parameter has been added to the renewal permit.

#### Total Residual Chlorine

The attached computer printout utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID No. 391-2000-015) for developing chlorine limitations. The Guidance references Chapter 92, Section 92.2d (3) which establishes a standard BAT limit of 0.5 mg/l unless a facility-specific BAT has been developed. The attached printout indicates that a water quality limit of 0.5 mg/l would be needed to prevent toxicity concerns. This is the same as the existing permit limit; therefore, a TRC limit of 0.5 mg/l monthly average and 1.6 mg/l instantaneous maximum will remain in the permit.

#### Sampling Frequency & Sample Type

The monitoring requirements were established based on BPJ and/or Table 6-3 of DEP's Technical Guidance No. 362-0400-001.

#### Anti-Degradation

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

#### 303(d) Listed Streams

The discharge is located on a stream segment that is listed as impaired. There is an aquatic life impairment for habitat alterations due to habitat modification – other than hydromodification, and siltation due to agriculture. There is a recreational impairment for due to pathogens from an unknown source.

#### Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit unless any exceptions are addressed by DEP in this fact sheet.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.


**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/week	Grab
CBOD5	0.8	1.2	XXX	25.0	37.0	50	1/month	Grab
TSS	1.0	1.5	XXX	30.0	45.0	60	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Calculation
Ammonia	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
TKN	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab

Compliance Sampling Location: Outfall 001

Other Comments: None

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]



Copyright © 2013 National Geographic Society, i-cubed


## Conestoga TWP Colemanville STP PA0085014 Outfall 001

**Region ID:** PA

**Workspace ID:** PA20240920135712767000

**Clicked Point (Latitude, Longitude):** 39.89943, -76.34408

**Time:** 2024-09-20 09:57:39 -0400



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	4.2281	degrees
DRNAREA	Area that drains to a point on a stream	152	square miles
ROCKDEP	Depth to rock	5.3	feet
URBAN	Percentage of basin with urban development	2.9887	percent

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	152	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	4.2281	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.3	feet	4.13	5.21
URBAN	Percent Urban	2.9887	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	46.1	ft^3/s
30 Day 2 Year Low Flow	55.9	ft^3/s
7 Day 10 Year Low Flow	26.3	ft^3/s
30 Day 10 Year Low Flow	31.5	ft^3/s
90 Day 10 Year Low Flow	45	ft^3/s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government

as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

**USGS Product Names Disclaimer:** Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.24.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

## Conestoga TWP Colemanville STP PA0085014 RMI = 0.0

**Region ID:** PA

**Workspace ID:** PA20240920140251704000

**Clicked Point (Latitude, Longitude):** 39.88748, -76.37056

**Time:** 2024-09-20 10:03:15 -0400



 [Collapse All](#)

### ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	4.2914	degrees
DRNAREA	Area that drains to a point on a stream	153	square miles
ROCKDEP	Depth to rock	5.3	feet
URBAN	Percentage of basin with urban development	2.9609	percent

## ➤ Low-Flow Statistics

### Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	152	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	4.2281	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.3	feet	4.13	5.21
URBAN	Percent Urban	2.9887	percent	0	89

### Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

### Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	46.1	ft^3/s
30 Day 2 Year Low Flow	55.9	ft^3/s
7 Day 10 Year Low Flow	26.3	ft^3/s
30 Day 10 Year Low Flow	31.5	ft^3/s
90 Day 10 Year Low Flow	45	ft^3/s

#### *Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government

as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

**USGS Product Names Disclaimer:** Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.24.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

TRC\_CALC

1A	B	C	D	E	F	G			
<b>2 TRC EVALUATION</b>									
3 Input appropriate values in B4:B8 and E4:E7									
4	26.3	= Q stream (cfs)		0.5	= CV Daily				
5	0.004	= Q discharge (MGD)		0.5	= CV Hourly				
6	30	= no. samples		1	= AFC_Partial Mix Factor				
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor				
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)				
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)				
	0	= % Factor of Safety (FOS)			= Decay Coefficient (K)				
10	Source	Reference	AFC Calculations	Reference	CFC Calculations				
11	TRC	1.3.2.iii	WLA_afc = #####	1.3.2.iii	WLA_cfc = 1321.811				
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581				
13	PENTOXSD TRG	5.1b	LTA_afc = 505.211	5.1d	LTA_cfc = 768.439				
14									
15	Source	Effluent Limit Calculations							
16	PENTOXSD TRG	5.1f	AML MULT = 1.231						
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ					
18			INST MAX LIMIT (mg/l) = 1.635						
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
LTAMULT_afc	$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^{0.5})$								
LTA_afc	$\text{wla\_afc}*\text{LTAMULT\_afc}$								
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
LTAMULT_cfc	$\text{EXP}((0.5*\text{LN}(cvd^2/no\_samples+1))-2.326*\text{LN}(cvd^2/no\_samples+1)^{0.5})$								
LTA_cfc	$\text{wla\_cfc}*\text{LTAMULT\_cfc}$								
AML MULT	$\text{EXP}(2.326*\text{LN}((cvd^2/no\_samples+1)^{0.5})-0.5*\text{LN}(cvd^2/no\_samples+1))$								
AVG MON LIMIT	$\text{MIN}(\text{BAT\_BPJ},\text{MIN}(\text{LTA\_afc},\text{LTA\_cfc})*\text{AML\_MULT})$								
INST MAX LIMIT	$1.5*((\text{av\_mon\_limit}/\text{AML\_MULT})/\text{LTAMULT\_afc})$								

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
07K	7450 PEQUEA CREEK				2.360	183.00	152.00	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)		
Q7-10	0.100	0.00	26.30	0.000	0.000	0.0	0.00	0.00	20.00	7.00		
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
<b>Discharge Data</b>												
		Name		Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
		Colemanville		PA0085014	0.0040	0.0040	0.0040	0.000	25.00	7.00		
<b>Parameter Data</b>												
				Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
				CBOD5		25.00	2.00	0.00	1.50			
				Dissolved Oxygen		5.00	8.24	0.00	0.00			
				NH3-N		25.00	0.00	0.00	0.70			

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07K		7450 PEQUEA CREEK			0.000	171.00	153.00	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.100	0.00	27.10	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			0.0000	0.0000	0.0000	0.000	0.00	7.00		
<b>Parameter Data</b>										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		3.00	8.24	0.00	0.00				
	NH3-N		25.00	0.00	0.00	0.70				

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
07K			7450			PEQUEA CREEK							
RMI	Stream Flow	PWS Wth	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
2.360	26.30	0.00	26.30	.0062 0.00096	.889	78.15	87.92	0.38	0.381	20.00	7.00		
<b>Q1-10 Flow</b>													
2.360	16.83	0.00	16.83	.0062 0.00096	NA	NA	NA	0.29	0.489	20.00	7.00		
<b>Q30-10 Flow</b>													
2.360	35.77	0.00	35.77	.0062 0.00096	NA	NA	NA	0.45	0.321	20.00	7.00		

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07K	7450	PEQUEA CREEK					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	2.360 Colemanville	16.76	50	16.76	50	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	2.360 Colemanville	1.89	25	1.89	25	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
	2.36 Colemanville	25	25	25	25	5	5
						0	0

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07K	7450	PEQUEA CREEK		
<u>RMI</u> 2.360	<u>Total Discharge Flow (mgd)</u> 0.004	<u>Analysis Temperature (°C)</u> 20.001	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 78.152	<u>Reach Depth (ft)</u> 0.889	<u>Reach WDRatio</u> 87.920	<u>Reach Velocity (fps)</u> 0.379	
<u>Reach CBOD5 (mg/L)</u> 2.01	<u>Reach Kc (1/days)</u> 0.003	<u>Reach NH3-N (mg/L)</u> 0.01	<u>Reach Kn (1/days)</u> 0.700	
<u>Reach DO (mg/L)</u> 8.242	<u>Reach Kr (1/days)</u> 1.701	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5	
<u>Reach Travel Time (days)</u> 0.381	<b>Subreach Results</b>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.038	2.01	0.01	8.24
	0.076	2.00	0.01	8.24
	0.114	2.00	0.01	8.24
	0.152	2.00	0.01	8.24
	0.190	2.00	0.01	8.24
	0.229	2.00	0.01	8.24
	0.267	2.00	0.00	8.24
	0.305	2.00	0.00	8.24
	0.343	2.00	0.00	8.24
	0.381	2.00	0.00	8.24

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07K	7450		PEQUEA CREEK				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.360	Colemanville	PA0085014	0.004	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5