

Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0085022  
APS ID 731  
Authorization ID 1460203

**Applicant and Facility Information**

Applicant Name	<u>Conoy Township</u>	Facility Name	<u>Conoy Township Falmouth WWTP</u>
Applicant Address	<u>211 Falmouth Road</u>	Facility Address	<u>2515 River Road</u>
	<u>Bainbridge, PA 17502</u>		<u>Bainbridge, PA 17502</u>
Applicant Contact	<u>Jennifer Rabuck</u>	Facility Contact	<u>Jennifer Rabuck</u>
Applicant Phone	<u>(717) 367-4991</u>	Facility Phone	<u>(717) 367-4991</u>
Client ID	<u>77263</u>	Site ID	<u>239235</u>
Ch 94 Load Status	<u>Existing Organic Overload</u>	Municipality	<u>Conoy Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lancaster</u>
Date Application Received	<u>October 31, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>November 15, 2023</u>	If No, Reason	
Purpose of Application	<u>NPDES Renewal.</u>		

**Summary of Review**

Conoy Township has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The existing permit was issued April 30, 2019, and became effective on June 1, 2019, authorizing discharge of treated sewage from the facility into UNT 9213 to the Susquehanna River. The existing permit expiration date was May 31, 2024, and the permit has been administratively extended since that time. An amendment was issued to the NPDES on December 28, 2023. The amendment was due to the change from chlorine to UV disinfection; the TRC limit was removed from the permit and a UV monitoring requirement was added.

Changes in this renewal: E. Coli monitoring has been added to the permit.

Sludge use and disposal description and location(s): Aerobic digester tank with offsite disposal at Conoy Township's Bainbridge WWTP

Supplemental information for this facility is provided at the end of this fact sheet.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	June 12, 2024
X		Maria D. Bebeneck for Daniel W. Martin, P.E. / Environmental Engineer Manager	June 13, 2024

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.025
Latitude	40° 7' 16"	Longitude	76° 42' 40"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to Susquehanna River (WWF, MF)	Stream Code	9213
NHD Com ID	57463595	RMI	0.1
Drainage Area	1.57 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.12
Q <sub>7-10</sub> Flow (cfs)	0.188	Q <sub>7-10</sub> Basis	USGS Stream Gage
Elevation (ft)	274	Slope (ft/ft)	
Watershed No.	7-G	Chapter 93 Class.	WWF, MF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	N/A		
Source(s) of Impairment	N/A		
TMDL Status	Name		N/A
Nearest Downstream Public Water Supply Intake	Columbia Water Company		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	13.9

Changes Since Last Permit Issuance: Stream flows were determined by establishing a correlation to the yield of USGS gage station No. 01576500 on Conestoga River. The Q<sub>7-10</sub> and drainage area at the gage station are 38.6 ft<sup>3</sup>/s and 324 mi<sup>2</sup>, respectively. The Q<sub>7-10</sub> runoff rate at the gage station was calculated as follows:

- Q<sub>7-10</sub> = (38.6 ft<sup>3</sup>/s)/324 mi<sup>2</sup> = 0.12 ft<sup>3</sup>/s/mi<sup>2</sup>

The drainage area at the discharge point = 1.57 mi<sup>2</sup>.

The Q<sub>7-10</sub> at the discharge point = 1.57 mi<sup>2</sup> x 0.12 ft<sup>3</sup>/s/mi<sup>2</sup> = 0.188 ft<sup>3</sup>/s.

Other Comments: None

Treatment Facility Summary				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	UV Disinfection	0.025
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.025	50	Existing Organic Overload	Aerobic Digester	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The treatment process consists of: Comminutor and Barscreen, 1 Equalization Tank, 1 Extended Aeration Tank, 1 Final Clarifier, UV Disinfection Process, 1 Sludge Holding Tank, Outfall 001 to UNT 9213 to Susquehanna River.

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	A summary of past DMR effluent data is presented on the next page of this fact sheet.
<b>Summary of Inspections:</b>	<p>3/27/2019: A Notice of Violation (NOV) was issued due to effluent violations for TSS, Fecal Coliform, Ammonia-N, and CBOD<sub>5</sub>.</p> <p>4/23/2019: A routine inspection was conducted. The clarifier influent had a heavy accumulation of solids, foam and grease. The effluent had a slight brown tint with fine suspended solids. Field results were within permitted limits.</p> <p>5/19/2020: A NOV was issued due to effluent violations for Fecal Coliform , TSS, and CBOD<sub>5</sub>.</p> <p>6/9/2020: An administrative inspection was conducted. All treatment units were operable, and there were no outstanding issues or needs.</p> <p>9/14/2020: A routine inspection was conducted. The clarifier effluent trough appeared slightly cloudy. Effluent samples revealed exceedances of pH and TRC. The effluent appeared cloudy with coarse brown suspended solids.</p> <p>7/8/2021: A routine partial inspection was conducted. The clarifier appeared mostly clear with large pin floc particles. The effluent trough appeared clear and free of excessive algae. The chlorine contact tank contents appeared mostly clear. The WWTP was not discharging during the inspection. The outfall was checked. The area just below the outfall appeared clear due to recent operator cleaning. An accumulation of sewage solids was visible approximately 8 feet from the outfall within UNT to Susquehanna River. Solids were visible approximately 20 feet downstream. Accumulations were 1 inch deep and appeared dark brown with a sewage odor. The solids were cleared from the outfall on 7/9/21.</p> <p>9/14/2021: A NOV was issued due to the violations documented during the 7/8/21 inspection, as well as effluent violations.</p>

Other Comments: There are no open violations for this Applicant.

Compliance History

DMR Data for Outfall 001 (from May 1, 2023 to April 30, 2024)

Parameter	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23
Flow (MGD) Average Monthly	0.021	0.015	0.152	0.0167	0.0147	0.0120	0.0119	0.0122	0.0117	0.0119	0.0118	0.0121
Flow (MGD) Daily Maximum	0.077	0.027	0.0195	0.0274	0.0357	0.0191	0.0175	0.0199	0.0166	0.0261	0.0179	0.0177
pH (S.U.) Instantaneous Minimum	6.6	6.5	7.12	6.75	6.61	6.70	6.68	6.87	6.52	6.26	6.49	6.28
pH (S.U.) Instantaneous Maximum	7.8	7.5	7.53	8.05	7.65	7.94	7.66	7.8	7.83	7.64	7.51	7.31
DO (mg/L) Instantaneous Minimum	5.3	7.0	7.21	8.89	8.19	7.73	6.43	6.12	6.21	6.40	6.96	6.86
TRC (mg/L) Average Monthly					GG							
TRC (mg/L) Instantaneous Maximum					GG							
CBOD5 (lbs/day) Average Monthly	1.1	0.6	0.40	0.82	1.16	0.48	0.53	0.24	0.38	0.14	0.59	0.59
CBOD5 (lbs/day) Weekly Average	1.4	0.8	0.51	1.22	1.42	0.69	0.64	0.26	0.58	0.27	0.60	0.68
CBOD5 (mg/L) Average Monthly	5.7	5.1	3.25	6.60	10.70	4.85	5.15	2.40	4.45	2.40	6.65	5.20
CBOD5 (mg/L) Weekly Average	6.4	6.6	4.40	9.20	15.20	6.90	6.80	2.70	6.90	2.80	7.0	5.70
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	36	22	10.63	20.66	16.41	8.64	8.74	6.32	2.09	15.17	4.87	7.61
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	49	26	13.09	24.40	17.393	9.33	9.79	6.65	3.16	26.15	5.48	7.87
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	211	206	84.25	172.50	147	88.35	80.95	64.20	23.75	154.30	55.05	67.65

NPDES Permit Fact Sheet  
Conoy Township Falmouth WWTP

NPDES Permit No. PA0085022

TSS (lbs/day) Average Monthly	3.2	1.1	0.50	1.54	1.56	0.75	0.55	0.50	0.37	1.64	0.78	0.91
TSS (lbs/day) Raw Sewage Influent   Average Monthly	54	30	14.17	22.20	11.32	12.59	24.33	5.90	1.98	8.64	5.57	6.03
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	60	38	21.62	32.62	12.55	17.51	37.70	6.47	2.09	13.66	6.47	6.57
TSS (lbs/day) Weekly Average	4.5	1.5	0.53	2.65	1.96	1.0	0.61	0.62	0.41	2.90	0.88	1.07
TSS (mg/L) Average Monthly	15.0	9.7	4	12.00	14.50	7.65	5.10	5.0	4.20	16.0	8.85	8.0
TSS (mg/L) Raw Sewage Influent   Average Monthly	271	285	110.00	179.00	97.00	127.50	245.00	60.0	22.50	87.50	63.0	54.0
TSS (mg/L) Weekly Average	16.0	12.8	4	20.0	21.0	10.00	5.20	6.0	4.40	28.0	10.40	9.0
Fecal Coliform (No./100 ml) Geometric Mean	120	138	28	54	61.85	15.91	62.03	138.56	21.75	61.48	113.84	53.38
Fecal Coliform (No./100 ml) Instantaneous Maximum	235	164	192	140	85.00	23.00	296.00	320.0	43.00	140.00	120.0	77.0
UV Intensity (mW/cm <sup>2</sup> ) Instantaneous Minimum	0.1	0.7	0.6	0.7	0.7							
Nitrate-Nitrite (lbs/day) Average Monthly	5.52	5.07	4.93	4.90	4.41	4.61	3.22	1.56	4.22	4.37	4.09	5.12
Nitrate-Nitrite (mg/L) Average Monthly	30.90	44.3	39.60	41.35	39.25	47.05	27.125	15.465	47.5	43.6	45.9	45.65
Total Nitrogen (lbs/day) Average Monthly	5.85	5.38	5.22	5.31	4.83	4.70	3.82	2.74	4.39	4.64	4.28	5.30
Total Nitrogen (mg/L) Average Monthly	32.50	47.05	41.95	44.70	42.95	48.05	33.3	27.75	49.45	46.2	47.95	47.30
Ammonia (lbs/day) Average Monthly	< 0.04	0.03	0.02	0.04	0.03	0.03	0.26	1.07	0.04	0.06	0.07	0.03
Ammonia (mg/L) Average Monthly	< 0.2	0.3	0.13	0.33	0.27	0.27	2.77	11.03	0.50	0.64	0.82	0.22
TKN (lbs/day) Average Monthly	0.34	0.32	5.22	0.40	0.42	0.10	0.59	1.19	0.17	0.25	0.34	0.18

**NPDES Permit Fact Sheet**  
**Conoy Township Falmouth WWTP**

**NPDES Permit No. PA0085022**

TKN (mg/L) Average Monthly	1.61	2.80	41.95	3.34	3.72	1.02	6.13	12.35	1.935	2.54	3.81	1.65
Total Phosphorus (lbs/day) Average Monthly	0.73	0.73	0.72	0.63	0.62	0.62	0.84	0.71	0.72	0.80	0.64	0.71
Total Phosphorus (mg/L) Average Monthly	4.29	6.38	5.80	5.32	5.62	6.37	7.735	7.14	8.155	7.975	7.225	6.33

**Compliance History**

**Effluent Violations for Outfall 001, from: June 1, 2023 To: April 30, 2024**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Ammonia	09/30/23	Avg Mo	11.03	mg/L	7.0	mg/L

**Existing Effluent Limitations and Monitoring Requirements**

**Outfall 001**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	5.2	8.3	XXX	25	40	50	2/month	8-Hr Composite
Biochemical Oxygen Demand (BOD5)		Report Daily Max	XXX	Report	XXX	XXX		8-Hr Composite
Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Suspended Solids	6.3	9.4	XXX	30	45	60	2/month	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ultraviolet light intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Ammonia-Nitrogen Nov 1 - Apr 30	4.3	XXX	XXX	21	XXX	42	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	1.4	XXX	XXX	7.0	XXX	21	2/month	8-Hr Composite
Total Kjeldahl Nitrogen	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	.025	
Latitude	40° 7' 16.00"	Longitude	-76° 42' 40.00"	
Wastewater Description:	Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

### Water Quality-Based Limitations

#### CBOD<sub>5</sub>, NH<sub>3</sub>-N

Pursuant to 40 CFR § 122.44(d)(1)(i), more stringent requirements should be considered when pollutants are discharged at the levels which have the reasonable potential to cause or contribute to excursions above water quality standards.

WQM 7.0 ver. 1.1b is a water quality model designed to assist DEP in determining appropriate water quality based effluent limits (WQBELs) for carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), ammonia (NH<sub>3</sub>-N) and dissolved oxygen (D.O.). DEP's Technical Guidance No. 391-2000-007 provides the technical methods contained in WQM 7.0 for determining wasteload allocations and for determining recommended NPDES effluent limits for point source discharges. The model was utilized for this permit renewal. The model output indicated a CBOD<sub>5</sub> average monthly limit of 25 mg/l, an NH<sub>3</sub>-N average monthly limit of 13.77 mg/l, and a D.O. minimum limit of 5.0 mg/l were protective of water quality. The flow data used to run the model was acquired from USGS PA StreamStats and is included as an attachment. The CBOD<sub>5</sub> limit is the same as the existing permit limit, which will remain in the permit. The existing NH<sub>3</sub>-N limit of 7.0 mg/l is more stringent and will remain in the permit.

There are no industrial/commercial users contributing industrial wastewater to the system and Conoy Township does not currently have an EPA-approved pretreatment program. Accordingly, evaluating reasonable potential of toxic pollutants is not necessary as effluent levels of toxic pollutants are expected to be insignificant.

### Additional Considerations

#### Chesapeake Bay Total Maximum Daily Load (TMDL)

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the *Pennsylvania Chesapeake Watershed Implementation Plan* (WIP), dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a *Phase 2 Watershed Implementation Plan Wastewater Supplement* (Phase 2 Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. A new update to the WIP was published as the Phase 3 WIP in August 2019. As

part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on December 17, 2019, and is the basis for the development of any Chesapeake Bay related permit parameters. Sewage discharges have been prioritized based on their design flow to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual Cap Loads based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. For Phase 4 and 5 facilities, Cap Loads are not currently being implemented for renewed or amended permits for facilities that do not increase design flow.

This facility is considered a Phase 5 non-significant facility with a design flow less than 0.2 MGD but greater than 0.002 MGD. According to the Phase 3 WIP, TN and TP monitoring is recommended for this facility, which is consistent with the existing permit.

#### Dissolved Oxygen

A minimum D.O. limit of 5.0 mg/L is a D.O. water quality criterion found in 25 Pa. Code § 93.7(a). This limit is included in the existing NPDES permit based BPJ. It is still recommended to include this limit in the draft permit to ensure that the facility continues to achieve compliance with DEP water quality standards.

#### Fecal Coliform

PA Code § 92a.47.(a)(4) requires a monthly average limit of 200/100 mL as a geometric mean and an instantaneous maximum limit not greater than 1,000/100 mL from May through September for fecal coliform. PA Code § 92a.47.(a)(5) requires a monthly average limit of 2,000/100 mL as a geometric mean and an instantaneous maximum limit not greater than 10,000/100 mL from October through April for fecal coliform. Fecal coliform IMAX limits have been added to the permit.

#### E. Coli

PA Code § 92a.61 requires IMAX reporting of E. Coli. Per DEP's SOP No. BCW-PMT-033, sewage dischargers with a design flow of 0.002 – 0.05 mgd will include E. Coli monitoring with a frequency of 1/year. This parameter has been added to the renewal permit.

#### Influent BOD<sub>5</sub> and Total Suspended Solids (TSS) Monitoring

As a result of negotiation with US EPA, influent monitoring of TSS and BOD<sub>5</sub> are required for any publicly owned treatment works (POTWs); therefore, influent sampling of BOD<sub>5</sub> and TSS are included in the permit. An 8-hr composite sample type will be required to be consistent with the sampling frequency for effluent TSS and CBOD<sub>5</sub>.

#### UV Monitoring

DEP's SOP No. BPNPSM-PMT-033 recommends at a minimum, routine monitoring of UV transmittance, dosage, or intensity when the facility is utilizing a UV disinfection system. The monitoring should occur at the same frequency as would be used for TRC. Presumably, this recommendation was implemented as a part of the proper operation and maintenance requirement specified in Part B of the NPDES permit, requesting permittees to demonstrate the effectiveness of UV disinfection system. This is a reasonable approach and has been assigned to other facilities equipped with similar technology. Accordingly, a parameter for UV Intensity will be included in the permit; the same as the existing permit requirements.

#### Sampling Frequency & Sample Type

The monitoring requirements were established based on BPJ and/or Table 6-3 of DEP's Technical Guidance No. 362-0400-001.

#### Anti-Degradation

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**303(d) Listed Streams**

The discharge is located on a stream segment that is listed as attaining uses.

**Class A Wild Trout Fisheries**

No Class A Wild Trout Fisheries are impacted by this discharge.

**Anti-Backsliding**

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit unless any exceptions are addressed by DEP in this fact sheet.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	5.2	8.3	XXX	25	40	50	2/month	8-Hr Composite
BOD5		Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Raw Sewage Influent	Report	6.3	9.4	XXX	30	45	2/month	8-Hr Composite
TSS			XXX					
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Nitrate-Nitrite	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	4.3	XXX	XXX	21.0	XXX	42	2/month	8-Hr Composite


Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia May 1 - Oct 31	1.4	XXX	XXX	7.0	XXX	21	2/month	8-Hr Composite
TKN	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: None

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]




Conoy Township Falmouth WWTP PA0085022 Outfall 001 RMI = 0.1

Region ID: PA

Workspace ID: PA20240612155004976000

Clicked Point (Latitude, Longitude): 40.12081, -76.71101

Time: 2024-06-12 11:50:25 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	4.0524	degrees
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	1.57	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.36	miles per square mile
URBAN	Percentage of basin with urban development	0.1228	percent

► Low-Flow Statistics

Low-Flow Statistics Parameters [99.0 Percent (1.55 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.57	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	4.0524	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4	feet	4.13	5.21
URBAN	Percent Urban	0.1228	percent	0	89

Low-Flow Statistics Parameters [1.0 Percent (0.0194 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.57	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
STRDEN	Stream Density	2.36	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [99.0 Percent (1.55 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [99.0 Percent (1.55 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.124	ft^3/s
30 Day 2 Year Low Flow	0.186	ft^3/s
7 Day 10 Year Low Flow	0.0428	ft^3/s
30 Day 10 Year Low Flow	0.0688	ft^3/s
90 Day 10 Year Low Flow	0.133	ft^3/s

Low-Flow Statistics Disclaimers [1.0 Percent (0.0194 square miles) Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [1.0 Percent (0.0194 square miles) Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0681	ft^3/s
30 Day 2 Year Low Flow	0.104	ft^3/s
7 Day 10 Year Low Flow	0.0232	ft^3/s
30 Day 10 Year Low Flow	0.036	ft^3/s
90 Day 10 Year Low Flow	0.0682	ft^3/s

Low-Flow Statistics Flow Report [Area-Averaged]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.123	ft^3/s
30 Day 2 Year Low Flow	0.185	ft^3/s
7 Day 10 Year Low Flow	0.0426	ft^3/s
30 Day 10 Year Low Flow	0.0685	ft^3/s
90 Day 10 Year Low Flow	0.132	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.20.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


Conoy Township Falmouth WWTP RMI = 0.0

Region ID: PA

Workspace ID: PA20240612155543343000

Clicked Point (Latitude, Longitude): 40.11835, -76.71184

Time: 2024-06-12 11:56:04 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	4.0649	degrees
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	1.6	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.2	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.44	miles per square mile
URBAN	Percentage of basin with urban development	0.369	percent

► Low-Flow Statistics

Low-Flow Statistics Parameters [99.0 Percent (1.58 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.6	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	4.0649	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.2	feet	4.13	5.21
URBAN	Percent Urban	0.369	percent	0	89

Low-Flow Statistics Parameters [1.0 Percent (0.0194 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.6	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
STRDEN	Stream Density	2.44	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.2	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [99.0 Percent (1.58 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [99.0 Percent (1.58 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.157	ft^3/s
30 Day 2 Year Low Flow	0.228	ft^3/s
7 Day 10 Year Low Flow	0.0569	ft^3/s
30 Day 10 Year Low Flow	0.0882	ft^3/s
90 Day 10 Year Low Flow	0.165	ft^3/s

Low-Flow Statistics Disclaimers [1.0 Percent (0.0194 square miles) Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [1.0 Percent (0.0194 square miles) Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0738	ft^3/s
30 Day 2 Year Low Flow	0.11	ft^3/s
7 Day 10 Year Low Flow	0.0267	ft^3/s
30 Day 10 Year Low Flow	0.0402	ft^3/s
90 Day 10 Year Low Flow	0.0736	ft^3/s

Low-Flow Statistics Flow Report [Area-Averaged]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.156	ft^3/s
30 Day 2 Year Low Flow	0.227	ft^3/s
7 Day 10 Year Low Flow	0.0566	ft^3/s
30 Day 10 Year Low Flow	0.0877	ft^3/s
90 Day 10 Year Low Flow	0.164	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.20.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC																																	
07G		9213	Trib 09213 to Susquehanna River		0.100	274.00	1.57	0.00000	0.00	<input checked="" type="checkbox"/>																																	
<b>Stream Data</b>																																											
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)																																	
<table> <tr> <td><b>Q7-10</b></td><td>0.100</td><td>0.00</td><td>0.19</td><td>0.000</td><td>0.000</td><td>0.0</td><td>0.00</td><td>0.00</td><td>20.00</td><td>7.00</td></tr> <tr> <td><b>Q1-10</b></td><td></td><td>0.00</td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td><b>Q30-10</b></td><td></td><td>0.00</td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td></td><td></td></tr> </table>											<b>Q7-10</b>	0.100	0.00	0.19	0.000	0.000	0.0	0.00	0.00	20.00	7.00	<b>Q1-10</b>		0.00	0.00	0.000	0.000						<b>Q30-10</b>		0.00	0.00	0.000	0.000					
<b>Q7-10</b>	0.100	0.00	0.19	0.000	0.000	0.0	0.00	0.00	20.00	7.00																																	
<b>Q1-10</b>		0.00	0.00	0.000	0.000																																						
<b>Q30-10</b>		0.00	0.00	0.000	0.000																																						
<b>Discharge Data</b>																																											
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH																																		
		Falmouth WWTP	PA0085022	0.0250	0.0250	0.0250	0.000	25.00	7.00																																		
<b>Parameter Data</b>																																											
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)																																				
				CBOD5	25.00	2.00	0.00	1.50																																			
				Dissolved Oxygen	5.00	8.24	0.00	0.00																																			
				NH3-N	25.00	0.00	0.00	0.70																																			

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC																																	
07G		9213	Trib 09213 to Susquehanna River		0.000	259.00	1.60	0.00000	0.00	<input checked="" type="checkbox"/>																																	
<b>Stream Data</b>																																											
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)																																	
<table> <tr> <td><b>Q7-10</b></td><td>0.100</td><td>0.00</td><td>0.19</td><td>0.000</td><td>0.000</td><td>0.0</td><td>0.00</td><td>0.00</td><td>20.00</td><td>7.00</td></tr> <tr> <td><b>Q1-10</b></td><td></td><td>0.00</td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td><b>Q30-10</b></td><td></td><td>0.00</td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td></td><td></td></tr> </table>											<b>Q7-10</b>	0.100	0.00	0.19	0.000	0.000	0.0	0.00	0.00	20.00	7.00	<b>Q1-10</b>		0.00	0.00	0.000	0.000						<b>Q30-10</b>		0.00	0.00	0.000	0.000					
<b>Q7-10</b>	0.100	0.00	0.19	0.000	0.000	0.0	0.00	0.00	20.00	7.00																																	
<b>Q1-10</b>		0.00	0.00	0.000	0.000																																						
<b>Q30-10</b>		0.00	0.00	0.000	0.000																																						
<b>Discharge Data</b>																																											
				Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)																																	
						0.0000	0.0000	0.0000	0.000	25.00																																	
<b>Parameter Data</b>																																											
						Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)																																		
				<table> <tr> <td>CBOD5</td><td>25.00</td><td>2.00</td><td>0.00</td><td>1.50</td></tr> <tr> <td>Dissolved Oxygen</td><td>3.00</td><td>8.24</td><td>0.00</td><td>0.00</td></tr> <tr> <td>NH3-N</td><td>25.00</td><td>0.00</td><td>0.00</td><td>0.70</td></tr> </table>		CBOD5	25.00	2.00	0.00	1.50	Dissolved Oxygen	3.00	8.24	0.00	0.00	NH3-N	25.00	0.00	0.00	0.70																							
CBOD5	25.00	2.00	0.00	1.50																																							
Dissolved Oxygen	3.00	8.24	0.00	0.00																																							
NH3-N	25.00	0.00	0.00	0.70																																							

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>		<u>Stream Name</u>								
07G			9213		Trib 09213 to Susquehanna River								
RMI	Stream Flow	PWS Wth	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
0.100	0.19	0.00	0.19	.0387	0.02841	.408	5.8	14.22	0.10	0.064	20.85	7.00	
<b>Q1-10 Flow</b>													
0.100	0.12	0.00	0.12	.0387	0.02841	NA	NA	NA	0.08	0.078	21.22	7.00	
<b>Q30-10 Flow</b>													
0.100	0.26	0.00	0.26	.0387	0.02841	NA	NA	NA	0.11	0.055	20.66	7.00	

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07G	9213	Trib 09213 to Susquehanna River					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.100	Falmouth WWTP	15.15	50	15.15	50	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.100	Falmouth WWTP	1.81	13.77	1.81	13.77	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
0.10	Falmouth WWTP	25	25	13.77	13.77	5	5
						0	0

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
07G	9213	Trib 09213 to Susquehanna River			
<u>RMI</u>		<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.100		0.025	20.853	7.000	
<u>Reach Width (ft)</u>		<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
5.804		0.408	14.224	0.096	
<u>Reach CBOD5 (mg/L)</u>		<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
5.92		1.065	2.35	0.748	
<u>Reach DO (mg/L)</u>		<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.690		24.137	Owens	5	
<u>Reach Travel Time (days)</u>		<b>Subreach Results</b>			
0.064		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
		0.006	5.88	2.34	7.77
		0.013	5.84	2.33	7.85
		0.019	5.80	2.32	7.91
		0.026	5.76	2.30	7.96
		0.032	5.72	2.29	8.01
		0.038	5.68	2.28	8.05
		0.045	5.64	2.27	8.09
		0.051	5.60	2.26	8.11
		0.057	5.56	2.25	8.11
		0.064	5.52	2.24	8.11

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07G	9213	Trib 09213 to Susquehanna River					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.100	Falmouth WWTP	PA0085022	0.025	CBOD5	25		
				NH3-N	13.77	27.54	
				Dissolved Oxygen			5