

Application Type Renewal
 Facility Type Industrial
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
 INDIVIDUAL INDUSTRIAL WASTE (IW)
 AND IW STORMWATER**

Application No. PA0085120
 APS ID 444
 Authorization ID 1550294

Applicant and Facility Information

Applicant Name	<u>Altoona Water Authority</u>	Facility Name	<u>Altoona Water Authority</u>
Applicant Address	<u>900 Chestnut Avenue</u> <u>Altoona, PA 16601-4617</u>	Facility Address	<u>3070 Old Route 22 West</u> <u>Duncansville, PA 16635</u>
Applicant Contact	<u>Michael Bianconi</u>	Facility Contact	<u>Irina Hott</u>
Applicant Phone	<u>(814) 944-2597</u>	Facility Phone	<u>(814) 944-2597</u>
Client ID	<u>85897</u>	Site ID	<u>238359</u>
SIC Code	<u>4941</u>	Municipality	<u>Juniata Township</u>
SIC Description	<u>Trans. & Utilities - Water Supply</u>	County	<u>Blair</u>
Date Application Received	<u>November 25, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 18, 2025</u>	If No, Reason	<u></u>
Purpose of Application	<u>This is an application request for NPDES renewal.</u>		

Approve	Deny	Signatures	Date
X		Nicholas Hong, P.E. / Environmental Engineer Nick Hong (via electronic signature)	February 25, 2026
x		Daniel W. Martin, P.E. / Environmental Engineer Manager Maria D. Bebenek for	February 25, 2026
x		Maria D. Bebenek, P.E. / Environmental Program Manager Maria D. Bebenek	February 25, 2026

Summary of Review

The application submitted by the applicant requests a NPDES renewal permit for the Altoona Water – Plane 9 located at 3070 Old Route 22 West, Duncansville, PA 16635 in Blair County, municipality of Juniata Township. The existing permit became effective on February 1, 2021 and expired on January 31, 2026. The application for renewal was received by DEP Southcentral Regional Office (SCRO) on November 25, 2025.

The purpose of this Fact Sheet is to present the basis of information used for establishing the proposed NPDES permit effluent limitations. The Fact Sheet includes a description of the facility, a description of the facility's receiving waters, a description of the facility's receiving waters attainment/non-attainment assessment status, and a description of any changes to the proposed monitoring/sampling frequency. Section 6 provides the justification for the proposed NPDES effluent limits derived from technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), total maximum daily loading (TMDL), antidegradation, anti-backsliding, and/or whole effluent toxicity (WET). A brief summary of the outlined descriptions has been included in the Summary of Review section.

The subject facility is a 0.24 MGD hydraulic design flow treatment facility. The applicant anticipates proposed upgrades to the treatment facility. A membrane filtration pilot study was performed and approved in 2023 with the intentions of replacing the existing traveling bridge dual media filters with a membrane filtration system. The construction project is expected to begin within the next five (5) years. The NPDES application has been processed as an Industrial Wastewater due to the type of wastewater and the design flow rate for the facility. The applicant disclosed the Act 14 requirement to Blair County Commissioners and Juniata Township Supervisors and the notice was received by the parties on September 19, 2025.

Utilizing the DEP's web-based Emap-PA information system, the receiving waters has been determined to be Blair Gap Run. The sequence of receiving streams that the Blair Gap Run discharges into are Beaverdam Branch, Frankstown Branch Juniata River, the Juniata River and the Susquehanna River which eventually drains into the Chesapeake Bay. The subject site is subject to the Chesapeake Bay implementation requirements. The receiving water has protected water usage for trout stocking fishes (TSF) and migratory fishes (MF). No Class A Wild Trout fisheries are impacted by this discharge. The absence of high quality and/or exceptional value surface waters removes the need for an additional evaluation of anti-degradation requirements.

The Blair Gap Run is a Category 2 stream listed in the 2024 Integrated List of All Waters (formerly 303d Listed Streams). This stream is an attaining stream that supports aquatic life. The receiving waters is subject to the Beaverdam Branch total maximum daily load (TMDL) plan to improve water quality in the subject facility's watershed.

The existing permit and proposed permit differ as follows:

- **Monitoring frequency for copper have increased**
- **Monitoring frequency for aluminum, iron, and manganese reduced to 2x/month**

Sludge use and disposal description and location(s):

- The facility did not report any biosolids disposal in 2025.

The proposed permit will expire five (5) years from the effective date.

Based on the review in this report, it is recommended that the permit be drafted. DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Any additional information or public review of documents associated with the discharge or facility may be available at PA DEP Southcentral Regional Office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file review, contact the SCRO File Review Coordinator at 717.705.4700.

1.0 Applicant

1.1 General Information

This fact sheet summarizes PA Department of Environmental Protection's review for the NPDES renewal for the following subject facility.

Facility Name: Altoona Water – Plane 9

NPDES Permit # PA0085120

Physical Address: 3070 Old Route 22 West
Duncansville, PA 16635

Mailing Address: 900 Chestnut Street
Altoona, PA 16601

Contact: Mark Perry
Manager
(814) 949-2222
mperry@altoonawater.gov

Irina Holt
Water Treatment Supervisor
(814) 944-2597
ihott@altoonawater.gov

Consultant: Maggie Weitzel
Sr. Environmental Scientist
Gwin, Dobson, and Foreman
(814) 943-5214
mweitzel@gdfengineers.com

1.2 Permit History

Permit submittal included the following information.

- NPDES Application
- Flow Diagrams
- Influent Sample Data
- Effluent Sample Data

2.0 Treatment Facility Summary

2.1.1 Site location

The physical address for the facility is 3070 Old Route 22 West, Duncansville, PA 16635. A topographical and an aerial photograph of the facility are depicted as Figure 1 and Figure 2.

Figure 1: Topographical map of the subject facility





Figure 2: Aerial Photograph of the subject facility



2.2 Description of Wastewater Treatment Process

The subject facility is a 0.24 MGD design flow facility.


The facility began treatment of the surface water sources in the early 1990s. The facility is comprised of ozone, rapid mixing, flocculation and traveling bridge dual media filters.

Chemical treatment consists of coagulation with alum, post chlorine disinfection and corrosion control. A waste washwater holding basin collects the filter backwash water where waste sludge pumps convey the tank solids to sand drying beds. The treatment facility currently produces an average of 0.0556 MGD, while operating the plant for 24-hours to 36-hour period until the Plane 9 and Duncansville water storage tanks are full.

Wastewater originates from (a) non-chlorinated filtered potable water (Outfall 001) and (b) wash water tank decant (MP101).

The facility is being evaluated for flow, pH, TSS, aluminum, copper, iron, manganese, phosphorus, and nitrogen. The existing permits limits for the facility is summarized in Section 2.4.

A schematic of the treatment process is depicted.



- LEGEND**
- CHEMICAL ADDITION POINTS**
- A = ALUM AND/OR POLYMER
 - B = OZONE
 - C = CHLORINE, CAUSTIC SODA, CORROSION INHIBITOR,
 - D = CHLORINE
- WATER QUALITY/OPERATIONS MONITORING**
- F = FLOW
 - pH = HYDROGEN ION CONCENTRATION
 - Tu = TURBIDITY
 - SC = STREAMING CURRENT
 - HL = HEADLOSS
 - L = LEVEL
 - Cl = CHLORINE RESIDUAL
 - PA = PARTICLE ANALYZER
 - T = TEMPERATURE

8-31-84		AS-BUILT	DESCRIPTION
NO.	DATE		
REVISIONS			
PROCESS FLOW DIAGRAM			<p>GD&F JOHN DORSON & FOREMAN INC. Consulting Engineers 2001 Anthony Drive P.O. Box 1110 Altoona, PA 16802</p>
ALTOONA CITY AUTHORITY CONTRACT DRAWINGS FOR PLANE NINE WATER TREATMENT FACILITY			
JUNIATA TOWNSHIP, BLAIR COUNTY, PENNSYLVANIA			
APPROVED:	DATE: 8-15-82	DRAWN BY: JRM	CHECKED BY: JRM
FAC. #101701		SECON. #1017	DESIGNED BY: JRM
			SHEET NO. C-1

2.3 Facility Outfall Information

The facility has the following outfall information for wastewater.

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.24</u>
Latitude	<u>40° 25' 47.00"</u>	Longitude	<u>-78° 30' 5.00"</u>
Wastewater Description: <u>Water Treatment Effluent</u>			

Outfall No.	<u>101</u>	Design Flow (MGD)	<u></u>
Latitude	<u>40° 25' 47.00"</u>	Longitude	<u>-78° 30' 5.00"</u>
Wastewater Description: <u></u>			

2.3.1 Operational Considerations- Chemical Additives

Chemical additives are chemical products introduced into a waste stream that is used for cleaning, disinfecting, or maintenance and which may be detected in effluent discharged to waters of the Commonwealth. Chemicals excluded are those used for neutralization of waste streams, the production of goods, and treatment of wastewater.

The subject facility utilizes the following chemicals as part of their treatment process.

- Chlorine for disinfection
- Caustic soda (effluent) for pH adjustment
- Aluminum sulfate for coagulant
- Orthophosphate for corrosion inhibitor

2.4 Existing NPDES Permits Limits

The existing NPDES permit limits are summarized in the table.

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. A. For Outfall 001, Latitude 40° 25' 47.00", Longitude 78° 30' 5.00", River Mile Index 5.51, Stream Code 16335

Receiving Waters: Blair Gap Run (TSF)

Type of Effluent: Water Treatment Effluent

1. The permittee is authorized to discharge during the period from **February 1, 2021** through **January 31, 2026**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. B. For Outfall 101, Latitude 40° 25' 47.00", Longitude 78° 30' 5.00", River Mile Index 5.51, Stream Code 16335

Receiving Waters: Blair Gap Run (TSF)

Type of Effluent: Internal Monitoring Point- Water Treatment Effluent

1. The permittee is authorized to discharge during the period from **February 1, 2021** through **January 31, 2026**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Total Suspended Solids	Report	Report	XXX	30	60	75	1/week	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Calculation
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Aluminum, Total	0.6	1.2	XXX	1.2	2.4	3	1/week	8-Hr Composite
Copper, Total	Report Avg Qrtly	Report	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Iron, Total	1.0	2.0	XXX	2.0	4.0	5	1/week	8-Hr Composite
Manganese, Total	Report	Report	XXX	1.0	2.0	2.5	1/week	8-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s): At Outfall 101

3.0 Facility NPDES Compliance History

3.1 Summary of Inspections

A summary of the most recent inspections during the existing permit review cycle is as follows.

The DEP inspector noted the following during the inspection.

03/17/2022:

- The facility is permitted for two outfalls. Outfall 101 is for the discharge of treated filter backwash water and outfall 001 is the discharge of “diversion flow”, which is treated (non-chlorinated) drinking water from the filter tank that cannot be used. Diversion flows occur at plant start-up and when water conditions are not suitable.
- An in-pipe magmeter is used to measure the flow of the treated backwash discharge and the diversion flow is measured with a pressure differential meter. Both meters are calibrated in-house by the Authority’s instrument technician on a yearly basis.
- Backwash treatment consists of a single large metal tank used for settling out solids. When the tank is full, an automatic valve will release the supernatant. When the tank discharges, the SCADA system activates a solenoid, which sends water samples to a collection bottle about every 15 minutes.
- The pH of the diversion flow is tested by a plant operator if they are on-site during the discharge. Otherwise, the pH is checked by an analyzer located before the filter unit.
- Doug stated that the Authority has plans to install a pH analyzer after the filter, as required by the NPDES permit. The new analyzer will be installed within the next three months.
- Sludge from the settling tank is sent to outdoor drying beds. Drain water from beds is mixed with the plant’s raw water intake. The Authority has plans to clean the sand drying beds and replace the sand this year.
- The effluent supplemental report needs to be updated to include a column for the Copper result

04/04/2023:

- The facility has two permitted outfalls. Outfall 101 is for the discharge of treated filter backwash water and outfall 001 is the discharge of “diversion flow”, which is treated (non-chlorinated) drinking water from the filter tank that cannot be used. Diversion flows occur at plant start-up and when water conditions are not suitable.
- The NPDES permit for the facility requires the diversion flow to be tested for pH any day there is a discharge.
- An in-pipe magmeter is used to measure the flow of the treated backwash discharge and the diversion flow is measured with a pressure differential meter. Both meters are calibrated in-house by the Authority’s instrument technician on a yearly basis.
- Backwash treatment consists of a single large metal tank used for settling out solids. When the tank is full, an automatic valve will release the supernatant. When the tank discharges, the SCADA system activates a solenoid, which sends water samples to a collection bottle about every 15 minutes.
- The pH is checked with the new pH analyzer. The pH of the diversion flow is tested by a plant operator if they are on-site during the discharge. Otherwise, the pH is checked by a newly installed pH analyzer located after the filter unit.

- Sludge from the settling tank is sent to outdoor drying beds. Drain water from the beds is mixed with the plant's raw water intake.
- Sludge was removed from the sand drying beds last year.

3.2 Summary of DMR Data

A review of approximately 1-year of DMR data shows that the monthly average flow data for the facility below the design capacity of the treatment system. The maximum average flow data for the DMR reviewed was 0.0708 MGD in May 2025. The design capacity of the treatment system is 0.24 MGD.

The off-site laboratory used for the analysis of the parameters was Pace Analytical located at 1803 Philadelphia Street, Indiana, PA 15701

DMR Data for Outfall 001 (from November 1, 2024 to October 31, 2025)

Parameter	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24
Flow (MGD) Average Monthly	0.04018 2	0.0452 2	0.02936 2	0.083 2	0.02312 4	0.08735 8	0.04730 8	0.7347	0.0387	0.0354	0.0488	0.0426
Flow (MGD) Daily Maximum	0.11273 5	0.066 5	0.0739 5	0.4083 5	0.05762 5	0.36644 7	0.21753 7	0.4649	0.0847	0.096	0.0783	0.0775
pH (S.U.) Instantaneous Minimum	6.59	6.46	6.34	6.22	6.41	6.18	6.48	6.43	6.67	6.61	6.48	6.64
pH (S.U.) Instantaneous Maximum	6.78	6.8	6.70	6.44	6.81	6.69	6.80	6.69	6.84	6.79	6.80	6.83

DMR Data for Outfall 101 (from November 1, 2024 to October 31, 2025)

Parameter	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24
Flow (MGD) Average Monthly	0.06052 6	0.06169 5	0.06197 3	0.06926 6	0.06790 6	0.07078 9	0.05624 7	0.0587	0.0593	0.058	0.0655	0.0556
Flow (MGD) Daily Maximum	0.09501 8	0.10252 9	0.09629 8	0.134 4	0.10193 4	0.1 0.1	0.10077 2	0.1016	0.1019	0.0967	0.0974	0.0954
pH (S.U.) Instantaneous Minimum	6.88	6.6	6.65	6.59	6.55	6.39	6.37	6.3	6.60	6.50	6.38	6.46
pH (S.U.) Instantaneous Maximum	7.13	7.19	7.08	6.89	7.04	6.85	6.83	6.85	6.96	6.94	6.92	7.12
TSS (lbs/day) Average Monthly	< 3	< 4	< 4	< 5	4	5	2.814	4	3	3	2.87	2.32
TSS (lbs/day) Daily Maximum	4	< 4	< 4	8	6	8	6.387	7	6	5	4.87	4.0
TSS (mg/L) Average Monthly	< 5	< 5	< 5	< 6	8	8	6	7	5	6	5.25	< 5
TSS (mg/L) Daily Maximum	6	< 5	5	10	9	14.8	7.6	10	7	7	6	< 5
Total Nitrogen (mg/L) Annual Average											< 0.729	

**NPDES Permit Fact Sheet
Altoona Water Authority**

NPDES Permit No. PA0085120

Total Phosphorus (mg/L) Annual Average											< 0.10	
Total Aluminum (lbs/day) Average Monthly	0.1	0.2	0.3	0.5	0.5	0.6	0.375	0.5	0.6	0.5	0.38	0.14
Total Aluminum (lbs/day) Daily Maximum	0.3	0.3	0.3	1.0	0.7	0.8	0.785	0.8	0.8	0.8	0.84	0.283
Total Aluminum (mg/L) Average Monthly	0.2	0.3	0.4	0.6	0.9	1.1	0.8	1.1	0.9	0.8	0.69	0.30
Total Aluminum (mg/L) Daily Maximum	0.556	0.392	0.443	0.999	0.934	1.36	0.935	1.14	0.982	0.956	1.04	0.356
Total Copper (lbs/day) Average Quarterly		0.00751 38			0.02169 157			0.009			1.09	
Total Copper (lbs/day) Daily Maximum		0.01565 598			0.03402 722			0.009			0.07	
Total Copper (mg/L) Average Quarterly		0.014			0.040			0.026			0.084	
Total Iron (lbs/day) Average Monthly	< 0.09	0.2	0.3	0.1	0.05	< 0.1	0.0938	< 0.1	< 0.1	0.06	0.0377	0.037
Total Iron (lbs/day) Daily Maximum	0.2	0.2	0.3	0.2	0.06	< 0.1	0.1680	< 0.1	< 0.2	0.09	0.073	0.074
Total Iron (mg/L) Average Monthly	< 0.1	0.2	0.4	0.2	0.1	< 0.2	< 0.2	< 0.2	< 0.2	0.1	0.069	0.08
Total Iron (mg/L) Daily Maximum	0.401	0.313	0.46	0.29	0.104	< 0.2	< 0.2	< 0.2	< 0.2	0.148	0.0899	0.0931
Total Manganese (lbs/day) Average Monthly	0.1	0.1	0.1	0.1	0.03	0.03	0.0187	0.02	0.02	0.02	0.017	0.019
Total Manganese (lbs/day) Daily Maximum	0.2	0.1	0.1	0.1	0.04	0.04	0.0518	0.04	0.04	0.03	0.03	0.034
Total Manganese (mg/L) Average Monthly	0.2	0.2	0.2	0.1	0.1	0.1	0.04	0.04	0.03	0.03	0.031	0.041
Total Manganese (mg/L) Daily Maximum	0.306	0.201	0.174	0.231	0.069	0.0675	0.0617	0.0577	0.044	0.074	0.0371	0.043

3.3 Non-Compliance

3.3.1 Non-Compliance- NPDES Effluent

A summary of the non-compliance to the permit limits for the existing permit cycle is as follows.

From the DMR data beginning in February 1, 2021 to January 20, 2026, the following were observed effluent non-compliances.

Summary of Non-Compliance with NPDES Effluent Limits									
Beginning February 1, 2021 and Ending January 20, 2026									
NON_COMPLIANCE_DATE	NON_COMPL_TYPE_DESC	NON_COMPL_CATEGORY_DESC	PARAMETER	SAMPLE_VALUE	VIOLATION_CONDITION	PERMIT_VALUE	UNIT_OF_MEASURE	STAT_BASE_CODE	FACILITY_COMMENTS
4/28/2021	Violation of permit condition	Effluent	Aluminum, Total	0.7	>	.6	lbs/day	Average Monthly	Continue to decrease Alum.
6/30/2024	Late DMR Submission	Other Violations							

3.3.2 Non-Compliance- Enforcement Actions

A summary of the non-compliance enforcement actions for the current permit cycle is as follows:

Beginning in February 1, 2021 and ending January 20, 2026, the following were observed enforcement actions.

Summary of Enforcement Actions
Beginning February 1, 2021 and ending January 20, 2026

ENF ID	ENF TYPE	EXECUTED DATE	VIOL CODE ID	PROGRAM NAME	VIOLATIONS	ENF FINALSTATUS	DATE
394768	NOV	05/28/2021	17291	WPCNP	92A.44	Comply/Closed	05/28/2021

3.4 Summary of Biosolids Disposal

A summary of the biosolids disposed of from the facility is as follows.

The facility did not report any biosolids disposal in 2025.

3.5 Open Violations

As of January 2026, the following open violations existed with the client. The final executed NPDES permit may be withheld pending remediation of the violation.

Summary of Open Violations

FACILITY	PF STATUS	INSP PROGRAM	PROGRAM SPECIFIC ID	INSP ID	VIOLATION ID	INSPECTION CATEGORY	VIOLATION DATE	VIOLATION CODE	VIOLATION
ALTOONA WATER AUTHWESTERLY	Active	Air Quality	23-6268625-1	3657892	8167952	PF	11/14/2023	127.444	Construction, Modification, Reactivation and Operation of Sources, Operating Permit Requirements, Compliance requirements.

4.0 Receiving Waters and Water Supply Information Detail Summary

4.1 Receiving Waters

The receiving waters has been determined to be Blair Gap Run. The sequence of receiving streams that the Blair Gap Run discharges into are Beaverdam Branch, Frankstown Branch Juniata River, the Juniata River and the Susquehanna River which eventually drains into the Chesapeake Bay.

4.2 Public Water Supply (PWS) Intake

The closest PWS to the subject facility is Mifflintown Municipal Authority (PWS ID # 4340008) located approximately 109 miles downstream of the subject facility on the Juniata River. Based upon the distance and the flow rate of the facility, the PWS should not be impacted.

4.3 Class A Wild Trout Streams

Class A Wild Trout Streams are waters that support a population of naturally produced trout of sufficient size and abundance to support long-term and rewarding sport fishery. DEP classifies these waters as high-quality coldwater fisheries.

The information obtained from EMAP suggests that no Class A Wild Trout Fishery will be impacted by this discharge.

4.4 2024 Integrated List of All Waters (303d Listed Streams)

Section 303(d) of the Clean Water Act requires States to list all impaired surface waters not supporting uses even after appropriate and required water pollution control technologies have been applied. The 303(d) list includes the reason for impairment which may be one or more point sources (i.e. industrial or sewage discharges) or non-point sources (i.e. abandoned mine lands or agricultural runoff and the pollutant causing the impairment such as metals, pH, mercury or siltation).

States or the U.S. Environmental Protection Agency (EPA) must determine the conditions that would return the water to a condition that meets water quality standards. As a follow-up to listing, the state or EPA must develop a Total Maximum Daily Load (TMDL) for each waterbody on the list. A TMDL identifies allowable pollutant loads to a waterbody from both point and non-point sources that will prevent a violation of water quality standards. A TMDL also includes a margin of safety to ensure protection of the water.

The water quality status of Pennsylvania's waters uses a five-part categorization (lists) of waters per their attainment use status. The categories represent varying levels of attainment, ranging from Category 1, where all designated water uses are met to Category 5 where impairment by pollutants requires a TMDL for water quality protection.

The receiving waters is listed in the 2024 Pennsylvania Integrated Water Quality Monitoring and Assessment Report as a Category 2 waterbody. The surface waters is an attaining stream that supports aquatic life. The designated use has been classified as protected waters for trout stocking fishes (TSF) and migratory fishes (MF).

4.5 Low Flow Stream Conditions

Water quality modeling estimates are based upon conservative data inputs. The data are typically estimated using either a stream gauge or through USGS web based StreamStats program. The NPDES effluent limits are based upon the combined flows from both the stream and the facility discharge.

A conservative approach to estimate the impact of the facility discharge using values which minimize the total combined volume of the stream and the facility discharge. The volumetric flow rate for the stream is based upon the seven-day, 10-year low flow (Q710) which is the lowest estimated flow rate of the stream during a 7 consecutive day period that occurs once in 10 -year time period. The facility discharge is based upon a known design capacity of the subject facility.

The closest WQN station to the subject facility is the Beaverdam Branch Juniata River station (WQN252). This WQN station is located approximately 9 miles downstream of the subject facility.

The closest gauge station to the subject facility is the Frankstown Br Juniata River at Williamsburg, PA (USGS station number 1556000). This gauge station is located approximately 23 miles downstream of the subject facility.

For WQM modeling, pH and stream water temperature data from the water quality network station was used. pH was estimated to be 7.3 and the stream water temperature was estimated to be 19.5 C.

The hardness of the stream was estimated by collecting a sample upstream of the facility. The sampling result was 17 mg/l CaCO₃.

The low flow yield and the Q710 for the subject facility was estimated using StreamStats.

The low flow yield is 0.0967 ft³/s/mi² and the Q710 is 1.18 ft³/s

4.6 Summary of Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.24</u>
Latitude	<u>40° 25' 42.91"</u>	Longitude	<u>-78° 30' 11.51"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Water Treatment Effluent</u>			

Receiving Waters	<u>Blair Gap Run (CWF)</u>	Stream Code	<u>16403</u>
NHD Com ID	<u>65609170</u>	RMI	<u>5.62</u>
Drainage Area	<u>12.2</u>	Yield (cfs/mi ²)	<u>0.0967</u>
Q ₇₋₁₀ Flow (cfs)	<u>1.18</u>	Q ₇₋₁₀ Basis	<u>StreamStata/streamgauge</u>
Elevation (ft)	<u>1360</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>11-A</u>	Chapter 93 Class.	<u>CWF, MF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>

Assessment Status	<u>Attaining Use(s) supports aquatic life</u>		
Cause(s) of Impairment	<u>Not applicable</u>		
Source(s) of Impairment	<u>Not applicable</u>		
TMDL Status	<u>Final</u>	Name	<u>Beaverdam Branch Watershed</u>

Background/Ambient Data		Data Source	
pH (SU)	<u>7.3</u>	WQN252; median July to Sept	<u></u>
Temperature (°C)	<u>19.5</u>	WQN252; median July to Sept	<u></u>
Hardness (mg/L)	<u>17</u>	NPDES renewal application dated 11/19/2025	<u></u>
Other:	<u></u>		<u></u>

Nearest Downstream Public Water Supply Intake	<u>Mifflintown MA</u>		
PWS Waters	<u>Juniata River</u>	Flow at Intake (cfs)	<u>1,000,000</u>
PWS RMI	<u>37</u>	Distance from Outfall (mi)	<u>109</u>

5.0: Overview of Presiding Water Quality Standards

5.1 General

There are at least six (6) different policies which determines the effluent performance limits for the NPDES permit. The policies are technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), antidegradation, total maximum daily loading (TMDL), anti-backsliding, and whole effluent toxicity (WET) The effluent performance limitations enforced are the selected permit limits that is most protective to the designated use of the receiving waters. An overview of each of the policies that are applicable to the subject facility has been presented in Section 6.

5.2.1 Technology-Based Limitations

TBEL treatment requirements under section 301(b) of the Act represent the minimum level of control that must be imposed in a permit issued under section 402 of the Act (40 CFR 125.3). Available TBEL requirements for the state of Pennsylvania are itemized in PA Code 25, Chapter 92a.47.

Permit limits for water treatment plant wastes are subject to handling and disposal of water treatment plant (WTP) using Best Practicable Control Technology (BPCT) currently available. Waste water from treatment of WTP sludges and filter backwash shall have the following permit limits.

Parameter	Monthly Average	Daily Max
	mg/l	mg/l
Suspended Solids	30	60
Iron (total)	2	4
Aluminum (total)	4	8
Manganese (total)	1	2
pH	6 - 9	-----
TRC	0.5	1

Notes:

Source: TECHNOLOGY-BASED CONTROL
 REQUIREMENTS FOR WATER TREATMENT PLANT
 WASTES

5.2.2 Mass Based Limits

For publicly owned treatment works (POTW), mass loadings are calculated based upon design flow rate of the facility and the permit limit concentration. The generalized calculation for mass loadings is shown below:

$$Quantity \left(\frac{lb}{day} \right) = (MGD)(Concentration)(8.34)$$

5.3 Water Quality-Based Limitations

WQBEL are based on the need to attain or maintain the water quality criteria and to assure protection of designated and existing uses (PA Code 25, Chapter 92a.2). The subject facility that is typically enforced is the more stringent limit of either the TBEL or the WQBEL.

Determination of WQBEL is calculated by spreadsheet analysis or by a computer modeling program developed by DEP. DEP permit engineers utilize the following computing programs for WQBEL permit limitations: (1) MS Excel worksheet for Total Residual Chlorine (TRC); (2) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and

Ammonia Nitrogen Version 1.1 (WQM Model) and (3) Toxics using DEP Toxics Management Spreadsheet for Toxics pollutants.

The modeling point nodes utilized for this facility are summarized below.

General Data 1	(Modeling Point #1)	(Modeling Point #2)	Units
Stream Code	16335	16335	
River Mile Index	5.62	4.33	miles
Elevation	1360	1230	feet
Latitude	40.429107	40.421184	
Longitude	-78.50162	-78.480592	
Drainage Area	12.2	13.3	sq miles
Low Flow Yield	0.0967	0.0887	cfs/sq mile

5.3.1 Water Quality Modeling 7.0

5.3.2 Toxics Modeling

The Toxics Management Spreadsheet model is a computer model that is used to determine effluent limitations for toxics (and other substances) for single discharge wasteload allocations. This computer model uses a mass-balance water quality analysis that includes consideration for mixing, first-order decay, and other factors used to determine recommended water quality-based effluent limits. Toxics Management Spreadsheet does not assume that all discharges completely mix with the stream. The point of compliance with water quality criteria are established using criteria compliance times (CCTs). The available CCTs are either acute fish criterion (AFC), chronic fish criterion (CFC), or human health criteria (THH & CRL).

Acute Fish Criterion (AFC) measures the criteria compliance time as either the maximum criteria compliance time (i.e.15 minutes travel time downstream of the current discharge) or the complete mix time whichever comes first. AFC is evaluated at Q710 conditions.

Chronic Fish Criterion (CFC) measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the complete mix time whichever comes first. CFC is evaluated at Q710 conditions.

Threshold Human Health (THH) measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the estimated travel time downstream to the nearest potable water supply intake whichever comes first. THH is evaluated at Q710 conditions.

Cancer Risk Level (CRL) measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the complete mix time whichever comes first. CRL is evaluated at Qh (harmonic mean or normal flow) conditions.

The Toxics Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

5.3.2.1 Determining if NPDES Permit Will Require Monitoring/Limits in the Proposed Permit for Toxic Pollutants

To determine if Toxics modeling is necessary, DEP has developed a Toxics Management Spreadsheet to identify toxics of concern. Toxic pollutants whose maximum concentrations as reported in the permit application or on DMRs are greater than the most stringent applicable water quality criterion are pollutants of concern. A Reasonable Potential Analysis was utilized to determine (a) if the toxic parameters modeled would require monitoring or (b) if permit limitations would be required for the parameters. The toxics reviewed for reasonable potential were the pollutants in Groups 1 and 2

The NPDES application collected three samples.

Based upon the SOP- Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants (Revised January 10, 2019), monitoring and/or limits will be established as follows.

- (a) When reasonable potential is demonstrated, establish limits where the maximum reported concentration equals or exceeds 50% of the WQBEL.
- (b) For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- (c) For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10% - 50% of the WQBEL.

Applicable monitoring or permit limits for toxics are summarized in Section 6.

The Toxics Management Spreadsheet output has been included in Attachment B.

5.3.3 Whole Effluent Toxicity (WET)

The facility is not subject to WET.

5.4 Total Maximum Daily Loading (TMDL)

5.4.1 TMDL

The goal of the Clean Water Act (CWA), which governs water pollution, is to ensure that all of the Nation's waters are clean and healthy enough to support aquatic life and recreation. To achieve this goal, the CWA created programs designed to regulate and reduce the amount of pollution entering United States waters. Section 303(d) of the CWA requires states to assess their waterbodies to identify those not meeting water quality standards. If a waterbody is not meeting standards, it is listed as impaired and reported to the U.S. Environmental Protection Agency. The state then develops a plan to clean up the impaired waterbody. This plan includes the development of a Total Maximum Daily Load (TMDL) for the pollutant(s) that were found to be the cause of the water quality violations. A Total Maximum Daily Load (TMDL) calculates the maximum amount of a specific pollutant that a waterbody can receive and still meet water quality standards.

A TMDL for a given pollutant and waterbody is composed of the sum of individual wasteload allocations (WLAs) for point sources and load allocations (LAs) for nonpoint sources and natural background levels. In addition, the TMDL must include an implicit or explicit margin of safety (MOS) to account for the uncertainty in the relationship between pollutant loads and the quality of the receiving waterbody. The TMDL components are illustrated using the following equation:

$$TMDL = \sum WLAs + \sum LAs + MOS$$

Pennsylvania has committed to restoring all impaired waters by developing TMDLs and TMDL alternatives for all impaired waterbodies. The TMDL serves as the starting point or planning tool for restoring water quality.

5.4.1.1 Local TMDL

The subject facility does not discharge directly into a local TMDL. The facility discharges into Blair Gap Run and subsequently the Beaverdam Branch. The Beaverdam Branch waters has a TMDL called the Beaverdam Branch TMDL. The entire length of Beaverdam Branch is listed as impaired, as well as three of its tributaries: Mill Run, Sugar Run, and Burgoon Run.

The Beaverdam Branch Total Maximum Daily Load (TMDL) was developed for a stream segment in the Beaverdam Branch Watershed. This was done to address impairments noted on the 1996, 1998, and 2002 Pennsylvania Section 303(d) lists, and the 2004 and 2006 Integrated Lists required under the Clean Water Act and covers one segment on this list. High levels of metals caused these impairments. The sources of the impairments are listed as urban runoff/storm sewers and combined sewer overflows (CSOs). The TMDL addresses the two primary metals (iron and aluminum) identified as the causes of impairment in the watershed. Beaverdam Branch is listed for abandoned mine drainage; this is addressed in a draft TMDL proposed in 2003 (Beaverdam Branch Watershed TMDL).

Blair Gap Run was not listed as one of Beaverdam tributaries. However, the TMDL includes the facility in the TMDL with effluent limits for iron and aluminum. See Table 6 of the Beaverdam Branch TDML.

5.4.1.2 Chesapeake Bay TMDL Requirement

The Chesapeake Bay Watershed is a large ecosystem that encompasses approximately 64,000 square miles in Maryland, Delaware, Virginia, West Virginia, Pennsylvania, New York and the District of Columbia. An ecosystem is composed of interrelated parts that interact with each other to form a whole. All of the plants and animals in an ecosystem depend on each other in some way. Every living thing needs a healthy ecosystem to survive. Human activities affect the Chesapeake Bay ecosystem by adding pollution, using resources and changing the character of the land.

Most of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the federal Water Pollution Control Act ("Clean Water Act"), 33 U.S.C. § 1313(d). While the Chesapeake Bay is outside the boundaries of Pennsylvania, more than half of the State lies within the watershed. Two major rivers in Pennsylvania are part of the Chesapeake Bay Watershed. They are (a) the Susquehanna River and (b) the Potomac River. These two rivers total 40 percent of the entire Chesapeake Bay watershed.

The overall management approach needed for reducing nitrogen, phosphorus and sediment are provided in the Bay TMDL document and the Phase I, II, and III WIPs which is described in the Bay TMDL document and Executive Order 13508.

The Bay TMDL is a comprehensive pollution reduction effort in the Chesapeake Bay watershed identifying the necessary pollution reductions of nitrogen, phosphorus and sediment across the seven Bay watershed jurisdictions of Delaware, Maryland, New York, Pennsylvania, Virginia, West Virginia and the District of Columbia to meet applicable water quality standards in the Bay and its tidal waters.

The Watershed Implementation Plans (WIPs) provides objectives for how the jurisdictions in partnership with federal and local governments will achieve the Bay TMDL's nutrient and sediment allocations.

Phase 3 WIP provides an update on Chesapeake Bay TMDL implementation activities for point sources and DEP's current implementation strategy for wastewater. The latest revision of the supplement was September 13, 2021.

The Chesapeake Bay TMDL (Appendix Q) categorizes point sources into four sectors:

- Sector A- significant sewage dischargers;
- Sector B- significant industrial waste (IW) dischargers;
- Sector C- non-significant dischargers (both sewage and IW facilities); and
- Sector D- combined sewer overflows (CSOs).

All sectors contain a listing of individual facilities with NPDES permits that were believed to be discharging at the time the TMDL was published (2010). All sectors with the exception of the non-significant dischargers have individual wasteload allocations (WLAs) for TN and TP assigned to specific facilities. Non-significant dischargers have a bulk or aggregate allocation for TN and TP based on the facilities in that sector that were believed to be discharging at that time and their estimated nutrient loads.

Cap Loads will be established in permits as Net Annual TN and TP loads (lbs/yr) that apply during the period of October 1 – September 30. For facilities that have received Cap Loads in any other form, the Cap Loads will be modified accordingly when the permits are renewed.

Offsets have been incorporated into Cap Loads in several permits issued to date. From this point forward, permits will be issued with the WLAs as Cap Loads and will identify Offsets separately to facilitate nutrient trading activities and compliance with the TMDL.

Based upon the supplement the subject facility has been categorized as a Sector C discharger. The supplement defines Sector C as a non-significant dischargers include sewage facilities (Phase 4 facilities: ≥ 0.2 MGD and < 0.4 MGD and Phase 5 facilities: > 0.002 MGD and < 0.2 MGD), small flow/single residence sewage treatment facilities (≤ 0.002 MGD), and non-significant IW facilities, all of which may be covered by statewide General Permits or may have individual NPDES permits.

For non-significant IW facilities, monitoring and reporting of TN and TP will be required throughout the permit term in renewed or amended permits anytime the facility has the potential to introduce a net TN or TP increase to the load contained within the intake water used in processing. In general, facilities that discharge groundwater and cooling water with no addition of chemicals containing N or P do not require monitoring. Monitoring for facilities with other discharges will generally conform to the following minimum sampling frequencies, with the permit writer having final discretion.

Non-significant IW facilities that propose expansion or production increases and as a result will discharge at least 75 lbs/day TN or 25 lbs/day TP (on an annual average basis), will be classified as Significant IW dischargers and receive Cap Loads in their permits based on existing performance (existing TN/TP concentrations at current average annual flow).

In general, for new non-significant IW discharges (including existing facilities discharging without a permit), DEP will issue permits containing Cap Loads of "0" and these facilities will be expected to purchase credits and/or apply offsets to achieve compliance.

Due to the Chesapeake Bay WIP, this facility is subject to Sector C monitoring requirements. Monitoring shall be at least 1x/yr.

5.5 Anti-Degradation Requirement

Chapter 93.4a of the PA regulations requires that surface water of the Commonwealth of Pennsylvania may not be degraded below levels that protect the existing uses. The regulations specifically state that *Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected*. Antidegradation requirements are implemented through DEP's guidance manual entitled Water Quality Antidegradation Implementation Guidance (Document #391-0300-02).

The policy requires DEP to protect the existing uses of all surface waters and the existing quality of High Quality (HQ) and Exceptional Value (EV) Waters. Existing uses are protected when DEP makes a final decision on any permit or approval for an activity that may affect a protected use. Existing uses are protected based upon DEP's evaluation of the best available information (which satisfies DEP protocols and Quality Assurance/Quality Control (QA/QC) procedures) that indicates the protected use of the waterbody.

For a new, additional, or increased point source discharge to an HQ or EV water, the person proposing the discharge is required to utilize a nondischarge alternative that is cost-effective and environmentally sound when compared with the cost of the proposed discharge. If a nondischarge alternative is not cost-effective and environmentally sound, the person must use the best available combination of treatment, pollution prevention, and wastewater reuse technologies and assure that any discharge is nondegrading. In the case of HQ waters, DEP may find that after satisfaction of intergovernmental coordination and public participation requirements lower water quality is necessary to accommodate important economic or social development in the area in which the waters are located. In addition, DEP will assure that cost-effective and reasonable best management practices for nonpoint source control in HQ and EV waters are achieved.

The subject facility's discharge will be to a non-special protection waters and the permit conditions are imposed to protect existing instream water quality and uses. Neither HQ waters or EV waters is impacted by this discharge.

5.6 Anti-Backsliding

Anti-backsliding is a federal regulation which prohibits a permit from being renewed, reissued, or modified containing effluent limitations which are less stringent than the comparable effluent limitations in the previous permit (40 CFR 122.1.1 and 40 CFR 122.1.2). A review of the existing permit limitations with the proposed permit limitations confirm that the facility is consistent with anti-backsliding requirements. The facility has proposed effluent limitations that are as stringent as the existing permit.

6.0 NPDES Parameter Details

The basis for the proposed sampling and their monitoring frequency that will appear in the permit for each individual parameter are itemized in this Section. The final limits are the more stringent of technology based effluent treatment (TBEL) requirements, water quality based (WQBEL) limits, TMDL, antidegradation, anti-degradation, or WET.

The reader will find in this section:

- a) a justification of recommended permit monitoring requirements and limitations for each parameter in the proposed NPDES permit;
- b) a summary of changes from the existing NPDES permit to the proposed permit; and
- c) a summary of the proposed NPDES effluent limits.

6.1 Recommended Monitoring Requirements and Effluent Limitations

A summary of the recommended monitoring requirements and effluent limitations are itemized in the tables. The tables are categorized by (a) Conventional Pollutants and Disinfection, (b) Nitrogen Species and Phosphorus, (c) Toxics.

6.1.1 Conventional Pollutants- Outfall 101

Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection			
Altoona Water - Plane 9, PA0085120; Outfall 101			
Parameter	Permit Limitation Required by ¹ :	Recommendation	
pH (S.U.)	TBEL	Monitoring:	The monitoring frequency shall be daily as a grab sample (Table 6-4).
		Effluent Limit:	Effluent limits may range from pH = 6.0 to 9.0
		Rationale:	Effluent limits are defined by DEP Guidance Document- Technology-Based Control Requirements for Water Treatment Plant Wastes- Waste Water from Treatment of WTP Sludges and Filter Backwash
TSS	TBEL	Monitoring:	The monitoring frequency shall be 1/week as an 8-hr composite sample (Table 6-4).
		Effluent Limit:	The average monthly limit should not exceed 30 mg/l as an average monthly .
		Rationale:	Effluent limits are defined by DEP Guidance Document- Technology-Based Control Requirements for Water Treatment Plant Wastes- Waste Water from Treatment of WTP Sludges and Filter Backwash
Notes:			
1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other			
2 Monitoring frequency based on flow rate of 0.24 MGD.			
3 Table 6-4 (Self Monitoring Requirements for Industrial Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97			
4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)			
5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021			

6.1.2 Nitrogen Species and Phosphorus- Outfall 101

Summary of Proposed NPDES Parameter Details for Nitrogen Species and Phosphorus			
Altoona Water - Plane 9, PA0085120; Outfall 101			
Parameter	Permit Limitation Required by ¹ :	Recommendation	
Total Nitrogen	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/yr as a calculation
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr.
Total Phosphorus	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/yr as a calculation
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr.
Notes:			
1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other			
2 Monitoring frequency based on flow rate of 0.24 MGD.			
3 Table 6-4 (Self Monitoring Requirements for Industrial Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97			
4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)			
5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021			

6.1.3 Toxics- Outfall 101

Two toxics modeling runs were conducted with Toxics Management Spreadsheet.

Modeling Run #1 utilized the sampling results in the NPDES renewal application.

Modeling Run #2 utilized the maximum data result for aluminum, iron, and manganese from the DMR beginning in February 2021 and ending in November 2025. For copper, the CV and concentration data was used from DEP’s ToxStats worksheet.

Modeling Run #1 recommends monitoring for aluminum and copper

Modeling Run #2 recommends monitoring for aluminum.

Effluent limits for copper were recommended. In lieu of effluent limits, DEP elected to increase monitoring for copper. Pending favorable results, the monitoring may be reduced or eliminated in future renewals. The NPDES permit shall include a permit re-opener to include effluent limits should the monitoring data in the first 24 months appear unfavorable.

Summary of Proposed NPDES Parameter Details for Toxics		
Altoona Water - Plane 9, PA0085120; Outfall 101		
Parameter	Permit Limitation Required by¹:	Recommendation
Aluminum	TMDL	Monitoring: The monitoring frequency shall be 2x/mo as a 24-hr composite sample (Table 6-3).
		Effluent Limit: The effluent limit shall not exceed 0.6 lb/day and 1.2 mg/l as a monthly average.
		Rationale: The Beaverdam Branch TMDL outlines wasteload allocations.
Copper	WQBEL	Monitoring: The monitoring frequency shall be 2x/mo as a 24-hr composite sample (Table 6-3).
		Effluent Limit: No effluent limits
		Rationale: Toxics management spreadsheet recommends effluent limits. . In lieu of effluent limits, DEP elected to increase monitoring for copper. Pending favorable results, the monitoring may be reduced or eliminated in future renewals. The NPDES permit shall include a permit re-opener to include effluent limits should the monitoring data in the first 24 months appears unfavorable.
Iron	TMDL	Monitoring: The monitoring frequency shall be 2x/mo as a 24-hr composite sample (Table 6-3).
		Effluent Limit: The performance effluent limit shall not exceed 1.0 lb.day and 2 mg/l as a monthly average.
		Rationale: The Beaverdam Branch TMDL outlines wasteload allocations.
Manganese	DEP Guidance Document-Water Treatment Plant Wastes	Monitoring: The monitoring frequency shall be 2x/mo as a 24-hr composite sample (Table 6-3).
		Effluent Limit: The performance effluent limit shall not exceed 1 mg/l as a monthly average.
		Rationale: Effluent limits are defined by DEP Guidance Document- Technology-Based Control Requirements for Water Treatment Plant Wastes- Waste Water from Treatment of WTP Sludges and Filter Backwash
Notes:		
1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other		
2 Monitoring frequency based on flow rate of 0.0556 MGD.		
3 Table 6-4 (Self Monitoring Requirements for Industrial Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97		
4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)		
5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021		

6.1.4 Conventional Pollutants and Disinfection- Outfall 001

Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection			
Altoona Water- Plane 9; PA0085120; Outfall 001			
Parameter	Permit Limitation Required by ¹ :	Recommendation	
pH (S.U.)	TBEL	Monitoring:	The monitoring frequency shall be daily as a grab sample (Table 6-4).
		Effluent Limit:	Effluent limits may range from pH = 6.0 to 9.0
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-4 and the effluent limits assigned by Chapter 95.2(1).

6.2 Summary of Changes From Existing Permit to Proposed Permit

A summary of how the proposed NPDES permit differs from the existing NPDES permit is summarized as follows.

- Monitoring frequency for copper have increased
- Monitoring frequency for aluminum, iron, and manganese reduced to 2x/month

6.3.1 Summary of Proposed NPDES Effluent Limits

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

The proposed NPDES effluent limitations are summarized in the table below.

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. A. For Outfall 001, Latitude 40° 25' 47.00", Longitude 78° 30' 5.00", River Mile Index 5.62, Stream Code 16335

Receiving Waters: Blair Gap Run (CWF)

Type of Effluent: Water Treatment Effluent

1. The permittee is authorized to discharge during the period from Permit Effective Date through Permit Expiration Date.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. B. For Outfall 101, Latitude 40° 25' 47.00", Longitude 78° 30' 5.00", River Mile Index 5.62, Stream Code 16335



Receiving Waters: Blair Gap Run (CWF)

Type of Effluent: Internal Monitoring Point – Water Treatment Effluent

1. The permittee is authorized to discharge during the period from **Permit Effective Date** through **Permit Expiration Date**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Total Suspended Solids	Report	Report	XXX	30	60	75	1/week	Composite
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Aluminum, Total	0.6	1.2	XXX	1.2	2.4	3	2/month	8-Hr Composite
Copper, Total	Report	XXX	XXX	Report	Report	XXX	2/month	24-Hr Composite
Iron, Total	1.0	2.0	XXX	2.0	4.0	5	2/month	8-Hr Composite
Manganese, Total	Report	Report	XXX	1.0	2.0	2.5	2/month	8-Hr Composite

6.3.2 Summary of Proposed Permit Part C Conditions

The subject facility has the following Part C conditions.

- Chesapeake Bay Nutrient Definitions
- Solids Management for Non-Lagoon Treatment Systems


Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

Attachment A

Stream Stats/Gauge Data

StreamStats Report

Region ID: PA
 Clicked Point (Latitude, Longitude): 40.42913, -78.50158
 Time: 2026-01-23 07:37:22 -0500



Altoona Water - Plane 9 PA0085120 Modeling Point #1 January 2026

StreamStats Update

Starting with version 4.30.0, the StreamStats application uses services that were redeveloped with open-source software components. Users may observe minor variations in computed results when compared to those from previous versions. These differences are expected and do not reflect errors in the underlying data or analytical methods. Users are advised to consider these potential variations when interpreting or comparing results generated across different versions of StreamStats. Please email streamstats@usgs.gov with any questions or concerns. A full list of changes can be found at <https://www.usgs.gov/streamstats/news/streamstats-data-updates-open-source-code-release>.

Collapse All

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	12.2	square miles
PRECIP	Mean Annual Precipitation	46.3	inches
ROCKDEP	Depth to rock	4.8	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.745	miles per square mile

> Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
CARBON	Percent Carbonate	0	percent	0	99
DRNAREA	Drainage Area	12.2	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	46.3	inches	35	50.4

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
ROCKDEP	Depth to Rock	4.8	feet	3.32	5.65
STRDEN	Stream Density	1.745	miles per square mile	0.51	3.1

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	2.31	ft ³ /s	38	38
30 Day 2 Year Low Flow	2.99	ft ³ /s	33	33
7 Day 10 Year Low Flow	1.18	ft ³ /s	51	51
30 Day 10 Year Low Flow	1.5	ft ³ /s	46	46
90 Day 10 Year Low Flow	2.14	ft ³ /s	36	36

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.


USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.30.0
 SSHydro Services Version: 1.0.0
 SSDelineate Services Version: 1.0.0
 NSS Services Version: 2.2.1
 GageStats Services Version: 1.2.1
 Pourpoint Services Version: 1.2.0
 Batch Processor Version: 1.6.0

StreamStats Report

Region ID: PA
 Clicked Point (Latitude, Longitude): 40.42114, -78.48068
 Time: 2026-01-23 07:39:55 -0500



Altoona Water- Plane 9 PA0085120 Modeling Point #2 January 2026

StreamStats Update

Starting with version 4.30.0, the StreamStats application uses services that were redeveloped with open-source software components. Users may observe minor variations in computed results when compared to those from previous versions. These differences are expected and do not reflect errors in the underlying data or analytical methods. Users are advised to consider these potential variations when interpreting or comparing results generated across different versions of StreamStats. Please email streamstats@usgs.gov with any questions or concerns. A full list of changes can be found at <https://www.usgs.gov/streamstats/news/streamstats-data-updates-open-source-code-release>.

Collapse All

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	13.3	square miles
PRECIP	Mean Annual Precipitation	45.8	inches
ROCKDEP	Depth to rock	4.71	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.748	miles per square mile

> Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
CARBON	Percent Carbonate	0	percent	0	99
DRNAREA	Drainage Area	13.3	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	45.8	inches	35	50.4

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
ROCKDEP	Depth to Rock	4.71	feet	3.32	5.65
STRDEN	Stream Density	1.748	miles per square mile	0.51	3.1

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	2.35	ft ³ /s	38	38
30 Day 2 Year Low Flow	3.07	ft ³ /s	33	33
7 Day 10 Year Low Flow	1.18	ft ³ /s	51	51
30 Day 10 Year Low Flow	1.51	ft ³ /s	46	46
90 Day 10 Year Low Flow	2.2	ft ³ /s	36	36

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.30.0

SSHydro Services Version: 1.0.0

SSDelineate Services Version: 1.0.0

NSS Services Version: 2.2.1

GageStats Services Version: 1.2.1

Pourpoint Services Version: 1.2.0

Batch Processor Version: 1.6.0

Table 1 13

Table 1. List of U.S. Geological Survey streamgauge locations in and near Pennsylvania with updated streamflow statistics.—Continued

[Latitude and Longitude in decimal degrees; mi², square miles]

Streamgauge number	Streamgauge name	Latitude	Longitude	Drainage area (mi ²)	Regulated ¹
01541303	West Branch Susquehanna River at Hyde, Pa.	41.005	-78.457	474	Y
01541308	Bradley Run near Ashville, Pa.	40.509	-78.584	6.77	N
01541500	Clearfield Creek at Dimeling, Pa.	40.972	-78.406	371	Y
01542000	Moshannon Creek at Osceola Mills, Pa.	40.850	-78.268	68.8	N
01542500	WB Susquehanna River at Karthaus, Pa.	41.118	-78.109	1,462	Y
01542810	Waldy Run near Emporium, Pa.	41.579	-78.293	5.24	N
01543000	Driftwood Branch Sinnemahoning Creek at Sterling Run, Pa.	41.413	-78.197	272	N
01543500	Sinnemahoning Creek at Sinnemahoning, Pa.	41.317	-78.103	685	N
01544000	First Fork Sinnemahoning Creek near Sinnemahoning, Pa.	41.402	-78.024	245	Y
01544500	Kettle Creek at Cross Fork, Pa.	41.476	-77.826	136	N
01545000	Kettle Creek near Westport, Pa.	41.320	-77.874	233	Y
01545500	West Branch Susquehanna River at Renovo, Pa.	41.325	-77.751	2,975	Y
01545600	Young Womans Creek near Renovo, Pa.	41.390	-77.691	46.2	N
01546000	North Bald Eagle Creek at Milesburg, Pa.	40.942	-77.794	119	N
01546400	Spring Creek at Houserville, Pa.	40.834	-77.828	58.5	N
01546500	Spring Creek near Axemann, Pa.	40.890	-77.794	87.2	N
01547100	Spring Creek at Milesburg, Pa.	40.932	-77.786	142	N
01547200	Bald Eagle Creek below Spring Creek at Milesburg, Pa.	40.943	-77.786	265	N
01547500	Bald Eagle Creek at Blanchard, Pa.	41.052	-77.604	339	Y
01547700	Marsh Creek at Blanchard, Pa.	41.060	-77.606	44.1	N
01547800	South Fork Beech Creek near Snow Shoe, Pa.	41.024	-77.904	12.2	N
01547950	Beech Creek at Monument, Pa.	41.112	-77.702	152	N
01548005	Bald Eagle Creek near Beech Creek Station, Pa.	41.081	-77.549	562	Y
01548500	Pine Creek at Cedar Run, Pa.	41.522	-77.447	604	N
01549000	Pine Creek near Waterville, Pa.	41.313	-77.379	750	N
01549500	Blockhouse Creek near English Center, Pa.	41.474	-77.231	37.7	N
01549700	Pine Creek below Little Pine Creek near Waterville, Pa.	41.274	-77.324	944	Y
01550000	Lycoming Creek near Trout Run, Pa.	41.418	-77.033	173	N
01551500	WB Susquehanna River at Williamsport, Pa.	41.236	-76.997	5,682	Y
01552000	Loyalsock Creek at Loyalsockville, Pa.	41.325	-76.912	435	N
01552500	Muncy Creek near Sonestown, Pa.	41.357	-76.535	23.8	N
01553130	Sand Spring Run near White Deer, Pa.	41.059	-77.077	4.93	N
01553500	West Branch Susquehanna River at Lewisburg, Pa.	40.968	-76.876	6,847	Y
01553700	Chillisquaque Creek at Washingtonville, Pa.	41.062	-76.680	51.3	N
01554000	Susquehanna River at Sunbury, Pa.	40.835	-76.827	18,300	Y
01554500	Shamokin Creek near Shamokin, Pa.	40.810	-76.584	54.2	N
01555000	Penns Creek at Penns Creek, Pa.	40.867	-77.048	301	N
01555500	East Mahantango Creek near Dalmatia, Pa.	40.611	-76.912	162	N
01556000	Frankstown Branch Juniata River at Williamsburg, Pa.	40.463	-78.200	291	N
01557500	Bald Eagle Creek at Tyrone, Pa.	40.684	-78.234	44.1	N
01558000	Little Juniata River at Spruce Creek, Pa.	40.613	-78.141	220	N
01559000	Juniata River at Huntingdon, Pa.	40.485	-78.019	816	LF
01559500	Standing Stone Creek near Huntingdon, Pa.	40.524	-77.971	128	N
01559700	Sulphur Springs Creek near Manns Choice, Pa.	39.978	-78.619	5.28	N
01560000	Dunning Creek at Belden, Pa.	40.072	-78.493	172	N

26 Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania

Table 2. Selected low-flow statistics for streamgage locations in and near Pennsylvania.—Continued

[ft³/s; cubic feet per second; —, statistic not computed; <, less than]

Streamgage number	Period of record used in analysis ¹	Number of years used in analysis	1-day, 10-year (ft ³ /s)	7-day, 10-year (ft ³ /s)	7-day, 2-year (ft ³ /s)	30-day, 10-year (ft ³ /s)	30-day, 2-year (ft ³ /s)	90-day, 10-year (ft ³ /s)
01546000	1912–1934	17	1.8	2.2	6.8	3.7	12.1	11.2
01546400	1986–2008	23	13.5	14.0	19.6	15.4	22.3	18.7
01546500	1942–2008	67	26.8	29.0	41.3	31.2	44.2	33.7
01547100	1969–2008	40	102	105	128	111	133	117
01547200	1957–2008	52	99.4	101	132	106	142	115
01547500	² 1971–2008	38	28.2	109	151	131	172	153
01547500	³ 1956–1969	14	90.0	94.9	123	98.1	131	105
01547700	1957–2008	52	.5	.6	2.7	1.1	3.9	2.2
01547800	1971–1981	11	1.6	1.8	2.4	2.1	2.9	3.5
01547950	1970–2008	39	12.1	13.6	28.2	17.3	36.4	23.8
01548005	² 1971–2000	25	142	151	206	178	241	223
01548005	³ 1912–1969	58	105	114	147	125	165	140
01548500	1920–2008	89	21.2	24.2	50.1	33.6	68.6	49.3
01549000	1910–1920	11	26.0	32.9	78.0	46.4	106	89.8
01549500	1942–2008	67	.6	.8	2.5	1.4	3.9	2.6
01549700	1959–2008	50	33.3	37.2	83.8	51.2	117	78.4
01550000	1915–2008	94	6.6	7.6	16.8	11.2	24.6	18.6
01551500	² 1963–2008	46	520	578	1,020	678	1,330	919
01551500	³ 1901–1961	61	400	439	742	523	943	752
01552000	1927–2008	80	20.5	22.2	49.5	29.2	69.8	49.6
01552500	1942–2008	67	.9	1.2	3.1	1.7	4.4	3.3
01553130	1969–1981	13	1.0	1.1	1.5	1.3	1.8	1.7
01553500	² 1968–2008	41	760	838	1,440	1,000	1,850	1,470
01553500	³ 1941–1966	26	562	619	880	690	1,090	881
01553700	1981–2008	28	9.1	10.9	15.0	12.6	17.1	15.2
01554000	² 1981–2008	28	1,830	1,990	3,270	2,320	4,210	3,160
01554000	³ 1939–1979	41	1,560	1,630	2,870	1,880	3,620	2,570
01554500	1941–1993	53	16.2	22.0	31.2	25.9	35.7	31.4
01555000	1931–2008	78	33.5	37.6	58.8	43.4	69.6	54.6
01555500	1931–2008	78	4.9	6.5	18.0	9.4	24.3	16.6
01556000	1918–2008	91	43.3	47.8	66.0	55.1	75.0	63.7
01557500	1946–2008	63	2.8	3.2	6.3	4.2	8.1	5.8
01558000	1940–2008	69	56.3	59.0	79.8	65.7	86.2	73.7
01559000	1943–2008	66	104	177	249	198	279	227
01559500	1931–1958	28	9.3	10.5	15.0	12.4	17.8	15.8
01559700	1963–1978	16	.1	.1	.2	.1	.3	.2
01560000	1941–2008	68	8.5	9.4	15.6	12.0	20.2	16.2
01561000	1932–1958	27	.4	.5	1.6	.8	2.5	1.7
01562000	1913–2008	96	64.1	67.1	106	77.4	122	94.5
01562500	1931–1957	27	1.1	1.6	3.8	2.3	5.4	3.7
01563200	² 1974–2008	35	—	—	—	112	266	129
01563200	³ 1948–1972	25	10.3	28.2	86.1	64.5	113	95.5
01563500	² 1974–2008	35	384	415	519	441	580	493
01563500	³ 1939–1972	34	153	242	343	278	399	333
01564500	1940–2008	69	3.6	4.2	10.0	6.2	14.4	10.6

Attachment B

Toxics Management Spreadsheet Output Values



Run #1

Discharge Information

Instructions Discharge Stream

Facility: Altoona Water - Plane 9 NPDES Permit No.: PA0085120 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Effluent Filter Backwash

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _n
0.0556	18.3	6.75						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	33								
	Chloride (PWS)	mg/L	1.33								
	Bromide	mg/L	< 0.1								
	Sulfate (PWS)	mg/L	9.6								
	Fluoride (PWS)	mg/L	< 0.05								
Group 2	Total Aluminum	µg/L	426								
	Total Antimony	µg/L	< 0.4								
	Total Arsenic	µg/L	2								
	Total Barium	µg/L	33								
	Total Beryllium	µg/L	< 0.4								
	Total Boron	µg/L	< 47								
	Total Cadmium	µg/L	< 0.1								
	Total Chromium (III)	µg/L	< 1								
	Hexavalent Chromium	µg/L	< 0.1								
	Total Cobalt	µg/L	< 1								
	Total Copper	µg/L	2								
	Free Cyanide	µg/L	< 0.5								
	Total Cyanide	µg/L	< 5								
	Dissolved Iron	µg/L	< 20								
	Total Iron	µg/L	120								
	Total Lead	µg/L	< 1								
	Total Manganese	µg/L	153								
	Total Mercury	µg/L	< 0.2								
	Total Nickel	µg/L	1								
	Total Phenols (Phenolics) (PWS)	µg/L	< 5								
	Total Selenium	µg/L	< 0.5								
	Total Silver	µg/L	< 0.2								
	Total Thallium	µg/L	< 0.05								
	Total Zinc	µg/L	< 4								
Total Molybdenum	µg/L	< 4									
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									



Stream / Surface Water Information

Altoona Water - Plane 9, NPDES Permit No. PA0085120, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: Blair Gap Run No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	016335	5.62	1360	12.2			Yes
End of Reach 1	016635	4.33	1230	13.3			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	5.62	0.0967	1.18									17	7.3		
End of Reach 1	4.33	0.0887										17	7.3		

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	5.62		1.18												
End of Reach 1	4.33														



Model Results

Altoona Water - Plane 9, NPDES Permit No. PA0085120, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min): 4.687

PMF: 1

Analysis Hardness (mg/l): 17.088

Analysis pH: 7.23

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	11,039	
Total Antimony	0	0		0	1,100	1,100	16,191	
Total Arsenic	0	0		0	340	340	5,004	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	309,095	
Total Boron	0	0		0	8,100	8,100	119,222	
Total Cadmium	0	0		0	0.360	0.35	5.21	Chem Translator of 1.018 applied
Total Chromium (III)	0	0		0	134.053	424	6,244	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	240	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	1,398	
Total Copper	0	0		0	2.543	2.65	39.0	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	22	22.0	324	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	9.030	8.61	127	Chem Translator of 1.048 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1.400	1.65	24.2	Chem Translator of 0.85 applied
Total Nickel	0	0		0	105.034	105	1,549	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	0.154	0.18	2.67	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	957	
Total Zinc	0	0		0	26.225	26.8	395	Chem Translator of 0.978 applied

CFC

CCT (min): 4.687

PMF: 1

Analysis Hardness (mg/l): 17.088

Analysis pH: 7.23

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	3,238	
Total Arsenic	0	0		0	150	150	2,208	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	60,347	
Total Boron	0	0		0	1,600	1,600	23,550	
Total Cadmium	0	0		0	0.072	0.073	1.08	Chem Translator of 0.983 applied
Total Chromium (III)	0	0		0	17.437	20.3	298	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	153	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	280	
Total Copper	0	0		0	1.979	2.06	30.3	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	5.2	5.2	76.5	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	22,078	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	0.352	0.34	4.94	Chem Translator of 1.048 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	13.3	Chem Translator of 0.85 applied
Total Nickel	0	0		0	11.666	11.7	172	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.600	4.99	73.4	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	191	
Total Zinc	0	0		0	26.440	26.8	395	Chem Translator of 0.986 applied

THH

CCT (min): 4.687

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	82.4	
Total Arsenic	0	0		0	10	10.0	147	
Total Barium	0	0		0	2,400	2,400	35,325	
Total Boron	0	0		0	3,100	3,100	45,628	

Total Cadmium	0	0	0	N/A	N/A	N/A
Total Chromium (III)	0	0	0	N/A	N/A	N/A
Hexavalent Chromium	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	N/A	N/A	N/A
Free Cyanide	0	0	0	4	4.0	58.9
Dissolved Iron	0	0	0	300	300	4,416
Total Iron	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	1,000	1,000	14,719
Total Mercury	0	0	0	0.050	0.05	0.74
Total Nickel	0	0	0	610	610	8,978
Total Phenols (Phenolics) (PWS)	0	0	0	5	5.0	N/A
Total Selenium	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0.24	0.24	3.53
Total Zinc	0	0	0	N/A	N/A	N/A

CRL

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	N/A	N/A	N/A	
Total Arsenic	0	0	0	0	N/A	N/A	N/A	
Total Barium	0	0	0	0	N/A	N/A	N/A	
Total Boron	0	0	0	0	N/A	N/A	N/A	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A	
Total Cobalt	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	
Free Cyanide	0	0	0	0	N/A	N/A	N/A	
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	N/A	N/A	N/A	
Total Nickel	0	0	0	0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	N/A	

Total Silver	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	N/A	N/A	N/A
Total Zinc	0	0	0	N/A	N/A	N/A

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	Discharge Conc < TQL
Total Aluminum	7,076	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	147	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	35,325	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	23,550	µg/L	Discharge Conc < TQL
Total Cadmium	1.08	µg/L	Discharge Conc < TQL
Total Chromium (III)	298	µg/L	Discharge Conc < TQL
Hexavalent Chromium	153	µg/L	Discharge Conc < TQL
Total Cobalt	280	µg/L	Discharge Conc < TQL
Total Copper	25.0	µg/L	Discharge Conc ≤ 10% WQBEL
Free Cyanide	58.9	µg/L	Discharge Conc < TQL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	4,416	µg/L	Discharge Conc < TQL
Total Iron	22,078	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	4.94	µg/L	Discharge Conc < TQL
Total Manganese	14,719	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	0.74	µg/L	Discharge Conc < TQL

Total Nickel	172	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	Discharge Conc < TQL
Total Selenium	73.4	µg/L	Discharge Conc < TQL
Total Silver	1.71	µg/L	Discharge Conc < TQL
Total Thallium	3.53	µg/L	Discharge Conc < TQL
Total Zinc	253	µg/L	Discharge Conc < TQL
Total Molybdenum	N/A	N/A	No WQS



Toxics Management Spreadsheet
Version 1.4, May 2023

RUN #2

Discharge Information

Instructions Discharge Stream

Facility: Altoona Water - Plane 9 NPDES Permit No.: PA0085120 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Effluent Filter Backwash

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _n
0.0556	18.3	6.75						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1											
Total Dissolved Solids (PWS)	mg/L	33									
Chloride (PWS)	mg/L	1.33									
Bromide	mg/L	< 0.1									
Sulfate (PWS)	mg/L	9.6									
Fluoride (PWS)	mg/L	< 0.05									
Total Aluminum	mg/L	0.774									
Total Antimony	µg/L	< 0.4									
Total Arsenic	µg/L	2									
Total Barium	µg/L	33									
Total Beryllium	µg/L	< 0.4									
Total Boron	µg/L	< 47									
Total Cadmium	µg/L	< 0.1									
Total Chromium (III)	µg/L	< 1									
Hexavalent Chromium	µg/L	< 0.1									
Total Cobalt	µg/L	< 1									
Total Copper	mg/L	0.04765			0.48						
Group 2											
Free Cyanide	µg/L	< 0.5									
Total Cyanide	µg/L	< 5									
Dissolved Iron	µg/L	< 20									
Total Iron	mg/L	0.4									
Total Lead	µg/L	< 1									
Total Manganese	mg/L	0.333									
Total Mercury	µg/L	< 0.2									
Total Nickel	µg/L	1									
Total Phenols (Phenolics) (PWS)	µg/L	< 5									
Total Selenium	µg/L	< 0.5									
Total Silver	µg/L	< 0.2									
Total Thallium	µg/L	< 0.05									
Total Zinc	µg/L	< 4									
Total Molybdenum	µg/L	< 4									
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									



Stream / Surface Water Information

Altoona Water - Plane 9, NPDES Permit No. PA0085120, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: Blair Gap Run No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	016335	5.62	1360	12.2			Yes
End of Reach 1	016335	4.33	1230	13.3			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	5.62	0.0967	1.18									17	7.3		
End of Reach 1	4.33	0.0887										17	7.3		

Q_n

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	5.62														
End of Reach 1	4.33														



Model Results

Altoona Water - Plane 9, NPDES Permit No. PA0085120, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min): 4.687

PMF: 1

Analysis Hardness (mg/l): 17.088

Analysis pH: 7.23

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	11,039	
Total Antimony	0	0		0	1,100	1,100	16,191	
Total Arsenic	0	0		0	340	340	5,004	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	309,095	
Total Boron	0	0		0	8,100	8,100	119,222	
Total Cadmium	0	0		0	0.360	0.35	5.21	Chem Translator of 1.018 applied
Total Chromium (III)	0	0		0	134.053	424	6,244	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	240	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	1,398	
Total Copper	0	0		0	2.543	2.65	39.0	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	22	22.0	324	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	9.030	8.61	127	Chem Translator of 1.048 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1.400	1.65	24.2	Chem Translator of 0.85 applied
Total Nickel	0	0		0	105.034	105	1,549	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	0.154	0.18	2.67	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	957	
Total Zinc	0	0		0	26.225	26.8	395	Chem Translator of 0.978 applied

CFC CCT (min): 4.687 PMF: 1 Analysis Hardness (mg/l): 17.088 Analysis pH: 7.23

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	3,238	
Total Arsenic	0	0		0	150	150	2,208	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	60,347	
Total Boron	0	0		0	1,600	1,600	23,550	
Total Cadmium	0	0		0	0.072	0.073	1.08	Chem Translator of 0.983 applied
Total Chromium (III)	0	0		0	17.437	20.3	298	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	153	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	280	
Total Copper	0	0		0	1.979	2.06	30.3	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	5.2	5.2	76.5	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	22,078	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	0.352	0.34	4.94	Chem Translator of 1.048 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	13.3	Chem Translator of 0.85 applied
Total Nickel	0	0		0	11.666	11.7	172	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.600	4.99	73.4	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	191	
Total Zinc	0	0		0	26.440	26.8	395	Chem Translator of 0.986 applied

THH CCT (min): 4.687 PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	82.4	
Total Arsenic	0	0		0	10	10.0	147	
Total Barium	0	0		0	2,400	2,400	35,325	
Total Boron	0	0		0	3,100	3,100	45,628	

Total Cadmium	0	0	0	N/A	N/A	N/A
Total Chromium (III)	0	0	0	N/A	N/A	N/A
Hexavalent Chromium	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	N/A	N/A	N/A
Free Cyanide	0	0	0	4	4.0	58.9
Dissolved Iron	0	0	0	300	300	4,416
Total Iron	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	1,000	1,000	14,719
Total Mercury	0	0	0	0.050	0.05	0.74
Total Nickel	0	0	0	610	610	8,978
Total Phenols (Phenolics) (PWS)	0	0	0	5	5.0	N/A
Total Selenium	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0.24	0.24	3.53
Total Zinc	0	0	0	N/A	N/A	N/A

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	N/A	N/A	N/A	
Total Arsenic	0	0	0	0	N/A	N/A	N/A	
Total Barium	0	0	0	0	N/A	N/A	N/A	
Total Boron	0	0	0	0	N/A	N/A	N/A	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A	
Total Cobalt	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	
Free Cyanide	0	0	0	0	N/A	N/A	N/A	
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	N/A	N/A	N/A	
Total Nickel	0	0	0	0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	N/A	

Total Silver	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	N/A	N/A	N/A
Total Zinc	0	0	0	N/A	N/A	N/A

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: **4**

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Aluminum	Report	Report	Report	Report	Report	mg/L	7.08	AFC	Discharge Conc > 10% WQBEL (no RP)
Total Copper	0.011	0.018	0.025	0.038	0.061	mg/L	0.025	AFC	Discharge Conc ≥ 50% WQBEL (RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	Discharge Conc < TQL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	147	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	35,325	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	23,550	µg/L	Discharge Conc < TQL
Total Cadmium	1.08	µg/L	Discharge Conc < TQL
Total Chromium (III)	298	µg/L	Discharge Conc < TQL
Hexavalent Chromium	153	µg/L	Discharge Conc < TQL
Total Cobalt	280	µg/L	Discharge Conc < TQL
Free Cyanide	58.9	µg/L	Discharge Conc < TQL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	4,416	µg/L	Discharge Conc < TQL
Total Iron	22.1	mg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	4.94	µg/L	Discharge Conc < TQL
Total Manganese	14.7	mg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	0.74	µg/L	Discharge Conc < TQL
Total Nickel	172	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	Discharge Conc < TQL

Total Selenium	73.4	µg/L	Discharge Conc < TQL
Total Silver	1.71	µg/L	Discharge Conc < TQL
Total Thallium	3.53	µg/L	Discharge Conc < TQL
Total Zinc	253	µg/L	Discharge Conc < TQL
Total Molybdenum	N/A	N/A	No WQS

Attachment D

DMR Data

Monitoring Period Begin Date	Monitoring Period End Date	DMR Received Date	Outfall	Discharge	Monitoring Location	Parameter Name	Parameter Code	DMR Value	Permit Limit	Units	Statistical Base Code
04/01/2021	06/30/2021	07/22/2021	101	Yes	Final Effluent	Copper, Total	01042	0.05	Monitor and Report	mg/L	Average Quarterly
07/01/2021	09/30/2021	10/28/2021	101	Yes	Final Effluent	Copper, Total	01042	< 0.082	Monitor and Report	mg/L	Average Quarterly
10/01/2021	12/31/2021	01/27/2022	101	Yes	Final Effluent	Copper, Total	01042	< 0.064	Monitor and Report	mg/L	Average Quarterly
01/01/2022	03/31/2022	04/28/2022	101	Yes	Final Effluent	Copper, Total	01042	< 0.052	Monitor and Report	mg/L	Average Quarterly
04/01/2022	06/30/2022	07/21/2022	101	Yes	Final Effluent	Copper, Total	01042	0.0377	Monitor and Report	mg/L	Average Quarterly
07/01/2022	09/30/2022	10/27/2022	101	Yes	Final Effluent	Copper, Total	01042	0.0532	Monitor and Report	mg/L	Average Quarterly
10/01/2022	12/31/2022	11/28/2022	101	Yes	Final Effluent	Copper, Total	01042	0.072	Monitor and Report	mg/L	Average Quarterly
01/01/2023	03/31/2023	04/27/2023	101	Yes	Final Effluent	Copper, Total	01042	< 0.031	Monitor and Report	mg/L	Average Quarterly
04/01/2023	06/30/2023	07/27/2023	101	Yes	Final Effluent	Copper, Total	01042	0.02	Monitor and Report	mg/L	Average Quarterly
07/01/2023	09/30/2023	10/25/2023	101	Yes	Final Effluent	Copper, Total	01042	0.058	Monitor and Report	mg/L	Average Quarterly
10/01/2023	12/31/2023	01/25/2024	101	Yes	Final Effluent	Copper, Total	01042	0.0493	Monitor and Report	mg/L	Average Quarterly
01/01/2024	03/31/2024	04/23/2024	101	Yes	Final Effluent	Copper, Total	01042	0.041	Monitor and Report	mg/L	Average Quarterly
04/01/2024	06/30/2024	07/28/2024	101	Yes	Final Effluent	Copper, Total	01042	0.066	Monitor and Report	mg/L	Average Quarterly
07/01/2024	09/30/2024	10/26/2024	101	Yes	Final Effluent	Copper, Total	01042	0.046	Monitor and Report	mg/L	Average Quarterly
10/01/2024	12/31/2024	01/28/2025	101	Yes	Final Effluent	Copper, Total	01042	0.084	Monitor and Report	mg/L	Average Quarterly
01/01/2025	03/31/2025	04/22/2025	101	Yes	Final Effluent	Copper, Total	01042	0.026	Monitor and Report	mg/L	Average Quarterly
04/01/2025	06/30/2025	07/22/2025	101	Yes	Final Effluent	Copper, Total	01042	0.04	Monitor and Report	mg/L	Average Quarterly
07/01/2025	09/30/2025	10/20/2025	101	Yes	Final Effluent	Copper, Total	01042	0.014	Monitor and Report	mg/L	Average Quarterly
							Min	0.0140			
							Max	0.0840			
							Average	0.0492			



Instructions **Inputs** CLEAR FORM CALCULATE

Facility: Altoona Plane 9
 NPDES #: PA0085120
 Outfall #: 001
 Sample Type*: Effluent

No. Parameters: 1
 No. Samples: 18

Parameter Name*	Total Copper			
Units	mg/L			
Quantitation Limit	0.082			
Sample Date*	Sample Results*	Sample Results*	Sample Results*	Sample Results*
4/1/2021	0.05			
7/1/2021	<0.082			
10/1/2021	<0.064			
1/1/2022	<0.052			
4/1/2022	0.0377			
7/1/2022	0.0532			
10/1/2022	0.072			
1/1/2023	<0.031			
4/1/2023	0.02			
7/1/2023	0.058			
10/1/2023	0.0493			
1/1/2024	0.041			
4/1/2024	0.066			
7/1/2024	0.046			
10/1/2024	0.084			
1/1/2025	0.026			
4/1/2025	0.04			
7/1/2025	0.014			

A B C D E F G H I J K L M N O P Q R S T U V W X Y Z AA AB

ToxStats Spreadsheet
Version 1.0, December 2025

Instructions **Results** RETURN TO INPUTS PRINT TO PDF

Facility:	Altoona Plane 9		
NPDES #:	PA0085120		
Outfall #:	001		
Sample Type:	Effluent		
Parameter	Distribution Applied	Daily CV	Concentration
Total Copper (mg/L)	Delta-Lognormal	0.48	0.04765

Monitoring Period End Date	DMR Received Date	Monitoring Location	Parameter Name	DMR Value		Permit Limit	Units	Statistical Base Code
02/28/2021	03/26/2021	Final Effluent	Aluminum, Total	<	0.774	1.2	mg/L	Average Monthly
03/31/2021	04/28/2021	Final Effluent	Aluminum, Total		1.0	1.2	mg/L	Average Monthly
04/30/2021	05/21/2021	Final Effluent	Aluminum, Total		0.4	1.2	mg/L	Average Monthly
05/31/2021	06/28/2021	Final Effluent	Aluminum, Total		0.3	1.2	mg/L	Average Monthly
06/30/2021	07/21/2021	Final Effluent	Aluminum, Total		0.5	1.2	mg/L	Average Monthly
07/31/2021	08/25/2021	Final Effluent	Aluminum, Total		0.341	1.2	mg/L	Average Monthly
08/31/2021	09/27/2021	Final Effluent	Aluminum, Total		0.2	1.2	mg/L	Average Monthly
09/30/2021	10/28/2021	Final Effluent	Aluminum, Total		0.8	1.2	mg/L	Average Monthly
10/31/2021	11/28/2021	Final Effluent	Aluminum, Total		0.4	1.2	mg/L	Average Monthly
11/30/2021	12/21/2021	Final Effluent	Aluminum, Total		0.4	1.2	mg/L	Average Monthly
12/31/2021	01/26/2022	Final Effluent	Aluminum, Total		0.5	1.2	mg/L	Average Monthly
01/31/2022	03/11/2022	Final Effluent	Aluminum, Total		0.7	1.2	mg/L	Average Monthly
04/30/2022	05/22/2022	Final Effluent	Aluminum, Total		0.6	1.2	mg/L	Average Monthly
05/31/2022	06/23/2022	Final Effluent	Aluminum, Total		0.611	1.2	mg/L	Average Monthly
06/30/2022	07/21/2022	Final Effluent	Aluminum, Total		0.4	1.2	mg/L	Average Monthly
07/31/2022	08/25/2022	Final Effluent	Aluminum, Total	<	0.2	1.2	mg/L	Average Monthly
08/31/2022	09/28/2022	Final Effluent	Aluminum, Total	<	0.3	1.2	mg/L	Average Monthly
09/30/2022	10/24/2022	Final Effluent	Aluminum, Total		0.5	1.2	mg/L	Average Monthly
10/31/2022	11/28/2022	Final Effluent	Aluminum, Total		0.4	1.2	mg/L	Average Monthly
11/30/2022	12/28/2022	Final Effluent	Aluminum, Total		0.6	1.2	mg/L	Average Monthly
12/31/2022	01/26/2023	Final Effluent	Aluminum, Total		0.6	1.2	mg/L	Average Monthly
01/31/2023	02/28/2023	Final Effluent	Aluminum, Total		0.7	1.2	mg/L	Average Monthly
02/28/2023	03/22/2023	Final Effluent	Aluminum, Total		0.6	1.2	mg/L	Average Monthly
03/31/2023	04/27/2023	Final Effluent	Aluminum, Total		0.6	1.2	mg/L	Average Monthly
04/30/2023	05/22/2023	Final Effluent	Aluminum, Total		0.3	1.2	mg/L	Average Monthly
05/31/2023	06/26/2023	Final Effluent	Aluminum, Total		0.3	1.2	mg/L	Average Monthly
06/30/2023	07/27/2023	Final Effluent	Aluminum, Total		0.2	1.2	mg/L	Average Monthly
07/31/2023	08/28/2023	Final Effluent	Aluminum, Total		0.5	1.2	mg/L	Average Monthly
08/31/2023	09/28/2023	Final Effluent	Aluminum, Total		0.5	1.2	mg/L	Average Monthly
09/30/2023	10/25/2023	Final Effluent	Aluminum, Total		0.4	1.2	mg/L	Average Monthly
10/31/2023	11/28/2023	Final Effluent	Aluminum, Total		0.2	1.2	mg/L	Average Monthly
11/30/2023	12/13/2023	Final Effluent	Aluminum, Total		0.4	1.2	mg/L	Average Monthly
12/31/2023	01/25/2024	Final Effluent	Aluminum, Total		0.6	1.2	mg/L	Average Monthly
01/31/2024	02/27/2024	Final Effluent	Aluminum, Total		0.8	1.2	mg/L	Average Monthly
02/29/2024	03/21/2024	Final Effluent	Aluminum, Total		0.7	1.2	mg/L	Average Monthly
03/31/2024	04/23/2024	Final Effluent	Aluminum, Total		0.8	1.2	mg/L	Average Monthly
04/30/2024	05/18/2024	Final Effluent	Aluminum, Total		0.80	1.2	mg/L	Average Monthly
05/31/2024	06/30/2024	Final Effluent	Aluminum, Total		0.557	1.2	mg/L	Average Monthly
06/30/2024	07/27/2024	Final Effluent	Aluminum, Total		0.233	1.2	mg/L	Average Monthly
07/31/2024	08/25/2024	Final Effluent	Aluminum, Total		0.187	1.2	mg/L	Average Monthly
08/31/2024	09/23/2024	Final Effluent	Aluminum, Total		0.135	1.2	mg/L	Average Monthly
09/30/2024	10/26/2024	Final Effluent	Aluminum, Total		0.147	1.2	mg/L	Average Monthly
10/31/2024	11/16/2024	Final Effluent	Aluminum, Total		0.349	1.2	mg/L	Average Monthly
11/30/2024	12/24/2024	Final Effluent	Aluminum, Total		0.30	1.2	mg/L	Average Monthly
12/31/2024	01/21/2025	Final Effluent	Aluminum, Total		0.69	1.2	mg/L	Average Monthly
01/31/2025	02/22/2025	Final Effluent	Aluminum, Total		0.8	1.2	mg/L	Average Monthly
02/28/2025	03/25/2025	Final Effluent	Aluminum, Total		0.9	1.2	mg/L	Average Monthly
03/31/2025	04/22/2025	Final Effluent	Aluminum, Total		1.1	1.2	mg/L	Average Monthly
04/30/2025	05/27/2025	Final Effluent	Aluminum, Total		0.8	1.2	mg/L	Average Monthly
05/31/2025	06/24/2025	Final Effluent	Aluminum, Total		1.1	1.2	mg/L	Average Monthly
06/30/2025	07/22/2025	Final Effluent	Aluminum, Total		0.9	1.2	mg/L	Average Monthly
07/31/2025	08/26/2025	Final Effluent	Aluminum, Total		0.6	1.2	mg/L	Average Monthly
08/31/2025	09/23/2025	Final Effluent	Aluminum, Total		0.4	1.2	mg/L	Average Monthly
09/30/2025	10/20/2025	Final Effluent	Aluminum, Total		0.3	1.2	mg/L	Average Monthly
10/31/2025	11/25/2025	Final Effluent	Aluminum, Total		0.2	1.2	mg/L	Average Monthly
11/30/2025	12/23/2025	Final Effluent	Aluminum, Total		0.3	1.2	mg/L	Average Monthly
			Min		0.200			
			Max	57	0.774			
			Average		0.425			

Monitoring Period	DMR	Outfall	Discharge	Monitoring	Parameter Name	DMR Value	Permit Limit	Units	Statistical Base Code
02/28/2021	03/26/2021	101	Yes	Final Effluent	Iron, Total	< 0.10	2.0	mg/L	Average Monthly
03/31/2021	04/28/2021	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
04/30/2021	05/21/2021	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
05/31/2021	06/28/2021	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
06/30/2021	07/21/2021	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
07/31/2021	08/25/2021	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
08/31/2021	09/27/2021	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
09/30/2021	10/28/2021	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
10/31/2021	11/28/2021	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
11/30/2021	12/21/2021	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
12/31/2021	01/26/2022	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
01/31/2022	03/11/2022	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
04/30/2022	05/22/2022	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
05/31/2022	06/23/2022	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
06/30/2022	07/21/2022	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
07/31/2022	08/25/2022	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
08/31/2022	09/28/2022	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
09/30/2022	10/24/2022	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
10/31/2022	11/28/2022	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
11/30/2022	12/28/2022	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
12/31/2022	01/26/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
01/31/2023	02/28/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
02/28/2023	03/22/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
03/31/2023	04/27/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
04/30/2023	05/22/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
05/31/2023	06/26/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
06/30/2023	07/27/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
07/31/2023	08/28/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
08/31/2023	09/28/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
09/30/2023	10/25/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
10/31/2023	11/28/2023	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
11/30/2023	12/13/2023	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
12/31/2023	01/25/2024	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
01/31/2024	02/27/2024	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
02/29/2024	03/21/2024	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
03/31/2024	04/23/2024	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
04/30/2024	05/18/2024	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
05/31/2024	06/30/2024	101	Yes	Final Effluent	Iron, Total	< 0.0823	2.0	mg/L	Average Monthly
06/30/2024	07/27/2024	101	Yes	Final Effluent	Iron, Total	< 0.038	2.0	mg/L	Average Monthly
07/31/2024	08/25/2024	101	Yes	Final Effluent	Iron, Total	< 0.1458	2.0	mg/L	Average Monthly
08/31/2024	09/23/2024	101	Yes	Final Effluent	Iron, Total	< 0.0634	2.0	mg/L	Average Monthly
09/30/2024	10/26/2024	101	Yes	Final Effluent	Iron, Total	< 0.054	2.0	mg/L	Average Monthly
10/31/2024	11/16/2024	101	Yes	Final Effluent	Iron, Total	< 0.117	2.0	mg/L	Average Monthly
11/30/2024	12/24/2024	101	Yes	Final Effluent	Iron, Total	< 0.08	2.0	mg/L	Average Monthly
12/31/2024	01/21/2025	101	Yes	Final Effluent	Iron, Total	< 0.069	2.0	mg/L	Average Monthly
01/31/2025	02/22/2025	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
02/28/2025	03/25/2025	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
03/31/2025	04/22/2025	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
04/30/2025	05/27/2025	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
05/31/2025	06/24/2025	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
06/30/2025	07/22/2025	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
07/31/2025	08/26/2025	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
08/31/2025	09/23/2025	101	Yes	Final Effluent	Iron, Total	< 0.4	2.0	mg/L	Average Monthly
09/30/2025	10/20/2025	101	Yes	Final Effluent	Iron, Total	< 0.2	2.0	mg/L	Average Monthly
10/31/2025	11/25/2025	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
11/30/2025	12/23/2025	101	Yes	Final Effluent	Iron, Total	< 0.1	2.0	mg/L	Average Monthly
					Min	0.038			
					Max	0.4			
					Average	0.149			

Monitoring Period Begin Date	Monitoring Period End Date	DMR Received Date	Outfall	Monitoring Location	Parameter Name	DMR Value		Permit Limit	Units	Statistical Base Code
						<				
02/01/2021	02/28/2021	03/26/2021	101	Final Effluent	Manganese, Total	<	0.1	1.0	mg/L	Average Monthly
03/01/2021	03/31/2021	04/28/2021	101	Final Effluent	Manganese, Total	<	0.1	1.0	mg/L	Average Monthly
04/01/2021	04/30/2021	05/21/2021	101	Final Effluent	Manganese, Total	<	0.1	1.0	mg/L	Average Monthly
05/01/2021	05/31/2021	06/28/2021	101	Final Effluent	Manganese, Total		0.2	1.0	mg/L	Average Monthly
06/01/2021	06/30/2021	07/21/2021	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
07/01/2021	07/31/2021	08/25/2021	101	Final Effluent	Manganese, Total	<	0.2	1.0	mg/L	Average Monthly
08/01/2021	08/31/2021	09/27/2021	101	Final Effluent	Manganese, Total		0.3	1.0	mg/L	Average Monthly
09/01/2021	09/30/2021	10/28/2021	101	Final Effluent	Manganese, Total	<	0.1	1.0	mg/L	Average Monthly
10/01/2021	10/31/2021	11/28/2021	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
11/01/2021	11/30/2021	12/21/2021	101	Final Effluent	Manganese, Total	<	0.1	1.0	mg/L	Average Monthly
12/01/2021	12/31/2021	01/26/2022	101	Final Effluent	Manganese, Total	<	0.1	1.0	mg/L	Average Monthly
01/01/2022	01/31/2022	03/11/2022	101	Final Effluent	Manganese, Total	<	0.1	1.0	mg/L	Average Monthly
04/01/2022	04/30/2022	05/22/2022	101	Final Effluent	Manganese, Total		0.05	1.0	mg/L	Average Monthly
05/01/2022	05/31/2022	06/23/2022	101	Final Effluent	Manganese, Total		0.03	1.0	mg/L	Average Monthly
06/01/2022	06/30/2022	07/21/2022	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
07/01/2022	07/31/2022	08/25/2022	101	Final Effluent	Manganese, Total		0.04	1.0	mg/L	Average Monthly
08/01/2022	08/31/2022	09/28/2022	101	Final Effluent	Manganese, Total	<	0.04	1.0	mg/L	Average Monthly
09/01/2022	09/30/2022	10/24/2022	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
10/01/2022	10/31/2022	11/28/2022	101	Final Effluent	Manganese, Total		0.2	1.0	mg/L	Average Monthly
11/01/2022	11/30/2022	12/28/2022	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
12/01/2022	12/31/2022	01/26/2023	101	Final Effluent	Manganese, Total		0.04	1.0	mg/L	Average Monthly
01/01/2023	01/31/2023	02/28/2023	101	Final Effluent	Manganese, Total		0.03	1.0	mg/L	Average Monthly
02/01/2023	02/28/2023	03/22/2023	101	Final Effluent	Manganese, Total		0.3	1.0	mg/L	Average Monthly
03/01/2023	03/31/2023	04/27/2023	101	Final Effluent	Manganese, Total		0.03	1.0	mg/L	Average Monthly
04/01/2023	04/30/2023	05/22/2023	101	Final Effluent	Manganese, Total		0.03	1.0	mg/L	Average Monthly
05/01/2023	05/31/2023	06/26/2023	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
06/01/2023	06/30/2023	07/27/2023	101	Final Effluent	Manganese, Total	<	0.1	1.0	mg/L	Average Monthly
07/01/2023	07/31/2023	08/28/2023	101	Final Effluent	Manganese, Total		0.3	1.0	mg/L	Average Monthly
08/01/2023	08/31/2023	09/28/2023	101	Final Effluent	Manganese, Total		0.2	1.0	mg/L	Average Monthly
09/01/2023	09/30/2023	10/25/2023	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
10/01/2023	10/31/2023	11/28/2023	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
11/01/2023	11/30/2023	12/13/2023	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
12/01/2023	12/31/2023	01/25/2024	101	Final Effluent	Manganese, Total		0.04	1.0	mg/L	Average Monthly
01/01/2024	01/31/2024	02/27/2024	101	Final Effluent	Manganese, Total		0.04	1.0	mg/L	Average Monthly
02/01/2024	02/29/2024	03/21/2024	101	Final Effluent	Manganese, Total		0.04	1.0	mg/L	Average Monthly
03/01/2024	03/31/2024	04/23/2024	101	Final Effluent	Manganese, Total		0.03	1.0	mg/L	Average Monthly
04/01/2024	04/30/2024	05/18/2024	101	Final Effluent	Manganese, Total		0.05	1.0	mg/L	Average Monthly
05/01/2024	05/31/2024	06/30/2024	101	Final Effluent	Manganese, Total		0.0828	1.0	mg/L	Average Monthly
06/01/2024	06/30/2024	07/27/2024	101	Final Effluent	Manganese, Total		0.112	1.0	mg/L	Average Monthly
07/01/2024	07/31/2024	08/25/2024	101	Final Effluent	Manganese, Total		0.197	1.0	mg/L	Average Monthly
08/01/2024	08/31/2024	09/23/2024	101	Final Effluent	Manganese, Total		0.333	1.0	mg/L	Average Monthly
09/01/2024	09/30/2024	10/26/2024	101	Final Effluent	Manganese, Total		0.186	1.0	mg/L	Average Monthly
10/01/2024	10/31/2024	11/16/2024	101	Final Effluent	Manganese, Total		0.123	1.0	mg/L	Average Monthly
11/01/2024	11/30/2024	12/24/2024	101	Final Effluent	Manganese, Total		0.041	1.0	mg/L	Average Monthly
12/01/2024	12/31/2024	01/21/2025	101	Final Effluent	Manganese, Total		0.031	1.0	mg/L	Average Monthly
01/01/2025	01/31/2025	02/22/2025	101	Final Effluent	Manganese, Total		0.03	1.0	mg/L	Average Monthly
02/01/2025	02/28/2025	03/25/2025	101	Final Effluent	Manganese, Total		0.03	1.0	mg/L	Average Monthly
03/01/2025	03/31/2025	04/22/2025	101	Final Effluent	Manganese, Total		0.04	1.0	mg/L	Average Monthly
04/01/2025	04/30/2025	05/27/2025	101	Final Effluent	Manganese, Total		0.04	1.0	mg/L	Average Monthly
05/01/2025	05/31/2025	06/24/2025	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
06/01/2025	06/30/2025	07/22/2025	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
07/01/2025	07/31/2025	08/26/2025	101	Final Effluent	Manganese, Total		0.1	1.0	mg/L	Average Monthly
08/01/2025	08/31/2025	09/23/2025	101	Final Effluent	Manganese, Total		0.2	1.0	mg/L	Average Monthly
09/01/2025	09/30/2025	10/20/2025	101	Final Effluent	Manganese, Total		0.2	1.0	mg/L	Average Monthly
10/01/2025	10/31/2025	11/25/2025	101	Final Effluent	Manganese, Total		0.2	1.0	mg/L	Average Monthly
11/01/2025	11/30/2025	12/23/2025	101	Final Effluent	Manganese, Total		0.04	1.0	mg/L	Average Monthly
					Min		0.03			
					Max		0.333			
					Average		0.108			

Monitoring Period Begin Date	Monitoring Period End Date	DMR Received Date	Outfall	Discharge	Monitoring Location	Parameter Name	DMR Value	Permit Limit	Units	Statistical Base Code
02/01/2021	02/28/2021	03/26/2021	1	Yes	Final Effluent	Flow	0.06238	Monitor and Report	MGD	Average Monthly
03/01/2021	03/31/2021	04/28/2021	1	Yes	Final Effluent	Flow	0.126	Monitor and Report	MGD	Average Monthly
04/01/2021	04/30/2021	05/21/2021	1	Yes	Final Effluent	Flow	0.0635	Monitor and Report	MGD	Average Monthly
05/01/2021	05/31/2021	06/28/2021	1	Yes	Final Effluent	Flow	0.0645	Monitor and Report	MGD	Average Monthly
06/01/2021	06/30/2021	07/21/2021	1	Yes	Final Effluent	Flow	0.0593	Monitor and Report	MGD	Average Monthly
07/01/2021	07/31/2021	08/25/2021	1	Yes	Final Effluent	Flow	0.0313	Monitor and Report	MGD	Average Monthly
08/01/2021	08/31/2021	09/27/2021	1	Yes	Final Effluent	Flow	0.0691	Monitor and Report	MGD	Average Monthly
09/01/2021	09/30/2021	10/28/2021	1	Yes	Final Effluent	Flow	0.049	Monitor and Report	MGD	Average Monthly
10/01/2021	10/31/2021	11/28/2021	1	Yes	Final Effluent	Flow	0.0526	Monitor and Report	MGD	Average Monthly
11/01/2021	11/30/2021	12/21/2021	1	Yes	Final Effluent	Flow	0.0431	Monitor and Report	MGD	Average Monthly
12/01/2021	12/31/2021	01/26/2022	1	Yes	Final Effluent	Flow	0.05214	Monitor and Report	MGD	Average Monthly
01/01/2022	01/31/2022	03/11/2022	1	Yes	Final Effluent	Flow	0.06877	Monitor and Report	MGD	Average Monthly
04/01/2022	04/30/2022	05/22/2022	1	Yes	Final Effluent	Flow	0.0706	Monitor and Report	MGD	Average Monthly
05/01/2022	05/31/2022	06/23/2022	1	Yes	Final Effluent	Flow	0.0378	Monitor and Report	MGD	Average Monthly
06/01/2022	06/30/2022	07/21/2022	1	Yes	Final Effluent	Flow	0.0815	Monitor and Report	MGD	Average Monthly
07/01/2022	07/31/2022	08/28/2022	1	Yes	Final Effluent	Flow	0.022452	Monitor and Report	MGD	Average Monthly
08/01/2022	08/31/2022	09/28/2022	1	Yes	Final Effluent	Flow	0.0692	Monitor and Report	MGD	Average Monthly
09/01/2022	09/30/2022	10/24/2022	1	Yes	Final Effluent	Flow	0.044248	Monitor and Report	MGD	Average Monthly
10/01/2022	10/31/2022	11/28/2022	1	Yes	Final Effluent	Flow	0.0836	Monitor and Report	MGD	Average Monthly
11/01/2022	11/30/2022	12/28/2022	1	Yes	Final Effluent	Flow	0.032602	Monitor and Report	MGD	Average Monthly
12/01/2022	12/31/2022	01/26/2023	1	Yes	Final Effluent	Flow	0.0447	Monitor and Report	MGD	Average Monthly
01/01/2023	01/31/2023	02/28/2023	1	Yes	Final Effluent	Flow	0.1075	Monitor and Report	MGD	Average Monthly
02/01/2023	02/28/2023	03/22/2023	1	Yes	Final Effluent	Flow	0.2995	Monitor and Report	MGD	Average Monthly
03/01/2023	03/31/2023	04/27/2023	1	Yes	Final Effluent	Flow	0.0315	Monitor and Report	MGD	Average Monthly
04/01/2023	04/30/2023	05/22/2023	1	Yes	Final Effluent	Flow	0.0132	Monitor and Report	MGD	Average Monthly
05/01/2023	05/31/2023	06/26/2023	1	Yes	Final Effluent	Flow	0.0408	Monitor and Report	MGD	Average Monthly
06/01/2023	06/30/2023	07/27/2023	1	Yes	Final Effluent	Flow	0.0416	Monitor and Report	MGD	Average Monthly
07/01/2023	07/31/2023	08/28/2023	1	Yes	Final Effluent	Flow	0.0897	Monitor and Report	MGD	Average Monthly
08/01/2023	08/31/2023	09/28/2023	1	Yes	Final Effluent	Flow	0.1308	Monitor and Report	MGD	Average Monthly
09/01/2023	09/30/2023	10/25/2023	1	Yes	Final Effluent	Flow	0.1604	Monitor and Report	MGD	Average Monthly
10/01/2023	10/31/2023	11/28/2023	1	Yes	Final Effluent	Flow	0.126611	Monitor and Report	MGD	Average Monthly
11/01/2023	11/30/2023	12/13/2023	1	Yes	Final Effluent	Flow	0.1547	Monitor and Report	MGD	Average Monthly
12/01/2023	12/31/2023	01/25/2024	1	Yes	Final Effluent	Flow	0.0783	Monitor and Report	MGD	Average Monthly
01/01/2024	01/31/2024	02/27/2024	1	Yes	Final Effluent	Flow	0.088	Monitor and Report	MGD	Average Monthly
02/01/2024	02/29/2024	03/21/2024	1	Yes	Final Effluent	Flow	0.0488	Monitor and Report	MGD	Average Monthly
03/01/2024	03/31/2024	04/23/2024	1	Yes	Final Effluent	Flow	0.0525	Monitor and Report	MGD	Average Monthly
04/01/2024	04/30/2024	05/18/2024	1	Yes	Final Effluent	Flow	0.069453	Monitor and Report	MGD	Average Monthly
05/01/2024	05/31/2024	06/30/2024	1	Yes	Final Effluent	Flow	0.0524	Monitor and Report	MGD	Average Monthly
06/01/2024	06/30/2024	07/27/2024	1	Yes	Final Effluent	Flow	0.0744	Monitor and Report	MGD	Average Monthly
07/01/2024	07/31/2024	08/25/2024	1	Yes	Final Effluent	Flow	0.0419	Monitor and Report	MGD	Average Monthly
08/01/2024	08/31/2024	09/23/2024	1	Yes	Final Effluent	Flow	0.0616	Monitor and Report	MGD	Average Monthly
09/01/2024	09/30/2024	10/26/2024	1	Yes	Final Effluent	Flow	0.057	Monitor and Report	MGD	Average Monthly
10/01/2024	10/31/2024	11/16/2024	1	Yes	Final Effluent	Flow	0.0272	Monitor and Report	MGD	Average Monthly
11/01/2024	11/30/2024	12/24/2024	1	Yes	Final Effluent	Flow	0.0426	Monitor and Report	MGD	Average Monthly
12/01/2024	12/31/2024	01/21/2025	1	Yes	Final Effluent	Flow	0.0488	Monitor and Report	MGD	Average Monthly
01/01/2025	01/31/2025	02/22/2025	1	Yes	Final Effluent	Flow	0.0354	Monitor and Report	MGD	Average Monthly
02/01/2025	02/28/2025	03/25/2025	1	Yes	Final Effluent	Flow	0.0387	Monitor and Report	MGD	Average Monthly
03/01/2025	03/31/2025	04/22/2025	1	Yes	Final Effluent	Flow	0.7347	Monitor and Report	MGD	Average Monthly
04/01/2025	04/30/2025	05/27/2025	1	Yes	Final Effluent	Flow	0.047308	Monitor and Report	MGD	Average Monthly
05/01/2025	05/31/2025	06/24/2025	1	Yes	Final Effluent	Flow	0.087358	Monitor and Report	MGD	Average Monthly
06/01/2025	06/30/2025	07/22/2025	1	Yes	Final Effluent	Flow	0.023124	Monitor and Report	MGD	Average Monthly
07/01/2025	07/31/2025	08/26/2025	1	Yes	Final Effluent	Flow	0.083	Monitor and Report	MGD	Average Monthly
08/01/2025	08/31/2025	09/23/2025	1	Yes	Final Effluent	Flow	0.029362	Monitor and Report	MGD	Average Monthly
09/01/2025	09/30/2025	10/20/2025	1	Yes	Final Effluent	Flow	0.0452	Monitor and Report	MGD	Average Monthly
10/01/2025	10/31/2025	11/25/2025	1	Yes	Final Effluent	Flow	0.040182	Monitor and Report	MGD	Average Monthly
11/01/2025	11/30/2025	12/23/2025	1	Yes	Final Effluent	Flow	0.04621	Monitor and Report	MGD	Average Monthly
12/01/2025	12/31/2025	01/19/2026	1	Yes	Final Effluent	Flow	0.02754	Monitor and Report	MGD	Average Monthly
						Min	0.0132			
						Max	0.7347			
						Average	0.0773			

Monitoring Period Begin Date	Monitoring Period End Date	DMR Received Date	Outfall	Discharge	Monitoring Location	Parameter Name	DMR Value	Permit Limit	Units	Statistical Base Code
02/01/2021	02/28/2021	03/26/2021	101	Yes	Final Effluent	Flow	0.0503	Monitor and Report	MGD	Average Monthly
03/01/2021	03/31/2021	04/28/2021	101	Yes	Final Effluent	Flow	0.05239	Monitor and Report	MGD	Average Monthly
04/01/2021	04/30/2021	05/21/2021	101	Yes	Final Effluent	Flow	0.0445	Monitor and Report	MGD	Average Monthly
05/01/2021	05/31/2021	06/28/2021	101	Yes	Final Effluent	Flow	0.04897	Monitor and Report	MGD	Average Monthly
06/01/2021	06/30/2021	07/21/2021	101	Yes	Final Effluent	Flow	0.053091	Monitor and Report	MGD	Average Monthly
07/01/2021	07/31/2021	08/25/2021	101	Yes	Final Effluent	Flow	0.0488	Monitor and Report	MGD	Average Monthly
08/01/2021	08/31/2021	09/27/2021	101	Yes	Final Effluent	Flow	0.059024	Monitor and Report	MGD	Average Monthly
09/01/2021	09/30/2021	10/28/2021	101	Yes	Final Effluent	Flow	0.0566	Monitor and Report	MGD	Average Monthly
10/01/2021	10/31/2021	11/28/2021	101	Yes	Final Effluent	Flow	0.0487	Monitor and Report	MGD	Average Monthly
11/01/2021	11/30/2021	12/21/2021	101	Yes	Final Effluent	Flow	0.0491	Monitor and Report	MGD	Average Monthly
12/01/2021	12/31/2021	01/26/2022	101	Yes	Final Effluent	Flow	0.0582	Monitor and Report	MGD	Average Monthly
01/01/2022	01/31/2022	03/11/2022	101	Yes	Final Effluent	Flow	0.0546	Monitor and Report	MGD	Average Monthly
04/01/2022	04/30/2022	05/22/2022	101	Yes	Final Effluent	Flow	0.05	Monitor and Report	MGD	Average Monthly
05/01/2022	05/31/2022	06/23/2022	101	Yes	Final Effluent	Flow	0.0475	Monitor and Report	MGD	Average Monthly
06/01/2022	06/30/2022	07/21/2022	101	Yes	Final Effluent	Flow	0.0509	Monitor and Report	MGD	Average Monthly
07/01/2022	07/31/2022	08/28/2022	101	Yes	Final Effluent	Flow	0.0679421	Monitor and Report	MGD	Average Monthly
08/01/2022	08/31/2022	09/28/2022	101	Yes	Final Effluent	Flow	0.0581	Monitor and Report	MGD	Average Monthly
09/01/2022	09/30/2022	10/24/2022	101	Yes	Final Effluent	Flow	0.057965	Monitor and Report	MGD	Average Monthly
10/01/2022	10/31/2022	11/28/2022	101	Yes	Final Effluent	Flow	0.0485	Monitor and Report	MGD	Average Monthly
11/01/2022	11/30/2022	12/28/2022	101	Yes	Final Effluent	Flow	0.054397	Monitor and Report	MGD	Average Monthly
12/01/2022	12/31/2022	01/26/2023	101	Yes	Final Effluent	Flow	0.048674	Monitor and Report	MGD	Average Monthly
01/01/2023	01/31/2023	02/28/2023	101	Yes	Final Effluent	Flow	0.06796	Monitor and Report	MGD	Average Monthly
02/01/2023	02/28/2023	03/22/2023	101	Yes	Final Effluent	Flow	0.0683	Monitor and Report	MGD	Average Monthly
03/01/2023	03/31/2023	04/22/2023	101	Yes	Final Effluent	Flow	0.0683	Monitor and Report	MGD	Average Monthly
04/01/2023	04/30/2023	05/22/2023	101	Yes	Final Effluent	Flow	0.0698	Monitor and Report	MGD	Average Monthly
05/01/2023	05/31/2023	06/26/2023	101	Yes	Final Effluent	Flow	0.0702	Monitor and Report	MGD	Average Monthly
06/01/2023	06/30/2023	07/27/2023	101	Yes	Final Effluent	Flow	0.0509	Monitor and Report	MGD	Average Monthly
07/01/2023	07/31/2023	08/28/2023	101	Yes	Final Effluent	Flow	0.02658	Monitor and Report	MGD	Average Monthly
08/01/2023	08/31/2023	09/28/2023	101	Yes	Final Effluent	Flow	0.0353	Monitor and Report	MGD	Average Monthly
09/01/2023	09/30/2023	10/25/2023	101	Yes	Final Effluent	Flow	0.0474	Monitor and Report	MGD	Average Monthly
10/01/2023	10/31/2023	11/28/2023	101	Yes	Final Effluent	Flow	0.050169	Monitor and Report	MGD	Average Monthly
11/01/2023	11/30/2023	12/13/2023	101	Yes	Final Effluent	Flow	0.0522	Monitor and Report	MGD	Average Monthly
12/01/2023	12/31/2023	01/25/2024	101	Yes	Final Effluent	Flow	0.0451	Monitor and Report	MGD	Average Monthly
01/01/2024	01/31/2024	02/27/2024	101	Yes	Final Effluent	Flow	0.05	Monitor and Report	MGD	Average Monthly
02/01/2024	02/29/2024	03/21/2024	101	Yes	Final Effluent	Flow	0.0515	Monitor and Report	MGD	Average Monthly
03/01/2024	03/31/2024	04/23/2024	101	Yes	Final Effluent	Flow	0.0479	Monitor and Report	MGD	Average Monthly
04/01/2024	04/30/2024	05/18/2024	101	Yes	Final Effluent	Flow	0.056544	Monitor and Report	MGD	Average Monthly
05/01/2024	05/31/2024	06/30/2024	101	Yes	Final Effluent	Flow	0.046	Monitor and Report	MGD	Average Monthly
06/01/2024	06/30/2024	07/27/2024	101	Yes	Final Effluent	Flow	0.0485	Monitor and Report	MGD	Average Monthly
07/01/2024	07/31/2024	08/25/2024	101	Yes	Final Effluent	Flow	0.0551	Monitor and Report	MGD	Average Monthly
08/01/2024	08/31/2024	09/23/2024	101	Yes	Final Effluent	Flow	0.0553	Monitor and Report	MGD	Average Monthly
09/01/2024	09/30/2024	10/26/2024	101	Yes	Final Effluent	Flow	0.054	Monitor and Report	MGD	Average Monthly
10/01/2024	10/31/2024	11/16/2024	101	Yes	Final Effluent	Flow	0.0535	Monitor and Report	MGD	Average Monthly
11/01/2024	11/30/2024	12/24/2024	101	Yes	Final Effluent	Flow	0.0556	Monitor and Report	MGD	Average Monthly
12/01/2024	12/31/2024	01/21/2025	101	Yes	Final Effluent	Flow	0.0655	Monitor and Report	MGD	Average Monthly
01/01/2025	01/31/2025	02/22/2025	101	Yes	Final Effluent	Flow	0.058	Monitor and Report	MGD	Average Monthly
02/01/2025	02/28/2025	03/25/2025	101	Yes	Final Effluent	Flow	0.0593	Monitor and Report	MGD	Average Monthly
03/01/2025	03/31/2025	04/22/2025	101	Yes	Final Effluent	Flow	0.0587	Monitor and Report	MGD	Average Monthly
04/01/2025	04/30/2025	05/27/2025	101	Yes	Final Effluent	Flow	0.056247	Monitor and Report	MGD	Average Monthly
05/01/2025	05/31/2025	06/24/2025	101	Yes	Final Effluent	Flow	0.070789	Monitor and Report	MGD	Average Monthly
06/01/2025	06/30/2025	07/22/2025	101	Yes	Final Effluent	Flow	0.067906	Monitor and Report	MGD	Average Monthly
07/01/2025	07/31/2025	08/26/2025	101	Yes	Final Effluent	Flow	0.069266	Monitor and Report	MGD	Average Monthly
08/01/2025	08/31/2025	09/23/2025	101	Yes	Final Effluent	Flow	0.061973	Monitor and Report	MGD	Average Monthly
09/01/2025	09/30/2025	10/20/2025	101	Yes	Final Effluent	Flow	0.061695	Monitor and Report	MGD	Average Monthly
10/01/2025	10/31/2025	11/25/2025	101	Yes	Final Effluent	Flow	0.060526	Monitor and Report	MGD	Average Monthly
11/01/2025	11/30/2025	12/23/2025	101	Yes	Final Effluent	Flow	0.0641	Monitor and Report	MGD	Average Monthly
12/01/2025	12/31/2025	01/19/2026	101	Yes	Final Effluent	Flow	0.058676	Monitor and Report	MGD	Average Monthly
						Min	0.0266			
						Max	0.0708			
						Average	0.0552			

Attachment E- Correspondence

Hong, Nicholas

From: Leslie Loughner <LLoughner@gdfengineers.com>
Sent: Tuesday, February 10, 2026 2:59 PM
To: Hong, Nicholas
Cc: Mark Perry; Irina Hott; Maggie Weitzel
Subject: [External] NPDES permit Plane 9 PA0085120
Attachments: NPDES_Appl_PlaneNine_Page 3&4 Revised.pdf

ATTENTION: This email message is from an external sender. Do not open attachments or click links from unknown senders. To report suspicious email, use the [Report Phishing button in Outlook](#).

Good afternoon Nick,

Below are our responses to your email from today on behalf of AWA in regard to the Plane Nine NPDES Renewal.

1. Confirm the flow rate for Outfall 101. The current permit utilizes a flow rate of 0.24 MGD.

We confirmed that the design capacity is 0.24 MGD. The flow rate has been revised on Page 4 of the application form which is attached.

2. The NPDES renewal application includes an average flow of 0.720 MGD. DMR from 02/2021 to 12/2025 has an average flow rate of 0.0552 MGD.

The average flow rate has been revised using the past two (2) years of daily flow rates which is 0.0556 MGD. That number has been revised on page 3 of the application form which is attached.

3. Also confirm the hydraulic design flow rate for Outfall 101.

We confirmed that the correct design capacity is 0.24 MGD per Page 4, Supplemental Information section of the current permit.

Please let us know if you have any more questions.

Thank you,

Leslie A. Loughner, C.E.P - I.T. | Environmental Scientist
GWIN, DOBSON & FOREMAN, INC. | gdfengineers.com
(814) 943-5214 | 3121 Fairway Drive Altoona, PA 16602