

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0085197  
 APS ID 34061  
 Authorization ID 1316537

**Applicant and Facility Information**

Applicant Name	<u>Kampel Enterprises Inc.</u>	Facility Name	<u>Kampel Enterprises Airplane &amp; Metalwork</u>
Applicant Address	<u>8930 Carlisle Road</u> <u>Wellsville, PA 17365-9735</u>	Facility Address	<u>8930 Carlisle Road</u> <u>Wellsville, PA 17365-9735</u>
Applicant Contact	<u>Tom Kampel</u>	Facility Contact	<u>Tom Kampel</u>
Applicant Phone	<u>(717) 432-9688</u>	Facility Phone	<u>(717) 432-9688</u>
Client ID	<u>44613</u>	Site ID	<u>452390</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Warrington Township</u>
Connection Status		County	<u>York</u>
Date Application Received	<u>May 21, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 15, 2020</u>	If No, Reason	
Purpose of Application	<u>NPDES permit renewal.</u>		

**Summary of Review**

Kampel Enterprises, Inc. has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit for Kampel Enterprises wastewater treatment plant. This permit renewal application was received on May 21, 2020. The permit was last reissued on November 17, 2015, authorizing discharge of treated sewage from the existing treatment plant located in Warrington Township, York County into UNT North Branch Bermudian Creek. The permit was expired on November 30, 2020 but the terms and conditions of the permit have been extended since that time.

The WWTP has a design flow and hydraulic design capacity of 0.0025 MGD.

Sludge use and disposal description and location(s): N/A due to the liquid sludge is hauled by Walter's Environmental.

The WQM No. 6793414 was issued on 6/01/1994.

- Changes from the previous permit:

- o Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml.
- o The E. Coli. monitoring and report requirements will add to the proposed permit.
- o The summer Ammonia-Nitrogen average monthly changed from 5.0 mg/l to 2.36 mg/l (IMAX changed to 4.72 mg/l), and winter average monthly changed to 7.08 mg/l (IMAX changed to 14.16 mg/l).

Based on the review outlined in this report, it is recommended that the permit be drafted and published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	August 13, 2021
X		<i>Maria D. Bebenek for Daniel W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	August 27, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0025
Latitude	40° 2' 58.0"	Longitude	-75° 58' 31.0"
Quad Name	Wellsville	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary of North Branch Bermudian Creek (WWF)	Stream Code	08643
NHD Com ID	57467649	RMI	2.0 miles
Drainage Area	0.11 mi. <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.014
Q <sub>7-10</sub> Flow (cfs)	0.0015	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	568.56	Slope (ft/ft)	
Watershed No.	7-F	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Wrightsville Water Supply Co., York County		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	43.54 miles	Distance from Outfall (mi)	Approximate 51 miles

Changes Since Last Permit Issuance: none

**Drainage Area**

The discharge is to Trib. 08643 of North Branch Bermudian Creek at RMI 2.0 miles. A drainage area upstream of the discharge is estimated to be 0.11 mi.<sup>2</sup>, according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

**Stream Flow**

According to StreamStats, the point of first use has a Q<sub>7-10</sub> of 0.0015 cfs and a drainage area of 0.11 mi.<sup>2</sup>, which results in a Q<sub>7-10</sub> low flow yield of 0.014 cfs/mi<sup>2</sup>. This information is used to obtain a chronic or 30-day (Q<sub>30-10</sub>), and an acute or 1-day (Q<sub>1-10</sub>) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 0.0015 \text{ cfs} \\
 \text{Low Flow Yield} &= 0.0015 \text{ cfs} / 0.11 \text{ mi}^2 = 0.014 \text{ cfs/mi}^2 \\
 Q_{30-10} &= 1.36 * 0.0015 \text{ cfs} = 0.002 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.0015 \text{ cfs} = 0.00096 \text{ cfs}
 \end{aligned}$$

The resulting Q<sub>7-10</sub> dilution ratio is:  $Q_{\text{stream}} / Q_{\text{discharge}} = 0.0015 \text{ cfs} / [0.0025 \text{ MGD} * (1.547 \text{ cfs/MGD})] = 0.39:1$

**Trib. 08643 of North Branch Bermudian Creek**

25 Pa. Code § 93.9o classifies Trib. 08643 of North Branch Bermudian Creek as Warm Water Fishes (WWF) surface water. Based on the 2020 Integrated Report, Trib. 08643 of North Branch Bermudian Creek, assessment unit IDs 12028; & 18609, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

**Public Water Supply**

The nearest downstream public water supply intake is the Wrightsville Water Supply Co. on Susquehanna River in York County, approximately 51 miles downstream of this discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Kampel Enterprises				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6793414		6/01/1994		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Gas Chlorine	0.0025
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0025		Not Overloaded		

Changes Since Last Permit Issuance: none

The current treatment process is as follows:

Bar screen → EQ tank → Aeration tank → Clarifier → Chlorinator Disinfection → Chlorine Contact tank → Discharge.

The chemical uses such as calcium hypochlorite for disinfection, alum for coagulation & removal/lower TSS, and soda ash for pH adjustment.

Compliance History	
<b>Summary of DMRs:</b>	The DMRs reported from July 1, 2020 to June 30, 2021 are summarized in the Table below (Page # 4).
<b>Summary of Inspections:</b>	6/27/2019: Austen Randecker, DEP WQS, conducted a compliance evaluation inspection. The recommendations were to upgrade chlorine tablets for specific wastewater treatment and report sent electronically to Mr. Kern. Effluent was clear. There were no identified violations during inspection. The field test results were within permit limits.
<b>Other Comments:</b>	There are no open violations associated to the facility or the permittee.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from July 1, 2020 to June 30, 2021)

Parameter	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20
Flow (MGD) Average Monthly	0.0002 6	0.00047 43	0.00034 7	0.00155 7	0.00113 6	0.00065 6	0.00054 2	0.00030 4	0.00031 7	0.00025 9	0.00023 6	0.00044 3
Flow (MGD) Daily Maximum	0.0012 69	0.00137 5	0.00112	0.00970 5	0.00483 9	0.00399 4	0.01014 6	0.00298 1	0.00073 2	0.00123 5	0.00084 4	0.00137 8
pH (S.U.) Minimum	6.9	6.82	7.01	6.98	7.0	6.8	7.01	7.01	7.03	6.93	7.04	6.96
pH (S.U.) Maximum	7.5	7.31	7.63	7.75	7.4	8.1	7.56	8.61	8.35	8.56	7.35	7.5
DO (mg/L) Minimum	8.3	8.75	9.45	10.67	10.6	10.2	10.37	10.33	9.59	10.01	10.34	10.77
TRC (mg/L) Average Monthly	0.24	0.25	0.24	0.22	0.26	0.24	0.27	0.25	0.27	0.27	0.26	0.23
TRC (mg/L) Instantaneous Maximum	0.38	0.36	0.33	0.3	0.35	0.34	0.38	0.35	0.4	0.4	0.37	0.4
CBOD5 (mg/L) Average Monthly	< 2.7	< 5.1	2.5	< 2.3	< 2	< 2	< 2	< 2	< 2.1	< 1.4	< 6	< 2
CBOD5 (mg/L) Instantaneous Maximum	3.4	8.1	2.9	2.6	< 2	< 2	< 2	< 2	2.1	2.6	9	< 2
TSS (mg/L) Average Monthly	< 6	6	7	7	17	17	15	10	21	20	13	6
TSS (mg/L) Instantaneous Maximum	7	6	8	9	20	23	15	11	28	20	16	6
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 1	< 1	< 4	< 1	< 81	< 2	< 1	< 66	< 1	< 1	< 2
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 1	< 1	< 1	15	< 1	6500	4	< 1	4400	< 1	< 1	7
Total Nitrogen (mg/L) Average Quarterly	< 43.3			< 21.6			< 29.6			34.4		
Ammonia (mg/L) Average Monthly	< 0.1	0.191	< 0.207	< 0.1	< 0.123	< 0.1	< 0.1	< 0.129	< 0.1	< 0.184	< 0.21	< 0.187
Ammonia (mg/L) Instantaneous Maximum	< 0.1	0.2	0.313	< 0.1	0.146	< 0.1	< 0.1	0.157	< 0.1	0.268	0.21	0.273
Total Phosphorus (mg/L) Average Quarterly	3.2			2.8			3.4			3.7		

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.0025</u>
<b>Latitude</b> <u>40° 3' 0.87"</u>	<b>Longitude</b> <u>-75° 58' 31.0"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

**Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>):**

The attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing limits of 25.0 mg/L monthly average (AML), and 50.0 mg/L instantaneous maximum (IMAX) will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

**Ammonia (NH<sub>3</sub>-N):**

NH<sub>3</sub>-N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached WQM 7.0 computer model of the stream:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	20°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	25°C	(Default)
*	Background NH <sub>3</sub> -N	=	0 mg/L	(Default)

Regarding NH<sub>3</sub>-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 2.36 mg/L as a monthly average and 4.72 mg/L IMAX are necessary to protect the aquatic life from toxicity effects at the point of discharge. These values are more stringent than the existing limits, and will be in the proposed permit, which were based on secondary treatment standards. The winter effluent limit will be set at three-times the summer limits. The Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

**Dissolved Oxygen (D.O.):**

A minimum D.O. of 6.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BPNPSM-PMT-033 and has been applied to other point source dischargers throughout the state.

**pH:**

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

**Fecal Coliform:**

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

**E. Coli:**

As recommended by DEP's SOP no. BPNPSM-PMT-033, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa Code §92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 2/month will be included in the permit to be consistent with the recommendation from this SOP.

**Total Residual Chlorine (TRC):**

DEP's guidance (391-2000-014) generally recommends evaluating WQBELs at the point of first surface water use (POFU) for dry stream dischargers. In early 1990s, a DEP biologist conducted a stream survey and determined that the POFU is approximately 6,000 ft. downstream of the actual point of discharge. At this point, the USGS StreamStats produced a Q7-10 of 0.0084 cfs and a drainage area of 0.38 sq. mi. Using this information, output from TRC-CALC shows average monthly limit of 0.326 mg/L and IMAX limit of 1.07 mg/L which are slightly more stringent and round off will be same as the existing limits as 0.33 mg/L average monthly and 1.1 mg/L IMAX. Therefore, the existing permit limits and monitoring frequency of 1/day will remain in the proposed permit, which is consistent with table 6-3 of Permit Writers Manual.

**Total Suspended Solids (TSS):**

The existing technology-based limits of 30.0 mg/L average monthly, and 60.0 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

**Chesapeake Bay TMDL:**

The facility is categorized as a Phase 5 facility, a facility with a design flow greater than 0.002 MGD and less than 0.2 GMD. DEP's Phase II Watershed Implementation Plan (WIP) recommends monitoring of Total Nitrogen (TN) and Total Phosphorus (TP) for these Phase 5 facilities at a frequency no less than annually. DEP's SOP also recommends monitoring of TN and TP for any sewage facilities. However, the existing quarterly monitoring of TN and TP will remain in the proposed permit.

**Stormwater**

There is no known stormwater outfall associated with this facility.

**Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

**303(d) Listed Streams:**

This discharge is not located on a 303(d) listed stream segment.

**Additional Considerations**

Considering the nature and quantity of discharge, this private well is unlikely impacted by the discharge. Part C, item F - *"The attention of the permittee is directed to the fact that effluent is discharged to a location with little or no assimilative capacity or dilution during critical periods. If the effluent creates a health hazard or nuisance, the permittee shall, upon notice from DEP, provide such additional treatment as may be required by DEP."* will remain in the proposed permit.

**WQM 7.0**

Node 1: Point of first use on Trib. 08643 of North Branch Bermudian Creek (08643)  
 Elevation: 568.56 ft (USGS National Map Viewer)  
 Drainage Area: 0.11 mi<sup>2</sup> (USGS PA StreamStats)  
 River Mile Index: 2.0 (PA DEP eMapPA)  
 Low Flow Yield: 0.014 cfs/mi<sup>2</sup>  
 Discharge Flow: 0.0025 MGD

Node 2: Just before confluence of Trib. 08641 to North Branch Bermudian Creek  
 Elevation: 445.19 ft (USGS National Map Viewer)  
 Drainage Area: 0.58 mi<sup>2</sup> (USGS PA StreamStats)  
 River Mile Index: 0.001 (PA DEP eMapPA)  
 Low Flow Yield: 0.014 cfs/mi<sup>2</sup>  
 Discharge Flow: 0.000 MGD

The screenshot displays the USGS StreamStats web application interface. On the left is a navigation sidebar with options like 'SELECT A STATE / REGION' (Pennsylvania), 'IDENTIFY A STUDY AREA' (Basin Delineated), and 'BUILD A REPORT'. The main content area is divided into several sections:

- Basin Characteristics:** A table listing parameters such as DRNAREA (0.11 square miles), BSLOPD (2.4455 degrees), ROCKDEP (4.2 feet), and URBAN (0.3283 percent).
- Low-Flow Statistics Parameters [Low Flow Region 1]:** A table showing values for parameters like Drainage Area (0.11), Mean Basin Slope (2.4455), Depth to Rock (4.2), and Percent Urban (0.3283), along with their respective min and max limits.
- Low-Flow Statistics Disclaimers [Low Flow Region 1]:** A yellow warning box stating: "One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors".
- Low-Flow Statistics Flow Report [Low Flow Region 1]:** A table listing flow statistics such as 7 Day 2 Year Low Flow (0.00557 ft<sup>3</sup>/s) and 90 Day 10 Year Low Flow (0.00683 ft<sup>3</sup>/s).
- Map View:** On the right, a map shows the stream network with a blue line indicating the study area. A 'Layers' panel is visible, showing options for Base Maps, Application Layers, National Layers, and PA Map Layers.

**NPDES Permit Fact Sheet**  
**Kampel Enterprises Airplane & Metalwork**

**NPDES Permit No. PA0085197**

USGS StreamStats

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Continue

POWERED BY WIM

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.58	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	2.9927	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.2	feet	4.13	5.21
URBAN	Percent Urban	0.1745	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0382	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.06	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.0118	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.0201	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.0443	ft <sup>3</sup> /s

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

USGS StreamStats

SELECT A STATE / REGION

Pennsylvania

IDENTIFY A STUDY AREA

Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Continue

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notice

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.38	square miles
BSLOPD	Mean basin slope measured in degrees	3.1715	degrees
ROCKDEP	Depth to rock	4.2	feet
URBAN	Percentage of basin with urban development	0.2662	percent

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.38	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	3.1715	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.2	feet	4.13	5.21
URBAN	Percent Urban	0.2662	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0269	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.0418	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.00835	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.0141	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.0304	ft <sup>3</sup> /s

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers



**TRC EVALUATION**

Input appropriate values in A3:A9 and D3:D9

0.0084	= Q stream (cfs)	0.5	= CV Daily
0.0025	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.712	1.3.2.iii	WLA_cfc = 0.686
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.265	5.1d	LTA_cfc = 0.399

Source	Effluent Limit Calculations
PENTOXSD TRG 5.1f	AML MULT = 1.231
PENTOXSD TRG 5.1g	AVG MON LIMIT (mg/l) = 0.326 INST MAX LIMIT (mg/l) = 1.068

WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$
LTA_afc	wla_afc * LTAMULT_afc
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$
LTA_cfc	wla_cfc * LTAMULT_cfc
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$
AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)
INST_MAX_LIMIT	$1.5 \cdot ((av\_mon\_limit / AML\_MULT) / LTAMULT\_afc)$

Analysis Results WQM 7.0

Hydrodynamics | NH3-N Allocations | D.O. Allocations | D.O. Simulation | **Effluent Limitations**

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
2.00	Kampel Enterp	PA0085197	0.0025

  

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	2.36	4.72	
Dissolved Oxygen			6

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

rptEffLimits

### WQM 7.0 Effluent Limits

WQI	Parameter	Units	Limit	Notes
330	Kampel Efflu. p.	Flow Rate (mgd)	20	
		Parameter	534	4.75
		Disolved Oxygen		6

Wednesday, August 11, 2021

Version 1.1

Page 1 of 1

Page: 1

No Filter

rpt\_WLA

### WQM 7.0 Wasteload Allocation

WQI	Discharge Name	Flow Rate (mgd)	5-Day BOD (mg/L)	5-Day BOD (mgd)	5-Day BOD (mgd)	5-Day BOD (mgd)	5-Day BOD (mgd)	5-Day BOD (mgd)	5-Day BOD (mgd)
<b>5-Day BOD Allocations</b>									
330	Kampel Efflu. p.	20	1.0	20	20	0	0	0	0
<b>Chronic Allocations</b>									
330	Kampel Efflu. p.	20	2.0	40	40	0	0	0	0
<b>Disolved Oxygen Allocations</b>									
330	Kampel Efflu. p.	20	20	400	400	0	0	0	0

Wednesday, August 11, 2021

Version 1.1

Page 1 of 1

Page: 1

No Filter



rptGeneral
— □ ×

**Input Data WQMT 3**

SSP Bios	Stream Code	Station Name	RSE	Structure	Outgoing Line	Major (SQ)	MSD WQMT Type	Apply PC
07F	WQ	765 28623 of 76 Street, Reynolds Co	8.88.1	455.18	0.38	0.0000.0	0.00	<input checked="" type="checkbox"/>

View in Data

Design Code	LPT Flow (MGD)	TSS Flow (MGD)	BOD5 Flow (MGD)	NH3 Flow (MGD)	NO3 Flow (MGD)	NH4 Flow (MGD)	NO2 Flow (MGD)	Temperature		pH	
								Temp (°C)	Temp (°F)	pH	pH
07F-W	0.04	0.00	0.00.0	0.00	0.0	0.00	0.00	20.0.0	7.00	0.00	0.0
07F-W	0.00	0.00	0.00.0	0.00							
02S-W	0.00	0.00	0.00.0	0.00							

**Wind Energy Data**

Name	Wind Number	Sailing		Power Grid		Design Power (mgd)	Dis Temp (°C)	Dis pH
		Dis Flow (mgd)	Dis Temp (°C)	Dis Flow (mgd)	Dis Temp (°C)			
Winged Entry	WQ 28623.07	0.000	0.000	0.000	0.00.0	2.000	7.00	

**Parameter Data**

Parameter Name	Dis Flow (mgd)	TSS Flow (mgd)	BOD5 Flow (mgd)	NH3 Flow (mgd)	NO3 Flow (mgd)	NH4 Flow (mgd)	NO2 Flow (mgd)
Dissolved Oxygen	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NODM	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Wednesday, August 11, 2021
Version 1.1
Page 2 of 2

Page: 14 ◀ 2 ▶ ▶ ▶ No Filter

**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	6.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.33	XXX	1.1	1/day	Grab
CBOD <sub>5</sub>	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	, Geo Mean	XXX	10,000	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5.0	XXX	10.0	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15.0	XXX	30.0	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab

<b>Proposed Effluent Limitations and Monitoring Requirements</b>
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	6.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.33	XXX	1.1	1/day	Grab
CBOD <sub>5</sub>	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.36	XXX	4.72	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	7.08	XXX	14.16	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]