

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0085332
APS ID 1082589
Authorization ID 1429635

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|--|
| Applicant Name | <u>Delta Borough Municipal Authority</u> | Facility Name | <u>Delta Borough WWTP</u> |
| Applicant Address | <u>PO Box 278 101 College Avenue</u> <u>Delta, PA 17314-0278</u> | Facility Address | <u>208 Bunker Hill Avenue</u> <u>Delta, PA 17314-8936</u> |
| Applicant Contact | <u>Greg Moul</u> | Facility Contact | <u>Greg Moul</u> |
| Applicant Phone | <u>(717) 810-8063</u> | Facility Phone | <u>(717) 456-6248</u> |
| Client ID | <u>375800</u> | Site ID | <u>451701</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Delta Borough</u> |
| Connection Status | <u>No Limitations</u> | County | <u>York</u> |
| Date Application Received | <u>February 27, 2023</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>April 12, 2023</u> | If No, Reason | <u></u> |
| Purpose of Application | <u>Renewal of Existing NPDES Permit</u> | | |

Summary of Review

The Delta Borough Municipal Authority (DBMA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of a NPDES permit for the Delta Borough STP. The permit was last reissued on August 16, 2018. The permit expired on August 31, 2023 but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days. A file review of documents associated with the discharge or permittee may be available at the PA DEP southcentral regional office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file reviews, contact the SCRO file review coordinator at 717.705.4700.

Sludge use and disposal description and location(s): Sod Run WWTP (Perryman, Maryland).

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|---|--------------|
| x | | Aaron Baar Aaron Baar / Project Manager | May 16, 2024 |
| x | | Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager | May 22, 2024 |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|--|------------------------------|----------------------------|
| Outfall No. | 001 | Design Flow (MGD) | .48 |
| Latitude | 39° 43' 37.70" | Longitude | -76° 19' 49.88" |
| Quad Name | Delta | Quad Code | 2135 |
| Wastewater Description: Sewage Effluent | | | |
| Receiving Waters | Scott Creek (CWF (existing use)) | Stream Code | 07280 |
| NHD Com ID | 57474373 | RMI | 2.93 |
| Drainage Area | 1.36 mi ² | Yield (cfs/mi ²) | 0.1985 |
| Q ₇₋₁₀ Flow (cfs) | 0.27 | Q ₇₋₁₀ Basis | USGS StreamStats |
| Elevation (ft) | 251.99 | Slope (ft/ft) | |
| Watershed No. | 7-I | Chapter 93 Class. | TSF |
| Existing Use | CWF(COLD WATER FISHES) | Existing Use Qualifier | Use Attainability Analysis |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | FLOW REGIME MODIFICATION, NUTRIENTS, SILTATION | | |
| Source(s) of Impairment | MUNICIPAL POINT SOURCE DISCHARGES, URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS | | |
| TMDL Status | Name | | |
| Nearest Downstream Public Water Supply Intake | Chester Water Authority | | |
| PWS Waters | Susquehanna River | Flow at Intake (cfs) | |
| | 1.42 (from the PA-MD border) | | |
| PWS RMI | | Distance from Outfall (mi) | 14.0 |

Drainage Area

The discharge is to Scott Creek at RMI 2.93. A drainage area upstream of the discharge is determined to be 1.36 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, the watershed has a Q₇₋₁₀ of 0.27 cfs. This information was used to obtain a LFY, a chronic 30-day (Q₃₀₋₁₀) and acute (Q₁₋₁₀) exposure stream flows for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned}
 Q_{7-10} &= 0.27 \text{ cfs} \\
 Q_{30-10} &= 1.36 * 0.27 \text{ cfs} = 0.3672 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.27 \text{ cfs} = 0.1728 \text{ cfs} \\
 LFY &= 0.27 \text{ cfs}/1.36 \text{ mi}^2 = 0.1985 \text{ cfs/mi}^2
 \end{aligned}$$

Scott Creek

25 Pa Code §93.9 classifies the receiving water, Scott Creek, with a CWF/TSF Existing Use designation. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed as not attaining use; the cause of the impairment has been identified as urban runoff (see *Local Watershed TMDL* below).

Local Watershed Total Maximum Daily Loads (TMDLs)

According to PA's 2024 integrated water quality monitoring and assessment report, Scott Creek in the vicinity of the proposed point of discharge is impaired for aquatic life due to flow regime modification, siltation and nutrients from urban runoff. The aquatic life impairment due to flow regime modification from urban runoff is listed as Category 4c in the 2024 integrated report, indicating that the waters are impaired for one or more uses not needing a TMDL because the impairment is not caused by a pollutant. The aquatic life impairments due to siltation and nutrients from

urban runoff are listed as Category 5 in the 2024 integrated report, indicating that the waters are impaired for one or more uses by a pollutant that requires the development of a TMDL. No TMDL has been developed for Scott Creek to date, so no local watershed TMDL has been taken into consideration during this review.

Public Water Supply Intake

The nearest downstream public water supply intake is Chester Water Authority, located on Susquehanna River, approximately 14 miles from the discharge point. Considering the dilution and distance from the intake, the discharge is not expected to significantly affect the water supply.

Class A Wild Trout Streams

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

DEP has evaluated information indicating that the existing use of the receiving waters is different than the designated use under 25 Pa. Code § 93.9. In developing the draft NPDES permit, DEP is proposing to protect the existing use of the receiving waters. Following DEP's notice of the receipt of the application and the draft permit in the Pennsylvania Bulletin, DEP will accept written comments during the public comment period regarding DEP's tentative determination to protect the existing use. DEP will make a final determination on existing use protection for the receiving waters as part of the final permit action.

| Treatment Facility Summary | | | | |
|--|-----------------------------------|--------------------------------------|----------------------------|-------------------------------|
| Treatment Facility Name: Delta Borough WWTP | | | | |
| WQM Permit No. | Issuance Date | | | |
| 6705401 | 08/22/2005 | | | |
| 6705408 | 03/25/2008 | | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Tertiary | Activated Sludge With Solids Removal | Hypochlorite | 0.24 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.24 MGD (See Comments Below) | 480 interim; 960 final | Not Overloaded | Sludge Holding | Land Applied |

The facility serves Peach Bottom Township and Delta Borough, as well as flows from Hartford County in Maryland. The 0.24 MGD facility currently has four (4) treatment trains, consisting of the following treatment units: Comminutor/Flow Distribution Box → Flow Equalization Tanks (2) → Aeration Tanks (4) → Clarifiers (4) → Sludge Holding Tanks (2) → Chlorine Contact Tank w/dechlorination → Outfall to Scott Creek.

Per the 2018 renewal Fact Sheet, the construction of the original plant was completed in 1998 and was considered a Phase I project. The Phase II project was proposed in 2008 to expand the facility to treat additional 0.24 MGD flows (a total of 0.48 MGD) from about 800 homes that were expected to be built in PA. The Water Quality Management Permit no. 6705408 was issued in 2008 for this expansion project. The project consisted of converting flow equalization tanks to anoxic tanks, installing an automatic bar screen, equalization tank, flow splitter tank, sand filters, and UV system, and removal of chlorination/dechlorination. Due to the 2008 housing industry collapse, the project fell through and this Phase II project has never been materialized. Consequently, both average annual design flow and hydraulic design capacity remained as 0.24 MGD.

The facility currently uses sodium hypochlorite for disinfection, sodium bisulfite for dechlorination, soda ash and polymer as coagulants, and MasterMet/MasterCat copper removal.

There are currently no industrial/commercial users contributing industrial wastes to the facility.

| Compliance History | |
|--------------------------------|---|
| Summary of DMRs: | DMR results for the past year are presented below. |
| Summary of Inspections: | <p>Since the last renewal of the facility's NPDES permit, the following inspections have been logged:</p> <p>November 6, 2019: A routine CEI was conducted by Austen Randecker. No violations were noted. Recommendations were made regarding sludge hauling record keeping, installing a secondary thermometer in the influent and effluent composite samplers, and replacing expired reagents.</p> <p>June 9, 2020: An administrative inspection was conducted via phone by Austen Randecker. No violations were noted.</p> |

Other Comments: As of May 16, 2024, there are no open violations associated with this facility.

Existing Effluent Limitations and Monitoring Requirements

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|---------------------|-----------------------|--------------------|-------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Daily Min | XXX | 9.0 Daily Max | XXX | 1/day | Grab |
| DO | XXX | XXX | 5.0 Daily Min | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.061 | XXX | 0.199 | 1/day | Grab |
| CBOD5 | 50 | 80 | XXX | 25.0 | 40.0 | 50 | 1/week | 8-Hr Composite |
| BOD5 Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| TSS | 60 | 90 | XXX | 30.0 | 45.0 | 60 | 1/week | 8-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 1/week | Grab |
| Nitrate-Nitrite | XXX | XXX | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| Nitrate-Nitrite (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 1/month | Calculation |
| Total Nitrogen (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Ammonia Nov 1 - Apr 30 | 12.0 | XXX | XXX | 6.0 | XXX | 12 | 1/week | 8-Hr Composite |
| Ammonia May 1 - Oct 31 | 4.0 | XXX | XXX | 2.0 | XXX | 4 | 1/week | 8-Hr Composite |
| Ammonia (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------|-------------------------------------|--------------------|-----------------------|--------------------|--------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| TKN | XXX | XXX | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| TKN (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | 4.0 | XXX | XXX | 2.0 | XXX | 4 | 1/week | 8-Hr Composite |
| Total Phosphorus (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Copper | 0.024 | 0.038 Daily Max | XXX | 0.012 | 0.019 Daily Max | XXX | 2/month | 24-Hr Composite |
| Total Zinc | 0.208 | 0.298 Daily Max | XXX | 0.104 | 0.149 Daily Max | XXX | 2/month | 24-Hr Composite |

Compliance History

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

| Parameter | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 | OCT-23 | SEP-23 | AUG-23 | JUL-23 | JUN-23 | MAY-23 | APR-23 |
|---|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Flow (MGD) Average Monthly | 0.0912 | 0.0929 | 0.0958 | 0.0806 | 0.0698 | 0.075 | 0.0782 | 0.0808 | 0.0819 | 0.0797 | 0.07361 | 0.0797 |
| Flow (MGD) Daily Maximum | 0.1217 | 0.1305 | 0.1863 | 0.152 | 0.1405 | 0.1258 | 0.1351 | 0.1166 | 0.1245 | 0.1353 | 0.0953 | 0.1349 |
| pH (S.U.) Daily Minimum | 6.92 | 7.01 | 6.91 | 7.02 | 7.02 | 6.76 | 7.26 | 7.19 | 7.27 | 7.03 | 7.19 | 7.08 |
| pH (S.U.) Daily Maximum | 7.5 | 7.47 | 7.73 | 7.54 | 7.6 | 7.68 | 7.91 | 7.83 | 7.75 | 7.71 | 7.88 | 7.66 |
| DO (mg/L) Daily Minimum | 7.95 | 8.69 | 8.45 | 6.7 | 6.94 | 8.51 | 8.51 | 8.52 | 8.1 | 7.84 | 8.38 | 8.12 |
| TRC (mg/L) Average Monthly | < 0.020 | < 0.010 | < 0.010 | < 0.020 | < 0.018 | < 0.010 | < 0.010 | < 0.010 | < 0.010 | < 0.010 | < 0.010 | < 0.020 |
| TRC (mg/L) Instantaneous Maximum | 0.050 | 0.040 | 0.030 | 0.050 | 0.050 | 0.030 | 0.030 | 0.030 | 0.030 | 0.040 | 0.020 | 0.040 |
| CBOD5 (lbs/day) Average Monthly | 3.0 | 3 | 6 | < 2 | < 2 | < 2 | < 2 | < 1 | < 1 | < 1 | < 1 | 2 |
| CBOD5 (lbs/day) Weekly Average | 4.0 | 4 | 9 | 3 | 4 | 3 | < 2 | < 2 | < 2 | < 2 | 2 | 3 |
| CBOD5 (mg/L) Average Monthly | 3.7 | 3.8 | 6.9 | < 2.9 | < 3.2 | < 3.5 | < 2.4 | < 2.4 | < 2.4 | < 2.4 | < 2.3 | 3.2 |
| CBOD5 (mg/L) Weekly Average | 5.0 | 4.0 | 9.0 | 4.0 | 6.0 | 7.0 | < 2.0 | < 2.0 | < 2.0 | < 2.0 | 2.0 | 5.0 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 203 | 183 | 218 | 121 | 129 | 59 | 88 | 64 | 62 | 78 | 147 | 132 |
| BOD5 (lbs/day) Raw Sewage Influent Daily Maximum | 353 | 299 | 407 | 156 | 178 | 71 | 129 | 78 | 69 | 116 | 167 | 146 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 276 | 229 | 262 | 220 | 215 | 106 | 135 | 103 | 101 | 127 | 251 | 245 |
| TSS (lbs/day) Average Monthly | 6.0 | 3 | 3 | 2 | 2 | 4 | 2 | 2 | 1.0 | 4.0 | < 3 | 2 |

**NPDES Permit Fact Sheet
Delta Borough WWTP**

NPDES Permit No. PA0085332

| | | | | | | | | | | | | |
|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 169 | 153 | 197 | 129 | 164 | 57 | 89 | 68 | 62 | 93 | 163 | 154 |
| TSS (lbs/day) Raw Sewage Influent Daily Maximum | 303 | 275 | 352 | 169 | 212 | 75 | 173 | 88 | 69 | 126 | 195 | 171 |
| TSS (lbs/day) Weekly Average | 11.0 | 4 | 5 | 3 | 3 | 11 | 4 | 3 | 2.0 | 7.0 | 4 | 3 |
| TSS (mg/L) Average Monthly | 8.5 | 3.8 | 4.3 | 3.0 | 2.6 | 9.3 | 3.0 | 2.6 | 2.0 | 7.3 | < 4.8 | 4.3 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 230 | 193 | 247 | 242 | 270 | 97 | 136 | 109 | 100 | 153 | 277 | 284 |
| TSS (mg/L) Weekly Average | 17.0 | 5.0 | 7.0 | 6.0 | 5.0 | 27.0 | 5.0 | 4.0 | 3.0 | 13.0 | 6.0 | 5.0 |
| Fecal Coliform (No./100 ml) Geometric Mean | < 3 | 2 | 6 | < 4 | < 2 | < 17 | < 3 | < 4 | 23 | 10 | 9 | < 2 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 5 | 10 | 147 | 10 | 8 | 80 | 30 | 32 | 32 | 61 | 74 | 6 |
| Nitrate-Nitrite (mg/L) Average Monthly | 44 | 36 | 31.17 | 40 | 48 | 46.44 | 48 | 50 | 49 | 47 | < 36.4 | < 35.6 |
| Nitrate-Nitrite (lbs) Total Monthly | 991 | 809 | 739 | 724 | 879 | 838 | 930 | 968 | 926 | 869 | < 653 | < 601 |
| Total Nitrogen (mg/L) Average Monthly | 44 | 36 | 31.17 | 40 | 48 | 48.31 | 48 | 50 | 49 | 47 | < 36.8 | 36.26 |
| Total Nitrogen (lbs) Total Monthly | 991 | 809 | 739 | 724 | 879 | 861 | 930 | 968 | 926 | 869 | < 661 | 611 |
| Total Nitrogen (lbs) Total Annual | | | | | | | < 9941 | | | | | |
| Ammonia (lbs/day) Average Monthly | < 0.08 | < 0.08 | < 0.2 | < 0.06 | < 0.06 | < 0.6 | < 0.07 | < 0.07 | < 0.06 | < 0.06 | < 0.07 | < 0.05 |
| Ammonia (mg/L) Average Monthly | < 0.11 | < 0.1 | < 0.28 | < 0.1 | < 0.1 | < 1.5 | < 0.1 | < 0.12 | < 0.1 | < 0.1 | < 0.12 | < 0.1 |
| Ammonia (lbs) Total Monthly | < 2.4 | < 2.3 | < 7.7 | < 1.9 | < 1.8 | < 18.2 | < 2.0 | < 2.3 | < 1.9 | < 1.8 | < 2.2 | < 1.6 |
| Ammonia (lbs) Total Annual | | | | | | | < 24 | | | | | |
| TKN (mg/L) Average Monthly | < 0.5 | < 0.5 | < 0.4 | < 0.5 | < 0.5 | < 2.3 | < 0.5 | < 0.5 | < 0.5 | < 0.5 | < 1 | < 1.3 |

**NPDES Permit Fact Sheet
Delta Borough WWTP**

NPDES Permit No. PA0085332

| | | | | | | | | | | | | |
|--|-------|---------|---------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| TKN (lbs) Total Monthly | < 11 | < 11 | < 13 | < 9 | < 9 | < 30 | < 9 | < 10 | < 10 | < 9 | < 19 | < 21 |
| Total Phosphorus (lbs/day) Average Monthly | 1.3 | 1.2 | 0.8 | 0.3 | 0.2 | 0.2 | 0.4 | 0.2 | 0.2 | 0.5 | 0.5 | 0.5 |
| Total Phosphorus (mg/L) Average Monthly | 1.8 | 1.5 | 0.95 | 0.54 | 0.39 | 0.48 | 0.64 | 0.39 | 0.39 | 0.79 | 0.82 | 0.94 |
| Total Phosphorus (lbs) Total Monthly | 39.2 | 33.8 | 25.4 | 10 | 7.0 | 7.4 | 12.5 | 7.6 | 7.3 | 14.4 | 15.4 | 15.4 |
| Total Phosphorus (lbs) Total Annual | | | | | | | < 173 | | | | | |
| Total Copper (lbs/day) Average Monthly | 0.007 | < 0.005 | < 0.004 | 0.003 | 0.004 | 0.003 | 0.005 | 0.004 | 0.004 | 0.005 | 0.004 | 0.004 |
| Total Copper (lbs/day) Daily Maximum | 0.008 | 0.007 | < 0.005 | 0.003 | 0.004 | 0.004 | 0.005 | 0.004 | 0.004 | 0.005 | 0.005 | 0.004 |
| Total Copper (mg/L) Average Monthly | 0.009 | < 0.006 | < 0.005 | 0.006 | 0.006 | 0.007 | 0.007 | 0.007 | 0.007 | 0.008 | 0.007 | 0.007 |
| Total Copper (mg/L) Daily Maximum | 0.010 | 0.007 | < 0.005 | 0.006 | 0.007 | 0.007 | 0.008 | 0.007 | 0.007 | 0.008 | 0.008 | 0.007 |
| Total Zinc (lbs/day) Average Monthly | 0.020 | 0.020 | 0.020 | 0.010 | 0.008 | 0.009 | 0.008 | 0.008 | 0.010 | 0.010 | 0.010 | 0.010 |
| Total Zinc (lbs/day) Daily Maximum | 0.020 | 0.030 | 0.030 | 0.010 | 0.009 | 0.010 | 0.009 | 0.008 | 0.010 | 0.010 | 0.010 | 0.020 |
| Total Zinc (mg/L) Average Monthly | 0.030 | 0.030 | 0.030 | 0.020 | 0.010 | 0.020 | 0.010 | 0.010 | 0.020 | 0.020 | 0.020 | 0.030 |
| Total Zinc (mg/L) Daily Maximum | 0.032 | 0.029 | 0.029 | 0.023 | 0.015 | 0.020 | 0.014 | 0.013 | 0.021 | 0.023 | 0.023 | 0.027 |

Development of Effluent Limitations

| | |
|---|---|
| Outfall No. <u>001</u> | Design Flow (MGD) <u>.48</u> |
| Latitude <u>39° 43' 37.86"</u> | Longitude <u>-76° 19' 51.00"</u> |
| Wastewater Description: <u>Sewage Effluent</u> | |

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

Water Quality-Based Limitations

CBOD₅, NH₃-N and Dissolved Oxygen (DO)

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD₅, NH₃-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. The model was utilized using data derived by USGS StreamStats and the model output indicated that existing WQBELs for ammonia and CBOD₅ are still protective of water quality

The model also determined that the facility's existing DO limits of 5 mg/L are still protective of water quality.

Total Dissolved Solids (TDS)

The requirement to monitor TDS and its constituents is not needed given that the maximum concentration of TDS reported in the application is less than 1,000 mg/L.

Toxics

A reasonable potential (RP) analysis was done for Copper, Lead and Zinc using the sampling results provided with the application. The Department's Toxics Management Spreadsheet (Version 1.3) was used to perform the RP analysis for these parameters at a pH of 7.0 and a discharge hardness of 100 mg/L. The analysis indicates that limits for Total Copper are needed to be protective of water quality

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: **4**

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|--------------|---------------|---------------|----------------------|------|------|-------|-----------------|-------------|---------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Copper | 0.028 | 39.9 | 0.014 | 19.9 | 19.9 | mg/L | 0.014 | AFC | Discharge Conc ≥ 50% WQBEL (RP) |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|------------|-----------------|-------|----------------------------|
| Total Lead | 5.5 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Zinc | 157 | µg/L | Discharge Conc ≤ 10% WQBEL |
| | | | |
| | | | |

However, the reviewer notes that TMS V1.3 is not configured to perform a statistical analysis on bimonthly samples, so modeling could only be performed with the assumption that sampling was occurring weekly. It is unknown how the sampling frequency is influencing the model output. Therefore, the Department proposes to continue the existing limits for Total Copper while increasing the sampling frequency to 1/week to allow for the future analysis of the need for effluent limits. This action is in conformity with DEP’s Technical Guidance for the Development and Specification of Effluent Limitations (PA Doc. No. 362-0400-001), Table 6-3 (plant design flow = 0.24 mgd, *Toxics*).

Similar to Total Copper, the need for more data to determine if limits are needed for Total Zinc exists. However, coding limits in WMS prevent the continuation of the existing average monthly limit of 0.104 mg/L of Total Zinc. The current minimum limit allowed is 0.12 mg/L of Total Zinc, a value consistent with the WQ OBJ value coded into TMS V1.3. Given that currently modelling suggests that no monitoring is needed for Total Zinc (based on bimonthly testing), a relaxation of the average monthly effluent limit from 0.104 mg/L to 0.12 mg/L is a reasonable change that is still protective of water quality while additional data is collected during the upcoming permit cycle. The Department proposes to also increase the sampling frequency of Total Zinc to 1/week to allow for the future analysis of the need for effluent limits. This action is in conformity with DEP’s Technical Guidance for the Development and Specification of Effluent Limitations (PA Doc. No. 362-0400-001), Table 6-3 (plant design flow = 0.24 mgd, *Toxics*).

No new monitoring requirements for Total Lead are proposed in this permit.

E. Coli Monitoring

In conformity with the Department’s *Establishing Effluent Limitations for Individual Sewage Permits* (SOP No. BCW-PMT-033) and as authorized by § 92a.61 of the PA Code, quarterly E. Coli monitoring has been proposed in this permit. The collection method will be via grab sample.

Best Professional Judgment (BPJ) Limitations

Dissolved Oxygen

A minimum of 5.0 mg/L for DO is an existing effluent limit and will remain unchanged in the draft permit as recommended by DEP’s SOP. This requirement has also been assigned to other sewage facilities in the region. 5.0 mg/L is taken directly from 25 Pa. Code § 93.7(a) and it is also determined to be appropriate according to water quality modeling.

Total Residual Chlorine (TRC)

Chlorine is currently used for disinfection and the current NPDES permit contains water quality based effluent limits for TRC. It is necessary to utilize DEP’s TRC_CALC excel worksheet to determine appropriate permit requirements for the upcoming permit term. The worksheet indicated that existing limits of 0.061 mg/L (average monthly) and 0.199 mg/L (instantaneous maximum) are still protective of water quality.

Total Phosphorus & Total Nitrogen

DEP's SOP no. BPNPSM-PMT-033 (Establishing Effluent Limitations for Individual Sewage Permits) recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, routine monitoring for TKN, Nitrate-Nitrite, and TN are recommended to be continued in this permit. Sampling frequency for TKN, Nitrate-Nitrite, TN, and TP are currently required 1/week, which is consistent with Table 6.3 in Guidance Doc. 362-0400-001, which recommends the testing of conventional pollutants weekly for facilities with flows between 0.1 mgd to 1.0 mgd. No change is proposed in this permit renewal.

Historically, an average monthly Total Phosphorus limit of 2.0 mg/L was recommended in NPDES permits, per DEP phosphorus guidance 391-2000-018, to control phosphorus effluent levels for any facilities that are expected to contribute 0.25% or more of the total phosphorus loading of the entire basin. DEP has previously determined that this facility meets the criteria and the limit has been continuously imposed in the permit. It is recommended to maintain this limit in the draft permit.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Chesapeake Bay TMDL

The Department formulated a strategy in April 2007, to comply with the EPA's and Chesapeake Bay Foundation's requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011, Phase 2 in March 2012 and Phase 3 in December 2019. In accordance with the Phase 3 WIP, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 3 WIP categorizes this facility as a phase 4 sewage facility that has a design flow less than 0.4 MGD but greater than 0.2 MGD. The WIP recommends the following:

1. Renewed or amended permits for facilities that do not increase design flow (compared to the date of the latest prior permit action) will contain monitoring and reporting for TN and TP throughout the permit term at a frequency no less than monthly.
2. Renewed or amended permits that include an increase in design flow will contain Cap Loads based on the lesser of a) existing TN and TP concentrations at current design average annual flow or b) 7,306 lbs/yr TN and 974 lbs/yr TP.

Monitoring Frequency and Sample Type

Unless discussed otherwise above, the permit's monitoring frequency and sample type for all parameters will remain unchanged from the last permit renewal.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-backsliding Requirement

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal unless noted otherwise above. This approach is in accordance with 40 CFR §122.44(l)(1).

Annual Fees

An annual fee clause was added to the permit in accordance with 25 Pa. Code § 92a.62. The facility covered by the permit is classified in the Minor Sewage Facility ≥ 0.05 and < 1 MGD fee category, which has an annual fee of \$1,000.

Mass Loading Limitations

Unless stated otherwise in this fact sheet, mass loading effluent limits are calculated based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34).

Other Permit Requirements

Given the previous impairment for Chlorine in Scott Creek, the following condition from Part C (modified from the existing permit) will be included in this permit:

“DEP strongly encourages the permittee to consider a method that leaves no detectable chlorine residual in the effluent. DEP considers a concentration level of 0.02 mg/L as the current method detection limit for Total Residual Chlorine.”

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--|-------------------------------------|------------------|-----------------------|-----------------|----------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Daily Min | XXX | 9.0 Daily Max | XXX | 1/day | Grab |
| DO | XXX | XXX | 5.0 Daily Min | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.061 | XXX | 0.199 | 1/day | Grab |
| CBOD5 | 50 | 80 | XXX | 25.0 | 40.0 | 50 | 1/week | 8-Hr Composite |
| BOD5 Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| TSS | 60 | 90 | XXX | 30.0 | 45.0 | 60 | 1/week | 8-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 1/week | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/quarter | Grab |
| Nitrate-Nitrite | XXX | XXX | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| Nitrate-Nitrite (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 1/month | Calculation |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---------------------------|-------------------------------------|--------------------|-----------------------|--------------------|--------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Total Nitrogen (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Ammonia Nov 1 - Apr 30 | 12.0 | XXX | XXX | 6.0 | XXX | 12 | 1/week | 8-Hr Composite |
| Ammonia May 1 - Oct 31 | 4.0 | XXX | XXX | 2.0 | XXX | 4 | 1/week | 8-Hr Composite |
| Ammonia (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| TKN | XXX | XXX | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| TKN (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | 4.0 | XXX | XXX | 2.0 | XXX | 4 | 1/week | 8-Hr Composite |
| Total Phosphorus (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Copper | 0.024 | 0.038 Daily Max | XXX | 0.012 | 0.019 Daily Max | XXX | 1/week | 24-Hr Composite |
| Total Zinc | 0.240 | 0.298 Daily Max | XXX | 0.12 | 0.149 Daily Max | XXX | 1/week | 24-Hr Composite |

Compliance Sampling Location: Outfall 001

Proposed Effluent Limitations and Monitoring Requirements


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------|-------------------------------------|------------------------|-----------------------|--------------------|---------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Monthly | Annual | Monthly | Monthly Average | Maximum | Instant. Maximum | | |
| Total Nitrogen (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Ammonia (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Total Phosphorus (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |


Compliance Sampling Location: Outfall 001

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment [redacted]) |
| <input checked="" type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [redacted]) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input checked="" type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input checked="" type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: [redacted] |
| <input type="checkbox"/> | Other: [redacted] |



StreamStats Report

Region ID: PA
 Workspace ID: PA20240514112827056000
 Clicked Point (Latitude, Longitude): 39.72627, -76.33211
 Time: 2024-05-14 07:28:50 -0400



[+ Collapse All](#)

Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|---------|--------------|
| BSLOPD | Mean basin slope measured in degrees | 5.5449 | degrees |
| DRNAREA | Area that drains to a point on a stream | 1.36 | square miles |
| ROCKDEP | Depth to rock | 5 | feet |
| URBAN | Percentage of basin with urban development | 13.6722 | percent |

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|--------------------------|---------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 1.36 | square miles | 4.78 | 1150 |
| BSLOPD | Mean Basin Slope degrees | 5.5449 | degrees | 1.7 | 6.4 |
| ROCKDEP | Depth to Rock | 5 | feet | 4.13 | 5.21 |
| URBAN | Percent Urban | 13.6722 | percent | 0 | 89 |

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

| Statistic | Value | Unit |
|-------------------------|-------|--------------------|
| 7 Day 2 Year Low Flow | 0.534 | ft ³ /s |
| 30 Day 2 Year Low Flow | 0.653 | ft ³ /s |
| 7 Day 10 Year Low Flow | 0.27 | ft ³ /s |
| 30 Day 10 Year Low Flow | 0.34 | ft ³ /s |
| 90 Day 10 Year Low Flow | 0.476 | ft ³ /s |

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)


USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

StreamStats Report

Region ID: PA
 Workspace ID: PA20240514113236109000
 Clicked Point (Latitude, Longitude): 39.74600, -76.34078
 Time: 2024-05-14 07:32:56 -0400



[+ Collapse All](#)

Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|---------|--------------|
| BSLOPD | Mean basin slope measured in degrees | 6.1614 | degrees |
| DRNAREA | Area that drains to a point on a stream | 2.63 | square miles |
| ROCKDEP | Depth to rock | 5 | feet |
| URBAN | Percentage of basin with urban development | 12.2801 | percent |

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|--------------------------|---------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 2.63 | square miles | 4.78 | 1150 |
| BSLOPD | Mean Basin Slope degrees | 6.1614 | degrees | 1.7 | 6.4 |
| ROCKDEP | Depth to Rock | 5 | feet | 4.13 | 5.21 |
| URBAN | Percent Urban | 12.2801 | percent | 0 | 89 |

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

| Statistic | Value | Unit |
|-------------------------|-------|--------------------|
| 7 Day 2 Year Low Flow | 1.16 | ft ³ /s |
| 30 Day 2 Year Low Flow | 1.37 | ft ³ /s |
| 7 Day 10 Year Low Flow | 0.621 | ft ³ /s |
| 30 Day 10 Year Low Flow | 0.757 | ft ³ /s |
| 90 Day 10 Year Low Flow | 0.995 | ft ³ /s |

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.



Discharge Information

Instructions **Discharge** Stream

Facility: Delta Borough STP NPDES Permit No.: PA0085332 Outfall No.: 001

Evaluation Type: Custom / Additives Wastewater Description: Treated Sewage

| Discharge Characteristics | | | | | | | | |
|---------------------------|------------------|----------|----------------------------|-----|-----|-----|--------------------------|----------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | | Complete Mix Times (min) | |
| | | | AFC | CFC | THH | CRL | Q ₇₋₁₀ | Q _h |
| 0.24 | 100 | 7 | | | | | | |

| Discharge Pollutant | Units | Max Discharge Conc | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | | 1 if left blank | |
|---------------------|-------|--------------------|-----------------|-------------|-------------------|-----------|-----------------|------------|-----|-----------------|-------------|
| | | | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteria Mod | Chem Transl |
| Total Copper | mg/L | 0.0131343 | | | 0.3835 | | | | | | |
| Total Lead | mg/L | 0.001 | | | | | | | | | |
| Total Zinc | mg/L | 0.066828 | | | 0.674 | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |



Stream / Surface Water Information

Delta Borough STP, NPDES Permit No. PA0085332, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: **Scott Creek**

No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 007280 | 2.93 | 381.12 | 1.36 | | | Yes |
| End of Reach 1 | 007280 | 0.96 | 251.99 | 2.63 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 2.93 | 0.1 | 0.27 | | | | | | | | | 100 | 7 | | |
| End of Reach 1 | 0.96 | 0.1 | 0.621 | | | | | | | | | | | | |

Q_h

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|----------|----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness | pH | Hardness | pH |
| Point of Discharge | 2.93 | | | | | | | | | | | | | | |
| End of Reach 1 | 0.96 | | | | | | | | | | | | | | |



Model Results

Delta Borough STP, NPDES Permit No. PA0085332, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/l) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|--------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Copper | 0 | 0 | | 0 | 13.439 | 14.0 | 24.2 | Chem Translator of 0.96 applic |
| Total Lead | 0 | 0 | | 0 | 64.581 | 81.6 | 141 | Chem Translator of 0.791 applied |
| Total Zinc | 0 | 0 | | 0 | 117.180 | 120 | 207 | Chem Translator of 0.978 applied |

CFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/l) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|--------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Copper | 0 | 0 | | 0 | 8.956 | 9.33 | 16.1 | Chem Translator of 0.96 applic |
| Total Lead | 0 | 0 | | 0 | 2.517 | 3.18 | 5.5 | Chem Translator of 0.791 applied |
| Total Zinc | 0 | 0 | | 0 | 118.139 | 120 | 207 | Chem Translator of 0.986 applied |

THH CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/l) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|--------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/l) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|--------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |

| | | | | | | | | |
|------------|---|---|--|---|-----|-----|-----|--|
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|--------------|---------------|---------------|----------------------|------|------|-------|-----------------|-------------|---------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Copper | 0.028 | 39.9 | 0.014 | 19.9 | 19.9 | mg/L | 0.014 | AFC | Discharge Conc ≥ 50% WQBEL (RP) |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|------------|-----------------|-------|----------------------------|
| Total Lead | 5.5 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Zinc | 157 | µg/L | Discharge Conc ≤ 10% WQBEL |
| | | | |
| | | | |

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | |
|------------------|-----------------|--------------------|-----------------|--------------------|--------------------------------|----------------------------|----------------------------|
| 071 | | 7280 | | SCOTT CREEK | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 2.930 | Delta Boro | PA0085332 | 0.240 | CBOD5 | 25 | | |
| | | | | NH3-N | 3.19 | 6.38 | |
| | | | | Dissolved Oxygen | | | 5 |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 1.120 | Peach Bottom In | PA0081833 | 0.007 | CBOD5 | 25 | | |
| | | | | NH3-N | 25 | 50 | |
| | | | | Dissolved Oxygen | | | 5 |

WQM 7.0 Wasteload Allocations

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
|------------------|--------------------|--------------------|
| 071 | 7280 | SCOTT CREEK |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|-----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 2.930 | Delta Boro | 12.63 | 18.51 | 12.63 | 18.51 | 0 | 0 |
| 1.120 | Peach Bottom In | NA | 50 | 13.98 | 50 | 0 | 0 |
| 0.970 | | NA | NA | 14 | NA | NA | NA |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|-----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 2.930 | Delta Boro | 1.6 | 3.19 | 1.6 | 3.19 | 0 | 0 |
| 1.120 | Peach Bottom In | NA | 25 | 1.73 | 25 | 0 | 0 |
| 0.970 | | NA | NA | 1.73 | NA | NA | NA |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|------|-----------------|-----------------|-----------------|-----------------|-----------------|-------------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 2.93 | Delta Boro | 25 | 25 | 3.19 | 3.19 | 5 | 5 | 0 | 0 |
| 1.12 | Peach Bottom In | 25 | 25 | 25 | 25 | 5 | 5 | 0 | 0 |
| 0.97 | | NA | NA | NA | NA | NA | NA | NA | NA |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|---------------------|-----------------------------|
| 071 | 7280 | SCOTT CREEK | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> |
| 2.930 | 0.240 | 22.895 | | 7.000 |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> |
| 8.294 | 0.469 | 17.678 | | 0.165 |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> |
| 15.32 | 1.354 | 1.85 | | 0.875 |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> |
| 6.365 | 28.161 | Owens | | 6 |
| <u>Reach Travel Time (days)</u> | Subreach Results | | | |
| 0.671 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> |
| | 0.067 | 13.81 | 1.74 | 7.12 |
| | 0.134 | 12.45 | 1.64 | 7.35 |
| | 0.201 | 11.22 | 1.55 | 7.48 |
| | 0.268 | 10.11 | 1.46 | 7.59 |
| | 0.336 | 9.12 | 1.38 | 7.69 |
| | 0.403 | 8.22 | 1.30 | 7.78 |
| | 0.470 | 7.41 | 1.23 | 7.82 |
| | 0.537 | 6.68 | 1.16 | 7.82 |
| | 0.604 | 6.02 | 1.09 | 7.82 |
| | 0.671 | 5.43 | 1.03 | 7.82 |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> |
| 1.120 | 0.247 | 21.661 | | 7.000 |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> |
| 11.285 | 0.512 | 22.040 | | 0.199 |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> |
| 4.14 | 1.003 | 0.82 | | 0.795 |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> |
| 7.975 | 23.831 | Tsivoglou | | NA |
| <u>Reach Travel Time (days)</u> | Subreach Results | | | |
| 0.046 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> |
| | 0.005 | 4.11 | 0.82 | 7.99 |
| | 0.009 | 4.09 | 0.81 | 7.99 |
| | 0.014 | 4.07 | 0.81 | 7.99 |
| | 0.018 | 4.05 | 0.81 | 7.99 |
| | 0.023 | 4.03 | 0.81 | 7.99 |
| | 0.028 | 4.01 | 0.80 | 7.99 |
| | 0.032 | 3.99 | 0.80 | 7.99 |
| | 0.037 | 3.97 | 0.80 | 7.99 |
| | 0.041 | 3.95 | 0.79 | 7.99 |
| | 0.046 | 3.93 | 0.79 | 7.99 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | | <u>Stream Name</u> | | | | | | |
|--------------------|-------------|--------------------|-----------------|--------------------|-------------|--------------------|-------|-----------|----------|-----------------|---------------|-------------|
| 071 | | 7280 | | | | SCOTT CREEK | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | (cfs) | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 2.930 | 0.27 | 0.00 | 0.27 | .3713 | 0.01213 | .469 | 8.29 | 17.68 | 0.16 | 0.671 | 22.89 | 7.00 |
| 1.120 | 0.77 | 0.00 | 0.77 | .3827 | 0.01210 | .512 | 11.29 | 22.04 | 0.20 | 0.046 | 21.66 | 7.00 |
| 0.970 | 0.78 | 0.00 | 0.78 | .3827 | 0.06780 | .61 | 8.27 | 13.55 | 0.23 | 0.003 | 21.64 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 2.930 | 0.17 | 0.00 | 0.17 | .3713 | 0.01213 | NA | NA | NA | 0.15 | 0.736 | 23.41 | 7.00 |
| 1.120 | 0.49 | 0.00 | 0.49 | .3827 | 0.01210 | NA | NA | NA | 0.17 | 0.054 | 22.19 | 7.00 |
| 0.970 | 0.50 | 0.00 | 0.50 | .3827 | 0.06780 | NA | NA | NA | 0.20 | 0.003 | 22.17 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 2.930 | 0.37 | 0.00 | 0.37 | .3713 | 0.01213 | NA | NA | NA | 0.18 | 0.620 | 22.51 | 7.00 |
| 1.120 | 1.05 | 0.00 | 1.05 | .3827 | 0.01210 | NA | NA | NA | 0.22 | 0.041 | 21.34 | 7.00 |
| 0.970 | 1.06 | 0.00 | 1.06 | .3827 | 0.06780 | NA | NA | NA | 0.26 | 0.002 | 21.32 | 7.00 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------|--------------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 07I | 7280 | SCOTT CREEK | 2.930 | 381.12 | 1.36 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|---------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.100 | 0.00 | 0.27 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Delta Boro | PA0085332 | 0.2400 | 0.2400 | 0.2400 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------|-------|----------------|-----------------------|---------------|----------------------|--------------------------|
| 071 | 7280 | SCOTT CREEK | 1.120 | 265.15 | 2.54 | 0.00000 | 0.00 | <input type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.423 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Peach Bottom In | PA0081833 | 0.0074 | 0.0074 | 0.0074 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------|--------------|----------------|-----------------------|---------------|----------------------|--------------------------|
| 071 | 7280 | SCOTT CREEK | 0.970 | 255.57 | 2.57 | 0.00000 | 0.00 | <input type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|---------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.423 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------|--------------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 07I | 7280 | SCOTT CREEK | 0.960 | 251.99 | 2.63 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|---------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.100 | 0.00 | 0.62 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |