

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0014</u>
Latitude	<u>39° 47' 47.85"</u>	Longitude	<u>-77° 13' 3.06"</u>
Quad Name	<u>Gettysburg</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Rock Creek (WWF)</u>	Stream Code	<u>59136</u>
NHD Com ID	<u>53320556</u>	RMI	<u>0.60</u>
Drainage Area	<u>0.21 mi.²</u>	Yield (cfs/mi ²)	<u>0.008</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.00175</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>450</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>13-D</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u>Name</u>		
Nearest Downstream Public Water Supply Intake	<u>City of Frederick, MD</u>		
PWS Waters	<u>Monocacy River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>Approximate 39.0 miles</u>

Changes Since Last Permit Issuance: none

Drainage Area

The discharge is to Unnamed Tributary to Rock Creek at RMI 0.60 mile. A drainage area upstream of the discharge is estimated to be 0.21 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>. USGS StreamStats also produced a Q₇₋₁₀ flow of 0.00175 cfs at the point of proposed discharge.

Unnamed Tributary to Rock Creek

25 Pa. Code 93.9z classifies Unnamed Tributary to Rock Creek as Warm-Water Fishes (CWF) and Migratory Fishes (MF) surface water. Based on the 2020 Integrated Report, Rock Creek, assessment unit ID 10202, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

PWS Intake

The nearest downstream Public Water Supply (PWS) intake is the City of Frederick intake on the Monocacy River, approximately 39.0 miles downstream of this discharge. Considering distance and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary

The Baladerry Inn Bed and Breakfast is a 1,400 gpd design flow facility. It treats wastewater using three (3) septic tanks, dose tank, sand filter bed, tablet chlorinator, and a chlorine contact tank for disinfection.

Compliance History	
Summary of DMRs:	DMR 2021-2022 report was submitted to DEP (see table below).
Summary of Inspections:	9/21/2021: Mr. Bettinger, DEP's WQS, conducted a compliance evaluation inspection. There was no violation noted during inspection. 2/16/2021: Mr. Bettinger, DEP's WQS, conducted an administrative inspection. There was no violation noted during inspection.
Other Comments:	There are no open violations associated with the permittee or the facility.

Other Comments:

DMR reported from June 2021 to March 2022

Parameter	Month									
	Jun 21	Jul 21	Aug 21	Sep 21	Oct 21	Nov 21	Dec 21	Jan 22	Feb 22	Mar 22
Flow (MGD)	0.0006	0.00069	0.00068	0.00040	0.00066	0.00042	0.00024	0.00028	0.00027	0.00025
TRC	0.05	0.1	0.1	0.06	0.03	0.02	0.02	0.025	0.03	0.03
CBOD₅	3.1	2.8	2.3	2.0	2.1	> 2.0	2.2	2.2	4.2	3.4
TSS	8.0	< 0.5	7.0	53.0	< 0.1	0.5	< 0.5	8.0	8.0	11.0
Fecal Coliform	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	> 1.0	< 1.0	< 1.0	< 1.0	< 1.0
Ammonia-Nitrogen	0.135	< 0.1	1.4	0.123	0.257	0.834	0.713	0.826	6.56	2.05

Development of Effluent Limitations and Monitoring Requirements

The proposed effluent limitations and monitoring requirements are derived from DEP's Standard Operating Procedure (SOP) for New and Reissuance Small Flow Treatment Facility Individual NPDES Permit Applications (SOP No. BPNPSM-PMT-003) revised on May 17, 2019.

pH is no longer a parameter of concern for SFTFs, so the pH monitoring requirement in the previous permit has been eliminated. The reviewer has determined that no other changes to the proposed limits and/or sampling frequencies are necessary at this time.

Ammonia-Nitrogen: while the ammonia-nitrogen limit from the existing permit was based on water quality modeling (WQM 7.0), new review procedures do not require use of WQM 7.0 for small flow treatment facilities. However, due to anti-backsliding requirements, the effluent limit of 4.5 mg/L of average monthly & 8.9 mg/L of IMAX during the summer season, and 13.5 mg/L of average monthly & 26.7 mg/L of IMAX during winter season in the existing permit will continue in the proposed permit. A review of the data supports that the facility will be able to meet the limitations.

D.O. is no longer a parameter of concern for SFTFs, so the dissolved oxygen monitoring requirement in the previous permit has been eliminated. The reviewer has determined that no other changes to the proposed limits and/or sampling frequencies are necessary at this time.

The reviewer notes that the existing BOD₅, and TSS monitoring frequencies and limits are inconsistent with the monitoring frequencies and limits recommended in DEP SOP no. BPNPSM-PMT-003 for SFTFs revised on May 17, 2019. A review of the facility's AMR and a review of the technology on site both verify that the existing facility cannot meet the more stringent limits in the SOP without upgrading the existing facility. Therefore, the monitoring frequencies and limits from the previous permit will remain the same. Also, because the SOP, PAG-04, and pre-printed AMR form all specify BOD₅ instead of the parameter CBOD₅, then the BOD₅ has replaced the parameter CBOD₅.

Biochemical Oxygen Demand (BOD₅): Only the minimum treatment requirements of secondary treatment will be necessary to protect water quality. The limits of 10.0 mg/L average monthly and 20.0 mg/L instantaneous will remain in the proposed permit.

Total Suspended Solids (TSS): The existing limits of 10.0 mg/L average monthly and 20.0 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47.

Fecal Coliform: The recent coliform guidance in 25 Pa. Code § 92a.47(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean (average monthly) and not greater than 1,000/100 ml (IMAX) and 25 Pa. Code §

NPDES Permit Fact Sheet
Baladerry Inn Bed & Breakfast

NPDES Permit No. PA0085405

92a.47(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean (average monthly) and not greater than 10,000/100 ml (IMAX), respectively.

Total Residual Chlorine (TRC): Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), and 0.00175 cfs of Q_{7-10} at discharge indicated monthly average limit of 0.13 mg/L and an instantaneous maximum limit of 0.42 mg/L which are more stringent and will replace in the proposed permit. Based on the DMRs from the past year, the facility has been consistently achieving these limits.

Toxic: This is a minor sewage facility receiving domestic wastewater only and the current application does not require sampling of toxic pollutants (or heavy metals) for those facilities with design flows less than 0.1 MGD. Therefore, no reasonable potential analysis for toxic pollutants has been performed for this permit renewal.

Chesapeake Bay Requirements

Facilities that are designed based on a flow of less than 2,000 GPD or considered as SFTFs are exempt from the Bay requirements. Accordingly, it is not necessary for the permittee to perform nutrient monitoring.

Total Maximum Daily Load (TMDL)


The discharge is located in a stream segment listed as attaining uses; therefore, no TMDL has been taken into consideration during this review.

Anti-Degradation Requirements

The discharge is to non-special protection waters/watershed. No HQ/EV waters are impacted by this discharge. The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Class A Wild Trout Streams

No Class A Wild Trout Fishery will be impacted by this discharge.



Map | eFacts Query | Advanced Query | Filter Plant Source Search

ESRI Streets & Imagery | Topographic | National Geographic

Streets | Imagery

Locate Latitude and Longitude

Decimal Degrees | DD/MM/SS

Latitude: Degrees: 39, Minutes: 47, Seconds: 51

Longitude: -77, 13, 5

Locate | Close

Latitude: 39.7975 - Longitude: 77.218056

0 300 600ft

POWERED BY esri

Imagery: undefined; ESRI Streets: Sources: Esri, HERE, DeLorme, USGS, Intermap, INCREMENT P, NRCan, Esri Japan, METI, Esri China (Hong Kong), Esri Korea, Esri (Thailand), MapnyIndia, NGCC, © OpenStreetMap contributors, and the GIS User Community

USGS StreamStats

SELECT A STATE / REGION
 Pennsylvania

IDENTIFY A STUDY AREA
 Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Continue

POWERED BY WIM

USGS Home | Contact USGS | Search USGS
 Accessibility | FOIA | Privacy | Policy & Notices

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.21	square miles
PRECIP	Mean Annual Precipitation	41	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	3.65	miles per square mile
ROCKDEP	Depth to rock	4	feet
CARBON	Percentage of area of carbonate rock	0	percent

Low-Flow Statistics Parameters [Low Flow Region 2]					
Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.21	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	3.65	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]		
Statistic	Value	Unit
7 Day 2 Year Low Flow	0.00601	ft ³ /s
30 Day 2 Year Low Flow	0.00961	ft ³ /s
7 Day 10 Year Low Flow	0.00175	ft ³ /s
30 Day 10 Year Low Flow	0.00284	ft ³ /s
90 Day 10 Year Low Flow	0.00557	ft ³ /s

Report | About | ? Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

TRC EVALUATION

Input appropriate values in A3:A9 and D3:D9

0.00175	= Q stream (cfs)	0.5	= CV Daily
0.0014	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.277	1.3.2.iii	WLA_cfc = 0.262
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.103	5.1d	LTA_cfc = 0.152

Source	Effluent Limit Calculations
PENTOXSD TRG 5.1f	AML_MULT = 1.231
PENTOXSD TRG 5.1g	AVG_MON_LIMIT (mg/l) = 0.127 INST_MAX_LIMIT (mg/l) = 0.415

WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$
LTA_afc	wla_afc * LTAMULT_afc
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$
LTA_cfc	wla_cfc * LTAMULT_cfc
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$
AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)
INST_MAX_LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
TRC	XXX	XXX	XXX	0.19	XXX	0.63	1/month	Grab
CBOD ₅	XXX	XXX	XXX	10.0	XXX	20	1/month	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/month	Grab
Ammonia-Nitrogen May 1 – Oct 31	XXX	XXX	XXX	4.5	XXX	8.9	1/month	Grab
Ammonia-Nitrogen Nov 1 – Apr 30	XXX	XXX	XXX	13.5	XXX	26.7	1/month	Grab

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
TRC	XXX	XXX	XXX	0.13	XXX	0.42	1/month	Grab
BOD ₅	XXX	XXX	XXX	10.0	XXX	20	1/month	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/month	Grab
Ammonia-Nitrogen May 1 – Oct 31	XXX	XXX	XXX	4.5	XXX	8.9	1/month	Grab
Ammonia-Nitrogen Nov 1 – Apr 30	XXX	XXX	XXX	13.5	XXX	26.7	1/month	Grab

Compliance Sampling Location:

Other Comments: