

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0085448  
 APS ID 977748  
 Authorization ID 1292773

**Applicant and Facility Information**

Applicant Name	<u>Goodville Industrial Center</u>	Facility Name	<u>Goodville Industrial Center WWTP</u>
Applicant Address	<u>222 Conestoga Creek Road</u> <u>Ephrata, PA 17522</u>	Facility Address	<u>1564 Main Street</u> <u>East Earl, PA 17519</u>
Applicant Contact	<u>Elvin Hoover</u>	Facility Contact	<u>Steve Cawley</u>
Applicant Phone	<u>(717) 733-0630</u>	Facility Phone	<u>(484) 593-2989</u>
Client ID	<u>345615</u>	Site ID	<u>239083</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>East Earl Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lancaster</u>
Date Application Received	<u>October 16, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 29, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Renewal.</u>		

**Summary of Review**

Goodville Industrial Center has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The permit was issued on April 9, 2015 and became effective on May 1, 2015. The permit authorized discharge of treated sewage from the existing wastewater treatment plant (WWTP) located in East Earl Township, Lancaster County into UNT to Conestoga River. The existing permit expiration date was April 30, 2020, and the permit has been administratively extended since that time.

Per the previous fact sheet, the industrial center previously had a subsurface sewage facility which malfunctioned. Because of the existence of nearby wetlands, the decision was made to construct a treatment system which would discharge to a constructed lined wetland system, which would flow into existing wetlands – instead of digging an outfall line to be placed through the existing wetlands. The constructed wetland is approximately 60' x 60'. After flowing through the constructed and natural wetland area, the discharge flows through a dry swale in a pasture area for approximately 800' before reaching the point of first use on UNT 07797 to Conestoga River. An aquatic biologist for the Department agreed with this determination.

A regional WWTP, the Weaverland Valley Authority (WVA) WWTP will ultimately be constructed, and will be located adjacent to Conestoga Wood Specialties. Once the WWTP is constructed, Goodville Industrial Center will discharge directly to WVA and will cease discharge from their onsite WWTP.

Changes to this renewal: Ammonia-nitrogen monitoring has been added to the permit.

Supplemental information is located at the end of this fact sheet.

Approve	Deny	Signatures	Date
X		<i>Benjamin Lockwood</i> Benjamin R. Lockwood / Environmental Engineering Specialist	February 13, 2021
		Daniel W. Martin, P.E. / Environmental Engineer Manager	
		Maria D. Bebenek, P.E. / Program Manager	

**Summary of Review**

Sludge use and disposal description and location(s): Offsite location

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.004</u>
Latitude	<u>40° 7' 11"</u>	Longitude	<u>76° 0' 12"</u>
Quad Name	<u>New Holland</u>	Quad Code	<u>1837</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary of Conestoga River (WWF, MF)</u>	Stream Code	<u>07797</u>
NHD Com ID	<u>57462375</u>	RMI	<u>0.8</u>
Drainage Area	<u>0.68 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.098</u>
Q <sub>7-10</sub> Flow (cfs)	<u>.0669</u>	Q <sub>7-10</sub> Basis	<u>USGS PA StreamStats</u>
Elevation (ft)	<u>436</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>7-J</u>	Chapter 93 Class.	<u>WWF, MF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>N/A</u>	Exceptions to Criteria	<u>N/A</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Nutrients, Pathogens</u>		
Source(s) of Impairment	<u>Agriculture, Source Unknown</u>		
TMDL Status	<u>N/A</u>	Name	<u>N/A</u>
Nearest Downstream Public Water Supply Intake	<u>Lancaster City Water Bureau</u>		
PWS Waters	<u>Conestoga River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>28</u>

Changes Since Last Permit Issuance: USGS PA StreamStats provided a drainage area of 0.68 mi<sup>2</sup> and a Q<sub>7-10</sub> flow of 0.0669 cfs at the point of discharge.

Other Comments: None

Treatment Facility Summary				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Activated Sludge	Calcium Hypochlorite	0.004
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.004		Not Overloaded	Sludge Holding	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The WWTP process is as follows: Equalization Tank – Aeration Tank – Clarifier – Chlorine Contact Tank – Dechlorination System – Outfall 001 to UNT of Conestoga River.

Compliance History	
<b>Summary of DMRs:</b>	A summary of the past 12-month DMR effluent data is presented on the next page of this fact sheet
<b>Summary of Inspections:</b>	<p>5/4/2016: A routine inspection was conducted. All treatment units were online. It appeared the operator was using bleach for disinfection. The outfall was not located. The effluent in the chlorine contact tank was clear.</p> <p>4/17/2018: A routine inspection was conducted. No floating debris was present in the EQ tank. The aeration tank appeared to have an even distribution of aeration. The EQ tank and aeration tank were covered with a tarp and weights. The clarifier had some popping sludge and pin floc. The sludge baffle in the clarifier had an accumulation of solids. The clarifier trough was free of debris. Effluent from the chlorine contact tank appeared mostly clear with some suspended solids. Field sample results were within permitted limits. Calcium hypochlorite tablets are used for disinfection.</p> <p>8/14/2020: An administrative inspection was conducted to determine the current status of operations. The facility was operating normally and all treatment units were online and operable. There were no issues noted in the inspection report.</p>

Other Comments: There are currently no open violations associated with the permittee or the facility.

Compliance History

DMR Data for Outfall 001 (from January 1, 2020 to December 31, 2020)

Parameter	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20
Flow (MGD) Average Monthly	0.00027	0.00042	0.00032	0.00058	0.00126	0.00205	0.00214	0.00171	0.00181	0.00107	0.00096	0.00079
Flow (MGD) Daily Maximum	0.00064	0.00085	0.00061	0.00224	0.00425	0.00374	0.00439	0.00332	0.00409	0.012	0.00261	0.00234
pH (S.U.) Instantaneous Minimum	7.71	6.79	7.28	7.3	6.01	7.68	7.62	7.18	7.38	7.1	6.69	7.26
pH (S.U.) Instantaneous Maximum	8.59	8.61	8.83	8.15	8.65	8.36	8.35	8.16	8.57	8.73	8.44	8.2
DO (mg/L) Instantaneous Minimum	9.01	7.57	7.03	7.35	7.06	7.35	7.82	8.14	9.52	8.85	9.73	8.91
TRC (mg/L) Average Monthly	< 0.02	< 0.02	< 0.02	< 0.03	< 0.02	< 0.03	< 0.02	< 0.03	< 0.03	< 0.10	< 0.02	0.10
TRC (mg/L) Instantaneous Maximum	0.27	0.11	0.09	0.41	0.09	0.21	0.26	0.37	0.22	1.66	0.08	0.53
CBOD5 (lbs/day) Average Monthly	0.005	< 0.006	< 0.009	< 0.009	< 0.03	< 0.05	< 0.04	< 0.02	< 0.04	0.20	< 0.02	< 0.01
CBOD5 (lbs/day) Weekly Average	0.007	< 0.007	0.01	< 0.01	< 0.04	< 0.05	< 0.05	0.03	0.08	0.4	< 0.02	0.02
CBOD5 (mg/L) Average Monthly	3	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	20	< 2	< 2
CBOD5 (mg/L) Weekly Average	3	< 2	3	< 2	< 2	2	< 2	2	2	53	< 2	3
TSS (lbs/day) Average Monthly	0.02	0.03	0.03	0.04	0.1	0.2	< 0.1	0.06	0.1	0.2	< 0.04	< 0.03
TSS (lbs/day) Weekly Average	0.03	0.05	0.04	0.06	0.2	0.3	0.2	0.09	0.2	0.2	0.05	< 0.03
TSS (mg/L) Average Monthly	11	10	7	11	11	11	< 6	6	7	19	< 5	< 4
TSS (mg/L) Weekly Average	11	16	10	14	14	15	8	6	8	26	6	4
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 2	16	< 2	< 1	< 1	4	< 1	1	< 1	< 1	< 60

**NPDES Permit Fact Sheet  
Goodville Industrial Center**

**NPDES Permit No. PA0085448**

Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	6	262	3	1	< 1	9	< 1	1	2	< 1	3600
Nitrate-Nitrite (mg/L) Average Monthly	39.2	85.8	62.7	69.2	47.9	47.2	67.7	84.8	59.1	83	88.8	64.1
Nitrate-Nitrite (lbs) Total Monthly	4	8	9	13	32	35	49	11	10	23	22	12
Total Nitrogen (mg/L) Average Monthly	41.2	87	64.3	69.9	49	49.2	67.7	84.8	60.1	83	90.2	64.1
Total Nitrogen (lbs) Total Monthly	4	8	9	13	32	36	49	11	11	23	23	12
TKN (mg/L) Average Monthly	2.05	1.26	1.58	0.69	1.08	1.98	< 0.5	< 0.5	1.06	< 0.5	1.4	< 0.5
TKN (lbs) Total Monthly	0.2	0.1	0.2	0.1	0.7	1	< 0.4	< 0.07	0.2	< 0.1	0.4	< 0.09
Total Phosphorus (mg/L) Average Monthly	4.75	10.9	12.1	13.4	7.61	7.78	1.34	9.84	6.34	6.94	7.06	6.66
Total Phosphorus (lbs) Total Monthly	0.4	1	2	3	5	6	1	1	1	2	2	1

**Compliance History**

**Effluent Violations for Outfall 001, from: February 1, 2020 To: December 31, 2020**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	03/31/20	IMAX	1.66	mg/L	1.6	mg/L
CBOD5	03/31/20	Wkly Avg	53	mg/L	40	mg/L

**Existing Effluent Limitations and Monitoring Requirements**

The table below summarizes the effluent limits and monitoring requirements implemented in the existing NPDES permit.

**Outfall 001**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.50	XXX	1.6	1/day	Grab
CBOD5	0.83	1.3	XXX	25	40	50	2/month	8-Hr Composite
TSS	1.0	1.5	XXX	30	45	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
TKN	Report Total Mo	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Nitrate-Nitrite	Report Total Mo	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Total Nitrogen	Report Total Mo	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	Report Total Mo	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Total Phosphorus	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: At discharge from facility

Other Comments: None

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.004</u>
<b>Latitude</b> <u>40° 7' 11"</u>	<b>Longitude</b> <u>76° 0' 12"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

Pursuant to 40 CFR § 122.44(d)(1)(i), more stringent requirements should be considered when pollutants are discharged at the levels which have the reasonable potential to cause or contribute to excursions above water quality standards.

WQM 7.0 ver. 1.0b is a water quality model designed to assist DEP in determining appropriate water quality based effluent limits (WQBELs) for carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), ammonia (NH<sub>3</sub>-N), and dissolved oxygen (D.O.). The model simulates two basic processes: In the NH<sub>3</sub>-N module, the model simulates the mixing and degradation of NH<sub>3</sub>-N in the stream and compares calculated instream NH<sub>3</sub>-N concentrations to NH<sub>3</sub>-N water quality criteria. In the D.O. module, the model simulates the mixing and consumption of D.O. in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N and compares calculated instream D.O. concentrations to D.O. water quality criteria. The model then determines the highest pollutant loadings that the stream can assimilate while still meeting water quality criteria under design conditions. DEP's Technical Guidance No. 391-2000-007 provides the technical methods contained in WQM 7.0 for determining wasteload allocations and for determining recommended NPDES effluent limits for point source discharges.

The model was utilized for this permit application. The flow data used to run the model was acquired from USGS PA StreamStats and is included in an attachment. Default stream pH and temperature inputs were used for this model run. The model output indicated a CBOD<sub>5</sub> average monthly limit of 25 mg/l, an NH<sub>3</sub>-N average monthly limit of 25 mg/l, and a D.O. minimum limit of 5.0 mg/l were protective of water quality. The CBOD<sub>5</sub> limit is the same as the existing limit, which will remain in the permit. DEP's SOP No. BCW-PMT-033 recommends that for existing dischargers, if WQM modeling results for summer indicates that an average monthly limit of 25 mg/l is acceptable, the application manager will generally establish a year round monitoring requirement for ammonia-nitrogen, at a minimum. Therefore, an NH<sub>3</sub>-N monitoring requirement has been added to the permit.

A review of the permit application revealed no toxic parameters of concern. Accordingly, evaluating reasonable potential of toxic pollutants is not necessary as effluent levels of toxic pollutants are expected to be insignificant.



### **Dissolved Oxygen (D.O.)**

A minimum D.O. limit of 5.0 mg/L is a D.O. water quality criterion found in 25 Pa. Code § 93.7(a). This limit is included in the existing NPDES permit. This limit will continue to be included in the permit to ensure that the facility continues to achieve compliance with DEP water quality standards.

### **Total Residual Chlorine**

The attached computer printout utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID No. 391-2000-015) for developing chlorine limitations. The Guidance references Chapter 92, Section 92.2d (3) which establishes a standard BAT limit of 0.50 mg/l unless a facility-specific BAT has been developed. The attached printout indicates that a water quality limit of 0.5 mg/l would be needed to prevent toxicity concerns. It is recommended that a TRC limit of 0.50 mg/l monthly average and 1.6 mg/l instantaneous maximum be applied this permit cycle, which is the same as the existing limit.

### **Chesapeake Bay Total Maximum Daily Load (TMDL)**

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the *Pennsylvania Chesapeake Watershed Implementation Plan* (WIP), dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a *Phase 2 Watershed Implementation Plan Wastewater Supplement* (Phase 2 Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. A new update to the WIP was published as the Phase 3 WIP in August 2019. As part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on December 17, 2019, and is the basis for the development of any Chesapeake Bay related permit parameters. Sewage discharges have been prioritized based on their design flow to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual Cap Loads based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. For Phase 4 and 5 facilities, Cap Loads are not currently being implemented for renewed or amended permits for facilities that do not increase design flow.

This facility is considered a Phase 5 non-significant discharger with a design flow less than 0.2 MGD but greater than 0.002 MGD. According to DEP's latest-revised Phase 3 Supplement, issuance of permits with monitoring and reporting for TN and TP is recommended for any Phase 5 non-significant sewage facilities. Furthermore, DEP's SOP No. BCW-PMT-033 states that in general, at a minimum, monitoring for TN and TP should be included in new and reissued permits for sewage discharges with design flows > 2,000 gpd. Therefore, TN and TP monitoring will be included in the renewed permit, which is consistent with the existing permit.

### **Fecal Coliform**

PA Code § 92a.47.(a)(4) requires a monthly average limit of 200/100 mL as a geometric mean and an instantaneous maximum limit not greater than 1,000/100 mL from May through September for fecal coliform. PA Code § 92a.47.(a)(5) requires a monthly average limit of 2,000/100 mL as a geometric mean and an instantaneous maximum limit not greater than 10,000/100 mL from October through April for fecal coliform. These limits will remain in the permit.

### **Flow Monitoring**

Flow monitoring is recommended by DEP's technical guidance and is also required by 25 PA Code §§ 92a.61.

### **Sampling Frequency & Sample Type**

The monitoring requirements were established based on BPJ and/or Table 6-3 of DEP's Technical Guidance No. 362-0400-001.

### **Anti-Degradation (93.4)**

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**303d Listed Streams**

The discharge is located on a stream segment that has a recreational impairment from pathogens due to an unknown source. There is also an aquatic life impairment from nutrients due to agriculture.

**Class A Wild Trout Fisheries**

No Class A Wild Trout Fisheries are impacted by this discharge.

**Anti-Backsliding**

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit unless any exceptions are addressed by DEP in this fact sheet.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.50	XXX	1.6	1/day	Grab
CBOD5	0.83	1.3	XXX	25	40	50	2/month	8-Hr Composite
TSS	1.0	1.5	XXX	30	45	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Nitrate-Nitrite	Report Total Mo	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
TKN	Report Total Mo	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Total Nitrogen	Report Total Mo	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus	Report Total Mo	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Total Phosphorus	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

Compliance Sampling Location: At discharge from facility

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: No. BCW-PMT-002, No. BCW-PMT-033
<input type="checkbox"/>	Other: [redacted]





Copyright: © 2013 National Geographic Society, i-cubed



Enter report title:


Goodville Industrial Center PA0085448 Outfall 001

Enter comments:

Some comments here

## Goodville Industrial Center PA0085448 Outfall 001

Region ID:	PA
Workspace ID:	PA20210212191944427000
Clicked Point (Latitude, Longitude):	40.11907, -76.00520
Time:	2021-02-12 14:20:02 -0500



Permit No. PA0085448

Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.68	square miles
BSLOPD	Mean basin slope measured in degrees	2.9863	degrees
ROCKDEP	Depth to rock	5.6	feet
URBAN	Percentage of basin with urban development	2.9028	percent

Low-Flow Statistics Parameters <sup>(Low Flow Region 1)</sup>					
Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.68	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	2.9863	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.6	feet	4.13	5.21
URBAN	Percent Urban	2.9028	percent	0	89

Low-Flow Statistics Disclaimers<sup>(Low Flow Region 1)</sup>

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report <sup>(Low Flow Region 1)</sup>		
Statistic	Value	Unit
7 Day 2 Year Low Flow	0.161	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.213	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.0669	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.0919	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.164	ft <sup>3</sup> /s

Low-Flow Statistics Citations

[Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.4.0

Permit No. PA0085448

Enter report title:

Goodville Industrial Center PA0085448 RMI = 0.0

Enter comments:

Some comments here

## Goodville Industrial Center PA0085448 RMI = 0.0

Region ID:

PA

Workspace ID:


PA20210212192404761000

Clicked Point (Latitude, Longitude):

40.12160, -76.01743

Time:

2021-02-12 14:24:22 -0500





Permit No. PA0085448

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.99	square miles
BSLOPD	Mean basin slope measured in degrees	2.7832	degrees
ROCKDEP	Depth to rock	5.7	feet
URBAN	Percentage of basin with urban development	2.377	percent

Low-Flow Statistics Parameters<sup>(Low Flow Region 1)</sup>

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.99	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	2.7832	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.7	feet	4.13	5.21
URBAN	Percent Urban	2.377	percent	0	89

Low-Flow Statistics Disclaimers<sup>(Low Flow Region 1)</sup>

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report<sup>(Low Flow Region 1)</sup>

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.23	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.305	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.0959	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.132	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.239	ft <sup>3</sup> /s

Low-Flow Statistics Citations

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.4.0

Permit No. PA0085448

	A	B	C	D	E	F	G	H
1	1A	B	C	D	E	F	G	
2	<b>TRC EVALUATION</b>							
3	Input appropriate values in B4:B8 and E4:E7							
4	0.0669	= Q stream (cfs)			0.5	= CV Daily		
5	0.004	= Q discharge (MGD)			0.5	= CV Hourly		
6	30	= no. samples			1	= AFC_Partial Mix Factor		
7	0.3	= Chlorine Demand of Stream			1	= CFC_Partial Mix Factor		
8	0	= Chlorine Demand of Disch			15	= AFC_Criteria Compliance Time (min)		
9	0.5	= BAT/BPJ Value			720	= CFC_Criteria Compliance Time (min)		
10	0	= % Factor of Safety (FOS)				= Decay Coefficient (K)		
11	Source		Reference	AFC Calculations		Reference	CFC Calculations	
12	TRC		1.3.2.iii	WLA_afc = 3.468		1.3.2.iii	WLA_cfc = 3.373	
13	PENTOXSD TRC		5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581	
14	PENTOXSD TRC		5.1b	LTA_afc = 1.292		5.1d	LTA_cfc = 1.961	
15	Source		Effluent Limit Calculations					
16	PENTOXSD TRC		5.1f	AML_MULT = 1.231				
17	PENTOXSD TRC		5.1g	AVG_MON_LIMIT (mg/l) = 0.500		BAT/BPJ		
18				INST_MAX_LIMIT (mg/l) = 1.635				
21	$\text{WLA\_afc} = \left( \frac{.019}{e^{-k \cdot \text{AFC\_tc}}} \right) + \left[ \left( \frac{\text{AFC\_Yc} \cdot \text{Qs} \cdot .019}{\text{Qd} \cdot e^{-k \cdot \text{AFC\_tc}}} \right) \dots \right. \\ \left. \dots + \text{Xd} + \left( \frac{\text{AFC\_Yc} \cdot \text{Qs} \cdot \text{Xs}}{\text{Qd}} \right) \right] \cdot (1 - \text{FOS}/100)$							
25	$\text{LTAMULT\_afc} = \text{EXP} \left( \left( 0.5 \cdot \text{LN}(\text{cvh}^2 + 1) \right) - 2.326 \cdot \text{LN}(\text{cvh}^2 + 1)^{0.5} \right)$							
26	$\text{LTA\_afc} = \text{wla\_afc} \cdot \text{LTAMULT\_afc}$							
28	$\text{WLA\_cfc} = \left( \frac{.011}{e^{-k \cdot \text{CFC\_tc}}} \right) + \left[ \left( \frac{\text{CFC\_Yc} \cdot \text{Qs} \cdot .011}{\text{Qd} \cdot e^{-k \cdot \text{CFC\_tc}}} \right) \dots \right. \\ \left. \dots + \text{Xd} + \left( \frac{\text{CFC\_Yc} \cdot \text{Qs} \cdot \text{Xs}}{\text{Qd}} \right) \right] \cdot (1 - \text{FOS}/100)$							
30	$\text{LTAMULT\_cfc} = \text{EXP} \left( \left( 0.5 \cdot \text{LN}(\text{cvd}^2 / \text{no\_samples} + 1) \right) - 2.326 \cdot \text{LN}(\text{cvd}^2 / \text{no\_samples} + 1)^{0.5} \right)$							
31	$\text{LTA\_cfc} = \text{wla\_cfc} \cdot \text{LTAMULT\_cfc}$							
33	$\text{AML\_MULT} = \text{EXP} \left( 2.326 \cdot \text{LN} \left( \left( \text{cvd}^2 / \text{no\_samples} + 1 \right)^{0.5} \right) - 0.5 \cdot \text{LN}(\text{cvd}^2 / \text{no\_samples} + 1) \right)$							
34	$\text{AVG\_MON\_LIMIT} = \text{MIN}(\text{BAT\_BPJ}, \text{MIN}(\text{LTA\_afc}, \text{LTA\_cfc}) \cdot \text{AML\_MULT})$							
35	$\text{INST\_MAX\_LIMIT} = 1.5 \cdot \left( \frac{\text{av\_mon\_limit}}{\text{AML\_MULT}} \right) / \text{LTAMULT\_afc}$							

Permit No. PA0085448

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07J	7797	Trib 07797 of Conestoga River	0.800	436.00	0.68	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.07	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Goodville Ind.	PA0085448	0.0040	0.0040	0.0040	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Permit No. PA0085448

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07J	7797	Trib 07797 of Conestoga River	0.000	409.00	0.99	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.10	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Permit No. PA0085448

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
07J		7797				Trib 07797 of Conestoga River						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.800	0.07	0.00	0.07	.0062	0.00639	.335	4.04	12.06	0.05	0.906	20.42	7.00
<b>Q1-10 Flow</b>												
0.800	0.04	0.00	0.04	.0062	0.00639	NA	NA	NA	0.04	1.134	20.63	7.00
<b>Q30-10 Flow</b>												
0.800	0.09	0.00	0.09	.0062	0.00639	NA	NA	NA	0.06	0.773	20.32	7.00

Permit No. PA0085448

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Permit No. PA0085448

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
07J	7797	Trib 07797 of Conestoga River

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.800	Goodville Ind.	9.24	50	9.24	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.800	Goodville Ind.	1.87	25	1.87	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.80	Goodville Ind.	25	25	25	25	5	5	0	0

Permit No. PA0085448

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07J	7797	Trib 07797 of Conestoga River		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.800	0.004	20.423	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
4.043	0.335	12.081	0.054	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
3.95	0.557	2.12	0.723	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.968	23.408	Owens	5	
<u>Reach Travel Time (days)</u>				
0.906				
	<u>Subreach Results</u>			
	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>
	(days)	(mg/L)	(mg/L)	(mg/L)
	0.091	3.75	1.98	8.18
	0.181	3.56	1.86	8.18
	0.272	3.38	1.74	8.18
	0.363	3.21	1.63	8.18
	0.453	3.05	1.53	8.18
	0.544	2.90	1.43	8.18
	0.635	2.75	1.34	8.18
	0.725	2.62	1.25	8.18
	0.816	2.48	1.17	8.18
	0.906	2.36	1.10	8.18



Permit No. PA0085448

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07J		7797	Trib 07797 of Conestoga River				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.800	Goodville Ind.	PA0085448	0.004	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5