

Application Type Renewal  
Facility Type Industrial  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. PA0085537  
APS ID 10001  
Authorization ID 1338544

**Applicant and Facility Information**

Applicant Name	<u>Altoona Water Authority</u>	Facility Name	<u>Altoona City Water System</u>
Applicant Address	<u>900 Chestnut Avenue</u> <u>Altoona, PA 16601-4617</u>	Facility Address	<u>120 Kelsey Road</u> <u>Tyrone, PA 16686</u>
Applicant Contact	<u>Mark Perry</u>	Facility Contact	<u>Doug DeAngelis</u>
Applicant Phone	<u>(814) 944-2222</u>	Facility Phone	<u>(814) 949-2222</u>
Client ID	<u>85897</u>	Site ID	<u>238359</u>
SIC Code	<u>4941</u>	Municipality	<u>Antis Township</u>
SIC Description	<u>Trans. &amp; Utilities - Water Supply</u>	County	<u>Blair</u>
Date Application Received	<u>January 5, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>February 18, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>This is an application for NPDES renewal</u>		

Approve	Deny	Signatures	Date
X		Nicholas Hong, P.E. / Environmental Engineer Nick Hong (via electronic signature)	April 29, 2021
x		Daniel W. Martin, P.E. / Environmental Engineer Manager Maria D. Bebenek for Daniel W. Martin	May 11, 2021
x		Maria D. Bebenek, P.E. / Environmental Program Manager Maria D. Bebenek	May 11, 2021

### Summary of Review

The application submitted by the applicant requests a NPDES renewal permit for the Altoona Water Authority- Bellwood Water Treatment Plant located at 120 Kelsey Road, Tyrone, PA 16686 in Blair County, municipality of Antis. The existing permit became effective on April 1, 2016 and expired on March 31, 2021. The application for renewal was received by DEP Southcentral Regional Office (SCRO) on January 5, 2021.

The purpose of this Fact Sheet is to present the basis of information used for establishing the proposed NPDES permit effluent limitations. The Fact Sheet includes a description of the facility, a description of the facility's receiving waters, a description of the facility's receiving waters attainment/non-attainment assessment status, and a description of any changes to the proposed monitoring/sampling frequency. Section 6 provides the justification for the proposed NPDES effluent limits derived from technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), total maximum daily loading (TMDL), antidegradation, anti-backsliding, and/or whole effluent toxicity (WET). A brief summary of the outlined descriptions has been included in the Summary of Review section.

The subject facility is a 0.115 MGD average annual design flow. The hydraulic design flow is 0.24 MGD. The applicant anticipates proposed upgrades to the treatment facility in the next five years. The facility plans to undergo an upgrade to membrane filters. The NPDES application has been processed as an Industrial Waste Facility due to the type of wastewater and the design flow rate for the facility. The applicant disclosed the Act 14 requirement to Blair County Planning Commission and Antis Township Board of Supervisors and the notice was received by the parties on November 27, 2020 and December 1, 2020. A planning approval letter was not necessary as the facility is neither new or expanding.

Utilizing the DEP's web-based Emap-PA information system, the receiving waters has been determined to be Bells Gap Run. The sequence of receiving streams that Bells Gap Run discharges into are the Little Juniata River, the Juniata River, and the Susquehanna River which eventually drains into the Chesapeake Bay. The subject site is subject to the Chesapeake Bay implementation requirements. The receiving water has protected water usage for trout stocking fishes (TSF) and migratory fishes (MF). No Class A Wild Trout fisheries are impacted by this discharge. The absence of high quality and/or exceptional value surface waters removes the need for an additional evaluation of anti-degradation requirements.

The Bells Gap Run is a Category 2 stream listed in the 2020 Integrated List of All Waters (formerly 303d Listed Streams). This stream is an attaining stream that supports aquatic life, recreational uses, and potable water supply. The receiving waters is not subject to a total maximum daily load (TMDL) plan to improve water quality in the subject facility's watershed.

The existing permit and proposed permit differ as follows:

- **Minor changes to the chemical additives usage limits**

Sludge use and disposal description and location(s): Sewage sludge disposed at Laurel Highlands landfill in Johnstown Township in Cambria County.

The proposed permit will expire five (5) years from the effective date.

Based on the review in this report, it is recommended that the permit be drafted. DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Any additional information or public review of documents associated with the discharge or facility may be available at PA DEP Southcentral Regional Office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file review, contact the SCRO File Review Coordinator at 717.705.4700.

**1.0 Applicant**

**1.1 General Information**

This fact sheet summarizes PA Department of Environmental Protection's review for the NPDES renewal for the following subject facility.

Facility Name: Altoona Water Authority- Bellwood Water Treatment Plant

NPDES Permit # PA0085537

Physical Address: 120 Kelsey Road  
Tyrone, PA 16686

Mailing Address: 900 Chestnut Avenue  
Altoona, PA 16601

Contact: Mark Perry  
Manager  
mperry@altoonawater.com

Consultant: Maggie Weitzel  
Gwin, Dobson, and Foreman, Inc.  
mweitzel@gdfengineers.com

**1.2 Permit History**

Description of Facility

Due to the anticipated upgrade to the facility, the facility submitted a request to amend the NDPEs in Summer of 2020. The amendment was necessary for approving their chemical additives usages for membrane cleaning.

Permit submittal included the following information.

- NPDES Application
- Influent Sample Data
- Effluent Sample Data

**2.0 Treatment Facility Summary**

**2.1.1 Site location**

The physical address for the facility is 120 Kelsey Road, Tyrone, PA 16686. A topographical and an aerial photograph of the facility are depicted as Figure 1 and Figure 2.

Figure 1: Topographical map of the subject facility






Figure 2: Aerial Photograph of the subject facility



**2.2 Description of Wastewater Treatment Process**

The subject facility is a 0.24 MGD hydraulic design flow facility. The subject facility's wastewater is effluent from the waste washwater holding basin (i.e. settling basin). Outfall IMP101 is at a location where samples would collect from supernatant. Outfall 001 is located at the discharge from the facility. A schematic of the process is shown in the figure. Internal monitoring point IMP101 and Outfall 001 locations are marked on the diagram.

The facility is being evaluated for flow, pH, TRC, TSS, nitrogen species, phosphorus, aluminum, iron, and manganese. The existing permits limits for the facility is summarized in Section 2.4.



**2.3 Facility Outfall Information**

The facility has the following outfall information for wastewater.

Outfall No.	001	Design Flow (MGD)	.24
Latitude	40° 37' 12.00"	Longitude	-78° 22' 47.00"
Wastewater Description:	Water Treatment Effluent		



**2.3.1 Operational Considerations- Chemical Additives**

Chemical additives are chemical products introduced into a waste stream that is used for cleaning, disinfecting, or maintenance and which may be detected in effluent discharged to waters of the Commonwealth. Chemicals excluded are those used for neutralization of waste streams, the production of goods, and treatment of wastewater.

The subject facility utilizes the following chemicals as part of their treatment process.

- Sodium Hydroxide (Caustic Soda) – 25% as a cleaning chemical for clean-in-place (CIP)
- Poly Orthophosphate for corrosion inhibitor
- Aluminum Sulfate for coagulation
- Chlorine gas for disinfection
- Sodium hypochlorite -12% for cleaning chemical for CIP
- Citric acid -50% for cleaning chemical for CIP
- Sodium Bisulfate for neutralizing agent for CIP

**2.4 Existing NPDES Permits Limits**

The existing NPDES permit limits are summarized in the table.

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. A. For Outfall 001, Latitude 40° 37' 12.00", Longitude 78° 22' 47.00", River Mile Index 3.3, Stream Code 15954

Receiving Waters: Bells Gap Run (TSF)

Type of Effluent: Water Treatment Effluent

1. The permittee is authorized to discharge during the period from **April 1, 2016** through **March 31, 2021**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	9.0 Daily Max	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. B. For Outfall 101, Latitude 40° 37' 12.00", Longitude 78° 22' 47.00", River Mile Index 3.3, Stream Code 15954

Receiving Waters: Bells Gap Run (TSF)

Type of Effluent: Water Treatment Effluent

1. The permittee is authorized to discharge during the period from **April 1, 2016** through **March 31, 2021**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	75	2/month	8-Hr Composite
Nitrate-Nitrite as N	Report SEMI AVG	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	8-Hr Composite
Total Nitrogen (lbs/year)	XXX	Report SEMI AVG	XXX	XXX	XXX	XXX	1/6 months	Calculation
Total Kjeldahl Nitrogen	Report SEMI AVG	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	8-Hr Composite
Total Phosphorus (lbs/year)	XXX	Report SEMI AVG	XXX	XXX	XXX	XXX	1/6 months	8-Hr Composite
Aluminum, Total	7.0	14.0 Daily Max	XXX	3.5	7.0	8.7	2/month	8-Hr Composite
Iron, Total	Report	Report Daily Max	XXX	2.0	4.0	5	2/month	8-Hr Composite
Manganese, Total	Report	Report Daily Max	XXX	1.0	2.0	2.5	2/month	8-Hr Composite



### **3.0 Facility NPDES Compliance History**

#### **3.1 Summary of Inspections**

A summary of the most recent inspections during the existing permit review cycle is as follows.

The DEP inspector noted the following during the inspection.

02/24/2016:

- The facility was adding polymer to the backwash water to aid in settling.
- Sludge from the settling tanks goes to outdoor drying beds prior to disposal at the landfill. The drain water from the beds is mixed with the plant's water intake.

03/24/2017:

- pH of the diversion flow was checked by the plant operator if discharge occurs during the visit to the plant. Otherwise, the diversion pH was monitored by an in-line meter.
- The facility was adding polymer to the backwash water to aid in settling.

04/17/2018:

- An 8-hr composite sample was required by the NPDES permit but the facility usually collects a 24-hr sample. The composite sampler runs daily in the event the operators are not at the plant during a discharge event.
- Effluent pH results should only be reported for days there is an effluent discharge from the plant.
- Polymer was no longer being added to the backwash water.

04/17/2019:

- The facility discharges from both the filter backwash and the diversion flow. The backwash water is treated in a settling tank before discharge. The diversion flow is composed of unchlorinated treated drinking water.
- The diversion pH was monitored by an in-line meter and monitored through SCADA.
- The facility was advised to amend their DMR for nutrient reporting due to errors.

#### **3.2 Summary of DMR Data**

A review of approximately 1-year of DMR data shows that the monthly average flow data for the facility. The maximum average flow data for the DMR reviewed was 0.2735 MGD in January 2021. The design capacity of the treatment system is 0.24 MGD.

The off-site laboratory used for the analysis of the parameters was Fairway Laboratories located at 2019 9<sup>th</sup> Avenue, Altoona, PA 16602.

DMR Data for Outfall 001 (from March 1, 2020 to February 28, 2021)

Parameter	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20
Flow (MGD) Average Monthly	0.0007	0.2735	0.1219	0.0315	0.0507		0.0031	0.0348	0.0150	0.1625	0.0446	0.0646
Flow (MGD) Daily Maximum	0.0007	0.2735	0.2872	0.0451	0.0985		0.0082	0.0541	0.0255	0.3779	0.1739	0.1281
pH (S.U.) Instantaneous Minimum	7.08	7.08	6.69	6.77	6.72							
pH (S.U.) Minimum							6.82	6.78	6.78	6.7	6.79	6.92
pH (S.U.) Daily Maximum	7.08	7.08	7.01	6.94	6.89		7.00	7.09	7.09	7.1	7.51	7.19
TRC (mg/L) Average Monthly	0.05	0.02	< 0.02	< 0.02	< 0.02							
TRC (mg/L) Instantaneous Maximum	0.05	0.02	0.04	0.05	0.03							

DMR Data for Outfall 101 (from March 1, 2020 to February 28, 2021)

Parameter	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20
Flow (MGD) Average Monthly	0.0865	0.0904	0.0950	0.0995	0.0922	0.0892	0.0854	0.07409	0.0727	0.0652	0.0628	0.0656
Flow (MGD) Daily Maximum	0.1306	0.1368	0.1674	0.128	0.1284	0.1389	0.1294	0.1164	0.1275	0.1099	0.1138	0.102
pH (S.U.) Instantaneous Minimum	6.77	6.75	6.69	6.80	6.89	6.82						
pH (S.U.) Minimum							6.96	6.86	6.79	6.76	6.72	6.87
pH (S.U.) Instantaneous Maximum	7.23	7.14	7.15	7.1	7.17	7.15						
pH (S.U.) Maximum							7.28	7.20	7.05	7.12	7.07	7.50
TSS (mg/L) Average Monthly	3	< 2.0	< 2	< 3	< 2	< 2.0	< 2	< 2	< 2	< 4	< 2	< 2

**NPDES Permit Fact Sheet  
Altoona City Water System**

**NPDES Permit No. PA0085537**

TSS (mg/L) Daily Maximum	3.7	3.9	< 2	4	3.2	< 2.0	2.7	2.3	2.4	9.8	2.9	3.4
Nitrate-Nitrite (lbs/day) Average Monthly						< 0.3						
Nitrate-Nitrite (lbs/day) Semi-Annual Average			0.2									
Nitrate-Nitrite (mg/L) Average Monthly						< 0.48						
Nitrate-Nitrite (mg/L) Semi-Annual Average			0.46									
Total Nitrogen (lbs/year) Semi-Annual Average			< 0.8									
Total Nitrogen (lbs) Total Annual						< 1						
TKN (lbs/day) Average Monthly						< 0.6						
TKN (lbs/day) Semi-Annual Average			< 0.5									
TKN (mg/L) Average Monthly						1						
TKN (mg/L) Semi-Annual Average			< 1.0									
Total Phosphorus (lbs/year) Semi-Annual Average			< 0.1									
Total Phosphorus (lbs) Total Annual						< 0.07						
Total Aluminum (lbs/day) Average Monthly	0.3	0.40	0.2	0.3	0.2	0.1	0.2	0.1	0.2	0.4	0.3	0.3
Total Aluminum (lbs/day) Daily Maximum	0.4	1.1	0.2	0.5	0.3	0.4	0.4	0.4	0.4	0.6	0.6	0.70
Total Aluminum (mg/L) Average Monthly	0.5	0.5	0.3	0.4	0.2	0.2	0.3	0.3	0.3	0.9	0.6	0.5
Total Aluminum (mg/L) Daily Maximum	0.776	1.041	0.451	0.706	0.569	0.338	0.385	0.669	0.389	1.85	1.193	0.974

**NPDES Permit Fact Sheet  
Altoona City Water System**

**NPDES Permit No. PA0085537**

Total Iron (lbs/day) Average Monthly	< 0.04	< 0.04	< 0.03	< 0.07	< 0.05	< 0.04	< 0.05	< 0.03	< 0.03	< 0.04	< 0.03	< 0.03
Total Iron (lbs/day) Daily Maximum	< 0.05	0.06	< 0.05	0.1	0.07	0.07	0.08	0.07	0.05	0.07	0.05	0.05
Total Iron (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
Total Iron (mg/L) Daily Maximum	0.068	0.058	0.054	0.149	0.147	0.064	0.082	0.112	0.06	0.203	0.085	0.071
Total Manganese (lbs/day) Average Monthly	< 0.04	0.06	0.06	0.1	0.08	< 0.04	< 0.07	< 0.07	0.06	0.05	0.05	< 0.04
Total Manganese (lbs/day) Daily Maximum	< 0.05	0.1	0.06	0.2	0.1	0.06	0.1	0.28	0.1	0.09	0.1	0.07
Total Manganese (mg/L) Average Monthly	< 0.1	0.1	0.1	0.1	0.1	< 0.1	< 0.1	< 0.1	0.1	0.1	0.1	< 0.1
Total Manganese (mg/L) Daily Maximum	0.081	0.094	0.124	0.259	0.271	0.058	0.148	0.473	0.121	0.28	0.183	0.105

**3.3 Non-Compliance**

**3.3.1 Non-Compliance- NPDES Effluent**

A summary of the non-compliance to the permit limits for the existing permit cycle is as follows.

From the DMR data beginning in April 1, 2016 to February 21, 2021, the following were observed effluent non-compliances.

**Summary of Non-Compliance with NPDES Effluent Limits  
Beginning April 1, 2016 and Ending February 21, 2021**

NON COMPLIANCE DATE	PARAMETER	SAMPLE VALUE	VIOLATION CONDITION	PERMIT VALUE	UNIT OF MEASURE	STATISTICAL BASE CODE
11/27/2017	Aluminum, Total	8.908	>	7.0	mg/L	Daily Maximum

**3.3.2 Non-Compliance- Enforcement Actions**

A summary of the non-compliance enforcement actions for the current permit cycle is as follows:

Beginning in April 1, 2016 to April 1, 2021, there were no observed enforcement actions.

**3.4 Summary of Biosolids Disposal**

A summary of the biosolids disposed of from the facility is as follows.

The facility did not have any biosolids disposal for 2020.

**3.5 Open Violations**

No open violations existed as of April 2021.

**4.0 Receiving Waters and Water Supply Information Detail Summary**

**4.1 Receiving Waters**

The receiving waters has been determined to be Bells Gap Run. The sequence of receiving streams that Bells Gap Run discharges into are the Little Juniata River, the Juniata River, and the Susquehanna River which eventually drains into the Chesapeake Bay.

**4.2 Public Water Supply (PWS) Intake**

The closest PWS to the subject facility is Mifflintown Municipal Authority (PWS ID #4340008) located approximately 92 miles downstream of the subject facility on the Juniata River. Based upon the distance and the flow rate of the facility, the PWS should not be impacted.

**4.3 Class A Wild Trout Streams**

Class A Wild Trout Streams are waters that support a population of naturally produced trout of sufficient size and abundance to support long-term and rewarding sport fishery. DEP classifies these waters as high-quality coldwater fisheries.

The information obtained from EMAP suggests that no Class A Wild Trout Fishery will be impacted by this discharge.

**4.4 2020 Integrated List of All Waters (303d Listed Streams):**

Section 303(d) of the Clean Water Act requires States to list all impaired surface waters not supporting uses even after appropriate and required water pollution control technologies have been applied. The 303(d) list includes the reason for impairment which may be one or more point sources (i.e. industrial or sewage discharges) or non-point sources (i.e.

abandoned mine lands or agricultural runoff and the pollutant causing the impairment such as metals, pH, mercury or siltation).

States or the U.S. Environmental Protection Agency (EPA) must determine the conditions that would return the water to a condition that meets water quality standards. As a follow-up to listing, the state or EPA must develop a Total Maximum Daily Load (TMDL) for each waterbody on the list. A TMDL identifies allowable pollutant loads to a waterbody from both point and non-point sources that will prevent a violation of water quality standards. A TMDL also includes a margin of safety to ensure protection of the water.

The water quality status of Pennsylvania's waters uses a five-part categorization (lists) of waters per their attainment use status. The categories represent varying levels of attainment, ranging from Category 1, where all designated water uses are met to Category 5 where impairment by pollutants requires a TMDL for water quality protection.

**The receiving waters is listed in the 2020 Pennsylvania Integrated Water Quality Monitoring and Assessment Report as a Category 2 waterbody. The surface waters is an attaining stream that supports aquatic life, recreational uses, and potable water supply. The designated use has been classified as protected waters for trout stocking fishes (TSF) and migratory fishes (MF).**

#### **4.5 Low Flow Stream Conditions**

Water quality modeling estimates are based upon conservative data inputs. The data are typically estimated using either a stream gauge or through USGS web based StreamStats program. The NPDES effluent limits are based upon the combined flows from both the stream and the facility discharge.

A conservative approach to estimate the impact of the facility discharge using values which minimize the total combined volume of the stream and the facility discharge. The volumetric flow rate for the stream is based upon the seven-day, 10-year low flow (Q710) which is the lowest estimated flow rate of the stream during a 7 consecutive day period that occurs once in 10 -year time period. The facility discharge is based upon a known design capacity of the subject facility.

The closest WQN station to the subject facility is the Little Juniata River station at Spruce Creek, PA (WQN217). This WQN station is located approximately 7 miles downstream of the subject facility.

The closest gauge station to the subject facility is the Little Juniata River station at Spruce Creek, PA (USGS station number 1558000). This gauge station is located approximately 7 miles downstream of the subject facility.

For WQM modeling, pH and stream water temperature data from the water quality network station was used. pH was estimated to be 8.2 and the stream water temperature was estimated to be 17.9 C.

The hardness of the stream was estimated by collecting a sample upstream of the facility. The sampling result was 23.8 mg/l CaCO<sub>3</sub>.

The low flow yield and the Q710 for the subject facility was estimated as shown below.

Gauge Station Data		
USGS Station Number	Little Juniata River at Spruce Creek, PA	
Station Name	01558000	
<a href="#">Q@Station</a>	59	ft <sup>3</sup> /sec
<a href="#">Q@Tyrone WWTP</a>	10.06	ft <sup>3</sup> /sec
<a href="#">Q@Altoona WWTP</a>	10.83	ft <sup>3</sup> /sec
<a href="#">Q@Logan WWTP</a>	1.08	ft <sup>3</sup> /sec
Q710 Adj	37.03	ft <sup>3</sup> /sec
Drainage Area (DA)	220	mi <sup>2</sup>
<b>Calculations</b>		
The low flow yield of the gauge station is:		
Low Flow Yield (LFY) = Q710 / DA		
LFY = 37.03 ft <sup>3</sup> /sec / 220 mi <sup>2</sup>		
LFY =	0.1683	ft <sup>3</sup> /sec/mi <sup>2</sup>
The low flow at the subject site is based upon the DA of		
	20	mi <sup>2</sup>
Q710 = (LFY@gauge station)(DA@Subject Site)		
Q710 = (0.1683 ft <sup>3</sup> /sec/mi <sup>2</sup> )(20 mi <sup>2</sup> )		
Q710 =	3.366	ft <sup>3</sup> /sec



**4.6 Summary of Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.24</u>
Latitude	<u>40° 37' 12.00"</u>	Longitude	<u>-78° 22' 47.00"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Water Treatment Effluent</u>			
Receiving Waters	<u>Bells Gap Run (TSF)</u>	Stream Code	<u>15954</u>
NHD Com ID	<u>65605732</u>	RMI	<u>3.3</u>
Drainage Area	<u>20</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1683</u>
Q <sub>7-10</sub> Flow (cfs)	<u>3.366</u>	Q <sub>7-10</sub> Basis	<u>StreamStats/StreamGauge</u>
Elevation (ft)	<u>1280</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>11-A</u>	Chapter 93 Class.	<u>TSF, MF</u>
Existing Use	<u>Same as Chapter 93 class.</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining supports aquatic life</u>		
Cause(s) of Impairment	<u>Not appl.</u>		
Source(s) of Impairment	<u>Not appl.</u>		
TMDL Status	<u>Not appl.</u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>8.2</u>	WQN217; median July to Sept	<u></u>
Temperature (°C)	<u>17.9</u>	WQN217; median July to Sept	<u></u>
Hardness (mg/L)	<u>23.8</u>	Data from NPDES application	<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Mifflintown Municipal Authority</u>		
PWS Waters	<u>Juniata River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u>37</u>	Distance from Outfall (mi)	<u>92</u>

**5.0: Overview of Presiding Water Quality Standards**

**5.1 General**

There are at least six (6) different policies which determines the effluent performance limits for the NPDES permit. The policies are technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), antidegradation, total maximum daily loading (TMDL), anti-backsliding, and whole effluent toxicity (WET) The effluent performance limitations enforced are the selected permit limits that is most protective to the designated use of the receiving waters. An overview of each of the policies that are applicable to the subject facility has been presented in Section 6.

**5.2.1 Technology-Based Limitations**

TBEL treatment requirements under section 301(b) of the Act represent the minimum level of control that must be imposed in a permit issued under section 402 of the Act (40 CFR 125.3).

Permit limits for water treatment plant wastes are subject to handling and disposal of water treatment plant (WTP) using Best Practicable Control Technology (BPCT) currently available. Wastewater from treatment of WTP sludges and filter backwash shall have the following permit limits.

Parameter	Monthly Average	Daily Max
	mg/l	mg/l
Suspended Solids	30	60
Iron (total)	2	4
Aluminum (total)	4	8
Manganese (total)	1	2
pH	6 - 9	-----
TRC	0.5	1

Notes:

Source: TECHNOLOGY-BASED CONTROL  
REQUIREMENTS FOR WATER TREATMENT PLANT  
WASTES

**5.3 Water Quality-Based Limitations**

WQBEL are based on the need to attain or maintain the water quality criteria and to assure protection of designated and existing uses (PA Code 25, Chapter 92a.2). The subject facility that is typically enforced is the more stringent limit of either the TBEL or the WQBEL.

Determination of WQBEL is calculated by spreadsheet analysis or by a computer modeling program developed by DEP. DEP permit engineers utilize the following computing programs for WQBEL permit limitations: (1) MS Excel worksheet for Total Residual Chlorine (TRC); (2) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen Version 1.1 (WQM Model) and (3) Toxics using DEP Toxics Management Spreadsheet for Toxics pollutants.

**5.3.1 Water Quality Modeling 7.0**

The subject facility is not subject to water quality modeling.

**5.3.2 Toxics Modeling**

The Toxics Management Spreadsheet model is a computer model that is used to determine effluent limitations for toxics (and other substances) for single discharge wasteload allocations. This computer model uses a mass-balance water quality

analysis that includes consideration for mixing, first-order decay, and other factors used to determine recommended water quality-based effluent limits. Toxics Management Spreadsheet does not assume that all discharges completely mix with the stream. The point of compliance with water quality criteria are established using criteria compliance times (CCTs). The available CCTs are either acute fish criterion (AFC), chronic fish criterion (CFC), or human health criteria (THH & CRL).

**Acute Fish Criterion (AFC)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 15 minutes travel time downstream of the current discharge) or the complete mix time whichever comes first. AFC is evaluated at Q710 conditions.

**Chronic Fish Criterion (CFC)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the complete mix time whichever comes first. CFC is evaluated at Q710 conditions.

**Threshold Human Health (THH)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the estimated travel time downstream to the nearest potable water supply intake whichever comes first. THH is evaluated at Q710 conditions.

**Cancer Risk Level (CRL)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the complete mix time whichever comes first. CRL is evaluated at Qh (harmonic mean or normal flow) conditions.

The Toxics Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

The input values utilized for the modeling are summarized in the table which can be found in Attachment B.

#### **5.3.2.1 Determining if NPDES Permit Will Require Monitoring/Limits in the Proposed Permit for Toxic Pollutants**

To determine if Toxics modeling is necessary, DEP has developed a Toxics Management Spreadsheet to identify toxics of concern. Toxic pollutants whose maximum concentrations as reported in the permit application or on DMRs are greater than the most stringent applicable water quality criterion are pollutants of concern. A Reasonable Potential Analysis was utilized to determine (a) if the toxic parameters modeled would require monitoring or (b) if permit limitations would be required for the parameters. The toxics reviewed for reasonable potential were the pollutants in Groups 1 and 2.

For parameters in Groups 1 and 2, the Toxics Management Spreadsheet indicated modeling was not required since the concentrations measured in the effluent sample were not within the normal range for safe water quality protection.

The Toxics Management Spreadsheet was utilized to determine maximum usages for additives used at the facility for cleaning.

**Applicable monitoring or permit limits for toxics are summarized in Section 6. The toxics requiring monitoring and limits are additives used at the facility for cleaning the plant.**

**The Toxics Management Spreadsheet output has been included in Attachment B.**

#### **5.3.3 Whole Effluent Toxicity (WET)**

The facility is not subject to WET.

#### **5.4 Total Maximum Daily Loading (TMDL)**

##### **5.4.1 TMDL**

The goal of the Clean Water Act (CWA), which governs water pollution, is to ensure that all of the Nation's waters are clean and healthy enough to support aquatic life and recreation. To achieve this goal, the CWA created programs designed to regulate and reduce the amount of pollution entering United States waters. Section 303(d) of the CWA requires states to assess their waterbodies to identify those not meeting water quality standards. If a waterbody is not meeting standards, it is listed as impaired and reported to the U.S. Environmental Protection Agency. The state then develops a plan to clean up

the impaired waterbody. This plan includes the development of a Total Maximum Daily Load (TMDL) for the pollutant(s) that were found to be the cause of the water quality violations. A Total Maximum Daily Load (TMDL) calculates the maximum amount of a specific pollutant that a waterbody can receive and still meet water quality standards.

Pennsylvania has committed to restoring all impaired waters by developing TMDLs and TMDL alternatives for all impaired waterbodies. The TMDL serves as the starting point or planning tool for restoring water quality.

#### **5.4.1.1 Local TMDL**

The subject facility does not discharge into a local TMDL.

#### **5.4.1.2 Chesapeake Bay TMDL Requirement**

The Chesapeake Bay Watershed is a large ecosystem that encompasses approximately 64,000 square miles in Maryland, Delaware, Virginia, West Virginia, Pennsylvania, New York and the District of Columbia. An ecosystem is composed of interrelated parts that interact with each other to form a whole. All of the plants and animals in an ecosystem depend on each other in some way. Every living thing needs a healthy ecosystem to survive. Human activities affect the Chesapeake Bay ecosystem by adding pollution, using resources and changing the character of the land.

Most of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the federal Water Pollution Control Act ("Clean Water Act"), 33 U.S.C. § 1313(d). While the Chesapeake Bay is outside the boundaries of Pennsylvania, more than half of the State lies within the watershed. Two major rivers in Pennsylvania are part of the Chesapeake Bay Watershed. They are (a) the Susquehanna River and (b) the Potomac River. These two rivers total 40 percent of the entire Chesapeake Bay watershed.

The overall management approach needed for reducing nitrogen, phosphorus and sediment are provided in the Bay TMDL document and the Phase I, II, and III WIPs which is described in the Bay TMDL document and Executive Order 13508.

The Bay TMDL is a comprehensive pollution reduction effort in the Chesapeake Bay watershed identifying the necessary pollution reductions of nitrogen, phosphorus and sediment across the seven Bay watershed jurisdictions of Delaware, Maryland, New York, Pennsylvania, Virginia, West Virginia and the District of Columbia to meet applicable water quality standards in the Bay and its tidal waters.

The Watershed Implementation Plans (WIPs) provides objectives for how the jurisdictions in partnership with federal and local governments will achieve the Bay TMDL's nutrient and sediment allocations.

Phase 3 WIP provides an update on Chesapeake Bay TMDL implementation activities for point sources and DEP's current implementation strategy for wastewater. The latest revision of the supplement was December 17, 2019.

The Chesapeake Bay TMDL (Appendix Q) categorizes point sources into four sectors:

- Sector A- significant sewage dischargers;
- Sector B- significant industrial waste (IW) dischargers;
- Sector C- non-significant dischargers (both sewage and IW facilities); and
- Sector D- combined sewer overflows (CSOs).

All sectors contain a listing of individual facilities with NPDES permits that were believed to be discharging at the time the TMDL was published (2010). All sectors with the exception of the non-significant dischargers have individual wasteload allocations (WLAs) for TN and TP assigned to specific facilities. Non-significant dischargers have a bulk or aggregate allocation for TN and TP based on the facilities in that sector that were believed to be discharging at that time and their estimated nutrient loads.

Based upon the supplement the subject facility has been categorized as a Sector C discharger. The supplement defines Sector C non-significant discharger that includes sewage facilities (Phase 4 facilities:  $\geq 0.2$  MGD and  $< 0.4$  MGD and Phase 5 facilities:  $> 0.002$  MGD and  $< 0.2$  MGD), small flow/single residence sewage treatment facilities ( $\leq 0.002$  MGD), and non-significant IW facilities, all of which may be covered by statewide General Permits or may have individual NPDES permits.

At this time, there are approximately 850 Phase 4 and 5 sewage facilities, approximately 715 small flow sewage treatment facilities covered by a statewide General Permit, and approximately 300 non-significant IW facilities.

For non-significant IW facilities, monitoring and reporting of TN and TP will be required throughout the permit term in renewed or amended permits anytime the facility has the potential to introduce a net TN or TP increase to the load contained within the intake water used in processing.

In general, facilities that discharge groundwater and cooling water with no addition of chemicals containing N or P do not require monitoring. Monitoring for facilities with other discharges will generally conform to the following minimum sampling frequencies, with the permit writer having final discretion: Phase 3 WIP Wastewater Supplement Revised, December 17, 2019

Non-significant IW facilities that propose expansion or production increases and as a result will discharge at least 75 lbs/day TN or 25 lbs/day TP (on an annual average basis), will be classified as Significant IW dischargers and receive Cap Loads in their permits based on existing performance (existing TN/TP concentrations at current average annual flow).

In general, for new non-significant IW discharges (including existing facilities discharging without a permit), DEP will issue permits containing Cap Loads of "0" and these facilities will be expected to purchase credits and/or apply offsets to achieve compliance.

**Due to Chesapeake Bay WIP, monitoring shall be required 2x/yr. The facility is a drinking water plant. Minimal contributions from nitrogen and phosphorus is anticipated.**

### **5.5 Anti-Degradation Requirement**

Chapter 93.4a of the PA regulations requires that surface water of the Commonwealth of Pennsylvania may not be degraded below levels that protect the existing uses. The regulations specifically state that *Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected*. Antidegradation requirements are implemented through DEP's guidance manual entitled Water Quality Antidegradation Implementation Guidance (Document #391-0300-02).

The policy requires DEP to protect the existing uses of all surface waters and the existing quality of High Quality (HQ) and Exceptional Value (EV) Waters. Existing uses are protected when DEP makes a final decision on any permit or approval for an activity that may affect a protected use. Existing uses are protected based upon DEP's evaluation of the best available information (which satisfies DEP protocols and Quality Assurance/Quality Control (QA/QC) procedures) that indicates the protected use of the waterbody.

For a new, additional, or increased point source discharge to an HQ or EV water, the person proposing the discharge is required to utilize a nondischarge alternative that is cost-effective and environmentally sound when compared with the cost of the proposed discharge. If a nondischarge alternative is not cost-effective and environmentally sound, the person must use the best available combination of treatment, pollution prevention, and wastewater reuse technologies and assure that any discharge is nondegrading. In the case of HQ waters, DEP may find that after satisfaction of intergovernmental coordination and public participation requirements lower water quality is necessary to accommodate important economic or social development in the area in which the waters are located. In addition, DEP will assure that cost-effective and reasonable best management practices for nonpoint source control in HQ and EV waters are achieved.

**The subject facility's discharge will be to a non-special protection waters and the permit conditions are imposed to protect existing instream water quality and uses. Neither HQ waters or EV waters is impacted by this discharge.**

### **5.6 Anti-Backsliding**

Anti-backsliding is a federal regulation which prohibits a permit from being renewed, reissued, or modified containing effluent limitations which are less stringent than the comparable effluent limitations in the previous permit (40 CFR 122.I.1 and 40 CFR 122.I.2). A review of the existing permit limitations with the proposed permit limitations confirm that the facility is consistent with anti-backsliding requirements. The facility has proposed effluent limitations that are as stringent as the existing permit.

### **6.0 NPDES Parameter Details**

The basis for the proposed sampling and their monitoring frequency that will appear in the permit for each individual parameter are itemized in this Section. The final limits are the more stringent of technology based effluent treatment (TBEL) requirements, water quality based (WQBEL) limits, TMDL, antidegradation, anti-degradation, or WET.

The reader will find in this section:

- a) a justification of recommended permit monitoring requirements and limitations for each parameter in the proposed NPDES permit;
- b) a summary of changes from the existing NPDES permit to the proposed permit; and
- c) a summary of the proposed NPDES effluent limits.

**6.1 Recommended Monitoring Requirements and Effluent Limitations**

A summary of the recommended monitoring requirements and effluent limitations are itemized in the tables. The tables are categorized by (a) Conventional Pollutants and Disinfection, (b) Nitrogen Species and Phosphorus, and (c) Toxics.

**6.1.1 Conventional Pollutants and Disinfection**

Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection			
Altoona Water Authority- Bellwood Water Treatment Plant; Outfall 001			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
pH (S.U.)	TBEL	Monitoring:	The monitoring frequency shall be daily as a grab sample (Table 6-4).
		Effluent Limit:	Effluent limits may range from pH = 6.0 to 9.0
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-4 and the effluent limits assigned by Chapter 95.2(1).
TRC	TBEL	Monitoring:	The monitoring frequency shall be on a daily basis as a grab sample (Table 6-4).
		Effluent Limit:	The average monthly limit should not exceed 0.5 mg/l and/or 1.6 mg/l as an instantaneous maximum.
		Rationale: Chlorine in both combined (chloramine) and free form is extremely toxic to freshwater fish and other forms of aquatic life (Implementation Guidance Total Residual Chlorine 1). The TRC effluent limitations to be imposed on a discharger shall be the more stringent of either the WQBEL or TBEL requirements and shall be expressed in the NPDES permit as an average monthly and instantaneous maximum effluent concentration (Implementation Guidance Total Residual Chlorine 4). Based on the stream flow rate (lowest 7-day flow rate in 10 years) and the design flow rate of the subject facility calculated by the TRC Evaluation worksheet, the TBEL is more stringent than the WQBEL. The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.48(b)(2)	

**Notes:**

- 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
- 2 Monitoring frequency based on flow rate of 0.24 MGD.
- 3 Table 6-4 (Self Monitoring Requirements for Industrial Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97
- 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)
- 5 Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017

Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection			
Altoona Water Authority- Bellwood Water Treatment Plant; IMP101			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
pH (S.U.)	TBEL	Monitoring:	The monitoring frequency shall be daily as a grab sample (Table 6-4).
		Effluent Limit:	Effluent limits may range from pH = 6.0 to 9.0
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-4 and the effluent limits assigned by Chapter 95.2(1).
TSS	DEP Guidance Document-Water Treatment Plant Wastes	Monitoring:	The monitoring frequency shall be 2x/mo as an 8-hr composite sample (Table 6-4).
		Effluent Limit:	Effluent limits shall not exceed 30 mg/l as an average monthly.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits are defined by DEP Guidance Document- Technology-Based Control Requirements for Water Treatment Plant Wastes- Waste Water from Treatment of WTP Sludges and Filter Backwash
<b>Notes:</b>			
1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other			
2 Monitoring frequency based on flow rate of 0.24 MGD.			
3 Table 6-4 (Self Monitoring Requirements for Industrial Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97			
4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)			
5 Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017			

**6.1.2 Nitrogen Species and Phosphorus**

Summary of Proposed NPDES Parameter Details for Nitrogen Species and Phosphorus			
Altoona Water Authority- Bellwood Water Treatment Plant; IMP101			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
Nitrate-Nitrite as N	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/yr as an 8-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/yr.
Total Nitrogen	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/yr as an 8-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/yr.
TKN	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/yr as an 8-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/yr.
Total Phosphorus	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/yr as an 8-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/yr.
<b>Notes:</b>			
1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other			
2 Monitoring frequency based on flow rate of 0.24 MGD.			
3 Table 6-4 (Self Monitoring Requirements for Industrial Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97			
4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)			
5 Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017			



**6.1.3 Toxics**

**6.1.3.2 Summary of Toxics Monitoring/Limits**

Summary of Proposed NPDES Parameter Details for Toxics			
Altoona Water Authority- Bellwood Water Treatment Plant; IMP101			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
Iron	DEP Guidance Document-Water Treatment Plant Wastes	Monitoring:	The monitoring frequency shall be 2x/mo as an 8-hr composite sample (Table 6-4).
		Effluent Limit:	The performance effluent limit shall not exceed 2.0 mg/l as a monthly average.
		Rationale:	Effluent limits are defined by DEP Guidance Document- Technology-Based Control Requirements for Water Treatment Plant Wastes- Waste Water from Treatment of WTP Sludges and Filter Backwash
Aluminum	Antibacksliding	Monitoring:	The monitoring frequency shall be 2x/mo as an 8-hr composite sample (Table 6-4).
		Effluent Limit:	The performance effluent limit shall not exceed 7.0 lbs/day and 3.5 mg/l as a monthly average.
		Rationale:	Due to antibacksliding regulations, the current limit shall continue to the proposed permit.
Manganese	DEP Guidance Document-Water Treatment Plant Wastes	Monitoring:	The monitoring frequency shall be 2x/mo as an 8-hr composite sample (Table 6-4).
		Effluent Limit:	The performance effluent limit shall not exceed 1.0 mg/l as a monthly average.
		Rationale:	Effluent limits are defined by DEP Guidance Document- Technology-Based Control Requirements for Water Treatment Plant Wastes- Waste Water from Treatment of WTP Sludges and Filter Backwash
Notes:			
1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other			
2 Monitoring frequency based on flow rate of 0.24 MGD.			
3 Table 6-4 (Self Monitoring Requirements for Industrial Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97			
4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)			
5 Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017			

The following table summarizes average monthly limits and maximum daily limits for additives used at the facility.

Chemical Additive Usage Limits		
Pollutant	Maximum Daily Limit	Average Monthly Limit
	lbs/day	mg/l
Citric Acid	16	5.13
Sodium Hydroxide	3.14	1.01
Sodium Bisulfite Solution 42%	39	12.5
Sequest/Corrosion Inhibitor	109	34.9

**6.2 Summary of Changes From Existing Permit to Proposed Permit**

A summary of how the proposed NPDES permit differs from the existing NPDES permit is summarized as follows.

Changes in Permit Monitoring or Effluent Quality		
Parameter	Existing Permit	Draft Permit
Additives	The existing permit has maximum daily usages for various additives	Based upon the Toxics Management Spreadsheet, the proposed permit has amended maximum daily usages. The amended usages are minor in comparison to the existing permit.

**6.3.1 Summary of Proposed NPDES Effluent Limits**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

The proposed NPDES effluent limitations are summarized in the table below.

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. A. For Outfall 001, Latitude 40° 37' 12.00", Longitude 78° 22' 47.00", River Mile Index 3.3, Stream Code 15954

Receiving Waters: Bells Gap Run (TSF)

Type of Effluent: Water Treatment Effluent

1. The permittee is authorized to discharge during the period from Permit Effective Date through Permit Expiration Date.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX 8.0	XXX	XXX 8.0	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	Inst Min	XXX	Daily Max	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

I. B. For Outfall 101, Latitude 40° 37' 12.00", Longitude 78° 22' 47.00", River Mile Index 3.3, Stream Code 15954  
 Receiving Waters: Bells Gap Run (TSF)

Type of Effluent: Water Treatment Effluent

1. The permittee is authorized to discharge during the period from Permit Effective Date through Permit Expiration Date.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX 8.0	XXX	XXX	XXX	1/day	Measured
pH (S.U.)	XXX	XXX	Inst Min	XXX	XXX	9.0	1/day	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	75	2/month	Composite
Nitrate-Nitrite as N	Report SEMI AVG	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	8-Hr Composite
Total Nitrogen (lbs/year)	XXX	Report SEMI AVG	XXX	XXX	XXX	XXX	1/6 months	Calculation
Total Kjeldahl Nitrogen	Report SEMI AVG	XXX	XXX	Report SEMI AVG	XXX	XXX	1/6 months	8-Hr Composite
Total Phosphorus (lbs/year)	XXX	Report SEMI AVG	XXX	XXX	XXX	XXX	1/6 months	8-Hr Composite
Aluminum, Total	7.0	Daily Max	XXX	3.5	7.0	8.7	2/month	Composite
Iron, Total	Report	Daily Max	XXX	2.0	4.0	5	2/month	8-Hr Composite
Manganese, Total	Report	Daily Max	XXX	1.0	2.0	2.5	2/month	8-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 101

### 6.3.2 Summary of Proposed Permit Part C Conditions

The subject facility has the following Part C conditions.

- Chlorine Minimization
- Solids Management for Non-Lagoon Treatment Systems
- Chesapeake Bay Nutrient Definitions
- Chemical Additives


Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: <i>New and Reissuance Industrial Waste and Industrial Stormwater</i> , rev. October 11, 2013
<input type="checkbox"/>	Other: [redacted]

# Attachment A

## Stream Stats/Gauge Data

## StreamStats Report

Region ID: PA  
 Workspace ID: PA20210429141224449000  
 Clicked Point (Latitude, Longitude): 40.61998, -78.37953  
 Time: 2021-04-29 10:12:42 -0400



Altoona Water Authority- Bellwood Water Plant PA0085537 Modeling Point #1 April 2021

Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	19.9	square miles
PRECIP	Mean Annual Precipitation	42	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	1.83	miles per square mile

Parameter Code	Parameter Description	Value	Unit
ROCKDEP	Depth to rock	4.7	feet
CARBON	Percentage of area of carbonate rock	0	percent

Low-Flow Statistics Parameters [99.9 Percent (19.9 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	19.9	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	42	inches	35	50.4
STRDEN	Stream Density	1.83	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.7	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Flow Report [99.9 Percent (19.9 square miles) Low Flow Region 2]

PlI: Prediction Interval-Lower, Plu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	2.52	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	3.34	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	1.27	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	1.66	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	2.5	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)



USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.5.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.1.1

**Table 1.** List of U.S. Geological Survey streamgauge locations in and near Pennsylvania with updated streamflow statistics.—Continued  
 [Latitude and Longitude in decimal degrees; mi<sup>2</sup>, square miles]

Streamgauge number	Streamgauge name	Latitude	Longitude	Drainage area (mi <sup>2</sup> )	Regulated <sup>1</sup>
01541303	West Branch Susquehanna River at Hyde, Pa.	41.005	-78.457	474	Y
01541308	Bradley Run near Ashville, Pa.	40.509	-78.584	6.77	N
01541500	Clearfield Creek at Dimeling, Pa.	40.972	-78.406	371	Y
01542000	Moshannon Creek at Osceola Mills, Pa.	40.850	-78.268	68.8	N
01542500	WB Susquehanna River at Karthaus, Pa.	41.118	-78.109	1,462	Y
01542810	Waldy Run near Emporium, Pa.	41.579	-78.293	5.24	N
01543000	Driftwood Branch Sinnemahoning Creek at Sterling Run, Pa.	41.413	-78.197	272	N
01543500	Sinnemahoning Creek at Sinnemahoning, Pa.	41.317	-78.103	685	N
01544000	First Fork Sinnemahoning Creek near Sinnemahoning, Pa.	41.402	-78.024	245	Y
01544500	Kettle Creek at Cross Fork, Pa.	41.476	-77.826	136	N
01545000	Kettle Creek near Westport, Pa.	41.320	-77.874	233	Y
01545500	West Branch Susquehanna River at Renovo, Pa.	41.325	-77.751	2,975	Y
01545600	Young Womans Creek near Renovo, Pa.	41.390	-77.691	46.2	N
01546000	North Bald Eagle Creek at Milesburg, Pa.	40.942	-77.794	119	N
01546400	Spring Creek at Houserville, Pa.	40.834	-77.828	58.5	N
01546500	Spring Creek near Axemann, Pa.	40.890	-77.794	87.2	N
01547100	Spring Creek at Milesburg, Pa.	40.932	-77.786	142	N
01547200	Bald Eagle Creek below Spring Creek at Milesburg, Pa.	40.943	-77.786	265	N
01547500	Bald Eagle Creek at Blanchard, Pa.	41.052	-77.604	339	Y
01547700	Marsh Creek at Blanchard, Pa.	41.060	-77.606	44.1	N
01547800	South Fork Beech Creek near Snow Shoe, Pa.	41.024	-77.904	12.2	N
01547950	Beech Creek at Monument, Pa.	41.112	-77.702	152	N
01548005	Bald Eagle Creek near Beech Creek Station, Pa.	41.081	-77.549	562	Y
01548500	Pine Creek at Cedar Run, Pa.	41.522	-77.447	604	N
01549000	Pine Creek near Waterville, Pa.	41.313	-77.379	750	N
01549500	Blockhouse Creek near English Center, Pa.	41.474	-77.231	37.7	N
01549700	Pine Creek below Little Pine Creek near Waterville, Pa.	41.274	-77.324	944	Y
01550000	Lycoming Creek near Trout Run, Pa.	41.418	-77.033	173	N
01551500	WB Susquehanna River at Williamsport, Pa.	41.236	-76.997	5,682	Y
01552000	Loyalsock Creek at Loyalsockville, Pa.	41.325	-76.912	435	N
01552500	Muncy Creek near Sonestown, Pa.	41.357	-76.535	23.8	N
01553130	Sand Spring Run near White Deer, Pa.	41.059	-77.077	4.93	N
01553500	West Branch Susquehanna River at Lewisburg, Pa.	40.968	-76.876	6,847	Y
01553700	Chillisquaque Creek at Washingtonville, Pa.	41.062	-76.680	51.3	N
01554000	Susquehanna River at Sumbury, Pa.	40.835	-76.827	18,300	Y
01554500	Shamokin Creek near Shamokin, Pa.	40.810	-76.584	54.2	N
01555000	Penns Creek at Penns Creek, Pa.	40.867	-77.048	301	N
01555500	East Mahantango Creek near Dalmatia, Pa.	40.611	-76.912	162	N
01556000	Frankstown Branch Juniata River at Williamsburg, Pa.	40.463	-78.200	291	N
01557500	Bald Eagle Creek at Tyrone, Pa.	40.684	-78.234	44.1	N
01558000	Little Juniata River at Spruce Creek, Pa.	40.613	-78.141	220	N
01559000	Juniata River at Huntingdon, Pa.	40.485	-78.019	816	LF
01559500	Standing Stone Creek near Huntingdon, Pa.	40.524	-77.971	128	N
01559700	Sulphur Springs Creek near Manns Choice, Pa.	39.978	-78.619	5.28	N
01560000	Dunning Creek at Belden, Pa.	40.072	-78.493	172	N

# Attachment B

## Toxics Management Spreadsheet Output Values



## Discharge Information

Instructions Discharge Stream

Facility: Altoona Water Authority- Bellwood NPDES Permit No.: PA0085537 Outfall No.: 001

Evaluation Type Major Sewage / Industrial Waste Wastewater Description: WTP effluent

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
0.24	23.8	8.2						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	34								
	Chloride (PWS)	mg/L	1.9								
	Bromide	mg/L	< 0.023								
	Sulfate (PWS)	mg/L	19.6								
	Fluoride (PWS)	mg/L	< 0.099								
Group 2	Total Aluminum	µg/L	450								
	Total Antimony	µg/L	< 1								
	Total Arsenic	mg/L	< 0.0015								
	Total Barium	µg/L	38.9								
	Total Beryllium	µg/L	< 2.5								
	Total Boron	mg/L	< 0.0565								
	Total Cadmium	µg/L	< 0.123								
	Total Chromium (III)	mg/L	< 0.00199								
	Hexavalent Chromium	mg/L	< 0.00025								
	Total Cobalt	µg/L	< 2								
	Total Copper	µg/L	< 2.21								
	Free Cyanide	µg/L									
	Total Cyanide	mg/L	< 0.008								
	Dissolved Iron	mg/L	< 0.06								
	Total Iron	mg/L	0.062								
	Total Lead	µg/L	< 0.5								
	Total Manganese	µg/L	203								
	Total Mercury	mg/L	< 0.000104								
	Total Nickel	µg/L	< 2.5								
	Total Phenols (Phenolics) (PWS)	mg/L	< 0.005								
	Total Selenium	µg/L	< 1.67								
	Total Silver	mg/L	< 0.00033								
	Total Thallium	µg/L	< 0.5								
Total Zinc	µg/L	< 12.5									
Total Molybdenum	µg/L	< 0.5									
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									
Carbon Tetrachloride	µg/L	<									
Chlorobenzene	µg/L	<									
Chlorodibromomethane	µg/L	<									
Chloroethane	µg/L	<									
2-Chloroethyl Vinyl Ether	µg/L	<									

Group 3	Chloroform	µg/L	<																				
	Dichlorobromomethane	µg/L	<																				
	1,1-Dichloroethane	µg/L	<																				
	1,2-Dichloroethane	µg/L	<																				
	1,1-Dichloroethylene	µg/L	<																				
	1,2-Dichloropropane	µg/L	<																				
	1,3-Dichloropropylene	µg/L	<																				
	1,4-Dioxane	µg/L	<																				
	Ethylbenzene	µg/L	<																				
	Methyl Bromide	µg/L	<																				
	Methyl Chloride	µg/L	<																				
	Methylene Chloride	µg/L	<																				
	1,1,2,2-Tetrachloroethane	µg/L	<																				
	Tetrachloroethylene	µg/L	<																				
	Toluene	µg/L	<																				
	1,2-trans-Dichloroethylene	µg/L	<																				
	1,1,1-Trichloroethane	µg/L	<																				
	1,1,2-Trichloroethane	µg/L	<																				
Trichloroethylene	µg/L	<																					
Vinyl Chloride	µg/L	<																					
Group 4	2-Chlorophenol	µg/L	<																				
	2,4-Dichlorophenol	µg/L	<																				
	2,4-Dimethylphenol	µg/L	<																				
	4,6-Dinitro-o-Cresol	µg/L	<																				
	2,4-Dinitrophenol	µg/L	<																				
	2-Nitrophenol	µg/L	<																				
	4-Nitrophenol	µg/L	<																				
	p-Chloro-m-Cresol	µg/L	<																				
	Pentachlorophenol	µg/L	<																				
	Phenol	µg/L	<																				
	2,4,6-Trichlorophenol	µg/L	<																				
Group 5	Acenaphthene	µg/L	<																				
	Acenaphthylene	µg/L	<																				
	Anthracene	µg/L	<																				
	Benzidine	µg/L	<																				
	Benzo(a)Anthracene	µg/L	<																				
	Benzo(a)Pyrene	µg/L	<																				
	3,4-Benzofluoranthene	µg/L	<																				
	Benzo(ghi)Perylene	µg/L	<																				
	Benzo(k)Fluoranthene	µg/L	<																				
	Bis(2-Chloroethoxy)Methane	µg/L	<																				
	Bis(2-Chloroethyl)Ether	µg/L	<																				
	Bis(2-Chloroisopropyl)Ether	µg/L	<																				
	Bis(2-Ethylhexyl)Phthalate	µg/L	<																				
	4-Bromophenyl Phenyl Ether	µg/L	<																				
	Butyl Benzyl Phthalate	µg/L	<																				
	2-Chloronaphthalene	µg/L	<																				
	4-Chlorophenyl Phenyl Ether	µg/L	<																				
	Chrysene	µg/L	<																				
	Dibenzo(a,h)Anthracene	µg/L	<																				
	1,2-Dichlorobenzene	µg/L	<																				
	1,3-Dichlorobenzene	µg/L	<																				
	1,4-Dichlorobenzene	µg/L	<																				
	3,3-Dichlorobenzidine	µg/L	<																				
	Diethyl Phthalate	µg/L	<																				
	Dimethyl Phthalate	µg/L	<																				
	DI-n-Butyl Phthalate	µg/L	<																				
	2,4-Dinitrotoluene	µg/L	<																				
	2,6-Dinitrotoluene	µg/L	<																				
	DI-n-Octyl Phthalate	µg/L	<																				
	1,2-Diphenylhydrazine	µg/L	<																				
	Fluoranthene	µg/L	<																				
	Fluorene	µg/L	<																				
Hexachlorobenzene	µg/L	<																					
Hexachlorobutadiene	µg/L	<																					
Hexachlorocyclopentadiene	µg/L	<																					
Hexachloroethane	µg/L	<																					
Indeno(1,2,3-cd)Pyrene	µg/L	<																					

	Isophorone	µg/L	<																		
	Naphthalene	µg/L	<																		
	Nitrobenzene	µg/L	<																		
	n-Nitrosodimethylamine	µg/L	<																		
	n-Nitrosodi-n-Propylamine	µg/L	<																		
	n-Nitrosodiphenylamine	µg/L	<																		
	Phenanthrene	µg/L	<																		
	Pyrene	µg/L	<																		
	1,2,4-Trichlorobenzene	µg/L	<																		
Group 6	Aldrin	µg/L	<																		
	alpha-BHC	µg/L	<																		
	beta-BHC	µg/L	<																		
	gamma-BHC	µg/L	<																		
	delta BHC	µg/L	<																		
	Chlordane	µg/L	<																		
	4,4-DDT	µg/L	<																		
	4,4-DDE	µg/L	<																		
	4,4-DDD	µg/L	<																		
	Dieldrin	µg/L	<																		
	alpha-Endosulfan	µg/L	<																		
	beta-Endosulfan	µg/L	<																		
	Endosulfan Sulfate	µg/L	<																		
	Endrin	µg/L	<																		
	Endrin Aldehyde	µg/L	<																		
	Heptachlor	µg/L	<																		
	Heptachlor Epoxide	µg/L	<																		
	PCB-1016	µg/L	<																		
	PCB-1221	µg/L	<																		
	PCB-1232	µg/L	<																		
	PCB-1242	µg/L	<																		
	PCB-1248	µg/L	<																		
PCB-1254	µg/L	<																			
PCB-1260	µg/L	<																			
PCBs, Total	µg/L	<																			
Toxaphene	µg/L	<																			
2,3,7,8-TCDD	ng/L	<																			
Group 7	Gross Alpha	pCi/L																			
	Total Beta	pCi/L	<																		
	Radium 226/228	pCi/L	<																		
	Total Strontium	µg/L	<																		
	Total Uranium	µg/L	<																		
Osmotic Pressure	mOsi/kg																				
	Citric Acid	mg/L																			
	Sodium Hydroxide	mg/L																			
	Sodium Hypochlorite	mg/L																			
	Sodium Bisulfite Solution 42%	mg/L																			
	SeaQuest/Corrosion Inhibitor	mg/L																			



Stream / Surface Water Information

Altoona Water Authority- Bellwood, NPDES Permit No. PA0085537, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: Bells Gap Run No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	015954	3.3	1280	20			Yes
End of Reach 1	015954	1.42	1137	22.5			Yes

Q<sub>7-10</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	3.3	0.1683										23.8	6.88		
End of Reach 1	1.42	0.1683										23.8	6.88		

Q<sub>n</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	3.3														
End of Reach 1	1.42														





## Model Results

Altoona Water Authority- Bellwood, NPDES Permit No. PA0085537, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min): 9.871

PMF: 1

Analysis Hardness (mg/l): 23.8

Analysis pH: 6.92

Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	7,549	
Total Antimony	0	0		0	1,100	1,100	11,073	
Total Arsenic	0	0		0	340	340	3,422	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	211,385	
Total Boron	0	0		0	8,100	8,100	81,534	
Total Cadmium	0	0		0	0.498	0.5	4.99	Chem Translator of 1.004 applied
Total Chromium (III)	0	0		0	175.837	556	5,601	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	164	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	956	
Total Copper	0	0		0	3.475	3.62	36.4	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	13.134	13.1	132	Chem Translator of 1 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1.400	1.65	16.6	Chem Translator of 0.85 applied
Total Nickel	0	0		0	139.011	139	1,402	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	0.272	0.32	3.23	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	654	
Total Zinc	0	0		0	34.724	35.5	357	Chem Translator of 0.978 applied
Citric Acid	0	0		0	4,620	4,620	46,505	
Sodium Hydroxide	0	0		0	910	910	9,160	
Sodium Hypochlorite	0	0		0	10	10.0	101	



Sodium Bisulfite Solution 42%	0	0	0	11,210	11,210	112,839
SeaQuest/Corrosion Inhibitor	0	0	0	31,250	31,250	314,560

**CFC**      CCT (min):       PMF:       Analysis Hardness (mg/l):       Analysis pH:

Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	2,215	
Total Arsenic	0	0		0	150	150	1,510	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	41,270	
Total Boron	0	0		0	1,600	1,600	16,105	
Total Cadmium	0	0		0	0.091	0.093	0.94	Chem Translator of 0.969 applied
Total Chromium (III)	0	0		0	22.873	26.6	268	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	105	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	191	
Total Copper	0	0		0	2.627	2.74	27.5	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	15,099	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	0.512	0.51	5.15	Chem Translator of 1 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	9.12	Chem Translator of 0.85 applied
Total Nickel	0	0		0	15.440	15.5	156	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.600	4.99	50.2	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	131	
Total Zinc	0	0		0	35.008	35.5	357	Chem Translator of 0.986 applied
Citric Acid	0	0		0	510	510	5,134	
Sodium Hydroxide	0	0		0	100	100.0	1,007	
Sodium Hypochlorite	0	0		0	1.1	1.1	11.1	
Sodium Bisulfite Solution 42%	0	0		0	1,240	1,240	12,482	
SeaQuest/Corrosion Inhibitor	0	0		0	3,470	3,470	34,929	

**THH**      CCT (min):       PMF:       Analysis Hardness (mg/l):       Analysis pH:

Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	56.4	
Total Arsenic	0	0		0	10	10.0	101	

Total Barium	0	0	0	2,400	2,400	24,158
Total Boron	0	0	0	3,100	3,100	31,204
Total Cadmium	0	0	0	N/A	N/A	N/A
Total Chromium (III)	0	0	0	N/A	N/A	N/A
Hexavalent Chromium	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	N/A	N/A	N/A
Dissolved Iron	0	0	0	300	300	3,020
Total Iron	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	1,000	1,000	10,066
Total Mercury	0	0	0	0.050	0.05	0.5
Total Nickel	0	0	0	610	610	6,140
Total Phenols (Phenolics) (PWS)	0	0	0	5	5.0	N/A
Total Selenium	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0.24	0.24	2.42
Total Zinc	0	0	0	N/A	N/A	N/A
Citric Acid	0	0	0	N/A	N/A	N/A
Sodium Hydroxide	0	0	0	N/A	N/A	N/A
Sodium Hypochlorite	0	0	0	210	210	2,114
Sodium Bisulfite Solution 42%	0	0	0	N/A	N/A	N/A
SeaQuest/Corrosion Inhibitor	0	0	0	N/A	N/A	N/A

CRL      CCT (min):       PMF:       Analysis Hardness (mg/l):       Analysis pH:

Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	N/A	N/A	N/A	
Total Nickel	0	0		0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	

Total Selenium	0	0	0	N/A	N/A	N/A	
Total Silver	0	0	0	N/A	N/A	N/A	
Total Thallium	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	N/A	N/A	N/A	
Citric Acid	0	0	0	N/A	N/A	N/A	
Sodium Hydroxide	0	0	0	N/A	N/A	N/A	
Sodium Hypochlorite	0	0	0	N/A	N/A	N/A	
Sodium Bisulfite Solution 42%	0	0	0	N/A	N/A	N/A	
SeaQuest/Corrosion Inhibitor	0	0	0	N/A	N/A	N/A	

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: **4**

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Citric Acid	10.3	16.0	5.13	8.01	12.8	mg/L	5.13	CFC	Discharge Conc ≥ 50% WQBEL (RP)
Sodium Hydroxide	2.01	3.14	1.01	1.57	2.52	mg/L	1.01	CFC	Discharge Conc ≥ 50% WQBEL (RP)
Sodium Hypochlorite	0.022	0.035	0.011	0.017	0.028	mg/L	0.011	CFC	Discharge Conc ≥ 50% WQBEL (RP)
Sodium Bisulfite Solution 42%	25.0	39.0	12.5	19.5	31.2	mg/L	12.5	CFC	Discharge Conc ≥ 50% WQBEL (RP)
SeaQuest/Corrosion Inhibitor	69.9	109	34.9	54.5	87.3	mg/L	34.9	CFC	Discharge Conc ≥ 50% WQBEL (RP)

**Other Pollutants without Limits or Monitoring**

# Attachment C

## TRC Evaluation

Altoona City Water- Bellwood  
PA0085537

April 2021

1A	B	C	D	E	F	G
2	<b>TRC EVALUATION</b>					
3	Input appropriate values in B4:B8 and E4:E7					
4	3.366	= Q stream (cfs)		0.5	= CV Daily	
5	0.24	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2 iii	WLA afc = 2.911	1.3.2 iii	WLA cfc = 2.831	
12	PENTOXSD TRG	5.1a	LTAMULT afc = 0.373	5.1c	LTAMULT cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 1.085	5.1d	LTA_cfc = 1.646	
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ		
18			INST MAX LIMIT (mg/l) = 1.635			
	WLA afc	$(.019/e^{-k^*AFC\_tc}) + [(AFC\_Yc^*Qs^*.019/Qd^*e^{-k^*AFC\_tc}) \dots + Xd + (AFC\_Yc^*Qs^*Xs/Qd)]^{*(1-FOS/100)}$				
	LTAMULT afc	$EXP((0.5^*LN(cvh^*2+1))-2.326^*LN(cvh^*2+1)^*0.5)$				
	LTA_afc	wla_afc^*LTAMULT_afc				
	WLA_cfc	$(.011/e^{-k^*CFC\_tc}) + [(CFC\_Yc^*Qs^*.011/Qd^*e^{-k^*CFC\_tc}) \dots + Xd + (CFC\_Yc^*Qs^*Xs/Qd)]^{*(1-FOS/100)}$				
	LTAMULT_cfc	$EXP((0.5^*LN(cvd^*2/no\_samples+1))-2.326^*LN(cvd^*2/no\_samples+1)^*0.5)$				
	LTA_cfc	wla_cfc^*LTAMULT_cfc				
	AML MULT	$EXP(2.326^*LN((cvd^*2/no\_samples+1)^*0.5)-0.5^*LN(cvd^*2/no\_samples+1))$				
	AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc)^*AML_MULT)				
	INST MAX LIMIT	1.5^*((av_mon_limit/AML_MULT)/LTAMULT_afc)				