

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0085740
APS ID 20614
Authorization ID 1289405

Applicant and Facility Information

Applicant Name	<u>Mill Creek Borough Area Municipal Authority Huntingdon County</u>	Facility Name	<u>Mill Creek Area STP</u>
Applicant Address	<u>PO Box 4</u> <u>Mill Creek, PA 17060-0004</u>	Facility Address	<u>Route 444</u> <u>Mill Creek, PA 17060</u>
Applicant Contact	<u>David Reed</u>	Facility Contact	<u>Keith Bollinger</u>
Applicant Phone	<u>(814) 643-5666</u>	Facility Phone	<u>(814) 388-4167</u>
Client ID	<u>44561</u>	Site ID	<u>451899</u>
Ch 94 Load Status	<u>Existing Hydraulic Overload</u>	Municipality	<u>Mill Creek Borough</u>
Connection Status	<u>No Exceptions Allowed</u>	County	<u>Huntingdon</u>
Date Application Received	<u>August 27, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 25, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

Mill Creek Area Municipal Authority has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on February 10, 2015 and became effective on March 1, 2015. The permit expired on February 29, 2020, and the permit has been administratively extended since that time.

The Mill Creek Borough Area Municipal Authority Waste Water Treatment Plant (WWTP) is located in Mill Creek Borough, Huntingdon County. The WWTP is owned and operated by the Authority. The WWTP has a design flow capacity of 0.12 MGD, hydraulic design capacity of 0.30 MGD, and discharges to the Juniata River (WWF). The facility received 34% of influents from Mill Creek Borough, 48% of Brady Township, and 17% of Henderson Township.

WQM No. 3193401 original was issued on August 22, 1995.

On September 20, 2018 the letter from DEP accepted and approved the Corrective Action Plan (CAP) subject to comments as follows:

1. The Authority intends to be hydraulically compliant by 6/2019 if the Inflow and Infiltration (I/I) removal activities are effective.
2. If the I/I removal activities are not effective the Authority will complete structural improvements and become hydraulically compliant in accordance with the implementation schedule on page 4 of the CAP, which indicates completion of construction improvements by 11/2022.
3. In accordance with item 9 of your CAP, all connections to the Mill Creek Area Municipal Authority system will be requested by submission of tap-in applications to the Department for approval.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	September 4, 2020
		Daniel W. Martin, P.E. / Environmental Engineer Manager	
		Maria D. Bebenek, P.E. / Clean Water Program Manager	

Summary of Review

Changes from the previous permit: Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.12
Latitude	40° 25' 49.83"	Longitude	-77° 55' 54.38"
Quad Name	Mount Union	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Juniata River (WWF)	Stream Code	11414
NHD Com ID	66209569	RMI	88.0
Drainage Area	2,000 mi. ²	Yield (cfs/mi ²)	0.102
Q ₇₋₁₀ Flow (cfs)	204	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	574.26	Slope (ft/ft)	
Watershed No.	12-C	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	Mifflintown Municipal Authority, Mifflin Borough		
PWS Waters	Juniata River	Flow at Intake (cfs)	
PWS RMI	34 miles	Distance from Outfall (mi)	Approximate 54 miles

Changes Since Last Permit Issuance: none

Drainage Area

The discharge is to Juniata River at RMI 88.0 miles. A drainage area upstream of the discharge is estimated to be 2,000 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

According to StreamStats, the discharge point on Juniata River has a Q₇₋₁₀ of 204 cfs and a drainage area of 2,000 mi.², which results in a Q₇₋₁₀ low flow yield of 0.102 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 204 \text{ cfs} \\
 \text{Low Flow Yield} &= 204 \text{ cfs} / 2,000 \text{ mi.}^2 \approx 0.102 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 204 \text{ cfs} \approx 277.4 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 204 \text{ cfs} \approx 130.6 \text{ cfs}
 \end{aligned}$$

Juniata River

25 Pa Code § 93.9n classifies Juniata River as Warm Water Fishes (WWF) surface water. Based on the 2018 Integrated Report, Juniata River, assessment unit ID 16843, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Public Water Supply

The nearest downstream public water supply intake is the Mifflintown Municipal Authority on the Juniata River in Mifflin Borough, approximately 54 miles downstream of this discharge. Considering distance and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Mill Creek STP				
WQM Permit No.		Issuance Date		
3193401		8/22/1995		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Chlorine with Dechlorination	0.12
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.12	204	Existing Hydraulic Overload	Belt Filtration	Landfill

Changes Since Last Permit Issuance: none

The WWTP train is as follows:

Equalization Tank (1) ⇒ Aeration Tanks (2) ⇒ Clarifiers (2) ⇒ Chlorine Contact Tank (1) ⇒ Sludge Holding Tank (1) ⇒ Sludge Baggers (2) ⇒ Blowers (4) ⇒ Discharge (Outfall 001)

The chemicals are sodium hypochlorite for disinfection, and sodium thiosulfate for de-chlorination.

Compliance History	
Summary of DMRs:	The DMRs reported from August 1, 2019 to July 31, 2020 is summarized in the Table below (Pages # 6 & 7).
Summary of Inspections:	<p>3/13/2019: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. The recommendations were to repair leaking air line in aeration tanks, properly maintain EQ and clarifier tanks, and more routine process control testing. All treatment units were in service, effluent was clear with fine solids, and field tests results were within permit limits. The sample on 3/13/2019 test results indicated within permit limits.</p> <p>2/22/2018: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. There was a recommendation such as repair leaking air lines in aeration tanks. There were no violations noted during inspection. Treatment plant appeared to be operating properly, effluent was clear, and field tests results were within permit limits. The facility had been experiencing high flow rates this month due to rain and snow melt for example a few days this month the plant received 300,000 GPD. The treatment plant is designed for an average flow of 120,000 GPD.</p> <p>3/8/2017: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. The effluent was clear, and field test results were within permit limits. There were no violations noted during inspection.</p> <p>4/21/2016: Mr. Clark, DEP WQS, conducted follow up inspection. The effluent was clear. There were no violations noted during inspection.</p>
Other Comments:	There are currently no open violations associated to the permittee or the facility.

Other Comments: There were monthly average overflow from December 2019, and January thru May 2020, which were violations.

The table below summarizes the influent/effluent testing results submitted along with the application.

<i>Influent Testing Results</i>			<i>Effluent Testing Results</i>		
Parameter	Min/Max Value	Average Value	Parameter	Min/Max Value	Average Value
BOD ₅ (mg/L)	222 mg/L	117 mg/L	pH (minimum)	6.6 S.U.	
BOD ₅ (lbs/day)	356 lbs/day	121 lbs/day	pH (maximum)	8.49 S.U.	
TSS (mg/L)	178 mg/L	79 mg/L	D.O (minimum)	5.54 mg/L	7.46 mg/L
TSS (lbs/day)	127 lbs/day	73 lbs/day	TRC	0.80 mg/L	0.21 mg/L
TN (mg/L)	mg/L	40 mg/L	Fecal Coliform	10.0 No./100mL	2 No./100mL
TN (lbs/day)	lbs/day	124 lbs/day	CBOD ₅	6.8 mg/L	3.6 mg/L
TP (mg/L)	mg/L	5.63 mg/L	TSS	6.8 mg/L	2.7 mg/L
TP (lbs/day)	lbs/day	3.45 lbs/day	NH ₃ -N	10.5 mg/L	2.8 mg/L
NH ₃ -N (mg/L)	mg/L	23.34 mg/L	TN	26.6 mg/L	15.3 mg/L
NH ₃ -N (lbs/day)	lbs/day	14.29 lbs/day	TP	3.4 mg/L	2.7 mg/L
TDS (mg/L)	mg/L	316 mg/L	Temp	N/A F	N/A F
TDS (lbs/day)	lbs/day	193 lbs/day	TKN	11.6 mg/L	8.6 mg/L
TKN	mg/L	40 mg/L	NO ₂ -N + NO ₃ -N	13.3 mg/L	8.9 mg/L
NO ₂ -N + NO ₃ -N	mg/L	< 2.4 mg/L	TDS	388 mg/L	376 mg/L
Fecal Coliform	No./100mL	3076000No./100mL	Chloride	48.1 mg/L	40.8 mg/L
			Bromide	< 0.4 mg/L	< 0.4 mg/L
			Sulfate	125 mg/L	102 mg/L
			Oil and Grease	< 5.4 mg/L	< 5.4 mg/L
			Total Copper	0.017 mg/L	0.013 mg/L
			Total Lead	< 0.008 mg/L	< 0.008 mg/L
			Total Zinc	0.043 mg/L	0.032 mg/L

Compliance History

DMR Data for Outfall 001 (from August 1, 2019 to July 31, 2020)

Parameter	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19	AUG-19
Flow (MGD) Average Monthly	0.0692	0.0868	0.1257	0.1567	0.1636	0.1524	0.1630	0.1326	0.0686	0.0748	0.0639	0.0685
Flow (MGD) Daily Maximum	0.1036	0.1753	0.3179	0.2388	0.3059	0.3001	0.3242	0.2582	0.07	0.1208	0.0938	0.0909
pH (S.U.) Minimum	6.71	6.67	6.59	6.71	6.69	6.67	6.61	6.59	6.85	6.8	6.88	6.86
pH (S.U.) Maximum	7.46	7.57	7.32	7.11	7.32	7.35	7.25	7.42	7.75	7.34	7.95	7.17
DO (mg/L) Minimum	6.04	7.80	6.72	6.48	6.81	7.56	6.58	7.71	8.36	7.14	7.67	7.36
TRC (mg/L) Average Monthly	0.35	0.43	0.5	0.48	0.48	0.34	0.32	0.34	0.29	0.37	0.41	0.39
TRC (mg/L) Instantaneous Maximum	0.77	0.63	0.81	0.69	0.82	0.85	0.9	0.72	0.9	0.99	1.43	1.25
CBOD5 (lbs/day) Average Monthly	2.04	2.72	3.37	5.17	4.21	5.49	4.98	6.4	1.71	2.01	2.03	1.76
CBOD5 (lbs/day) Weekly Average	2.17	3.65	4.07	5.36	4.95	6.78	5.46	8.96	1.72	2.09	2.36	1.82
CBOD5 (mg/L) Average Monthly	3	3	3	4.15	4.14	4.02	4.02	4.24	3	3.12	3.48	3
CBOD5 (mg/L) Weekly Average	3	3	3	5.3	5.28	4.54	4.33	5.47	3	3.23	3.96	3
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	85	133	63	119	125	159	174	55	55	62	76	111
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	90	184	69	151	154	175	188	89	65	64	88	113
BOD5 (mg/L) Raw Sewage Influent Average Monthly	125.5	145	60	101.05	118	121.05	134	55	95.95	95.6	130.5	189
TSS (lbs/day) Average Monthly	1.81	1.93	6.38	5.22	7.85	5.66	6.45	5.65	1.82	1.81	0.93	0.59
TSS (lbs/day) Raw Sewage Influent Average Monthly	93	93	62	74	58	124	110	89	59	52	97	55

**NPDES Permit Fact Sheet
Mill Creek Area STP**

NPDES Permit No. PA0085740

TSS (lbs/day) Raw Sewage Influent Daily Maximum	130	128	89	93	68	150	139	131	73	69	129	59
TSS (lbs/day) Weekly Average	2.61	2.44	8.13	5.99	12.01	7.47	8.08	7.2	1.92	1.81	1.02	0.73
TSS (mg/L) Average Monthly	2.6	2.2	5.6	4	8	4.1	5	3.8	3.2	2.8	1.6	1
TSS (mg/L) Raw Sewage Influent Average Monthly	134	102	63	55	57	95	84	58.5	103	80.5	168.5	94
TSS (mg/L) Weekly Average	3.6	2.4	6	4.4	12.8	5	6.4	4.4	3.4	2.8	1.8	1.2
Fecal Coliform (CFU/100 ml) Average Monthly	1.41	6.28	1.41	3.32	33.5	1	1	< 1	1	1	1	1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	2	38.8	2	11	69.7	1	1	< 1	1	1	1	1
Nitrate-Nitrite (mg/L) Average Monthly	31.09	21.11	15.61	12.255	17.64	14.06	15.15	16.67	23.24	30.665	24.48	28.035
Total Nitrogen (mg/L) Average Monthly	31.59	21.61	16.11	12.755	18.14	14.56	15.65	17.17	24.24	31.665	25.48	29.035
Ammonia (mg/L) Average Monthly	< 0.1	0.4935	0.148	0.1	< 0.1	0.244	< 0.1	0.1	0.227	0.179	0.523	0.1
TKN (mg/L) Average Monthly	< 0.5	0.5	< 0.5	0.5	< 0.5	0.5	< 0.5	0.5	< 1	1	< 1	1
Total Phosphorus (mg/L) Average Monthly	3.845	2.87	2.3	1.89	2.47	2.18	2.45	1.855	2.92	3.26	2.9	2.715

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.12</u>
Latitude <u>40° 25' 50.75"</u>	Longitude <u>-77° 55' 52.04"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

Water Quality-Based Limitations

Carbonaceous Biochemical Oxygen Demand (CBOD₅)

Only the minimum treatment requirements of secondary treatment will be necessary to protect water quality. The existing limits of 25 mg/L average monthly (AML), 40 mg/L average weekly (AWL), and 50 mg/L instantaneous maximum (IMAX) will remain in the permit. The facility has consistently achieved CBOD₅ levels well below these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Mass based AML (lb/day)} &= 25 \text{ (mg/L)} \times 0.12 \text{ (MG/day)} \times 8.34 \text{ (lb/MG)} \text{ (L/mg)} = 25.02 \text{ lb/day} \\ \text{Mass based AWL (lb/day)} &= 40 \text{ (mg/L)} \times 0.12 \text{ (MG/day)} \times 8.34 \text{ (lb/MG)} \text{ (L/mg)} = 40.03 \text{ lb/day} \end{aligned}$$

Ammonia (NH₃-N)

NH₃-N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The attached printout of the WQM 7.0 data indicates that at a discharge of 0.12 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 25 mg/L NH₃-N as a monthly average and 50 mg/L NH₃-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects.

The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

- Discharge pH = 7.0 (Default)
- Discharge Temperature = 20°C (Default)
- Stream pH = 7.0 (Default)
- Stream Temperature = 25°C (Default for WWF)
- Background NH₃-N = 0 (Default)

There are no NH₃-N effluent limits in this permit. The "Monitor & Report" twice per month for average monthly will remain in the proposed permit.

Dissolved Oxygen (DO)

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

pH

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa. Code § 95.2(2).

Total Suspended Solids (TSS)

The existing limits of 30 mg/L average monthly (AML), 45 mg/L average weekly (AWL), and 60 mg/L instantaneous maximum (IMAX) will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Past DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\text{Mass based AML (lb/day)} = 30 \text{ (mg/L)} \times 0.12 \text{ (MG/day)} \times 8.34 \text{ (lb/MG)} \text{ (L/mg)} = 30.02 \text{ lb/day}$$

$$\text{Mass based AWL (lb/day)} = 45 \text{ (mg/L)} \times 0.12 \text{ (MG/day)} \times 8.34 \text{ (lb/MG)} \text{ (L/mg)} = 45.04 \text{ lb/day}$$

Fecal Coliform

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

Total Residual Chlorine

The attached computer printout utilizes the equations and calculations as presented in the Department's 2003 Implementation Guidance for Residual Chlorine (TRC) (ID # 391-2000-015) for developing chlorine limitations. The attached printout indicates that an average monthly water quality limit of 0.5 mg/L and 1.6 mg/L maximum daily would be needed to prevent toxicity concerns. This is consistent with the existing permit. The treatment facility is meeting this limit.

Toxics

No toxic parameters of concern associated with this discharge.

Biosolids Management

Sludge is digested on-site, via an aerobic sludge digester, and removed by a certified hauler.

Stormwater

There is no known stormwater outfall associated with this facility.

Chesapeake Bay Strategy

According to DEP's Chesapeake Bay Phase II Watershed Implementation Plan (WIP) Wastewater Supplement, this facility is considered a phase 5 non-significant sewage discharger with design flow less than 0.2 MGD but greater than 0.002 MGD. In general, DEP will issue permits for all phase 5 facilities with monitoring and reporting for Total Nitrogen (TN) and Total Phosphorus (TP) throughout the permit term at a frequency no less than annually. Furthermore, DEP's SOP No. BPNPSM-PMT-033 states that in general, at a minimum, monitoring for TN and TP should be included in new and reissued permits for sewage discharges with design flows > 2,000 gpd. At this time, the Department is not requiring a total maximum annual nitrogen or phosphorus loading cap. Ammonia-Nitrogen, Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, TN, and TP monitoring is already included in the existing permit and will remain in the proposed renewal.

The Chesapeake Bay parameters monitoring frequency for this facility will match that of the conventional pollutants monitoring frequency of two samples per month.

Anti-Degradation (93.4)

The effluent limits for this discharge have been developed to ensure that the existing in-stream water used and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

303d Listed Streams:

The discharge is not located on a 303d listed stream segment.

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the proposed permit per 40 CFR § 122.44(i)(1)(ii).

Monitoring Frequency and Sample Type

The facility currently is required to collect daily effluent grab samples for D.O., TRC, and pH; two per month effluent 8-hr composite samples of CBOD₅, and TSS; two per month effluent grab samples of Fecal Coliform; two per month effluent 8-hr composite samples of Ammonia-Nitrogen, Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, and TP; and two per month effluent calculation samples of TN. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the existing monitoring frequencies will remain the same as those specified in the proposed permit.

WQM 7.0 data:

Node 1: Outfall 001 on Juniata River (11414)

Elevation: 574.26 ft (USGS National Map Viewer)
 Drainage Area: 2000.0 mi.² (USGS PA StreamStats)
 River Mile Index: 88.00 (PA DEP eMapPA)
 Low Flow Yield: 0.102 cfs/mi.²
 Discharge Flow: 0.120 MGD (NPDES Application)

Node 2: Station ID 01563500 on Juniata River at Mapleton Depot, PA

Elevation: 562.06 ft (USGS National Map Viewer)
 Drainage Area: 2030.00 mi.² (USGS PA StreamStats)
 River Mile Index: 85.21 (PA DEP eMapPA)
 Low Flow Yield: 0.102 cfs/mi.²
 Discharge Flow: 0.000 MGD

The screenshot displays the USGS StreamStats interface. On the left, a sidebar shows 'Basin Delineated' and 'SELECT SCENARIOS'. The main content area is divided into three sections:

- Parameter Table:** Lists parameters such as DRNAREA (2000 square miles), PRECIP (38.5 inches), STRDEN (2.05 miles per square mile), ROCKDEP (4.5 feet), and CARBON (19.7 percent).
- Low-Flow Statistics Parameters:** A table with columns for Parameter Code, Parameter Name, Value, Units, Min Limit, and Max Limit. The DRNAREA value of 2000 is highlighted in yellow, indicating it is outside the suggested range.
- Low-Flow Statistics Disclaimers:** A yellow banner states: "One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors".
- Low-Flow Statistics Flow Report:** A table showing flow statistics for different return periods and durations, such as 7 Day 2 Year Low Flow (314 ft³/s) and 30 Day 10 Year Low Flow (250 ft³/s).

On the right side of the screenshot, a map view is visible with a 'Layers' panel showing 'Base Maps', 'Application Layers', 'National Layers', and 'PA Map Layers'.

USGS StreamStats

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Continue

POWERED BY WIM

DRNAREA	Area that drains to a point on a stream	2030	square miles
PRECIP	Mean Annual Precipitation	38.5	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	2.04	miles per square mile
ROCKDEP	Depth to rock	4.5	feet
CARBON	Percentage of area of carbonate rock	19.5	percent

Low-Flow Statistics Parameters: 100 Percent (2030 square miles) Low Flow Region 2

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	2030	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	38.5	inches	35	50.4
STRDEN	Stream Density	2.04	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	19.5	percent	0	99

Low-Flow Statistics Disclaimers: 100 Percent (2030 square miles) Low Flow Region 2

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report: 100 Percent (2030 square miles) Low Flow Region 2

Statistic	Value	Unit
7 Day 2 Year Low Flow	320	ft ³ /s
30 Day 2 Year Low Flow	390	ft ³ /s
7 Day 10 Year Low Flow	208	ft ³ /s
30 Day 10 Year Low Flow	254	ft ³ /s
90 Day 10 Year Low Flow	330	ft ³ /s

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Map showing Mill Creek area with various towns and roads.

rptEffLimits

WQM 7.0 Effluent Limits

WQM Code	WQM Code	WQM Code	WQM Code	WQM Code	WQM Code	WQM Code	WQM Code
001	002	003	004	005	006	007	008

Wednesday, September 3, 2020

Version: 1.0

Page 1 of 1

Page: 1 No Filter

rpt_WLA

WQM 7.0 Wasteload Allocations

WQM Code	WQM Code	WQM Code	WQM Code	WQM Code	WQM Code	WQM Code	WQM Code
001	002	003	004	005	006	007	008

Wednesday, September 3, 2020

Version: 1.0

Page 1 of 1

Page: 1 No Filter

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameter	Set	Use Specified Q1 and Q2 DTP Values	<input checked="" type="checkbox"/>
SEA Method	EMPH	Use Specified Q2 Value	<input type="checkbox"/>
Q1 DTP of Value	0.62	Use Specified Reach Flow Time	<input type="checkbox"/>
Q2 DTP of Value	1.36	Specify value Adjust N	<input checked="" type="checkbox"/>
Q3 Substrate	0.025%	Use Reduced Trapping	<input checked="" type="checkbox"/>
Q3 Coef	0		

Wednesday, September 3, 2020 Version 1.0a Page 1 of 1

Page: 1 | No Filter

rptDOSim

WQM 7.0 D.O. Simulation

WQM Spec	Stream Code	Stream Name
Q1	11414	JAMA/RA/WR
Q2		
Q3		
Q4		
Q5		
Q6		
Q7		
Q8		
Q9		
Q10		
Q11		
Q12		
Q13		
Q14		
Q15		
Q16		
Q17		
Q18		
Q19		
Q20		
Q21		
Q22		
Q23		
Q24		
Q25		
Q26		
Q27		
Q28		
Q29		
Q30		
Q31		
Q32		
Q33		
Q34		
Q35		
Q36		
Q37		
Q38		
Q39		
Q40		
Q41		
Q42		
Q43		
Q44		
Q45		
Q46		
Q47		
Q48		
Q49		
Q50		
Q51		
Q52		
Q53		
Q54		
Q55		
Q56		
Q57		
Q58		
Q59		
Q60		
Q61		
Q62		
Q63		
Q64		
Q65		
Q66		
Q67		
Q68		
Q69		
Q70		
Q71		
Q72		
Q73		
Q74		
Q75		
Q76		
Q77		
Q78		
Q79		
Q80		
Q81		
Q82		
Q83		
Q84		
Q85		
Q86		
Q87		
Q88		
Q89		
Q90		
Q91		
Q92		
Q93		
Q94		
Q95		
Q96		
Q97		
Q98		
Q99		
Q100		

Wednesday, September 3, 2020 Version 1.0a Page 1 of 1

Page: 1 | No Filter

rptHydro

WQM 7.0 Hydrodynamic Outputs

WQM Spec	Stream Code	Stream Name
Q1	11414	JAMA/RA/WR
Q2		
Q3		
Q4		
Q5		
Q6		
Q7		
Q8		
Q9		
Q10		
Q11		
Q12		
Q13		
Q14		
Q15		
Q16		
Q17		
Q18		
Q19		
Q20		
Q21		
Q22		
Q23		
Q24		
Q25		
Q26		
Q27		
Q28		
Q29		
Q30		
Q31		
Q32		
Q33		
Q34		
Q35		
Q36		
Q37		
Q38		
Q39		
Q40		
Q41		
Q42		
Q43		
Q44		
Q45		
Q46		
Q47		
Q48		
Q49		
Q50		
Q51		
Q52		
Q53		
Q54		
Q55		
Q56		
Q57		
Q58		
Q59		
Q60		
Q61		
Q62		
Q63		
Q64		
Q65		
Q66		
Q67		
Q68		
Q69		
Q70		
Q71		
Q72		
Q73		
Q74		
Q75		
Q76		
Q77		
Q78		
Q79		
Q80		
Q81		
Q82		
Q83		
Q84		
Q85		
Q86		
Q87		
Q88		
Q89		
Q90		
Q91		
Q92		
Q93		
Q94		
Q95		
Q96		
Q97		
Q98		
Q99		
Q100		

Wednesday, September 3, 2020 Version 1.0a Page 1 of 1

Page: 1 | No Filter

rptGeneral

Input Data WQM 7.0

WQM Spec	Stream Code	Stream Name	Flow	Velocity	Depth	Width	Area	Perim	Wet Perim	Hyd Rad	Wet Area	Wet Perim	Wet Area	Wet Perim	Wet Area	Wet Perim	Wet Area	Wet Perim	Wet Area
Q1	11414	JAMA/RA/WR	100	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0

Wednesday, September 3, 2020 Version 1.0a Page 1 of 2

Page: 1 | No Filter

Input Data WQIM 7.0														
SEW Name	Stream Code	Stream Name	RWS	Residual Time	Design Flow (MG)	Design Flow (MG)	Flow (MG)	Flow (MG)	Flow (MG)	Flow (MG)	Flow (MG)	Flow (MG)	Flow (MG)	Flow (MG)
120	11414	JARMA 14 N/101	0.210	0.00	200.00	0.00000	0.00							

Design Code	LFY (MG)	SL (MG)	Stream Flow (MG)	Sub Flow (MG)	W Flow (MG)	W Flow (MG)	W Flow (MG)	Temperature		pH		
								Temp (°C)	pH	Temp (°C)	pH	
Q1-W	0.00	0.00	0.00	0.00	0.00	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q2-W	0.00	0.00	0.00	0.00	0.00							
Q3-W	0.00	0.00	0.00	0.00	0.00							

Discharge Code		Building	Wastewater Flow (MG)	Design Flow (MG)	Design Flow (MG)	Residual Time (MG)	Flow Temp (°C)	Flow pH
Mill Creek Area	PA0085740	0.0000	0.0000	0.0000	0.0000	0.00	20.00	7.00

Parameter Code		Flow Code	SL Code	Stream Code	Flow Code
CRD5	3.0.00	3.00	0.00	0.00	1.00
Disinfecting	0.00	R24	0.00	0.00	
NSBN	3.0.00	0.00	0.00	0.70	

Wednesday, September 2, 2020 Module 1.06 Page 2 of 2

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
204	= Q stream (cfs)		0.5	= CV Daily	
0.12	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 350.568		1.3.2.iii	WLA_cfc = 341.769
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 130.630		5.1d	LTA_cfc = 198.689
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD ₅	25	40 Wkly Avg	XXX	25	40	50	2/month	8-Hr Composite
TSS	30	45 Wkly Avg	XXX	30	45	60	2/month	8-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Calculation 8-Hr Composite
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD ₅	25.0	40.0 Wkly Avg	XXX	25.0	40.0	50.0	2/month	8-Hr Composite
TSS	30.0	45.0 Wkly Avg	XXX	30.0	45.0	60.0	2/month	8-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Calculation
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input checked="" type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]