

Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0085782
APS ID 485115
Authorization ID 1456967

Applicant and Facility Information

Applicant Name	Ruscombmanor Township Berks County		
Applicant Address	204 Oak Lane	Facility Name	Golden Oaks
	Fleetwood, PA 19522-8942	Facility Address	2 Erhardt Lane
Applicant Contact	Don Miller	Facility Contact	Don Miller
Applicant Phone	(610) 944-7242	Facility Phone	(610) 944-7242
Client ID	117230	Site ID	260819
Ch 94 Load Status	Not Overloaded	Municipality	Ruscombmanor Township
Connection Status		County	Berks
Date Application Received	<u>October 4, 2023</u>	EPA Waived?	Yes
Date Application Accepted	<u>October 11, 2023</u>	If No, Reason	
Purpose of Application	NPDES permits renewal.		

Summary of Review

On behalf of Ruscombmanor Township Berks County, LTL Consultants, has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. This permit renewal application was received on October 4, 2023. The permit was last reissued on March 29, 2019; and became effective on April 1, 2019. The permit will expire on March 31, 2024 but the terms and conditions of the permit have been extended since that time.

The facility has a design of 0.0645 MGD average annual flow and hydraulic capacity design of 0.105 MGD. The collection system has 100% sewers from Ruscombmanor Township. The discharge of treated sewage located in Ruscombmanor Township; Berks County is into UNT to Furnace Creek which is designated for cold-water fishes.

The facility's DMRs from August 1, 2023 to July 31, 2024 indicated not exceeding 0.05 MGD monthly average. Therefore, the average design flow of 0.05 MGD is used for calculation of pollutants concentration & mass load limits in this proposed permit.

The WQM No. 0693410 ownership transfer was issued on 6/11/2003. The 0693410 04-1 & 0693410 08-1 amendments were issued on 7/23/2004 & 8/6/2008. The WQG02060801 was issued on 5/14/2008. The WQM No. 0608405 was issued on 5/15/2009. The WQG02061201 was issued on 2/19/2012.

DRBC Docket No. D-2007-034 CP-4 approval date was 12/11/2019 and expiration date was 3/31/2024.

Sludge use and disposal description and location(s): N/A because sludge is hauled by Kline's Septic contractor.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the permit.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	September 19, 2024
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	September 26, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.05
Latitude	40° 25' 20"	Longitude	-75° 49' 27"
Quad Name	Fleetwood	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	UNT to Furnace Creek (CWF)	Stream Code	1689 to 1688
NHD Com ID	25973104	RMI	0.38
Drainage Area	0.45 mi. ²	Yield (cfs/mi ²)	0.07
Q ₇₋₁₀ Flow (cfs)	0.0322	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)		Slope (ft/ft)	
Watershed No.	3-D	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	PA American Water at Royersford/Phoenixville		
PWS Waters	Schuylkill River	Flow at Intake (cfs)	
PWS RMI	46.5 miles	Distance from Outfall (mi)	Approximate 31.0 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to UNT to Furnace Creek at RMI 0.38 miles. A drainage area upstream of the discharge is estimated to be 0.45 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>. The Q₇₋₁₀ is 0.0322 cfs, then the low flow yield is 0.07 cfs/mi.² (0.0322 cfs/0.45 mi.²).

303d Listed Streams (Impaired Waters)

The discharge enters an Unnamed Tributary of Furnace Creek which has not been assessed. Furnace Creek is included on a 303d list: more than 6 miles are impaired for recreation use due to pathogens. It was listed in 2016 but no TMDL has yet been developed. This permit includes limits for Fecal Coliform based on State Standards. The facility has been consistently meeting their Fecal Coliform limits. No increase in discharge flow is occurring.

Potable Water Supply Intake

The nearest downstream public water supply intake is the PA American Water at Royersford/Phoenixville intake on the Schuylkill River, approximately 31 miles from the point of discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Golden Oaks WWTP				
WQM Permit No.	Issuance Date			
0693410 T-1	6/11/2003			
0693410 04-1	7/23/2004			
0693410 08-1	8/6/2008			
WQG02060801	5/14/2008			
0608405	5/15/2009			
WQG02061201	2/29/2012			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Activated Sludge	Hypochlorite	0.0645
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.105	188	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance:

Treatment plant consists of: bar screen (1) – EQ tanks (2) – aeration tanks (6) – clarifier tanks (2) - sludge storage tanks (2) – Chlorine contact tank (1) – Dechlorination chamber (1) - discharge.

Chemical used:

Soda Ash is used for pH control at a rate of 100 lbs/day.

Biosolids:

The total sewage sludge/biosolids production within the facility for the previous year was 2.715 dry tons.

Industrial/Commercial Users:

The permit application indicated there are no commercial or industrial contributors to the treatment plant.

Compliance History	
Summary of DMRs:	DMRs reported last 12 months are summarized in the next page.
Summary of Inspections:	5/03/2018: Mr. Buss, DEP's WQS, conducted a compliance evaluation inspection. The field test results were within permitted limits. Effluent appeared clear. There were no violations identified during inspection. The recommendation was update emergency notification information to include DEP 24-hour hotline.
Other Comments:	There is one open violation against the facility or the permittee.

Other Comments: 

Compliance History

DMR Data for Outfall 001 (from August 1, 2023 to July 31, 2024)

Parameter	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23
Flow (MGD) Average Monthly	0.0243	0.0239	0.0222	0.0212	0.0221	0.0199	0.0232	0.0235	0.0211	0.0218	0.0225	0.025
Flow (MGD) Daily Maximum	0.0372	0.0362	0.0349	0.0325	0.0421	0.0282	0.0472	0.0514	0.034	0.0308	0.0491	0.044
pH (S.U.) Instantaneous Minimum	6.7	6.4	7.4	7.5	7.4	7.6	7.5	7.5	7.5	7.6	7.0	6.9
pH (S.U.) Instantaneous Maximum	8.0	8.2	9.3	8.8	8.4	9.3	8.2	8.6	9.3	8.9	8.8	8.3
DO (mg/L) Instantaneous Minimum	7.8	7.5	7.6	8.3	8.0	7.6	7.7	6.8	9.1	8.6	6.0	6.7
TRC (mg/L) Average Monthly	< 0.02	< 0.04	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.03	< 0.03	< 0.02	< 0.02
TRC (mg/L) Instantaneous Maximum	0.05	0.27	0.08	0.06	0.06	0.06	0.07	0.09	0.05	0.12	0.09	0.05
CBOD5 (lbs/day) Average Monthly	0.8	0.4	1.1	1.4	0.08	0.8	1.0	0.7	0.7	0.9	0.8	0.8
CBOD5 (mg/L) Average Monthly	3.0	3.3	5.6	7.7	4.4	4.5	4.7	3.8	3.9	4.3	4.0	3.8
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	94	62	60	34	62	113	55	118	24	45	17	41
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	103	83	65	34	71	134	59	197	26	67	23	42
BOD5 (mg/L) Raw Sewage Influent Average Monthly	338	596	287	169	316	674	271	602	124	238	90	181
TSS (lbs/day) Average Monthly	< 0.4	0.4	1.6	5.0	1.2	0.7	< 0.8	0.7	0.8	3.3	1.8	2.9
TSS (lbs/day) Raw Sewage Influent Average Monthly	125	65	65	27	50	63	74	90	25	40	40	47
TSS (lbs/day) Raw Sewage Influent Daily Maximum	150	82	74	27	57	79	111	160	39	65	65	57

NPDES Permit Fact Sheet
Golden Oaks

NPDES Permit No. PA0085782

TSS (mg/L)	< 1.5	3.5	8.0	29.5	6.5	4.0	< 4.0	3.5	4.0	14.5	9.0	13.0
TSS (mg/L)												
Raw Sewage Influent												
Average Monthly	463	611	310	135	256	373	362	457	128	217	203	211
Total Dissolved Solids (lbs/day)												
Average Monthly	252	112	172	170	105	145	142	146	153	189	172	196
Total Dissolved Solids (mg/L)												
Average Monthly	909.0	945.0	821.0	822.0	572.0	860.0	704.0	765.0	804.0	926.0	885.0	881.0
Fecal Coliform (No./100 ml)												
Geometric Mean	50	50	16	44	< 24	26	14	35	23	52	150	140
Fecal Coliform (No./100 ml)												
Instantaneous Maximum	52	76	38	48	280	31	18	36	26	62	230	200
Total Nitrogen (lbs/day)												
Average Monthly	< 15	E	< 11	6	5	< 7	6	< 7	8	10	10	E
Total Nitrogen (mg/L)												
Average Monthly	< 58.3	E	< 49.4	35.08	22.91	< 40.2	29.78	< 34.9	45.24	48.74	52.94	E
Ammonia (lbs/day)												
Average Monthly	0.02	0.01	0.1	0.05	< 0.04	0.01	0.009	0.02	0.04	0.02	0.01	0.02
Ammonia (mg/L)												
Average Monthly	0.1	0.1	0.6	0.3	< 0.2	0.1	0.05	0.1	0.2	0.1	0.1	0.1
Total Phosphorus (lbs/day)												
Average Monthly	2	E	2	1	1	0.9	1	1	1	1	2	E
Total Phosphorus (mg/L)												
Average Monthly	6.8	E	7.91	8.57	5.64	5.28	5.98	6.73	6.26	6.51	7.9	E

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.07	XXX	0.23	1/day	Grab
CBOD5	10.4	XXX	XXX	25.0	XXX	50	2/month	8-hour composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-hour composite
TSS	12.5	XXX	XXX	30.0	XXX	60	2/month	8-hour composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-hour composite
Total Dissolved Solids	Report	XXX	XXX	1000.0	XXX	2000	1/month	8-hour composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	3.0	XXX	XXX	7.2	XXX	14.4	2/month	8-hour composite
Ammonia May 1 - Oct 31	1.0	XXX	XXX	2.4	XXX	4.8	2/month	8-hour composite
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1month	8-hour composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/month	8-hour composite

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 25' 20.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.05
Longitude -75° 49' 27.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation	DRBC Regulations
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)	
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)	
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)	
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)	
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)	
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)	
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)	
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)	
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)	
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)	
Ammonia	20	Average Monthly	-	-	18 CFR Part 410
Total Dissolved Solids (TDS)	1,000 (unless DRBC approves a different limit after a TDS determination)	Average Monthly	-	-	18 CFR Part 410

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

- * Discharge pH = 7.0 (Default)
- * Discharge Temperature = 25°C (Default)
- * Stream pH = 7.0 (Default)
- * Stream Temperature = 20°C (Default)
- * Background NH₃-N = 0 mg/L (Default)

Analysis Results WQM 7.0

Effluent Limitations			
RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.38	Golden Oaks WTP	PA0085782	0.0500
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD ₅	25		
NH ₃ -N	2.38	4.76	
Dissolved Oxygen		5	

Record: 14 < 1 of 1 > No Filter Search

Print < Back Next > Archive Cancel

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 2.38 (2.4) mg/L as a monthly average and 4.76 (4.8) mg/L instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects at the point of discharge. However, the existing summer limits of 2.4 mg/L monthly average & 4.8 mg/L IMAX are same and will remain in the proposed permit. Per anti-backsliding policy, the existing winter average monthly limit of 7.2 mg/L & IMAX limit of 14.4 mg/L will remain in place. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

Summer average monthly mass limit: 2.4 mg/L x 0.05 MGD x 8.34 = 1.0 lbs/day

Winter average monthly mass limit: 7.2 mg/L x 0.05 MGD x 8.34 = 3.0 lbs/day

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. This limit is consistent with the before upgrade permit. Therefore, the limits of 25.0 mg/L monthly average (AML), and 50.0 mg/L instantaneous maximum will remain in the amendment permit. Mass limits are calculated as follows:

Average monthly mass limit: 25.0 mg/L x 0.05 MGD x 8.34 = 10.43 (10.4) lbs/day

Dissolved Oxygen (DO):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

pH:

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa Code § 95.2(1).

Total Suspended Solids (TSS):

The existing technology-based limits of 30.0 mg/L average monthly, and 60.0 mg/L instantaneous maximum will remain in the amendment permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Mass limits are calculated as follows:

Average monthly mass limit: 30.0 mg/L x 0.05 MGD x 8.34 = 12.51 (12.5) lbs/day

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/quarter will be included in the permit to be consistent with the recommendation from this SOP.

Influent BOD₅ and TSS Monitoring:

The amendment permit will continue influent BOD₅ and TSS weekly monitoring at the same frequency as is done for effluent in order to implement Chapter 94.12 and assess percent removal requirements, per DEP policy.

Total Dissolved Solids (TDS):

Additionally, DRBC's regulations, 18 CFR Part 410 Section 3.10.4D.2., state: "Total dissolved solids shall not exceed 1,000 mg/L, or a concentration established by the Commission which is compatible with designated water uses and stream quality objectives, and recognizes the need for reserve capacity to serve future dischargers."

Therefore, the existing TDS limit 1,000.0 mg/L average monthly & 2,000.0 mg/L IMAX will remain in the proposed permit.

And maximum TDS reported in the application from effluent sampling was 1000 mg/l. The TDS baseline is calculated as:

1000 mg/l x 0.050 MGD x 8.34 c.f. = 417 lbs/day

Toxics:

Due to the facility is not to receive industrial or commercial contributions in the renewal application, page 8, then no toxics monitoring, or limit requirement will need to be evaluated in this time of renewal.

Golden Oaks**Stormwater:**

There is no known stormwater outfall associated with this facility.

Total Nitrogen & Total Phosphorus:

To gather data on the impact of nutrients in surface waters, a monitoring requirement for Total Nitrogen and Total Phosphorus will remain in the proposed permit in accordance with the DEP's Standard Operating Procedure for Establishing Effluent Limitations for individual Sewage permits and as authorized by Chapter 92a.61. Because the downstream water, UNT flows into Furnace Creek, has already been identified as impaired for Recreation use due to pathogens, the monitoring frequency included in the renewal permit is one per month, per the Permit Writers' Manual No. 362-0400-001.

Total Residual Chlorine (TRC):

Based on the attached TRC Excel spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), the facility's discharge must meet a monthly average limit of 0.07 mg/L and an instantaneous maximum limit of 0.228 (0.23) mg/L. These limits are the same as in existing permit and will be carried over. The minimum monitoring frequency is 1/day.

TRC EVALUATION							
Input appropriate values in A3:A9 and D3:D9							
Source	Reference	AFC Calculations		Reference	CFC Calculations		
TRC	1.3.2.iii	WLA_afc =	0.152	1.3.2.iii	WLA_cfc =	0.140	
PENTOXSD TRG	5.1a	LTAMULT_afc =	0.373	5.1c	LTAMULT_cfc =	0.581	
PENTOXSD TRG	5.1b	LTA_afc =	0.057	5.1d	LTA_cfc =	0.082	
Effluent Limit Calculations							
PENTOXSD TRG	5.1f	AML MULT =	1.231				
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) =	0.070		AFC		
		INST MAX LIMIT (mg/l) =	0.228				
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_afc		$\exp((0.5*\ln(cvh^2+1))-2.326*\ln(cvh^2+1)^0.5)$					
LTA_afc		wla_afc*LTAMULT_afc					
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_cfc		$\exp((0.5*\ln(cvd^2/no_samples+1))-2.326*\ln(cvd^2/no_samples+1)^0.5)$					
LTA_cfc		wla_cfc*LTAMULT_cfc					
AML MULT		$\exp(2.326*\ln((cvd^2/no_samples+1)^0.5)-0.5*\ln(cvd^2/no_samples+1))$					
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)					
INST MAX LIMIT		$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$					

WETT:

Minor facilities and facilities without a formal EPA approved pretreatment program are exempted from WETT.

Anti-Backsliding:

The proposed limits are at least as stringent as are in existing permit; therefore, anti-backsliding is not applicable

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

WQM 7.0:

The following data were used in the attached computer model (WQM 7.0) of the stream:

* Discharge pH = 7.0 (Default)
* Discharge Temperature = 25°C (Default)
* Stream pH = 7.0 (Default)
* Stream Temperature = 20°C (Default)
* Background NH₃-N = 0 mg/L (Default)

Node 1: Outfall 001 UNT to Furnace Creek (1688)

Elevation: 800 ft (USGS National Map Viewer)
Drainage Area: 0.45 mi² (USGS PA StreamStats)
River Mile Index: 0.380 (PA DEP eMapPA)
Low Flow Yield: 0.07 cfs/mi²
Discharge Flow: 0.05 MGD

Node 2: At confluence with Unnamed Tributary to Furnace Creek (1688)

Elevation: 776 ft (USGS National Map Viewer)
Drainage Area: 0.46 mi² (USGS PA StreamStats)
River Mile Index: 0.001 (PA DEP eMapPA)
Low Flow Yield: 0.07 cfs/mi²
Discharge Flow: 0.0 MGD

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI	Discharge Name	Permit Number Disc Flow (mgd)	
		30 Day Average (mg/L)	Maximum (mg/L)
0.38	Golden Oaks WTP	PA0085782	0.0500
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	2.38	4.76	
Dissolved Oxygen			5

Record: 1 of 1 < Back Next > No Filter Search

Print Archive Cancel

NPDES Permit Fact Sheet Golden Oaks

NPDES Permit No. PA0085782

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name						
03D	1688	FURNACE CREEK						
RMB	Name	Permit Number	Disc. Flow (mpd)	Parameter	Eff. Limit (mg/L)	SWP Limit (mg/L)	Eff. Limit (mg/L)	SWP Limit (mg/L)
0.360	Golden Oaks WTP	P40085782	0.050	CBD (S)	25	25	4.76	4.76
				NH3-N	2.38			
				Discharged Oxygen	5			

Wednesday, September 18, 2024

Version 1.1

Page: 14 | 1 | No Filter

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name							
03D	1688	FURNACE CREEK							
NHS-N Allocations									
RMB	Discharge Name	Baseline Criteria (mpg/L)	Baseline WLA (mpg/L)	Multiple Criteria (mpg/L)	Multiple WLA (mpg/L)	Critical Reach	Percent Reduction		
0.360	Golden Oaks WTP	12.06	12.06	15.21	15.21	0	0		
NHS-N Chrome Allocations									
RMB	Discharge Name	Baseline Criteria (mpg/L)	Baseline WLA (mpg/L)	Multiple Criteria (mpg/L)	Multiple WLA (mpg/L)	Critical Reach	Percent Reduction		
0.360	Golden Oaks WTP	1.53	2.06	1.53	2.06	0	0		
Dissolved Oxygen Allocations									
RMB	Discharge Name	CBD (S)	NH3-N	Baseline Criteria (mpg/L)	Baseline Multiple (mpg/L)	Discharged Oxygen	Baseline Multiple (mpg/L)	Critical Reach	Percent Reduction
0.360	Golden Oaks WTP	25	25	2.38	2.38	5	5	0	0

Wednesday, September 18, 2024

Version 1.1

Page: 14 | 1 | No Filter

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name	
03D	1688	FURNACE CREEK	
RMB	Total Discharge Flow (mpd)	Analytic Temperature (°C)	Analytic pH
0.360	0.050	25.00	7.00
Reach Width (ft)	Reach Depth (ft)	Reach W/Ratio	Reach Velocity (ft/s)
3.887	0.358	10.854	0.076
Reach CDD05 (mpg/L)	Reach Kc (1/day)	Reach NH3-N (mpg/L)	Reach Kn(1/day)
16.34	1.438	1.69	0.920
Reach DO (mpg/L)	Reach Kt (1/day)	Kt Equation	Reach DO Goal (mpg/L)
5.938	28.368	Owens	5
Reach Travel Time (days)		Subreach Results	
0.298		Travel Time (days)	CBD (S) NH3-N (mpg/L) D.O. (mpg/L)
		0.030	17.44 1.05 6.40
		0.060	16.58 1.00 6.64
		0.090	15.77 1.56 6.60
		0.119	14.99 1.32 6.91
		0.149	14.26 1.18 7.05
		0.179	13.56 1.44 7.07
		0.208	12.88 1.00 7.15
		0.238	12.25 1.56 7.21
		0.268	11.65 1.32 7.28
		0.298	11.08 1.29 7.34

Wednesday, September 18, 2024

Version 1.1

Page: 14 | 1 | No Filter

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameters	Value	Notes
WLA Method	EMPR	Use Inputted Q1-10 and Q30-10 Flows
Q1-10/Q74-0 Ratio	0.61	Use Inputted W/D Ratio
Q30-10/Q7-10 Ratio	1.36	Use Inputted Reach Travel Times
D.O. Saturation	90.0%	Temperature Adjust Kt
D.O. Goal	5	Use Balanced Technology

Wednesday, September 18, 2024

Version 1.1

Page: 14 | 1 | No Filter

NPDES Permit Fact Sheet
Golden Oaks

NPDES Permit No. PA0085782

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name: FURNACE CREEK									
RMB	Stream Flow	PWS With	Net Streamflow	Reach	Depth	Width	WD Ratio	Velocity	Reach Time	Analytic Temp	Analytic pH
(cfs)	(cfs)	(cfs)	(cfs)	(ft)	(ft)	(ft)	(ft)	(ft/s)	(days)	(°C)	
Q1-10 Flow	0.380	0.03	0.03	0773.001199	.309	3.9	10.85	0.08	0.298	23.55	7.00
Q1-10 Flow	0.380	0.02	0.00	0773.001199	NA	NA	NA	0.07	0.317	23.97	7.00
Q30-10 Flow	0.380	0.04	0.00	0773.001199	NA	NA	NA	0.08	0.282	23.22	7.00

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name: FURNACE CREEK									
RMB	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC						
(ft)	(ft)	(sq mi)	(ft)	(inpd)							
030	1688	FURNACE CREEK	0.380	80.00	0.45	0.000000	0.00	<input checked="" type="checkbox"/>			

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tributary Temp	pH	Stream Temp	pH
(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)	(ft)	(ft)	(ft)	(°C)		(°C)	
Q1-10	0.070	0.00	0.000	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	7.00	
Q1-10	0.00	0.00	0.000	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	7.00	
Q30-10	0.00	0.00	0.000	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	7.00	

Discharge Data

Name	Permit Number	Existing Disc. Flow (inpd)	Permitted Disc. Flow (inpd)	Design Disc. Flow (inpd)	Disc. Reserve Factor	Disc. Temp (°C)	Disc. pH
Golden Oaks WTP	PA0085782	0.0500	0.0500	0.0500	0.0000	25.00	7.00

Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Date Coef (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Wednesday, September 18, 2024

Version 1.1

Page 1 of 1

Wednesday, September 18, 2024

Version 1.1

Page 1 of 2

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name: FURNACE CREEK									
RMB	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC						
(ft)	(ft)	(sq mi)	(ft)	(inpd)							
030	1688	FURNACE CREEK	0.380	80.00	0.45	0.000000	0.00	<input checked="" type="checkbox"/>			

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tributary Temp	pH	Stream Temp	pH
(cfs)	(cfs)	(cfs)	(days)	(ft/s)	(ft)	(ft)	(ft)	(ft)	(°C)		(°C)	
Q1-10	0.070	0.00	0.000	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	7.00	
Q1-10	0.00	0.00	0.000	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	7.00	
Q30-10	0.00	0.00	0.000	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	7.00	

Discharge Data

Name	Permit Number	Existing Disc. Flow (inpd)	Permitted Disc. Flow (inpd)	Design Disc. Flow (inpd)	Reserve Factor	Disc. Temp (°C)	Disc. pH
Golden Oaks WTP	PA0085782	0.0500	0.0500	0.0500	0.0000	25.00	7.00

Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Date Coef (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Wednesday, September 18, 2024

Version 1.1

Page 1 of 2



Page: 1 No Filter

12

NPDES Permit Fact Sheet

Golden Oaks

NPDES Permit No. PA0085782



NPDES Permit Fact Sheet

Golden Oaks

NPDES Permit No. PA0085782



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.4934	degrees
DRNAREA	Area that drains to a point on a stream	0.46	square miles
ROCKDEP	Depth to rock	5	feet
URBAN	Percentage of basin with urban development	4.2699	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.46	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	3.4934	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5	feet	4.13	5.21
URBAN	Percent Urban	4.2699	percent	0	89

Low-Flow Statistics Disclaimer [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.084	ft³/s
30 Day 2 Year Low Flow	0.115	ft³/s
7 Day 10 Year Low Flow	0.0327	ft³/s
30 Day 10 Year Low Flow	0.0473	ft³/s
90 Day 10 Year Low Flow	0.0854	ft³/s



Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.07	XXX	0.23	1/day	Grab
CBOD ₅	10.4	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	12.5	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Total Dissolved Solids	Report	XXX	XXX	1,000.0	XXX	2,000	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	3.0	XXX	XXX	7.2	XXX	14.4	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	1.0	XXX	XXX	2.4	XXX	4.8	2/month	8-Hr Composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment █)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment █)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment █)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment █)
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input checked="" type="checkbox"/>	Other: DRBC regulation