

Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0086525  
APS ID 324570  
Authorization ID 1455763

**Applicant and Facility Information**

Applicant Name	<b>Centre Township Municipal Authority</b> <b>Berks County</b>	Facility Name	<b>Centre Township Kingsgate East STP</b>
Applicant Address	449 Bucks Hill Road Mohrsville, PA 19541-9340	Facility Address	39 Cornerstone Drive Mohrsville, PA 19541-9250
Applicant Contact	David Phillips	Facility Contact	David Kline
Applicant Phone	(610) 926-8833	Facility Phone	(717) 560-2760
Client ID	93104	Site ID	448217
Ch 94 Load Status	Existing Hydraulic and Organic Overload	Municipality	Centre Township
Connection Status	Self-Imposed Connection Prohibition	County	Berks
Date Application Received	<u>September 19, 2023</u>	EPA Waived?	Yes
Date Application Accepted	<u>October 2, 2023</u>	If No, Reason	
Purpose of Application	NPDES renewal permit.		

**Summary of Review**

System Design Engineering, Inc. on behalf of the Centre Township Municipal Authority (Authority/Permittee), applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The permit was reissued on March 21, 2019 and became effective on April 1, 2019. The permit expired on March 31, 2024 but the terms and conditions of the permit have been administratively extended since that time.

The average annual design flow and hydraulic design capacity is 0.012 MGD, and the organic loading capacity is 24 lbs BOD<sub>5</sub>/day. The renewal application indicated the STP receives its 100% from the Centre Township.

The WQM Part II permit No. 0694424 was issued on 4/5/1995. The WQM Part II permit No. 0694424 amendment was issued on 12/28/2020.

Sludge use and disposal description and location(s): N/A because sludge hauled by ARRO Water Service.

DRBC Docket No. D-2018-006 CP-1 approval date was 6/12/2019 and expiration date is 12/31/2027.

Changes from the previous permit: E. Coli monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	October 11, 2024
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	October 15, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.012
Latitude	40° 28' 4.00"	Longitude	-76° 3' 4.00"
Quad Name	Bernville	Quad Code	1537
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to Irish Creek (WWF)	Stream Code	02171
NHD Com ID	25962076	RMI	0.45
Drainage Area	1.39 mi. <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	See comments below
Q <sub>7-10</sub> Flow (cfs)	See comments below	Q <sub>7-10</sub> Basis	See comments below
Elevation (ft)	376	Slope (ft/ft)	
Watershed No.	3-B	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	See comments below		
Cause(s) of Impairment	See comments below		
Source(s) of Impairment	See comments below		
TMDL Status	See comment below	Name	Irish Creek
Nearest Downstream Public Water Supply Intake		Borough of Pottstown Water and Sewer Authority	
PWS Waters	Schuylkill River	Flow at Intake (cfs)	
PWS RMI	33.03 miles	Distance from Outfall (mi)	Approximate 40.0 miles

Changes Since Last Permit Issuance:

*Drainage Area*

The discharge is to Unnamed Tributary 02171 to Irish Creek at RMI 0.45. A drainage area upstream of the discharge point is estimated to be 1.39 sq.mi. according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

*Streamflow*

USGS StreamStats produced a Q<sub>7-10</sub> flow of 0.0223 cfs. However, the drainage area used in regression equations to calculate the low flow statistics is lower than the minimum required value; therefore, the produced Q<sub>7-10</sub> flow may not be entirely accurate. Consequently, flows measured at USGS gage station on the Schuylkill River at Berne (station No. 01470500) have been correlated with the stream conditions at the point of discharge as follows:

$$\text{Low Flow Yield} = Q_{7-10\text{gage}} / \text{Drainage Area}_{\text{gage}} = 86 \text{ cfs} / 358 \text{ sq.mi.} = 0.24 \text{ cfs/sq.mi.}$$

$$Q_{7-10\text{site}} = \text{Low Flow Yield} * \text{Drainage Area}_{\text{site}} = 0.24 \text{ cfs/sq.mi.} * 1.39 \text{ sq.mi.} = 0.334 \text{ cfs.}$$

*Unnamed Tributary 02171 to Irish Creek*

Under Pa Code §93.9f, the entire Irish Creek basin is designated as warm water and migratory fishes. The main stem, Schuylkill River is also designated as warm water and migratory fishes. No special protection water(s) is therefore impacted by this discharge. No Class A Wild Trout fishery is impacted by this discharge. While Pennsylvania's 2024 integrated water quality report indicates that the receiving stream is not impaired, the report also specifies that Irish Creek is impaired for excessive siltation resulting from agricultural activities and derelict lands. A Total Maximum Daily Load (TMDL) has been prepared in 2012 to address this impairment. More details will be discussed later in this fact sheet.

*Public Water Supply Intake*

The fact sheet developed for the last permit renewal indicates that the nearest downstream public water supply intake is the Borough of Pottstown Water and Sewer Authority, located on the Schuylkill River approximately 40.0 miles from the discharge. Given the distance, the discharge is not expected to significantly affect the water supply.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Centre Township Kingsgate E STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
0694424	4/5/1995			
0694424 A-1	12/28/2020			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Hypochlorite	0.012
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.012	24	Not Overloaded	Sludge Holding	Other WWTP

Changes Since Last Permit Issuance:

The WWTP is an extended air/activated sludge type treatment process with an influent comminutor, EQ tank, 2 extended air treatment tanks, 2 clarifiers, 3 sludge thickening/aerobic digester tanks, chlorine contact tank, and outfall to Unnamed Tributary to Irish Creek.

Chlorine tablets are used for disinfection.

Sludge generated from the facility is stored in the sludge holding tank prior to being hauled off site via Marlin Nolt, LLC and ARRO Water Service.

Compliance History	
<b>Summary of DMRs:</b>	A summary of past 12-month DMR is presented on the next page.
<b>Summary of Inspections:</b>	May 8, 2018: Kevin Buss, DEP Water Quality Specialist, conducted a compliance evaluation inspection. No issues were specified on the inspection report. Recommendation was please submit the new chemical additive notification form for the anti-foam concentrate.
<b>Other Comments:</b>	There is currently no open violation associated with this facility or permittee.

Other Comments: 

Compliance History

DMR Data for Outfall 001 (from September 1, 2023 to August 31, 2024)

Parameter	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23
Flow (MGD) Average Monthly	0.01044 7	0.00971 4	0.00981 8	0.01086 5	0.01208 7	0.01386 3	0.01184 2	0.01396 4	0.01328 2	0.00989 2	0.00931 3	0.01001 5
Flow (MGD) Daily Maximum	0.01539 5	0.01407 5	0.01262 3	0.02748 9	0.02054 3	0.01988 3	0.02687 9	0.02308 4	0.01455 3	0.01560 9	0.01364 6	
pH (S.U.) Daily Minimum	7.09	7.38	7.28	7.15	6.9	6.91	7.1	7.0	7.04	7.2	7.01	7.3
pH (S.U.) Daily Maximum	8.52	8.51	8.48	8.16	8.18	8.46	8.6	8.42	8.79	8.11	8.37	8.78
DO (mg/L) Daily Minimum	6.0	6.8	7.4	7.5	7.0	7.3	8.0	7.94	7.78	7.32	5.26	6.99
TRC (mg/L) Average Monthly	0.16	0.17	0.18	0.18	0.18	0.16	0.21	0.13	0.16	0.2	0.2	0.21
TRC (mg/L) Instantaneous Maximum	0.28	0.43	0.39	0.48	0.26	0.5	0.50	0.38	0.45	0.47	0.36	0.56
CBOD5 (lbs/day) Average Monthly	0.3	0.3	0.3	0.4	0.4	0.4	0.7	0.8	0.6	1.1	0.4	0.2
CBOD5 (lbs/day) Weekly Average	0.4	0.3	0.4	0.5	0.4	0.4	0.7	0.8	0.9	1.8	0.4	0.3
CBOD5 (mg/L) Average Monthly	4.1	3.2	3.4	4.3	5.2	2.7	7.6	7.3	6.5	16.5	5.9	3.3
CBOD5 (mg/L) Weekly Average	4.0	4.0	4.0	6.0	7.0	3.0	8.0	8.0	10.0	27.0	6.0	4.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	12	12	10	21	20	15	16	18	17	16	13	14
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	17	17	14	24	28	18	17	23	19	19	14	14
BOD5 (mg/L) Raw Sewage Influent Average Monthly	143.4	136.8	123.4	233	231	106.4	185	162	184	210	190	179
TSS (lbs/day) Average Monthly	< 0.5	< 0.5	< 0.4	< 0.7	0.5	< 0.6	< 0.4	0.7	0.7	1.2	< 0.5	< 0.4
TSS (lbs/day) Raw Sewage Influent Average Monthly	5	8	9	6	8	9	5	8	7	4	4	4

## NPDES Permit Fact Sheet

## Centre Township Kingsgate East STP

## NPDES Permit No. PA0086525

TSS (lbs/day) Raw Sewage Influent   Daily Maximum	6	8	10	7	10	9	5	8	7	5	4	5
TSS (lbs/day) Weekly Average	0.7	0.5	0.4	1.0	0.6	0.7	0.5	0.9	1.0	1.2	0.7	0.5
TSS (mg/L) Average Monthly	< 6.5	< 5.3	< 4.3	< 7.5	6.0	< 4.4	< 5.2	6.2	7.9	15.6	< 7.0	< 5.2
TSS (mg/L) Raw Sewage Influent Average Monthly	58	86.6	101	71	117	65	53.8	67	72	50	58	56
TSS (mg/L) Weekly Average	9.0	7.0	5.0	11.0	7.0	5.0	6.0	8.0	11.0	18.0	10.0	6.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1	4	< 1	< 5	< 2	1	2	< 3	10	3	< 1	< 4
Fecal Coliform (No./100 ml) Instantaneous Maximum	1	13	< 1	22	6	2	3	9	11	12	1	18
Nitrate-Nitrite (lbs/day) Daily Maximum			2			3.0			3			4
Nitrate-Nitrite (mg/L) Daily Maximum			19.6			23.1			40.1			52.4
Total Nitrogen (lbs/day) Daily Maximum			2			4.0			3			4
Total Nitrogen (mg/L) Daily Maximum			20.9			24.4			42.5			53.6
Ammonia (lbs/day) Average Monthly	< 0.008	< 0.009	0.07	< 0.009	< 0.08	< 0.01	< 0.009	< 0.01	< 0.09	0.07	0.02	< 0.008
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	0.83	< 0.1	< 0.8	< 0.1	< 0.1	< 0.12	< 0.97	0.9	0.33	< 0.1
TKN (lbs/day) Daily Maximum			0.1			0.2			0.2			0.08
TKN (mg/L) Daily Maximum			1.34			1.34			2.41			1.21
Total Phosphorus (lbs/day) Daily Maximum			0.5			0.4			0.5			0.5
Total Phosphorus (mg/L) Daily Maximum			4.46			2.55			6.87			7.37

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Daily Max	XXX	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	2.5	4.0	XXX	25	40	50	2/month	8-Hr Composite
BOD Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	2/month	8-Hr Composite
TSS	3.0	4.5	XXX	30	45	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Ammonia Nov 1 - Apr 30	2.0	XXX	XXX	20	XXX	40	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	1.8	XXX	XXX	18	XXX	36	2/month	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite
Total Kjeldahl Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite
Nitrate-Nitrite as N	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	Calculation

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 40° 28' 4.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.012  
Longitude -76° 3' 4.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: [redacted]

**Water Quality-Based Limitations**

**Ammonia (NH<sub>3</sub>-N):**

NH<sub>3</sub>N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached WQM 7.0 computer model of the stream:

- \* Discharge pH = 7.0 (Default)
- \* Discharge Temperature = 25°C (Default)
- \* Stream pH = 7.0 (Default)
- \* Stream Temperature = 25°C (Default)
- \* Background NH<sub>3</sub>-N = 0 mg/L (Default)
- \*

Analysis Results WQM 7.0

RMI	Discharge Name	Permit Number	Disc. Flow (mgd)																
0.45	CTMA Kingsgate	PA0086525	0.0120																
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Effluent Limit 30 Day Average (mg/L)</th> <th>Effluent Limit Maximum (mg/L)</th> <th>Effluent Limit Minimum (mg/L)</th> </tr> </thead> <tbody> <tr> <td>CBOD<sub>5</sub></td> <td>25</td> <td></td> <td></td> </tr> <tr> <td>NH<sub>3</sub>-N</td> <td>18</td> <td>36</td> <td></td> </tr> <tr> <td>Dissolved Oxygen</td> <td></td> <td></td> <td>5</td> </tr> </tbody> </table>				Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)	CBOD <sub>5</sub>	25			NH <sub>3</sub> -N	18	36		Dissolved Oxygen			5
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)																
CBOD <sub>5</sub>	25																		
NH <sub>3</sub> -N	18	36																	
Dissolved Oxygen			5																
Record: 1 of 1   < Back   Next >   No Filter   Search																			
Print   Archive   Cancel																			

Regarding NH<sub>3</sub>-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 18.0 mg/L as a monthly average and 36.0 mg/L instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects at the point of discharge. Therefore, the existing summer limits of 18.0 mg/L monthly average & 36.0 mg/L IMAX are same and will remain in the proposed permit. The existing winter average monthly limit of 20.0 mg/L & IMAX limit of 40.0 mg/L will remain in place. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Summer average monthly mass limit: 18.0 mg/L x 0.012 MGD x 8.34 = 1.8 lbs/day  
Winter average monthly mass limit: 20.0 mg/L x 0.012 MGD x 8.34 = 2.0 lbs/day

**Dissolved Oxygen (D.O.):**

The minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BCW-PMT-033, version 2.0 revised February 5, 2024, and has been applied to other point source dischargers throughout the state.

**Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>):**

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. Therefore, the existing summer permit 25.0 mg/L as AML, 40.0 mg/L as weekly average limit (AWL), & 50.0 mg/L as IMAX will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has typically been achieving concentrations below this limit. Mass limits are calculated as follows:

Summer Average monthly mass limit: 25.0 mg/L x 0.012 MGD x 8.34 = 2.502 (2.5) lbs/day  
Summer Average weekly mass limit: 40.0 mg/L x 0.012 MGD x 8.34 = 4.00 (4.0) lbs/day

**pH:**

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

**Total Suspended Solids (TSS):**

The existing technology-based limits of 30.0 mg/L average monthly, 45.0 mg/L weekly average, and 60.0 mg/L IMAX will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Average monthly mass limit: 30.0 mg/L x 0.012 MGD x 8.34 = 3.0 lbs/day  
Average weekly mass limit: 45.0 mg/L x 0.012 MGD x 8.34 = 4.5 lbs/day

**Fecal Coliform:**

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

**E. Coli:**

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

**Raw Sewage Influent Monitoring:**

As a result of negotiation with EPA, influent monitoring of TSS and BOD<sub>5</sub> are required for any POTWs; therefore, influent sampling of BOD<sub>5</sub> and TSS will remain in the proposed permit. A 24-hr composite sample type will be required to be consistent with the proposed sampling frequency for TSS and BOD<sub>5</sub> in the effluent.

**Total Residual Chlorine (TRC):**

The attached computer printout utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for TRC (ID No. 391-2000-015) for developing chlorine limitations. The attached printout indicates that a water quality limit of 0.5 mg/L monthly average and 1.6 mg/L IMAX would be needed to prevent toxicity concerns. Therefore, the existing TRC limit of 0.5 mg/L monthly average and 1.6 mg/L IMAX are same and will remain in the proposed permit.

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.334	= Q stream (cfs)			
0.012	= Q discharge (MGD)			
30	= no. samples			
0.3	= Chlorine Demand of Stream			
0	= Chlorine Demand of Discharge			
0.5	= BAT/BPJ Value			
0	= % Factor of Safety (FOS)			
0.5	= CV Daily			
0.5	= CV Hourly			
1	= AFC_Partial Mix Factor			
1	= CFC_Partial Mix Factor			
15	= AFC_Criteria Compliance Time (min)			
720	= CFC_Criteria Compliance Time (min)			
	=Decay Coefficient (K)			
Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA afc = 5.758	1.3.2.iii	WLA cfc = 5.606
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373	5.1c	LTAMULT cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 2.146	5.1d	LTA_cfc = 3.259
Source		Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		
		INST MAX LIMIT (mg/l) = 1.635		
WLA afc		(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)		
LTAMULT afc		EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)		
LTA_afc		wla_afc*LTAMULT_afc		
WLA_cfc		(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)		
LTAMULT_cfc		EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)		
LTA_cfc		wla_cfc*LTAMULT_cfc		
AML MULT		EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))		
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)		
INST MAX LIMIT		1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)		

#### Stormwater:

There is no known stormwater outfall associated with this facility.

#### Toxics:

The application submitted for this permit renewal did not require sampling of toxics pollutants. According to the application, there is no commercial establishment/business within the service area. Therefore, there is no toxics pollutants of concern from this discharge.

#### Irish Creek Total Maximum Daily Load (TMDL):

Irish Creek is impaired for excessive siltation as a result of agricultural activities and derelict lands. A TMDL was developed in 2012 to address this impairment and specifies a Total Suspended Solids wasteload allocation (WLA) of 3.0 lbs/day (average monthly) or 1,095.88 lbs/yr (annual average) for this facility. However, since this TMDL has not yet been finalized, it is not appropriate at this time to include this WLA in the permit. DEP has therefore determined to include the following reopen clause in Part C of this permit in case the TMDL is finalized during the upcoming permit term:

*“A Total Maximum Daily Load (TMDL) for sediment was developed by the Department in 2012 to address impairments noted in Pennsylvania’s 2010 Integrated Report for the Irish Creek watershed in Berks County. In case the TMDL is finalized and approved by U.S. EPA during this permit term, the permit will be reopened and modified, if necessary, to reflect any TMDL requirements associated with this facility.”*

#### Chesapeake Bay Total Maximum Daily Load (TMDL):

The facility is not located within the Chesapeake Bay watershed; therefore, no Chesapeake Bay TMDL has been taken into consideration at this time.

*Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the permit per 40 CFR § 122.44(i)(1)(ii).

*Mass Loading Limitations*

All applicable effluent mass loading limits will be based on the formula: design flow x concentration limit x conversion factor of 8.34.

*Total Phosphorus / Total Nitrogen*

DEP's current Standard Operating Procedure for establishing effluent limitations for individual sewage permits (SOP no. BPNPSM-PMT-033) recommends a routine monitoring of Total Phosphorus and Total Nitrogen for facilities with design flows greater than 0.002 MGD. The requirement to monitor for these pollutants will therefore be included in the permit. Since the receiving stream is not impaired for nutrients at this time, a quarterly monitoring will provide ample data for further evaluation.

*Delaware River Basin Commission Permitting*

The facility is located in the Delaware River basin; yet, the discharge is less than 0.05 MGD. DRBC approval is not required for those facilities discharging less than 0.05 MGD.

*Antidegradation Requirements*

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

*Antibacksliding Requirements*

Unless specified otherwise throughout this fact sheet, effluent limits for all pollutants of concern have been developed at least as stringent as effluent limits written in the existing permit renewal. This approach is consistent with 40 CFR §122.44(l)(1).

**WQM 7.0:**

The following data were used in the attached computer model (WQM 7.0) of the stream:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	25°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	25°C	(Default)
*	Background NH <sub>3</sub> -N	=	0 mg/L	(Default)

Node 1: Outfall 001(02171) to Irish Creek



Elevation:	376.0 ft (USGS National Map Viewer)
Drainage Area:	1.39 mi <sup>2</sup> (USGS PA StreamStats)
River Mile Index:	0.45 (PA DEP eMapPA)
Low Flow Yield:	0.24 cfs/mi <sup>2</sup>
Discharge Flow:	0.012 MGD

Node 2: At confluence with Irish Creek (02153)

Elevation:	350.0 ft (USGS National Map Viewer)
Drainage Area:	1.56 mi <sup>2</sup> (USGS PA StreamStats)
River Mile Index:	0.001 (PA DEP eMapPA)
Low Flow Yield:	0.24 cfs/mi <sup>2</sup>
Discharge Flow:	0.0 MGD

NPDES Permit Fact Sheet  
Centre Township Kingsgate East STP

NPDES Permit No. PA0086525



# NPDES Permit Fact Sheet

## Centre Township Kingsgate East STP

NPDES Permit No. PA0086525

**USGS StreamStats** science for a changing world

SELECT A STATE / REGION Pennsylvania

IDENTIFY A STUDY AREA Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built >

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

Basin Characteristics Report

Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Zoom Level: Map Scale: 1:250,000 Lat: 40.6926, Long: -75.5000 5 km 3 mi

**Basin Characteristics**

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0.12	percent
DRNAREA	Area that drains to a point on a stream	358	square miles
PRECIP	Mean Annual Precipitation	49	inches
ROCKDEP	Depth to rock	4.5	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.25	miles per square mile

**Low-Flow Statistics**

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	358	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	49	inches	35	50.4
STRDEN	Stream Density	1.25	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	0.12	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, Pseudo R<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	143	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	174	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	86	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	104	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	136	ft <sup>3</sup> /s	36	36

Batch Processor Report About ? Help

Layers Base Maps Application Layers National Layers PA Map Layers

**USGS StreamStats** science for a changing world

SELECT A STATE / REGION Pennsylvania

IDENTIFY A STUDY AREA Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built >

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

Basin Characteristics Report

Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Zoom Level: Map Scale: 1:250,000 Lat: 40.4655, Long: -75.5000 300 m 1000 ft

**Basin Characteristics**

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	1.56	square miles
PRECIP	Mean Annual Precipitation	45	inches
ROCKDEP	Depth to Rock	3	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.64	miles per square mile

**Low-Flow Statistics**

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.56	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	45	inches	35	50.4
STRDEN	Stream Density	1.64	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	3	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.095	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.155	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.0236	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.0421	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.09	ft <sup>3</sup> /s

Batch Processor Report About ? Help

Layers Base Maps Application Layers National Layers PA Map Layers

NPDES Permit Fact Sheet  
Centre Township Kingsgate East STP

NPDES Permit No. PA0086525

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.45	CTMA Kingsgate	PA0086525	0.0120

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	18	36	
Dissolved Oxygen			5

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name
03 B	2471	Trib 02171 to Irish Creek

RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
0.450	CTMA Kingsgate	PA0086525	0.012	CBOD5	25		
				NH3-N	18	36	
				Dissolved Oxygen			5

rpt\_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
03 B	2471	Trib 02171 to Irish Creek

NH3-N Acute Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.450 CTMA Kingsgate		11.07	36	11.07	36	0	0

NH3-N Chronic Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.450 CTMA Kingsgate		1.37	18	1.37	18	0	0

Dissolved Oxygen Allocations							
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)
0.450 CTMA Kingsgate		25	25	18	18	5	5

Friday, October 11, 2024 Version 1.1 Page 1 of 1

Friday, October 11, 2024 Version 1.1 Page 1 of 1

Page: 1 of 1 No Filter Page: 1 of 1 No Filter

NPDES Permit Fact Sheet  
Centre Township Kingsgate East STP

NPDES Permit No. PA0086525

rptDOSim

**WQM 7.0 D.O. Simulation**

SWP Basin	Stream Code	Stream Name
03B	2171	Trib 02171 to Iah Creek
RB	Total Discharge Flow (mgd)	Analysis Temp (°C)
0.450	Reach Depth (ft)	Analysis pH
7.111	Reach DWRatio	Reach Velocity (ft/s)
Reach CBOD5 (mg/L)	Reach K1 (days)	Reach NH3-N (mg/L)
Reach DO (mg/L)	Reach K2 (days)	Reach K3 (days)
8.072	Reach K4 (days)	Reach DO Goal (mg/L)
Reach Travel Time (days)	Reach Extension	Current
0.236		5
Time Step	Stream Reach	D.O.
(days)	(mg/L)	(mg/L)
0.050	3.16	8.82
0.077	3.11	7.54
0.071	3.06	7.54
0.091	3.01	7.54
0.118	2.97	7.54
0.145	2.97	7.54
0.165	2.97	7.54
0.189	2.83	7.54
0.212	2.78	7.54
0.236	2.74	7.54

Friday, October 11, 2024 Version 1.1 Page 1 of 1

rptModelSpecs

**WQM 7.0 Modeling Specifications**

Parameters	Value	Notes
Both	Use Inputted Q1-10 and Q30-10 Flow	<input checked="" type="checkbox"/>
WLA Method	EMPR	<input type="checkbox"/>
Q1-10/Q7-4 Ratio	0.64	<input type="checkbox"/>
Q30-10/Q1-10 Ratio	1.36	<input type="checkbox"/>
Temp. Adjustment	0.00	<input checked="" type="checkbox"/>
D.O. Saturation	90.0%	<input type="checkbox"/>
D.O. Goal	5	<input checked="" type="checkbox"/>
Balanced Technology		<input checked="" type="checkbox"/>

Friday, October 11, 2024 Version 1.1 Page 1 of 1

rptHydro

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin	Stream Code	Stream Name										
03B	2171	Trib 02171 to Iah Creek										
RB	PWS Flow	Net Precip Flow	Net Analysis Flow	Disc. Flow	Reach Flow	Depth (ft)	Width (ft)	WD Ratio	Velocity (ft/s)	Reach Time (days)	Analysis Temp (°C)	Analysis pH
	(d/s)	(d/s)	(d/s)	(d/s)	(d/s)	(ft)	(ft)		(ft/s)	(days)		

**Q7-10 Flow**

RB	Stream	PWS Flow (d/s)	Net Precip Flow (d/s)	Net Analysis Flow (d/s)	Disc. Flow (d/s)	Reach Flow (d/s)	Depth (ft)	Width (ft)	WD Ratio	Velocity (ft/s)	Reach Time (days)	Analysis Temp (°C)	Analysis pH
0.450	0.30	0.00	0.33	0.186	0.01097	.426	7.11	16.69	0.12	0.236	25.00	7.00	

**Q1-10 Flow**

RB	Stream	PWS Flow (d/s)	Net Precip Flow (d/s)	Net Analysis Flow (d/s)	Disc. Flow (d/s)	Reach Flow (d/s)	Depth (ft)	Width (ft)	WD Ratio	Velocity (ft/s)	Reach Time (days)	Analysis Temp (°C)	Analysis pH
0.450	0.21	0.00	0.21	0.186	0.01097	NA	NA	NA	0.09	0.298	25.00	7.00	

**Q30-10 Flow**

RB	Stream	PWS Flow (d/s)	Net Precip Flow (d/s)	Net Analysis Flow (d/s)	Disc. Flow (d/s)	Reach Flow (d/s)	Depth (ft)	Width (ft)	WD Ratio	Velocity (ft/s)	Reach Time (days)	Analysis Temp (°C)	Analysis pH
0.450	0.45	0.00	0.45	0.186	0.01097	NA	NA	NA	0.14	0.200	25.00	7.00	

Friday, October 11, 2024 Version 1.1 Page 1 of 1

rptGeneral

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RB	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	App FC
03B	2171	Trib 02171 to Iah Creek	0.450	376.00	1.38	0.000000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rch Flow Time (days)	Rch Velocity (ft/s)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Temp (°C)	Temp (°F)	Temp (pH)
Q7-10	0.210	0.00	0.00	0.0000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	25.00	7.00	0.00	0.00

**Discharge Data**

Name	Permit Number	Design Flow (mgd)	Design Flow (mgd)	Design Flow (mgd)	Disc. Temp (°C)	Disc. pH
CTMA Kingsgate	PA0086525	0.0120	0.0120	0.0120	25.00	7.00

**Parameter Data**

Parameter Name	Disc. Conc. (mg/L)	TRB Conc. (mg/L)	Streams Conc. (mg/L)	Rate Coef. (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	18.00	0.00	0.00	0.70

Friday, October 11, 2024 Version 1.1 Page 1 of 2

rptGeneral

Input Data WQ M 7.0

SWP Basin	Stream Code	Stream Name	R.M.	Elevation (ft)	Drainage Area (sq. mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
03B	2171	Trib 02171 to Irish Creek	0.001	35.00	1.56	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rich Trav Time (days)	Rich Velocity (fts)	WD Ratio	Rich Width (ft)	Rich Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
Q1-10	0.240	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00	
Q1-10	0.00	0.00	0.000									
Q30-10	0.00	0.00	0.000									

Discharge Data

Name	Permit Number	Existing Dis. Flow (mgd)	Punctuated Dis. Flow (mgd)	Design Dis. Flow (mgd)	Reserve Factor	Dis. Temp (°C)	Dis. pH
CTMA Kingsgate	PA0086525	0.0000	0.0000	0.0000	0.00	25.00	7.00

Parameter Data

Parameter Name	Dis. Conc. (mg/L)	Trib. Conc. (mg/L)	Stream Conc. (mg/L)	Fate Coef.
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	0.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Friday, October 11, 2019

Version 1.1

Page 2 of 2

Page: 14   <input type="button" value="84

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Daily Max	XXX	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD <sub>5</sub>	2.5	4.0	XXX	25.0	40.0	50.0	2/month	8-Hr Composite
BOD <sub>5</sub> Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	3.0	4.5	XXX	30.0	45.0	60.0	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	2.0	XXX	XXX	20.0	XXX	40	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	1.8	XXX	XXX	18.0	XXX	36	2/month	8-Hr Composite
TKN	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite

## NPDES Permit Fact Sheet

Centre Township Kingsgate East STP

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

## NPDES Permit No. PA0086525

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Nitrate-Nitrite	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	Calculation
Total Phosphorus	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite

Compliance Sampling Location: Other Comments: 

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment █ )
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment █ )
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment █ )
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment █ )
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input checked="" type="checkbox"/>	Other: DRBC regulation