

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0086894
 APS ID 1069560
 Authorization ID 1430685

Applicant and Facility Information

Applicant Name	<u>The York Water Co.</u>	Facility Name	<u>Country View Manor STP</u>
Applicant Address	<u>130 E Market Street</u> <u>York, PA 17401-1219</u>	Facility Address	<u>1 Country View Court 151 Rowland Road</u> <u>East Berlin, PA 17316-8956</u>
Applicant Contact	<u>Vaughn Wenger</u>	Facility Contact	<u>Vaughn Wenger</u>
Applicant Phone	<u>(717) 894-6475</u>	Facility Phone	<u>(717) 894-6475</u>
Client ID	<u>69800</u>	Site ID	<u>258360</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Washington Township</u>
Connection Status	<u>No Limitations</u>	County	<u>York</u>
Date Application Received	<u>March 14, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 16, 2023</u>	If No, Reason	<u></u>
Purpose of Application	<u>.Renewal of existing sewage discharge permit.</u>		

Summary of Review

The York Water Co. (YWC) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of a NPDES permit for the Country View Manor STP. The permit was last issued to the Country View Manor Community, LLC on December 4, 2020 (Amendment A-1) and transferred to YWC on November 23, 2022. The permit expired on September 30, 2023 but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days. A file review of documents associated with the discharge or permittee may be available at the PA DEP southcentral regional office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file reviews, contact the SCRO file review coordinator at 717.705.4700.

Sludge use and disposal description and location(s): Land application via Smith's Disposal Facility (Adams County).

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
x		<i>Aaron Baar</i> Aaron Baar / Permits Section	February 27, 2024
x		<i>Maria D. Bebenek</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	April 11, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0125</u>
Latitude	<u>39° 59' 3.24"</u>	Longitude	<u>-76° 59' 12.14"</u>
Quad Name	<u>Abbottstown</u>	Quad Code	<u>1930</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Red Run (WWF)</u>	Stream Code	<u>08600</u>
NHD Com ID	<u>57468875</u>	RMI	<u>0.40</u>
Drainage Area	<u>0.56 mi²</u>	Yield (cfs/mi ²)	<u>0.043</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.0243</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>7-F</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u>Name</u>		
Nearest Downstream Public Water Supply Intake	<u>Wrightsville Water Supply Co.</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u>28.51</u>	Distance from Outfall (mi)	<u>44.95</u>

Changes Since Last Permit Issuance: All Clean Water permits issued to the Country View Manor Community, LLC, the previous permittee, were transferred to YWC on November 23, 2022. At the time of transfer, it was noted that there was an open violation associated with this facility for not installing an effluent flow meter at the outfall for the sewage treatment plant. YWC committed to rectifying this omission upon taking possession of the facility; it is unknown at this time if an effluent flow meter has been installed yet.

Drainage Area

The discharge is to an UNT to Red Run at RMI 0.40. A drainage area upstream of the discharge is determined to be 0.56 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, the watershed has a Q₇₋₁₀ of 0.0243 cfs. This information was used to obtain a LFY, a chronic 30-day (Q₃₀₋₁₀) and acute (Q₁₋₁₀) exposure stream flows for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned}
 Q_{7-10} &= 0.0243 \text{ cfs} \\
 Q_{30-10} &= 1.36 * 0.0243 \text{ cfs} = 0.033 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.0243 \text{ cfs} = 0.0156 \text{ cfs} \\
 LFY &= 0.243 \text{ cfs}/0.56 \text{ mi}^2 = 0.043 \text{ cfs/mi}^2
 \end{aligned}$$

UNT to Red Run

25 Pa Code §93.9 classifies the receiving water, UNT to Red Run, with a WWF Existing Use designation. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed as attaining use(s).

Local Watershed Total Maximum Daily Loads (TMDLs)

According to PA's 2024 integrated water quality monitoring and assessment report, UNT to Red Run in the vicinity of the point of discharge is impaired for recreational activities as a result of an unknown source of pathogens. The impairment is listed as Category 5 in the report, indicating that the UNT to Red Run is impaired for one or more uses by a pollutant that require the development of a TMDL. A TMDL for this waterway has not been developed to date.

Public Water Supply Intake

The nearest downstream public water supply intake is the The Wrightsville Water Supply Company intake located on the Susquehanna River approximately 45 miles from the discharge. Considering the distance and nature, the discharge is not expected to significantly affect the water supply.

Class A Wild Trout Streams

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

Treatment Facility Summary				
Treatment Facility Name: Country View Mobile Home Park				
WQM Permit No.		Issuance Date		
6796405 T-2		12/4/2020		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Chlorine With Dechlorination	0.0125
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0125		Not Overloaded	Aerobic Digestion	Other WWTP

YWC owns and operates the sanitary wastewater treatment facility located in Washington Township, York County. This NPDES permit covers discharges of sewage treated by the Country View Manor STP. The facility serves the Country View Manor MHP; all sewer systems are 100% separated. With an annual average design flow 0.0125 MGD, this facility utilizes an extended aeration system consisting of:

Grease Trap (1) ⇒ Comminutor / Bar Screen (1) ⇒ EQ Tank (1) ⇒ Aeration Tank (3) ⇒ Clarifier (1) ⇒ Tablet Chlorinator / Chlorine Contact Tank (1) ⇒ Post Aeration Tank (1) ⇒ Discharge

The system incorporates the chemical additions of sodium hypochlorite (for disinfection) and soda ash (for pH control). A sludge holding tank is used for solids storage. There are no industrial/commercial user contributing industrial wastewater to the sewer system.

Compliance History	
Summary of DMRs:	DMR results for the past year are presented below.
Summary of Inspections:	<p>Since the last renewal of the facility's NPDES permit, the following inspections have been logged:</p> <p>April 21, 2022: A routine annual inspection was conducted by Brandon Bettinger. A violation was issued for failure to monitor flow as required by the NPDES permit (no flow measurement device). It was also recommended that NIST traceable thermometers are used for temperature verification within the sample storage refrigerator and the facility was told to include aeration pH readings on daily plant log.</p>

Other Comments: As of February 27, 2024, there are 10 open violations associated with this facility. The violations include 5 safe drinking water violations at the Country View Manor MHP, 3 safe drinking water violations at other YWC facilities and two unidentified clean water violations at the Country View Manor MHP. The SCRO CW Operations Chief has stated that the facility is on a path to compliance in regards to the 2 clean water violations, and the SCRO CW Program Manager has directed that this permit be drafted without requiring closure of the open drinking water violations. We will re-visit the open violations with SDW and consult with legal before issuance of the final permit to determine if there is a path to compliance at this facility.



WATER MANAGEMENT SYSTEM
OPEN VIOLATIONS BY CLIENT

3/27/2024 9:20:23 AM

Permit: PA0266566
Client: All

Open Violations: 10

CLIENT ID	CLIENT	PF ID	FACILITY	PF KIND	PF STATUS	NSP PROGRAM	PROGRAM SPECIFIC ID	NSP ID	VIOLATION ID	INSPECTION CATEGORY	VIOLATION DATE	VIOLATION CODE	VIOLATION	PF INSPECTOR	NSP REGION	INSPECTED SITE ID	INSPECTED SITE
69800	THE YORK WATER CO					WPC State Water Pollution Control	69800	3418993	967149	Cnt	08/20/2022	91.13(A)	CSL - Failure to immediately report to DEP a pollution incident		SCRO		
69800	THE YORK WATER CO					WPC State Water Pollution Control	69800	3418993	967147	Cnt	08/20/2022	CSL401	CSL - Unauthorized, unpermitted discharge of polluting substances to waters of the Commonwealth resulting in pollution		SCRO		
69800	THE YORK WATER CO	272896	COUNTRY VIEW MANOR YWC	Community	Active	Safe Drinking Water	7670129	3039963	991729	PF	04/17/2023	BIA	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	HOFFMAN, DREW	SCRO		
69800	THE YORK WATER CO	272896	COUNTRY VIEW MANOR YWC	Community	Active	Safe Drinking Water	SM2312731	3502361	984739	PF	02/10/2023	02	EXCEEDED THE CHEMICAL AVERAGE MAXIMUM CONTAMINANT LEVEL	HOFFMAN, DREW	SCRO		
69800	THE YORK WATER CO	272896	COUNTRY VIEW MANOR YWC	Community	Active	Safe Drinking Water	SM2321406	3542426	992289	PF	04/04/2023	02	EXCEEDED THE CHEMICAL AVERAGE MAXIMUM CONTAMINANT LEVEL	HOFFMAN, DREW	SCRO		
69800	THE YORK WATER CO	272896	COUNTRY VIEW MANOR YWC	Community	Active	Safe Drinking Water	SM2327936	3604333	8196396	PF	08/23/2023	02	EXCEEDED THE CHEMICAL AVERAGE MAXIMUM CONTAMINANT LEVEL	HOFFMAN, DREW	SCRO		
69800	THE YORK WATER CO	256634	FRANKLIN SYSTEM YORK WATER	Community	Active	Safe Drinking Water	SM2339837	3646212	8165460	PF	11/16/2023	27	DISINFECTION/DISINFECTION BYPRODUCTS MONITORING/REPORTING VIOLATION	METZGER, KRISTINE	SCRO		
69800	THE YORK WATER CO	256634	FRANKLIN SYSTEM YORK WATER	Community	Active	Safe Drinking Water	SM2339838	3646226	8165462	PF	11/16/2023	27	DISINFECTION/DISINFECTION BYPRODUCTS MONITORING/REPORTING VIOLATION	METZGER, KRISTINE	SCRO		
69800	THE YORK WATER CO	256634	FRANKLIN SYSTEM YORK WATER	Community	Active	Safe Drinking Water	SM2339839	3646228	8165463	PF	11/16/2023	27	DISINFECTION/DISINFECTION BYPRODUCTS MONITORING/REPORTING VIOLATION	METZGER, KRISTINE	SCRO		
69800	THE YORK WATER CO	272896	COUNTRY VIEW MANOR YWC	Community	Active	Safe Drinking Water	SM2409132	3701453	8173191	PF	01/29/2024	02	EXCEEDED THE CHEMICAL AVERAGE MAXIMUM CONTAMINANT LEVEL	HOFFMAN, DREW	SCRO		

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.06	XXX	0.20	1/day	Grab
CBOD5 Nov 1 - Apr 30	XXX	XXX	XXX	12.0	XXX	24.0	2/month	8-Hr Composite
CBOD5 May 1 - Oct 31	XXX	XXX	XXX	5.5	XXX	11.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	3.5	XXX	7.0	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	Report	XXX	XXX	1.5	XXX	3.0	2/month	8-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

Compliance History

DMR Data for Outfall 001 (from December 1, 2022 to November 30, 2023)

Parameter	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22
Flow (MGD) Average Monthly	0.006	0.005	0.004	0.004	0.004	0.005	0.004	0.004	0.006	0.007	0.006	0.007
Flow (MGD) Daily Maximum	0.012	0.008	0.008	0.006	0.007	0.007	0.013	0.010	0.017	0.010	0.011	0.021
pH (S.U.) Instantaneous Minimum	7.42	7.62	7.65	7.6	7.77	7.63	7.57	7.5	7.47	7.66	7.67	6.74
pH (S.U.) Instantaneous Maximum	8.34	8.32	8.26	8.25	8.37	8.45	8.36	8.35	8.32	8.37	8.31	7.98
DO (mg/L) Instantaneous Minimum	9.46	8.87	8.34	8.01	7.83	8.13	8.74	9.04	9.84	10.05	9.71	7.7
TRC (mg/L) Average Monthly	0.02	0.02	0.03	0.03	< 0.03	< 0.02	< 0.02	< 0.04	< 0.04	< 0.03	< 0.04	< 0.02
TRC (mg/L) Instantaneous Maximum	0.05	0.05	0.10	0.06	0.05	0.04	0.05	0.09	0.16	0.06	0.07	0.08
CBOD5 (mg/L) Average Monthly	< 2.4	< 2.4	< 2.5	< 2.4	3.0	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 2.6

**NPDES Permit Fact Sheet
Country View Manor STP**

NPDES Permit No. PA0086894

CBOD5 (mg/L) Instantaneous Maximum	< 2.4	2.4	2.6	< 2.4	3.2	3.0	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	2.8
TSS (mg/L) Average Monthly	2.0	3.5	2.0	7.0	5.0	3.0	3.0	6.0	1.0	5.0	3.0	8.0
TSS (mg/L) Instantaneous Maximum	3.0	4.0	2.0	7.0	6.0	3.0	3.0	5.0	1.0	5.0	3.0	9.0
Fecal Coliform (No./100 ml) Geometric Mean	4	9	184	44.0	101	60	10	44	167	34	11.14	207
Fecal Coliform (No./100 ml) Instantaneous Maximum	5	30	1203	75.0	135	326	12	214	411	49	71	387
Nitrate-Nitrite (mg/L) Average Monthly	71	64.0	61.0	64.0	63.0	62.5	52	53	43	36	37.0	44.0
Nitrate-Nitrite (lbs) Total Monthly	80	50	69.0	58.0	73.0	71.0	57	46.0	73	50	57.4	< 64
Total Nitrogen (mg/L) Average Monthly	< 71.5	64.5	< 61.0	< 64.5	< 63.5	< 63.0	< 52	< 53	< 43.5	< 36	< 75.00	< 44.0
Total Nitrogen (lbs) Total Monthly	< 80.4	< 50.2	< 69.0	< 59.0	< 74.0	< 71.0	< 58	< 47	< 74	< 50	< 58.2	< 64
Total Nitrogen (lbs) Total Annual			765									
Ammonia (lbs/day) Average Monthly	< 0.004	< 0.003	< 2.0	< 0.003	< 0.004	< 0.004	< 0.004	< 0.003	< 0.005	< 0.005	< 0.005	< 0.007
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.12	< 0.1	< 0.1	< 0.1	< 0.1	< 0.11	< 0.14
Ammonia (mg/L) Instantaneous Maximum	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	0.14	< 0.1	< 0.1	< 0.1	< 0.1	0.11	0.18
Ammonia (lbs) Total Monthly	< 0.1	< 0.1	< 0.1	< 0.003	< 0.1	< 0.1	< 0.1	< 0.09	< 0.2	< 0.1	< 0.2	< 0.2
Ammonia (lbs) Total Annual			1									
TKN (mg/L) Average Monthly	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
TKN (lbs) Total Monthly	< 1	< 1	< 0.6	< 0.5	< 0.6	< 0.6	< 0.6	< 0.4	< 0.8	< 0.7	< 0.03	< 0.7
Total Phosphorus (lbs/day) Average Monthly	0.3	0.2	0.3	0.2	0.3	0.3	0.2	0.1	0.3	0.2	0.2	0.2

**NPDES Permit Fact Sheet
Country View Manor STP**

NPDES Permit No. PA0086894

Total Phosphorus (mg/L) Average Monthly	7.5	7.5	7.5	8.3	9.0	9.3	6	4.27	5.5	4.5	4.0	4.6
Total Phosphorus (lbs) Total Monthly	8	6	9.0	7.0	10.0	10.0	7	3.0	9	6.0	6.0	7.0
Total Phosphorus (lbs) Total Annual			89									

Compliance History

Effluent Violations for Outfall 001, from: January 1, 2023 To: November 30, 2023

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	09/30/23	IMAX	1203	No./100 ml	1000	No./100 ml

Other Comments: Permittee stated in response to the Fecal Coliform violations that the facility will begin testing and recording TRC on pre-dechlorination tank to establish a minimum TRC reading to ensure adequate disinfection before discharging.

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.0125</u>
Latitude <u>39° 59' 2.60"</u>	Longitude <u>-76° 59' 12.49"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

Water Quality-Based Limitations

CBOD₅, NH₃-N and Dissolved Oxygen (DO)

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD₅, NH₃-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. The model was utilized, and the model output indicated that existing limits for ammonia are lower than those specified in the model. Due to anti-backsliding provisions, however, the existing limits are deemed to be still appropriate.

The existing D.O. limit of 5 mg/L is considered still appropriate.

The monitoring frequency and sample type for CBOD₅, DO and ammonia are proposed to remain unchanged.

Toxics

There are no industrial or commercial contributions to this facility. DEP's NPDES permit application for minor sewages (less than 0.1 MGD) does not require sampling for heavy metals including Total Copper, Total Lead, and Total Zinc.

Total Residual Chlorine

Since chlorine is used for disinfection, Total Residual Chlorine (TRC) effluent levels must be regulated in accordance with 25 Pa Code §92a.48(b). DEP's TRC_CALC worksheet was utilized to determine if the existing BAT TBEL is still appropriate. The worksheet indicated that existing limits for TRC are lower than those specified in the worksheet. Due to anti-backsliding provisions, however, the existing limits are deemed to be still appropriate.

E. Coli Monitoring

In conformity with the Department's *Establishing Effluent Limitations for Individual Sewage Permits* (SOP No. BCW-PMT-033) and as authorized by § 92a.61 of the PA Code, annual E. Coli monitoring has been proposed in this permit. The collection method will be via grab sample.

Best Professional Judgment (BPJ) Limitations

Dissolved Oxygen

A minimum of 5.0 mg/L for DO is an existing effluent limit and will remain unchanged in the draft permit as recommended by DEP's SOP. This requirement has also been assigned to other sewage facilities in the region. 5.0 mg/L is taken directly from 25 Pa. Code § 93.7(a) and it is also determined to be appropriate according to water quality modeling.

Total Phosphorus & Total Nitrogen

DEP's SOP no. BPNPSM-PMT-033 recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, a routine monitoring for TKN, Nitrate-Nitrite, and TN are recommended to be continued in this permit as previously permitted.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Chesapeake Bay TMDL

The Department formulated a strategy in April 2007, to comply with the EPA's and Chesapeake Bay Foundation's requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011, Phase 2 in March 2012 and Phase 3 in December 2019. In accordance with the Phase 3 WIP, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 3 WIP categorizes this facility as a Phase 5, non-significant sewage facility. As such, the facility will be required to monitor and report TN and TP.

Monitoring Frequency and Sample Type

Unless discussed otherwise above, the permit's monitoring frequency and sample type for all parameters will remain unchanged from the last permit renewal.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-backsliding Requirement

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal. This approach is in accordance with 40 CFR §122.44(l)(1).

Annual Fees

An annual fee clause was added to the permit in accordance with 25 Pa. Code § 92a.62. The facility covered by the permit is classified in the Minor Sewage Facility < 0.05 fee category, which has an annual fee of \$500.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.06	XXX	0.20	1/day	Grab
CBOD5 Nov 1 - Apr 30	XXX	XXX	XXX	12.0	XXX	24.0	2/month	8-Hr Composite
CBOD5 May 1 - Oct 31	XXX	XXX	XXX	5.5	XXX	11.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	3.5	XXX	7.0	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	Report	XXX	XXX	1.5	XXX	3.0	2/month	8-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001


Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Total Nitrogen (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation


Compliance Sampling Location: Outfall 001



Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

StreamStats Report

Region ID: PA
 Workspace ID: PA20240110132540984000
 Clicked Point (Latitude, Longitude): 39.98399, -76.98627
 Time: 2024-01-10 08:26:02 -0500



[+ Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	2.9106	degrees
DRNAREA	Area that drains to a point on a stream	0.56	square miles
ROCKDEP	Depth to rock	4.9	feet
URBAN	Percentage of basin with urban development	0.1244	percent

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.56	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	2.9106	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.9	feet	4.13	5.21
URBAN	Percent Urban	0.1244	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0688	ft ³ /s
30 Day 2 Year Low Flow	0.0992	ft ³ /s
7 Day 10 Year Low Flow	0.0243	ft ³ /s
30 Day 10 Year Low Flow	0.0372	ft ³ /s
90 Day 10 Year Low Flow	0.0747	ft ³ /s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.
(<http://pubs.usgs.gov/sir/2006/5130/>)


USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

StreamStats Report

Region ID: PA
 Workspace ID: PA20240110132748717000
 Clicked Point (Latitude, Longitude): 39.98105, -76.97998
 Time: 2024-01-10 08:28:09 -0500



Collapse All

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	2.783	degrees
DRNAREA	Area that drains to a point on a stream	0.66	square miles
ROCKDEP	Depth to rock	4.9	feet
URBAN	Percentage of basin with urban development	0.1523	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.66	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	2.783	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.9	feet	4.13	5.21
URBAN	Percent Urban	0.1523	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0767	ft ³ /s
30 Day 2 Year Low Flow	0.112	ft ³ /s
7 Day 10 Year Low Flow	0.0269	ft ³ /s
30 Day 10 Year Low Flow	0.0415	ft ³ /s
90 Day 10 Year Low Flow	0.0848	ft ³ /s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.19.3

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07F		8600	Trib 08600 to Red Run				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.400	Country View Ma	PA0086894	0.013	CBOD5	25		
				NH3-N	4.54	9.08	
				Dissolved Oxygen			5

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
07F	8600	Trib 08600 to Red Run

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.400	Country View Ma	13.32	24.03	13.32	24.03	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.400	Country View Ma	1.68	4.54	1.68	4.54	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.40	Country View Ma	25	25	4.54	4.54	5	5	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07F	8600	Trib 08600 to Red Run		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.400	0.012	22.216	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
3.254	0.306	10.628	0.044	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
12.19	1.289	2.01	0.830	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.806	25.117	Owens	6	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.557	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.056	11.26	1.92	7.34
	0.111	10.40	1.83	7.53
	0.167	9.61	1.75	7.64
	0.223	8.87	1.67	7.73
	0.278	8.20	1.60	7.80
	0.334	7.57	1.52	7.87
	0.390	6.99	1.46	7.92
	0.445	6.46	1.39	7.92
	0.501	5.96	1.33	7.92
	0.557	5.51	1.27	7.92

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
07F		8600				Trib 08600 to Red Run						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
0.400	0.02	0.00	0.02	.0193	0.01009	.306	3.25	10.63	0.04	0.557	22.22	7.00
Q1-10 Flow												
0.400	0.02	0.00	0.02	.0193	0.01009	NA	NA	NA	0.04	0.631	22.77	7.00
Q30-10 Flow												
0.400	0.03	0.00	0.03	.0193	0.01009	NA	NA	NA	0.05	0.503	21.85	7.00

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07F	8600	Trib 08600 to Red Run	0.400	415.93	0.56	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.02	0.000	0.000	0.0	0.00	0.00	20.00	7.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Country View Ma	PA0086894	0.0125	0.0125	0.0125	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

TRC EVALUATION					
Input appropriate values in B4:B8 and E4:E7					
0.0243	= Q stream (cfs)	0.5	= CV Daily		
0.0125	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)		
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.420		1.3.2.iii	WLA_cfc = 0.402
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.156		5.1d	LTA_cfc = 0.234
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.193		AFC	
		INST_MAX_LIMIT (mg/l) = 0.630			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST_MAX_LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				