



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0087025

APS ID

20

Authorization ID

1494328

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Applicant and Facility Information

Applicant Name	<u>David M Ott</u>	Facility Name	<u>Dave & Janes Crab House Restaurant</u>
Applicant Address	<u>2989 Tract Road</u>	Facility Address	<u>2989 Tract Road</u>
	<u>Fairfield, PA 17320-9333</u>		<u>Fairfield, PA 17320-9333</u>
Applicant Contact	<u>Dave Ott</u>	Facility Contact	<u>Dave Ott</u>
Applicant Phone	<u>(717) 642-5025</u>	Facility Phone	<u>(717) 642-5025</u>
Client ID	<u>92214</u>	Site ID	<u>461077</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Liberty Township</u>
Connection Status		County	<u>Adams</u>
Date Application Received	<u>July 31, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 28, 2024</u>	If No, Reason	
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

Dave & Jane's Crab House Restaurant has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The permit was issued on January 28, 2020, and became effective on February 1, 2020.

The permit authorized discharge of treated sewage from the existing wastewater treatment plant (WWTP) located in Liberty Township, Adams County to Flat Run. The existing permit expiration date was January 31, 2025.

WQM No. 0195405 was issued on 2/26/1997.

Sludge use and disposal description and location(s): N/A

Changes from the previous permit: The E. Coli monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	January 17, 2025
X		<i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	January 27, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0034
Latitude	39° 43' 16.19"	Longitude	-77° 20' 27.99"
Quad Name	Emmitsburg	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Flat Run (WWF)	Stream Code	58724
NHD Com ID	53322090	RMI	3.67 miles
Drainage Area	7.13 mi. ²	Yield (cfs/mi ²)	0.04
Q ₇₋₁₀ Flow (cfs)	0.305	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	446	Slope (ft/ft)	
Watershed No.	13-D	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Not Assessed		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake		City of Frederick, MD	
PWS Waters	Monocacy River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	Approximate 31 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Unnamed Tributary to Flat Run at RMI 3.67 miles. A drainage area upstream of the discharge is estimated to be 7.13 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>. The Q₇₋₁₀ is 0.305 cfs, then the low flow yield is 0.04 cfs/mi.².

Flat Run

25 Pa. Code § 93.9z classifies Flat Run as warm water fishes (WWF) surface water.

Potable Water Supply Intake

The nearest downstream public water supply intake is the City of Frederick, MD intake on the Monocacy River, approximately 31 miles from the point of discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Dave & Janes Crabhouse				
WQM Permit No.	Issuance Date			
0195405	2/26/1967			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.0034
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0034		Not Overloaded	Anaerobic Digestion	Other WWTP

Changes Since Last Permit Issuance:

Other Comments:

The treatment process is as follows: Grease Trap (1) – Septic Tanks (2) - Aeration Tank (1) – Chlorine Contact Tank (1) – Final Effluent Tank (1) – Blower (1) – Discharge (Outfall 001)

Septic tanks and a grease trap are cleaned every 5 to 6 months.

Compliance History	
Summary of DMRs:	A summary of past 12-month DMRs is presented on the next page.
Summary of Inspections:	10/24/2023: Mr. Hoy, DEP WQS, conducted the compliance evaluation inspection. The recommendations were as follows: testing alarm monthly and recording the test in the daily logbook and recording the monthly settleability test in the daily logbook. Requests were as follows: completing and submitting the electronic daily effluent & sewage sludge supplemental reports to eDMR monthly as required by NPDES permit and keeping copies readily available to review for future inspections, storing the sample chain of custody records on-site, retaining sludge use and disposal records for a period of at least 5 years as required by NPDES permit, replacing the expired pH buffers as soon as possible, and the Total Phosphorous samples are collected as 8-hour composite samples in accordance with NPDES permit requirements. Four were violations such as: failure to use current pH buffers or reagent standards (25 Pa. Code 92a.41(a)(10)), failure to submit a required DMR supplemental report (25 Pa. Code 92a.41(a)(12)), failure to provide information or records required by the permit or otherwise needed to determine compliance (25 Pa. Code 92a.41(a)(8)), and failure to monitor pollutants as required by the NPDES permit (25 Pa. Code 92a.61(c)).
Other Comments:	There are currently three open violations associated with the permittee or the facility. 10/24/23: CSL201-Unauthorized, unpermitted discharge of sewage to waters of the commonwealth, 271.918-Biosolids-Permittee violated the record keeping requirements, and 92a.41(a)12B-NPDES-Failure to submit monitoring report(s) or properly complete monitoring reports.

Other Comments: 

Compliance History

DMR Data for Outfall 001 (from December 1, 2023 to November 30, 2024)

Parameter	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23
Flow (MGD) Average Monthly	0.00039 9	0.00042 1	0.00042 7	0.00041 4	0.00038 3	0.00034 7	0.00031 7	0.00030 3	0.00027 3	0.00027 4	0.00029 4	
Flow (MGD) Daily Maximum	0.00041 0	0.00043 0	0.00044 0	0.00042 0	0.00040 5	0.00036 5	0.00033 0	0.00031 5	0.00028 5	0.00029 0	0.00034 0	
pH (S.U.) Daily Minimum	7.4	7.6	7.7	7.9	8.1	8.1	8.1	8.0	7.2	7.3	7.4	
pH (S.U.) Instantaneous Maximum	8.0	7.9	8.2	8.5	8.7	8.6	8.5	8.5	8.0	8.0	7.9	
DO (mg/L) Daily Minimum	6.6	6.4	6.3	6.0	5.3	6.6	6.6	6.6	5.8	8.4	7.4	
TRC (mg/L) Average Monthly	0.38	0.28	0.31	0.38	0.33	0.41	0.42	0.37	0.35	0.36	0.41	
TRC (mg/L) Instantaneous Maximum	0.47	0.34	0.36	0.47	0.40	0.47	0.48	0.42	0.49	0.42	0.48	
CBOD5 (mg/L) Average Monthly	14.2	5.3	3.7	4.0	60.3	3.7	5.2	1.6	54.2	96.6	13.0	
CBOD5 (mg/L) Instantaneous Maximum	15.7	5.5	4.5	5.5	117.0	4.4	6.0	2.1	103.0	109.0	15.7	
TSS (mg/L) Average Monthly	9.5	11.0	18.0	19.5	24.5	18.5	11.5	5.5	11.0	31.0	10.0	
TSS (mg/L) Instantaneous Maximum	10.0	12.0	27.0	28.0	39.0	31.0	12.0	6.0	16.0	42.0	19.0	
Oil and Grease (mg/L) Average Monthly	1.0	1.0	1.0	1.0	6.3	1.0	1.0	1.0	6.0	5.2	1.0	
Oil and Grease (mg/L) Instantaneous Maximum	1.0	1.0	1.0	1.0	6.3	1.0	1.0	1.0	6.0	5.2	1.0	
Fecal Coliform (No./100 ml) Geometric Mean	1.0	3.3	29.9	49.2	49.3	36.1	12.4	49.8	69.6	69.6	69.6	
Fecal Coliform (No./100 ml) Instantaneous Maximum	1.0	11.0	687	2419.6	2419.6	1300	132.0	1990	4839.2	2419.6	2419.6	

NPDES Permit Fact Sheet
Dave & Janes Crab House Restaurant

NPDES Permit No. PA0087025

Total Nitrogen (mg/L) Annual Average												0.238
Total Phosphorus (mg/L) Annual Average												1.4

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.2	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Oil and Grease	XXX	XXX	XXX	15.0	XXX	30.0	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 43' 16.19"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.0034
Longitude -77° 20' 27.99"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: [REDACTED]

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃-N calculations were first based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

- Discharge pH = 7.0 (Default)
- Discharge Temperature = 25°C (Default)
- Stream pH = 7.0 (Default)
- Stream Temperature = 20°C (Default)
- Background NH₃-N = 0 (Default)

Analysis Results WQM 7.0

Hydrodynamics		NH ₃ -N Allocations		D.O. Allocations		D.O. Simulation		Effluent Limitations																	
RMI	Discharge Name	Permit Number Disc Flow (mgd)																							
3.67	Dave & Janes	PA0087025 0.0034																							
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Effluent Limit 30 Day Average (mg/L)</th> <th>Effluent Limit Maximum (mg/L)</th> <th>Effluent Limit Minimum (mg/L)</th> </tr> </thead> <tbody> <tr> <td>CBOD₅</td> <td>25</td> <td>25</td> <td></td> </tr> <tr> <td>NH₃-N</td> <td>25</td> <td>50</td> <td></td> </tr> <tr> <td>Dissolved Oxygen</td> <td></td> <td></td> <td>5</td> </tr> </tbody> </table>										Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)	CBOD ₅	25	25		NH ₃ -N	25	50		Dissolved Oxygen			5
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)																						
CBOD ₅	25	25																							
NH ₃ -N	25	50																							
Dissolved Oxygen			5																						
Record: 1 of 1 < Back Next > No Filter Search																									
Print								Archive Cancel																	

The attached computer printout of the WQM7.0 stream model shows that no NH₃-N requirements are needed to protect the aquatic life from NH₃-N toxicity.

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

Only the minimum treatment requirements of secondary treatment will be necessary to protect water quality. The existing limits of 25 mg/L average monthly and 50 mg/L instantaneous maximum will remain in the proposed permit. Past DMRs and inspection reports show that the facility has been consistently achieving concentrations under these limits.

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

Total Suspended Solids (TSS):

The existing limits of 30 mg/L average monthly and 60 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Past DMRs and inspection reports show that the facility has been consistently achieving concentrations under these limits.

pH:

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa. Code § 95.2(2).

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean (average monthly) and not greater than 1,000/100 ml (IMAX) and 25 Pa. Code § 92a.47(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean (average monthly) and not greater than 10,000/100 ml (IMAX), respectively.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Oil & Grease:

The oil & grease limits are required for restaurant waste per 25 Pa. Code § 95.2 (2)(ii). The average monthly limit of 15.0 mg/L and daily maximum limit of 30.0 mg/L in existing permit will remain in the proposed permit.

Toxic:

This is a minor sewage facility receiving domestic wastewater only and the current application does not require sampling of toxic pollutants (or heavy metals) for those facilities with design flows less than 0.1 MGD. Therefore, no reasonable potential analysis for toxic pollutants has been performed for this permit renewal.

Chesapeake Bay Strategy:

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase 4 (0.2 -0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase 5 (below 0.2 MGD) will monitor during current permit renewal once a year. However, any facility in Phases 4 and 5 that undergoes expansion is subjected to cap load right away. This plant is classified as a phase 5, will be required to monitor and report TN & TP once a year, and these monitoring requirements will remain in the proposed permit.

Total Residual Chlorine (TRC):

Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), indicated monthly average limit of 0.5 mg/L and an instantaneous maximum limit of 1.6 mg/L. However, the existing IMAX limit of 1.2 mg/L is more stringent than new IMAX limit recommended by the spreadsheet, the existing IMAX limit will remain in the proposed permit. The average monthly limit of 0.5 mg/L is in existing permit. Based on the DMRs from the past year, the facility has been consistently achieving these limits. Therefore, these limits will remain in the proposed permit.

TRC EVALUATION

Input appropriate values in A3:A9 and D3:D9

0.305	= Q stream (cfs)	0.5	= CV Daily
0.0034	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 18.517	1.3.2.iii	WLA_cfc = 18.045
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 6.900	5.1d	LTA_cfc = 10.490

Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635	

WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$
LTA_afc	wla_afc*LTAMULT_afc
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$
LTA_cfc	wla_cfc*LTAMULT_cfc
AML_MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$
AVG_MON_LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$
INST_MAX_LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$

Additional Consideration

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the proposed permit per 40 CFR § 122.44(i)(1)(ii).

Monitoring Frequency and Sample Type

The facility currently is required to collect daily effluent grab samples for D.O., TRC, and pH; bi-monthly effluent grab samples of CBOD₅, TSS, Fecal Coliform, and Oil & Grease; annually effluent 8-hr composite samples of TP; and annually effluent calculation samples of TN. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the renewal permit monitoring frequencies will remain the same as those specified in the existing permit.

Antidegradation (93.4)

The effluent limits and monitoring requirements have been established to ensure that the existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

The 2012 Pennsylvania Integrated Water Quality Monitoring and Assessment Report (formerly 303(d) list) groups Flat Run in List 2, *Attaining some designated uses and insufficient or no data available for remaining uses*. Flat Run is currently unassessed; therefore, the stream condition is unknown. A Total Maximum Daily Load (TMDL) has not been developed for this stream.

Anti-Backsliding

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as existing permit requirements in accordance with 40 CFR §122.44(l)(1).

WQM 7.0


*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	25°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	20°C	(Default)
*	Background NH ₃ -N	=	0	(Default)

Node 1: Point of First Use on Flat Run (58724)

Elevation: 446 ft (USGS National Map Viewer)
 Drainage Area: 7.13 mi.² (USGS PA StreamStats)
 River Mile Index: 3.67 miles (PA DEP eMapPA)
 Low Flow Yield: 0.04 cfs/mi.²
 Discharge Flow: 0.0034 MGD (NPDES PA0087025)

Node 2: Just before PA & MA Border on Flat Run


Elevation: 441 ft (USGS National Map Viewer)
 Drainage Area: 7.38 mi.² (USGS PA StreamStats)
 River Mile Index: 3.39 mile (PA DEP eMapPA)
 Low Flow Yield: 0.04 cfs/mi.²
 Discharge Flow: 0.00 MGD



NPDES Permit Fact Sheet

Dave & Janes Crab House Restaurant

NPDES Permit No. PA0087025



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	7.13	square miles
PRECIP	Mean Annual Precipitation	43	inches
ROCKDEP	Depth to rock	4.5	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.21	miles per square mile

Low-Flow Statistics


Low-Flow Statistics Parameters [Low Flow Region 2]


Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	7.13	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	43	inches	35	50.4
STRDEN	Stream Density	2.21	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.69	ft^3/s	38	38
30 Day 2 Year Low Flow	0.952	ft^3/s	33	33
7 Day 10 Year Low Flow	0.305	ft^3/s	51	51
30 Day 10 Year Low Flow	0.417	ft^3/s	46	46
90 Day 10 Year Low Flow	0.66	ft^3/s	36	36





Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	7.38	square miles
PRECIP	Mean Annual Precipitation	43	inches
ROCKDEP	Depth to rock	4.6	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.23	miles per square mile

Low-Flow Statistics


Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	7.38	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	43	inches	35	50.4
STRDEN	Stream Density	2.23	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.6	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.74	ft^3/s	38	38
30 Day 2 Year Low Flow	1.01	ft^3/s	33	33
7 Day 10 Year Low Flow	0.337	ft^3/s	51	51
30 Day 10 Year Low Flow	0.454	ft^3/s	46	46
90 Day 10 Year Low Flow	0.708	ft^3/s	36	36



10

NPDES Permit Fact Sheet
Dave & Janes Crab House Restaurant

NPDES Permit No. PA0087025

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
3.67	Dave & Janes	PA0087025	0.0034

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	25	50	
Dissolved Oxygen			5

Record: 1 of 1 < Back Next > No Filter Search

Print Archive Cancel

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.2	1/day	Grab
CBOD ₅	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Oil and Grease	XXX	XXX	XXX	15.0	XXX	30.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Compliance Sampling Location: 

Other Comments: 

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]