

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0087611
APS ID 3926
Authorization ID 1291956

Applicant and Facility Information

Applicant Name	<u>Richfield Area Joint Authority</u>	Facility Name	<u>Richfield STP</u>
Applicant Address	<u>186 Seven Stars Road</u> <u>Richfield, PA 17086-8824</u>	Facility Address	<u>186 Seven Stars Road</u> <u>Richfield, PA 17086-8824</u>
Applicant Contact	<u>Steve Sauers</u>	Facility Contact	<u>Todd Mace</u>
Applicant Phone	<u>(717) 694-0016</u>	Facility Phone	<u>(570) 898-1602</u>
Client ID	<u>68007</u>	Site ID	<u>462883</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Monroe Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Juniata</u>
Date Application Received	<u>October 11, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 21, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Renewal.</u>		

Summary of Review

The Richfield Area Joint Authority has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit for the Richfield STP. The permit was last reissued to the Richfield Area Joint Authority on March 26, 2015 and became effective on May 1, 2015. The permit expired on April 30, 2020 but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days. A file review of documents associated with the discharge or permittee may be available at the PA DEP southcentral regional office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file reviews, contact the SCRO file review coordinator at 717.705.4700.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures		Date
X		Aaron Baar / Permits Section	Aaron Baar	January 15, 2021
		Daniel W. Martin, P.E. / Environmental Engineer Manager		

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.085</u>
Latitude	<u>40° 41' 22.12"</u>	Longitude	<u>-77° 6' 11.11"</u>
Quad Name	<u>Richfield</u>	Quad Code	<u>1329</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>West Branch Mahantango Creek (TSF)</u>	Stream Code	<u>17427</u>
NHD Com ID	<u>54971257</u>	RMI	<u>16.1</u>
Drainage Area	<u>10.8</u>	Yield (cfs/mi ²)	<u>0.14167</u>
Q ₇₋₁₀ Flow (cfs)	<u>1.53</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>631.18</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>6-C</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u>Name</u>		
Nearest Downstream Public Water Supply Intake	<u>United Water Company</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>~43</u>

Drainage Area

The discharge is to West Branch Mahantango Creek at RMI 16.1. A drainage area upstream of the discharge point is determined to be 10.8 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, the West Branch Mahantango Creek watershed has a Q₇₋₁₀ of 1.53 cfs and a drainage area of 10.8 mi², which results in a LFY of 0.14167 cfs/mi².

West Branch Mahantango Creek

West Branch Mahantango Creek is classified as aTSF waterway. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Public Water Supply Intake

The nearest downstream public water supply intake is the United Water Company intake located on the Susquehanna River. Considering the distance and nature of the discharge, the discharge is not expected to significantly affect the water supply.

Class A Wild Trout Streams

The receiving stream is not a Class A Wild Trout stream.

Treatment Facility Summary				
Treatment Facility Name: Richfield Area Joint Authority - STP				
WQM Permit No.		Issuance Date		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Ultraviolet	0.085
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.085	170	Not Overloaded		

The Richfield Area Joint Authority owns and operates the Richfield sanitary wastewater treatment facility located in Monroe Township, Juniata County. The facility serves Monroe Township and portions of West Perry Township (Snyder County), all wastes are residential in nature, and all sewer systems are 100% separated. Having an annual average design flow of 0.085 MGD and a hydraulic design capacity of 0.085 MGD, this facility consists of two SBR tanks, a UV disinfection unit, one aerobic digester and the outfall (Outfall 001). No chemical amendments are identified as being used to supplement the treatment process. Sludge is disposed of at the Kelly Township Municipal Authority STP.

Compliance History	
Summary of DMRs:	A summary of past DMR data is presented on the next page.
Summary of Inspections:	<p>Since the last NPDES permit renewal, there are records in the Department's File Room that the facility has been inspected three times. The notes from the inspections are as follows:</p> <p>11/15/2016: Pat Bowen, DEP Water Quality Specialist, conducted a routine inspection. No violations were noted.</p> <p>03/28/2017: Pat Bowen, DEP Water Quality Specialist, conducted a routine inspection. Operational issues were identified, but no violations were noted.</p> <p>07/20/2018: Pat Bowen, DEP Water Quality Specialist, conducted a routine inspection. No violations were noted.</p>

Other Comments: A records review revealed that there are no Clean Water open violations associated with this permittee as of January 15, 2021.

Compliance History

DMR Data for Outfall 001 (from December 1, 2019 to November 30, 2020)

Parameter	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20	DEC-19
Flow (MGD) Average Monthly	0.052	0.061	0.055	0.054	0.044	0.032	0.041	0.047	0.048	0.045	0.042	0.046
Flow (MGD) Daily Maximum	0.09	0.115	0.077	0.118	0.068	0.048	0.193	0.26	0.153	0.137	0.078	0.162
pH (S.U.) Minimum	6.75	6.84	6.48	6.4	6.89	6.82	6.72	6.78	6.88	6.82	6.55	6.81
pH (S.U.) Maximum	7.15	7.14	7.12	7.16	7.25	7.17	7.13	7.08	7.34	7.19	7.11	7.43
DO (mg/L) Minimum	5.2	5.1	5.3	5.12	5.19	5.34	5.04	5.16	5.08	5.22	5.03	5.24
CBOD5 (lbs/day) Average Monthly	3	3	< 2	< 2	< 1	< 1	< 1	< 1	< 2	< 1	< 1	< 1
CBOD5 (lbs/day) Weekly Average	5	4	2	3	2	2	3	2	3	3	< 1	2
CBOD5 (mg/L) Average Monthly	6	6	< 3	< 4	< 4	< 4	< 4	< 3	< 4	< 4	< 3	< 3
CBOD5 (mg/L) Weekly Average	8	7	5	6	6	8	5	4	6	6	4	4
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	84	128	107	74	69	63	45	57	82	74	63	58
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	117	143	133	138	89	77	66	66	102	96	143	84
BOD5 (mg/L) Raw Sewage Influent Average Monthly	182	239	230	157	215	231	157	145	254	243	172	173
TSS (lbs/day) Average Monthly	2	4	< 2	< 0.9	< 0.8	< 0.5	< 0.9	< 1	< 0.8	0.9	< 0.8	< 1
TSS (lbs/day) Raw Sewage Influent Average Monthly	65	70	78	69	43	70	50	61	48	51	35	83

**NPDES Permit Fact Sheet
Richfield STP**

NPDES Permit No. PA0087611

TSS (lbs/day) Raw Sewage Influent Daily Maximum	85	107	129	112	58	105	82	93	86	63	57	145
TSS (lbs/day) Weekly Average	4	6	3	2	2	0.8	2	3	2	1	1	2
TSS (mg/L) Average Monthly	5	8	< 3	< 2	< 2	< 2	< 3	< 3	< 2	3	< 2	< 3
TSS (mg/L) Raw Sewage Influent Average Monthly	154	133	168	147	137	237	171	147	148	177	100	218
TSS (mg/L) Weekly Average	7	12	5	3	5	2	6	5	4	5	4	4
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 1	< 1	< 4	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 4	< 4	< 1	54.8	2	2	< 1	< 1	< 1	< 1	< 1	< 1
Nitrate-Nitrite (mg/L) Average Monthly	< 2.35	< 8.236	FF	7.969	< 1.698	< 2.868	< 12.941	< 7.537	< 1.8	< 2.19	4.73	8.606
Total Nitrogen (mg/L) Average Monthly	< 4.962	< 9.878	FF	< 8.629	< 2.198	< 3.368	17.48	< 8.037	< 4.193	< 2.742	< 5.23	< 9.356
Ammonia (lbs/day) Average Monthly	< 0.3	< 0.3	< 0.05	< 0.05	< 2.0	< 0.2	< 0.04	< 0.04	< 0.04	< 0.03	< 0.07	< 0.04
Ammonia (mg/L) Average Monthly	< 0.541	< 0.61	< 0.1	< 0.1	< 7.03	< 0.642	< 0.1	< 0.1	< 0.133	< 0.1	< 0.2	< 0.1
TKN (mg/L) Average Monthly	2.613	1.643	FF	< 0.66	< 0.5	< 0.5	< 0.5	< 0.5	2.393	< 0.553	< 0.5	< 0.8
Total Phosphorus (mg/L) Average Monthly	4.73	7.47	FF	4.24	3.083	3.36	2.28	3.38	2.62	3.19	3.02	5.7

Existing Permit Limits

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	18	23	XXX	25	40	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
BOD5 (lbs) Raw Sewage Influent	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Calculation
TSS Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	21	32	XXX	30	45	60	1/week	8-Hr Composite
Total Suspended Solids (lbs) Raw Sewage Influent	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Calculation
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Calculation
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	Report	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	5.3	XXX	XXX	7.5	Report Daily Max	15	1/week	8-Hr Composite
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001

Development of Effluent Limitations

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.085</u>
Latitude	<u>40° 41' 22.49"</u>	Longitude	<u>-77° 6' 11.02"</u>
Wastewater Description: <u>Sewage Effluent</u>			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

Water Quality-Based Limitations

CBOD₅, NH₃-N and Dissolved Oxygen (DO)

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD₅, NH₃-N and DO. DEP's guidance 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges.

The model was utilized, and the model output indicated that existing limits for ammonia are lower than those specified in the model. Due to anti-backsliding provisions, however, the existing limits are deemed to be still appropriate. The existing D.O. limit of 5 mg/L is also considered still appropriate.

The monitoring frequency and sample type for CBOD₅, DO and ammonia are proposed to remain unchanged.

Toxics

There are no industrial contributions to this facility. DEP's NPDES permit application for minor sewages (less than 1.0 MGD) does not require sampling for heavy metals including Total Copper, Total Lead, and Total Zinc.

Best Professional Judgment (BPJ) Limitations

Total Phosphorus & Total Nitrogen

DEP's SOP no. BPNPSM-PMT-033 recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. The monitoring of NO_x and TKN have been added to this permit to facilitate the collection of TN data. Also, the reporting frequency of TN is proposed to be increased in this permit to once every six months (from 1/year) in conformity with other Chesapeake Bay Phase 5 permits issued in the region.

Ultraviolet Disinfection

Based on inspection reports, it appears that the existing UV system is equipped with an intensity sensor; therefore, UV intensity is proposed to be added to the permit as the monitoring parameter for UV system.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Chesapeake Bay TMDL

The Department formulated a strategy in April 2007, to comply with the EPA's and Chesapeake Bay Foundation's requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011 and Phase 2 in March 2012. In accordance with the Phase 3 WIP and its supplement, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 3 WIP categorizes this facility as a phase 5 non-significant sewage facility that has a design flow less than 0.2 MGD but greater than 0.002 MGD. The WIP recommends monitoring and reporting for Total Nitrogen and Total Phosphorus throughout the permit term at a frequency no less than annual. The monitoring of NOx, TKN and TN twice monthly will be continued from the previous renewal.

Monitoring Frequency and Sample Type

The facility currently is required to collect 2/month grab effluent samples for CBOD5, TSS, fecal, and TP. This monitoring frequency is consistent with Table 6-3 of DEP's technical guidance no. 362-0400-001 and will remain unchanged in this permit.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-backsliding Requirement

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal. This approach is in accordance with 40 CFR §122.44(l)(1).

Mass Loading Limitations

All effluent mass loading limits are based on the formula: design flow x concentration limit x conversion factor of 8.34.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	18	23	XXX	25	40	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
BOD5 (lbs) Raw Sewage Influent	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Calculation
TSS Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	21	32	XXX	30	45	60	1/week	8-Hr Composite
Total Suspended Solids (lbs) Raw Sewage Influent	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Calculation
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Calculation

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report	Report Daily Max	XXX	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	7.5	Report Daily Max	15	1/week	8-Hr Composite
Ammonia (lbs) Nov 1 - Apr 30	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Calculation
Ammonia (lbs) May 1 - Oct 31	5.3	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Calculation
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001



Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

PA0087611

Region ID: PA
 Workspace ID: PA20210114125722620000
 Clicked Point (Latitude, Longitude): 40.68937, -77.10272
 Time: 2021-01-14 07:57:40 -0500



Outfall 001


Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	10.8	square miles
PRECIP	Mean Annual Precipitation	45	inches
STRDEN	Stream Density – total length of streams divided by drainage area	1.96	miles per square mile
ROCKDEP	Depth to rock	5	feet
CARBON	Percentage of area of carbonate rock	33.17	percent

Low-Flow Statistics Parameters _[Low Flow Region 2]					
Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	10.8	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	45	inches	35	50.4
STRDEN	Stream Density	1.96	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	5	feet	3.32	5.65
CARBON	Percent Carbonate	33.17	percent	0	99

Low-Flow Statistics Flow Report _[Low Flow Region 2]				
PI: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other – see report)				
Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	2.65	ft ³ /s	38	38
30 Day 2 Year Low Flow	3.19	ft ³ /s	33	33
7 Day 10 Year Low Flow	1.53	ft ³ /s	51	51
30 Day 10 Year Low Flow	1.8	ft ³ /s	46	46
90 Day 10 Year Low Flow	2.23	ft ³ /s	36	36

PA0087611

Region ID: PA
 Workspace ID: PA20210114130258944000
 Clicked Point (Latitude, Longitude): 40.67779, -77.03714
 Time: 2021-01-14 08:03:17 -0500



Downstream reach:

Basin Characteristics				
Parameter Code	Parameter Description	Value	Unit	
DRNAREA	Area that drains to a point on a stream	19.6	square miles	
PRECIP	Mean Annual Precipitation	44	inches	
STRDEN	Stream Density – total length of streams divided by drainage area	1.88	miles per square mile	
ROCKDEP	Depth to rock	4.6	feet	
CARBON	Percentage of area of carbonate rock	21.26	percent	

Low-Flow Statistics Parameters <small>(Low Flow Region 2)</small>					
Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	19.6	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	44	inches	35	50.4
STRDEN	Stream Density	1.88	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.6	feet	3.32	5.65
CARBON	Percent Carbonate	21.26	percent	0	99

Low-Flow Statistics Flow Report <small>(Low Flow Region 2)</small>					
PI: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other – see report)					
Statistic	Value	Unit	SE	SEp	
7 Day 2 Year Low Flow	3.65	ft ³ /s	38	38	
30 Day 2 Year Low Flow	4.62	ft ³ /s	33	33	
7 Day 10 Year Low Flow	1.91	ft ³ /s	51	51	
30 Day 10 Year Low Flow	2.4	ft ³ /s	46	46	
90 Day 10 Year Low Flow	3.28	ft ³ /s	36	36	

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
06C		17427		WEST BRANCH MAHANTANGO CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
16.100	Richfield STP	PA0087611	0.085	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
06C	17427	WEST BRANCH MAHANTANGO CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
16.100	Richfield STP	9.27	50	9.27	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
16.100	Richfield STP	1.88	25	1.88	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
16.10	Richfield STP	25	25	25	25	5	5	0	0

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
06C	17427	WEST BRANCH MAHANTANGO CREEK		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
16.100	0.085	20.396	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
18.740	0.557	33.624	0.159	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
3.82	0.345	1.98	0.722	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.986	4.769	Tsivoglou	6	
<u>Reach Travel Time (days)</u>	Subreach Results			
1.844	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.184	3.58	1.73	7.65
	0.369	3.36	1.52	7.62
	0.553	3.15	1.33	7.70
	0.738	2.95	1.16	7.82
	0.922	2.76	1.02	7.95
	1.106	2.59	0.89	8.06
	1.291	2.43	0.78	8.17
	1.475	2.28	0.68	8.18
	1.660	2.13	0.60	8.18
	1.844	2.00	0.52	8.18

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
06C		17427		WEST BRANCH MAHANTANGO CREEK								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
16.100	1.53	0.00	1.53	.1315	0.00313	.557	18.74	33.62	0.16	1.844	20.40	7.00
Q1-10 Flow												
16.100	0.98	0.00	0.98	.1315	0.00313	NA	NA	NA	0.13	2.310	20.59	7.00
Q30-10 Flow												
16.100	2.08	0.00	2.08	.1315	0.00313	NA	NA	NA	0.19	1.571	20.30	7.00

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
06C	17427	WEST BRANCH MAHANTANGO CR	16.100	631.18	10.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.142	0.00	1.53	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Richfield STP	PA0087611	0.0850	0.0850	0.0850	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70