

Application Type

**Renewal**

Facility Type

**Non-Municipal**

Major / Minor

**Minor**

Application No.

**PA0087696**

APS ID

**633865**

Authorization ID

**1449554**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<b>GSP Management Company</b>	Facility Name	<b>Shadyback Acres MHP</b>
Applicant Address	PO Box 677	Facility Address	401 Glenn Avenue
	Morgantown, PA 19543-0677		Harrisburg, PA 17112-9366
Applicant Contact	James Perano	Facility Contact	Matthew Crump
Applicant Phone	(610) 286-0490	Facility Phone	(610) 823-7376
Client ID	33789	Site ID	1169
Ch 94 Load Status	Not Overloaded	Municipality	East Hanover Township
Connection Status		County	Dauphin
Date Application Received	August 3, 2023	EPA Waived?	Yes
Date Application Accepted	August 16, 2023	If No, Reason	
Purpose of Application	NPDES permit renewal		

**Summary of Review**

**1.0 General Discussion**

This fact sheet supports the renewal of an existing NPDES permit for discharge of treated domestic wastewater from Shadyback Acres Mobile Home Park wastewater treatment plant located in East Hanover Township, Dauphin County. The facility is owned and operated by GSP Management Company. The facility is a Cromaglass batch treatment system with an annual average design capacity of 0.00275MGD and receives flow from a mobile home park. The discharge goes to unnamed tributary of Manada Creek classified for warm water fishes (WWF). The existing NPDES permit was issued on December 21, 2018 with an effective date of January 1, 2019 and expiration date of December 31, 2023. The applicant submitted a complete NPDES renewal application to the Department and is currently operating under the terms and conditions in the existing permit pending Department action on the renewal application. A topographic map showing the discharge location is presented in attachment A.

**1.1 Sludge use and disposal description and location(s):**

Sludge is hold up in a tank and hauled out by a licensed hauler periodically

Approve	Deny	Signatures	Date
X		<i>J. Pascal Kwedza</i> J. Pascal Kwedza, P.E. / Environmental Engineer	July 26, 2024
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	August 27, 2024
X		Maria D. Bebenek Maria D. Bebenek, P.E. / Program Manager	August 27, 2024

### Summary of Review

#### **1.2 Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

#### **1.3 Changes to the existing Permit**

Annual E. Coli monitoring has been added.

**1.4 Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.00275
Latitude	40° 21' 19.48"	Longitude	-76° 42' 14.64"
Quad Name	Hershey	Quad Code	1632
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Manada Creek (WWF)	Stream Code	09587
NHD Com ID	56398747	RMI	0.05
Drainage Area	0.14	Yield (cfs/mi <sup>2</sup> )	0.106
Q <sub>7-10</sub> Flow (cfs)	0.014	Q <sub>7-10</sub> Basis	USGS Gage Station
Elevation (ft)	420	Slope (ft/ft)	
Watershed No.	7-D	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Pathogens		
Source(s) of Impairment	Source Unknown		
TMDL Status		Name _____	
Background/Ambient Data		Data Source	
pH (SU)	_____	_____	
Temperature (°F)	_____	_____	
Hardness (mg/L)	_____	_____	
Other:	_____	_____	
Nearest Downstream Public Water Supply Intake	PA American Water Company		
PWS Waters	Manada Creek	Flow at Intake (cfs)	_____
PWS RMI	_____	Distance from Outfall (mi)	>8

Changes Since Last Permit Issuance: None

**1.4.1 Water Supply Intake**

The closest water supply intake located downstream from the discharge is the Pa American Water Co. on Manada Creek in South Hanover Twp. The distance downstream from the discharge to the intake is approximately 8 miles. There is no impact on the water intake.

## **2.0 Treatment Facility Summary**

**Treatment Facility Name:** Shadyback Acres MHP

WQM Permit No.	Issuance Date
2297403 10-1	9/11/2001

Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Hypochlorite	0.00275

Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.00275		Not Overloaded	Concentration	Other WWTP

Changes Since Last Permit Issuance: None

## **2.1 Treatment Facility**

The treatment plant consists of influent pump station, Chromaglass batch treatment units, liquid chlorination, chlorine contact tank, two intermittent sand filters, post aeration, sludge holding tank and de-chlorination.

3.0 Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.49	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	Calculation
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	7.5	XXX	15	2/month	8-Hr Composite
TKN	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	8-Hr Composite

**3.1 Compliance History**

**3.1.1 DMR Data for Outfall 001 (from June 1, 2023 to May 31, 2024)**

Parameter	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23
Flow (MGD) Average Monthly	0.0022	0.0019	0.0014	0.0014	0.0023	0.0015	0.0012	0.0018	0.0016	0.0021	0.0018	0.0011
Flow (MGD) Daily Maximum	0.0038	0.0032	0.0029	0.0026	0.0045	0.0023	0.0025	0.0045	0.0033	0.0045	0.0027	0.0018
pH (S.U.) Daily Minimum	7.5	7.6	7.7	7.6	7.6	7.7	7.4	7.2	7.6	7.8	7.6	7.7
pH (S.U.) Daily Maximum	8.3	8.5	8.5	8.4	8.9	8.7	8.5	8.1	8.2	8.4	8.4	8.4
DO (mg/L) Daily Minimum	5.4	5.41	5.23	5.86	3.47	6.88	6.35	5.13	5.68	5.52	5.62	5.14
TRC (mg/L) Average Monthly	< 0.01	< 0.02	< 0.02	< 0.01	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
TRC (mg/L) Instantaneous Maximum	0.07	0.23	0.04	0.05	0.04	0.04	0.08	0.07	0.08	0.08	0.07	0.05
CBOD5 (mg/L) Average Monthly	3.2	< 2.4	3.1	< 2.3	7	< 10.7	4.8	< 2	< 2	< 7.3	< 7.9	< 2
TSS (mg/L) Average Monthly	5.6	< 4	< 5	< 5	10.1	< 4.2	< 4	< 4	< 4	< 4	< 4	< 4
Fecal Coliform (No./100 ml) Geometric Mean	12	< 2	< 1	< 1	< 2	< 12	< 1	< 1	< 1	< 4	< 5	< 1
Fecal Coliform (No./100 ml) Instant Maximum	20	3	< 1	< 1	6	144	< 1	< 1	< 1	14	25	2
Nitrate-Nitrite (mg/L) Daily Maximum						20.8						11.4
Total Nitrogen (mg/L) Daily Maximum						34.8						< 12.1
Ammonia (mg/L) Average Monthly	< 0.43	< 1.86	< 0.78	< 0.56	5.78	9.4	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
TKN (mg/L) Daily Maximum						14						< 0.7
Total Phosphorus (mg/L) Daily Maximum						6.2						5.21

**3.1.2 Effluent Violations for Outfall 001, from: July 1, 2023 To: May 31, 2024**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
DO	01/31/24	Daily Min	3.47	mg/L	5.0	mg/L

**3.1.3 Summary of DMRs:**

Discharge Monitoring Reports (DMRs) review for the facility for the last 12 months of operation presented on the table above in section 3.1.1 indicate permit limits have been most of the time. One permit limit violation for DO was noted on DMRs during the period reviewed presented in section 3.1.2. The violation appears to be a one-time occurrence.

**3.1.4 Summary of Inspections:**

The facility was inspected a couple of times during the past permit cycle. Inspection reports review for the facility during the period indicate permit limits have been met most of the time. Operation and maintenance issues with sand filter were noted during inspections. Sand filter was covered in a layer of foam and solids, which affected proper functioning of the filters. Notices of violations were sent to the permittee due to solids accumulation on sand filters. Solids accumulation on the sand filters has been going on for some time now. It was recommended that sludge should regularly be wasted from the treatment system to maintain an appropriate balance of solids to optimize the treatment process. The permittee has been routinely cleaning and removing solids from the top of the sand filters to ensure proper functioning of the sand filters.

#### 4.0 Development of Effluent Limitations

Outfall No. 001  
Latitude 40° 21' 19.49"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .00275  
Longitude -76° 42' 14.76"

#### 4.1 Basis for Effluent Limitations

In general, the Clean Water Act (CWA) requires that the effluent limits for a particular pollutant be the more stringent of either technology-based limits or water quality-based limits. Technology-based limits are set according to the level of treatment that is achievable using available technology. A water quality-based effluent limit (WQBEL) is designed to ensure that the water quality standards applicable to a waterbody are being met and may be more stringent than technology-based effluent limits.

#### 4.2 Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Weekly averages are not applicable to this discharge

#### 4.3 Water Quality-Based Limitations

##### 4.3.1 WQM 7.0 Stream Model

WQM 7.0 is a water quality model DEP utilizes to establish appropriate effluent limits for CBOD<sub>5</sub>, NH<sub>3</sub>-N and DO in permits. The model simulates mixing and degradation of NH<sub>3</sub>-N in the stream and compares calculated instream NH<sub>3</sub>-N concentrations to NH<sub>3</sub>-N water quality criteria and also simulates mixing and consumption of D.O. in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>N and compares calculated instream D.O. concentrations to D.O. water quality criteria and recommends effluent limits.

##### 4.3.2 Receiving Stream

The receiving stream is an UNT to Manada Creek. According to 25 PA § 93.9, the UNT to Manada Creek is protected for Warm Water Fishes (WWF). The UNT to Manada Creek is located in Drainage List N and State Watershed 7-D and has been assigned a stream code of 09587. According to the Department's *Integrated Water Quality Monitoring and Assessment Report*, the segment of the UNT to Manada Creek receiving the discharge is impaired not supporting recreational use due to pathogens.

#### **4.3.3 Streamflows**

Streamflows for the water quality analysis were taken from the nearby USGS gauging station No 01573500 on Manada Creek. The drainage area of the gage is 14.2sq.mi. The yield at the gage are :

- $Q_{7-10} = (1.51)/(14.2) = 0.106 \text{ cfs/sq.mi.}$
- $Q_{30-10} / Q_{7-10} = 1.23$
- $Q_{1-10} / Q_{7-10} = 0.89$

The drainage area at discharge point taken from previous protection report is 0.14sq.mi. The design streamflow ( $Q_{7-10}$ ) is calculated as:

$$Q_{7-10} = (0.106)(0.14) = 0.014 \text{ cfs}$$

#### **4.3.4 NH}\_3N calculations:**

$\text{NH}_3\text{N}$  calculations will be based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the instream  $\text{NH}_3\text{N}$  criteria used in the of the WQM 7.0 stream model:

- STP pH = 7.6 (DMR Median July to Sept.)
- STP Temperature = 25 °C (default)
- Stream pH = 7.0 (default)
- Stream Temperature = 20 °C (WWF)
- Background  $\text{NH}_3\text{-N}$  = 0.0 (default)

#### **4.3.5 CBOD}\_5**

The results of the WQM 7.0 stream model presented in attachment B indicates an average monthly limit (AML) of 25mg/L  $\text{CBOD}_5$  is required to protect the water quality of the stream. This limit is consistent with the existing permit and past DMRs and inspection reports show that the facility has been consistently complying the limitation. Therefore, a limit of 25mg/L AML and 50 mg/L IMAX is recommended again for this permit cycle.

#### **4.3.6 NH}\_3\text{N}**

The results of the WQM 7.0 stream model (attachment B) also indicates that a summer limitation of 8.6 mg/l  $\text{NH}_3$  as a monthly average is necessary to protect the aquatic life from toxicity effects. But due to anti-backsliding restrictions, the existing 7.5 mg/l monthly summer limit will be retained with the existing monitoring requirement for winter months

#### **4.3.7 Dissolved Oxygen**

The existing permit contains a limit of 5 mg/l for Dissolved Oxygen (DO). DEP's Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001, 10/97) suggests that either the adopted minimum stream D.O. criteria for the receiving stream or the effluent level determined through water quality modeling be used for the limit. Since the WQM 7.0 model was run using a minimum D.O. of 5.0 mg/l, this limit will be continued in the renewed permit with a daily monitoring requirement.

#### **4.3.8 Total Suspended Solids (TSS):**

There is no water quality criterion for TSS. The existing limit of 30 mg/l AML based on the minimum level of effluent quality attainable by secondary treatment as defined in 40 CFR 133.102b(1) and 25 PA § 92a.47(a)(1) will remain the permit for the next permit cycle.

#### **4.3.9 Total Residual Chlorine:**

TRC analysis was based on the equations and calculations presented in the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID No. 391-2000-015) for developing chlorine limitations. The Guidance references Chapter 92a, Section 92a.48 (b) which establishes a standard BAT limit of 0.5 mg/L unless a facility-specific BAT has been developed. The attached results presented in attachment C indicates a water quality limit of 0.49 mg/L AML and IMAX of 1.6 mg/L would be needed to prevent toxicity concerns. This recommendation is consistent with the existing permit and will remain in the permit for the current permit cycle. DMRs and inspection reports indicate the facility has been complying with the limitation.

#### **4.3.10 Toxics**

A reasonable potential (RP) analysis was done for pollutants in the discharge. The discharge consists entirely of domestic wastewater with no pollutants of concern that needs further analysis.

#### **4.3.11 Chesapeake Bay Strategy:**

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized based on their delivered TN and TP loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets if approved by DEP. Phase 4 (0.2 -0.4mgd) and Phase 5(below 0.2mdg) will be required to monitor and report TN and TP during permit renewal. Any facility in Phases 4 and 5 that undergoes expansion is subjected to cap load right away. This facility is, classified as a phase 5, and has been monitoring Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, Total Nitrogen and Total Phosphorus semi-annually and will continue during the current permit cycle.

#### **4.3.12 Fecal Coliform and E. Coli**

The existing Fecal Coliform limit is consistent with the technology limits recommended in 92a.47(a)(4) and (a)(5) and will remain in the permit. In March of 2021, EPA approved DEP's Triennial Review of Water Quality Standards, which included a new swimming season criterion for E. coli. As a result, DEP is including monitoring requirements for E. Coli in new and renewed sewage permits above 2000gpd. Monitoring frequency is based on annual average flow as follows: 1/month for design flows  $\geq$  1 MGD, 1/quarter for design flows  $\geq$  0.05 and  $<$  1 MGD and 1/year for design flows of 0.002 – 0.05 MGD. Your discharge of 0.00275 MGD requires 1/year monitoring as included in the permit

### **5.0 Other Considerations and Requirements**

#### **5.1 Anti-backsliding**

Not applicable to this permit

#### **5.2 Stormwater:**

No storm water outfall is associated with this facility

### **5.3 Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

### **5.4 Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

### **5.5 303d Listed Streams:**

The discharge is located on a 303d listed segment. The UNT to Manada Creek is not supporting recreational use due to pathogens. This is a category 5 impairment which does not warrant any action at this time.

### **5.6 Special Permit Conditions**

The permit will contain the following special conditions:

Stormwater Prohibition, Approval Contingencies, Management of collected screenings, slurries, sludges and other solids, Requirement to connect if a public sewer becomes available in the area, Chlorine minimization and Solids Management.

### **5.7 Basis for Effluent and Surface Water Monitoring**

Section 308 of the CWA and federal regulation 40 CFR 122.44(i) require monitoring in permits to determine compliance with effluent limitations. Monitoring may also be required to gather effluent and surface water data to determine if additional effluent limitations are required and/or to monitor effluent impacts on receiving water quality. The permittee is responsible for conducting the monitoring and for reporting results on Discharge Monitoring Reports (DMRs).

### **5.8 Effluent Monitoring frequency**

Monitoring frequencies are based on the nature and effect of the pollutant, as well as a determination of the minimum sampling necessary to adequately monitor the facility's performance. Permittees have the option of taking more frequent samples than are required under the permit. These samples can be used for averaging if they are conducted using EPA-approved test methods (generally found in 40 CFR 136) and if the Method Detection limits are less than the effluent limits. The sampling location must be after the last treatment unit and prior to discharge to the receiving water. If no discharge occurs during the reporting period, "no discharge" shall be reported on the DMR.

**6.0 Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.49	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Nitrate-Nitrite	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	Calculation
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	7.5	XXX	15	2/month	8-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
TKN	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	8-Hr Composite

Compliance Sampling Location: At Outfall 001

7.0 Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing effluent limitation for individual sewage permit
<input type="checkbox"/>	Other: [REDACTED]

**8. Attachments**

**A. Topographical Map**



**B. WQM MODEL Results**

**WQM 7.0 Effluent Limits**

SWP Basin	Stream Code	Stream Name					
		07D	9587	Trib 09587 to Manada Creek			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.050	Shadyback Acres	PA0087696	0.003	CBOD5	25		
				NH3-N	8.69	17.38	
				Dissolved Oxygen			5

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07D	9587	Trib 09587 to Manada Creek	0.050	420.00	0.14	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH	Temp (°C)	Stream pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Shadyback Acres	PA0087696	0.0027	0.0027	0.0027	0.000	25.00	7.60
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		5.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07D	9587	Trib 09587 to Manada Creek	0.001	412.00	0.18	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
07D			9587			Trib 09587 to Manada Creek						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.050	0.01	0.00	0.01	.0043	0.03092	.277	1.65	5.96	0.04	0.075	21.17	7.08
<b>Q1-10 Flow</b>												
0.050	0.01	0.00	0.01	.0043	0.03092	NA	NA	NA	0.04	0.079	21.27	7.09
<b>Q30-10 Flow</b>												
0.050	0.02	0.00	0.02	.0043	0.03092	NA	NA	NA	0.04	0.068	20.99	7.07

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.89	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.23	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>															
07D	9587	Trib 09587 to Manada Creek																
<b>NH3-N Acute Allocations</b>																		
<b>NH3-N Chronic Allocations</b>																		
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction											
0.050	Shadyback Acres	13.84	50	13.84	50	0	0											
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction											
0.050	Shadyback Acres	1.72	8.69	1.72	8.69	0	0											
<b>Dissolved Oxygen Allocations</b>																		
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>												
0.05	Shadyback Acres	25	26	8.69	8.69	5	5											

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07D	9587	Trib 09587 to Manada Creek		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.050	0.003	21.165	7.083	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
1.649	0.277	5.960	0.040	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
7.36	1.172	2.02	0.766	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.487	27.826	Owens	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.075	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.007	7.29	2.01	7.63
	0.015	7.23	2.00	7.74
	0.022	7.16	1.99	7.83
	0.030	7.09	1.98	7.91
	0.037	7.03	1.97	7.97
	0.045	6.96	1.96	8.02
	0.052	6.90	1.94	8.07
	0.060	6.84	1.93	8.07
	0.067	6.77	1.92	8.07
	0.075	6.71	1.91	8.07

C. TRC Calculations Results

TRC EVALUATION									
Input appropriate values in A3:A9 and D3:D9									
0.014	= Q stream (cfs)	0.5	= CV Daily						
0.00275	= Q discharge (MGD)	0.5	= CV Hourly						
30	= no. samples	1	= AFC_Partial Mix Factor						
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor						
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)						
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)						
0	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)						
Source	Reference	AFC Calculations			Reference	CFC Calculations			
TRC	1.3.2.iii	WLA_afc = 1.069			1.3.2.iii	WLA_cfc = 1.034			
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373			5.1c	LTAMULT_cfc = 0.581			
PENTOXSD TRG	5.1b	LTA_afc = 0.398			5.1d	LTA_cfc = 0.601			
Effluent Limit Calculations									
PENTOXSD TRG	5.1f	AML MULT = 1.231							
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.490			AFC				
		INST MAX LIMIT (mg/l) = 1.603							
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ ... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$							
LTAMULT_afc		$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$							
LTA_afc		wla_afc*LTAMULT_afc							
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ ... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$							
LTAMULT_cfc		$\text{EXP}((0.5*\text{LN}(cvd^2/no\_samples+1))-2.326*\text{LN}(cvd^2/no\_samples+1)^0.5)$							
LTA_cfc		wla_cfc*LTAMULT_cfc							
AML MULT		$\text{EXP}(2.326*\text{LN}((cvd^2/no\_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no\_samples+1))$							
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)							
INST MAX LIMIT		$1.5*((av\_mon\_limit/AML\_MULT)/LTAMULT\_afc)$							