

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0087700
APS ID 39654
Authorization ID 1177443

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|--|
| Applicant Name | <u>South Londonderry Township Municipal Authority</u> | Facility Name | <u>South Londonderry Campbelltown East STP</u> |
| Applicant Address | <u>27 W Market Street Palmyra, PA 17078-8736</u> | Facility Address | <u>27 W Market Street Palmyra, PA 17078</u> |
| Applicant Contact | <u>Scott Galbraith</u> | Facility Contact | <u>Scott Galbraith</u> |
| Applicant Phone | <u>(717) 838-5556</u> | Facility Phone | <u>(717) 838-5556</u> |
| Client ID | <u>43038</u> | Site ID | <u>250908</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>South Londonderry Township</u> |
| Connection Status | | County | <u>Lebanon</u> |
| Date Application Received | <u>March 28, 2017</u> | EPA Waived? | <u>No</u> |
| Date Application Accepted | <u>April 14, 2017</u> | If No, Reason | <u>Discharge to TMDL Waters</u> |
| Purpose of Application | <u>NPDES permit renewal to discharge treated sewage</u> | | |

Summary of Review

1.0 General Discussion

This fact sheet supports the re-issuance of an existing NPDES permit for discharge of treated domestic wastewater from Campbelltown East wastewater treatment plant located in South Londonderry Township, Lebanon County. South Londonderry Township Municipal Authority owns and operates the wastewater treatment plant, which provides sanitary services to South Londonderry Township. The sewer collection system is not combined and there is no bypasses or overflows approved in the collection system. The treatment plant has a hydraulic design capacity of 0.21 MGD and an organic design capacity of 350 lbs/day- BOD5. The permittee listed 490 lbs/day- BOD5 as organic capacity of in their Chapter 94 report which the Department disagreed with and that created organic overload condition at the facility. The permittee is under a corrective action plan to increase the organic capacity to address the organic overload at the facility. The discharge goes to Killinger Creek classified for Trout Stocking (TSF). The existing NPDES permit was issued on July 31, 2012 with an effective date of August 1, 2012 and expiration date of July 31, 2017. The permit was amended on September 23, 2015 to revise copper limitation as a results of water effect ratio (WER) study that established a site-specific criterion for copper for the site. The applicant submitted an administratively complete NPDES renewal application to the Department on March 28, 2017 and is currently operating under the terms and conditions in the existing permit under administrative extension provisions pending Department action on the renewal application.

A topographic map showing the discharge location is presented in attachment A.

| Approve | Deny | Signatures | Date |
|---------|------|---|----------------|
| X | | J. Pascal Kwedza / Environmental Engineer, P.E. | April 10, 2019 |
| X | | Daniel W. Martin, P.E. / Environmental Engineer Manager | July 1, 2019 |
| X | | Maria D. Bebenek, P.E. / Program Manager | July 1, 2019 |

Summary of Review

1.1 Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

1.2 Changes to the existing Permit

- Monthly monitoring of Total Copper has been added

1.3 Existing Permit Limits and Monitoring Requirements

| DISCHARGE LIMITATIONS | | | | | | | | MONITORING REQUIREMENTS | |
|----------------------------------|--------------------|------------------|------------------|----------------------------------|----------------|---------------|---------------|-------------------------|--------------|
| Discharge Parameter | Mass Units lbs/day | | | Concentrations mg/l | | | | Monitoring Frequency | Sample Type |
| | Average Monthly | Average Weekly | Maximum Daily | Average Monthly | Average Weekly | Maximum Daily | Inst. Maximum | | |
| Flow (mgd) | Monitor & Report | XXX | Monitor & Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | XXX | From 6.0 to 9.0 inclusive | | | | 1/day | Grab |
| D.O. | XXX | XXX | XXX | Minimum of 5.0 mg/l at all times | | | | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.12 | XXX | XXX | 0.40 | 1/day | Grab |
| TSS | 52 | 78 | XXX | 30 | 45 | XXX | 60 | 1/week | 24-hour comp |
| CBOD ₅ | 43 | 70 | XXX | 25 | 40 | XXX | 50 | 1/week | 24-hour comp |
| NH ₃ N (5/1 to 10/31) | 4.3 | XXX | XXX | 2.5 | XXX | XXX | 5.0 | 1/week | 24-hr comp |
| NH ₃ N (11/1 to 4/30) | 13.1 | XXX | XXX | 7.5 | XXX | XXX | 15 | 1/week | 24-hr comp |
| Fecal Col. (5/1 to 9/30) | XXX | XXX | XXX | 200 | XXX | XXX | XXX | 1/week | Grab |
| Fecal Col. (10/1 to 4/30) | XXX | XXX | XXX | 2,000 | XXX | XXX | XXX | 1/week | Grab |
| Total Phosphorus | 3.5 | XXX | XXX | 2.0 | XXX | XXX | 4.0 | 1/week | 24-hour comp |
| Nitrate-Nitrite | XXX | XXX | XXX | Report | XXX | XXX | XXX | 1/month | 24-hour comp |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | XXX | 1/month | Calculation |
| TKN | XXX | XXX | XXX | Report | XXX | XXX | XXX | 1/month | 24-hour comp |
| Total Phosphorus (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Phosphorus (lbs) | XXX | 974 Total Annual | XXX | XXX | XXX | XXX | XXX | 1/year | Calculation |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|------------------------------------|------------------------------|--------------------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>.21</u> |
| Latitude | <u>40° 17' 18.74"</u> | Longitude | <u>-76° 33' 43.12"</u> |
| Quad Name | _____ | Quad Code | _____ |
| Wastewater Description: <u>Sewage Effluent</u> | | | |
| Receiving Waters | <u>Killinger Creek (TSF)</u> | Stream Code | <u>09705</u> |
| NHD Com ID | <u>56400711</u> | RMI | <u>4.05</u> |
| Drainage Area | <u>2.01</u> | Yield (cfs/mi ²) | <u>0.14</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>0.28</u> | Q ₇₋₁₀ Basis | <u>USGS Gage station</u> |
| Elevation (ft) | <u>423</u> | Slope (ft/ft) | _____ |
| Watershed No. | <u>7-D</u> | Chapter 93 Class. | <u>TSF</u> |
| Existing Use | _____ | Existing Use Qualifier | _____ |
| Exceptions to Use | _____ | Exceptions to Criteria | _____ |
| Assessment Status | <u>Impaired</u> | | |
| Cause(s) of Impairment | <u>Nutrients, Pathogens</u> | | |
| Source(s) of Impairment | <u>Agriculture, Source Unknown</u> | | |
| TMDL Status | <u>Final</u> | Name | <u>Quittapahilla Creek Watershed</u> |
| Background/Ambient Data | | Data Source | |
| pH (SU) | _____ | | _____ |
| Temperature (°F) | _____ | | _____ |
| Hardness (mg/L) | _____ | | _____ |
| Other: | _____ | | _____ |
| Nearest Downstream Public Water Supply Intake | <u>PA American Water Company</u> | | |
| PWS Waters | <u>Swatara Creek</u> | Flow at Intake (cfs) | _____ |
| PWS RMI | _____ | Distance from Outfall (mi) | <u>16</u> |

Changes Since Last Permit Issuance: None

1.4.1 Water Supply Intake

The nearest downstream water supply intake is approximately 16 miles downstream for PA American Water on Swatara Creek in South Hanover Township, Dauphin County. No impact is expected from this discharge on the intake.

| Treatment Facility Summary | | | | |
|--|---------------------------------------|----------------------|---------------------|------------------------|
| Treatment Facility Name: S Londonderry Campbell E STP | | | | |
| WQM Permit No. | | Issuance Date | | |
| | | | | |
| | | | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary With Ammonia And Phosphorus | Extended Aeration | Gas Chlorine | 0.21 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.21 | | Not Overloaded | | |

Changes Since Last Permit Issuance: None

2.1 Treatment Facility

The plant consist of an influent pump station, a comminutor/bypass bar screen, one aerated equalization tank fitted with duplex submersible discharge pumps and a flow control box, two aeration tanks equipped with coarse bubble diffusers, two dual hopper bottom clarifiers, a chlorine contact tank fitted with a chlorine gas diffuser at the inlet for chlorination and a sulfur dioxide at the end for de-chlorination, one aerobic digester and four reed beds for sludge processing.

2.2 Chemicals

- Lime for pH adjustment as needed
- Chlorine Gas for disinfection
- Sulfur Dioxide for de-chlorination
- DelPac 2000 for phosphorus removal

3.0 Compliance History

3.1 DMR Data for Outfall 001 (from March 1, 2018 to February 28, 2019)

| Parameter | FEB-19 | JAN-19 | DEC-18 | NOV-18 | OCT-18 | SEP-18 | AUG-18 | JUL-18 | JUN-18 | MAY-18 | APR-18 | MAR-18 |
|--|----------|---------|--------|--------|--------|--------|---------|---------|---------|--------|--------|---------|
| Flow (MGD) Average Monthly | 0.163 | 0.184 | 0.180 | 0.185 | 0.144 | 0.177 | 0.192 | 0.209 | 0.164 | 0.176 | 0.172 | 0.167 |
| Flow (MGD) Daily Maximum | 0.222 | 0.318 | 0.277 | 0.298 | 0.174 | 0.326 | 0.349 | 0.609 | 0.257 | 0.325 | 0.261 | 0.215 |
| pH (S.U.) Minimum | 6.36 | 6.54 | 6.36 | 6.39 | 6.19 | 6.29 | 6.44 | 6.12 | 6.17 | 6.51 | 6.43 | 6.29 |
| pH (S.U.) Maximum | 7.55 | 7.13 | 7.16 | 7.17 | 7.23 | 7.15 | 7.30 | 7.37 | 7.14 | 7.18 | 7.10 | 7.15 |
| DO (mg/L) Minimum | 5.56 | 6.07 | 6.25 | 5.65 | 5.89 | 5.06 | 4.99 | 4.36 | 5.73 | 5.91 | 6.27 | 6.41 |
| TRC (mg/L) Average Monthly | 0.02 | 0.02 | 0.03 | 0.02 | 0.04 | 0.01 | 0.04 | 0.02 | 0.01 | 0.02 | 0.01 | 0.01 |
| TRC (mg/L) Instant. Maximum | 0.12 | 0.11 | 0.14 | 0.16 | 0.39 | 0.11 | 0.28 | 0.40 | 0.09 | 0.13 | 0.05 | 0.08 |
| CBOD5 (lbs/day) Average Monthly | 35.73 | 7.15 | < 4.34 | 6.40 | < 3.08 | < 3.24 | < 4.07 | < 6.15 | 6.11 | 5.87 | 6.37 | < 3.44 |
| CBOD5 (lbs/day) Weekly Average | 126.00 | 11.33 | 5.63 | 12.88 | 3.88 | 4.32 | 5.49 | 13.65 | 11.08 | 7.98 | 7.43 | 4.89 |
| CBOD5 (mg/L) Average Monthly | 24.18 | 4.40 | < 2.93 | 4.86 | < 2.50 | < 2.28 | < 2.64 | < 4.33 | 4.75 | 4.10 | 4.78 | < 2.42 |
| CBOD5 (mg/L) Weekly Average | 84.20 | 5.00 | 3.90 | 9.30 | 3.00 | 3.10 | 3.50 | 8.10 | 8.80 | 4.60 | 5.50 | 3.60 |
| BOD5 (lbs/day) Raw Sewage Influent Ave. Monthly | 419.1 | 583.5 | 548.4 | 429.9 | 316.7 | 361.6 | 394.2 | 384.5 | 440.9 | 374.2 | 362.40 | 303.5 |
| BOD5 (lbs/day) Raw Sewage Influent Daily Maximum | 697.2 | 1080.5 | 636.6 | 461.7 | 325.7 | 447.7 | 595.8 | 518.1 | 482.2 | 663.4 | 476.0 | 482.0 |
| BOD5 (mg/L) Raw Sewage Influent Ave. Monthly | 300.8 | 353.8 | 374.5 | 332.6 | 263.7 | 253.5 | 253.8 | 290.5 | 339.5 | 272.2 | 273.8 | 213.8 |
| TSS (lbs/day) Average Monthly | < 124.80 | < 16.25 | < 7.34 | < 8.03 | < 6.70 | 10.10 | < 11.26 | < 12.20 | < 10.02 | < 9.77 | 12.10 | < 11.02 |
| TSS (lbs/day) Raw Sewage Influent Ave. Monthly | 292 | 796 | 738 | 447 | 375 | 400 | 389 | 384 | 441 | 423 | 367 | 217 |

**NPDES Permit Fact Sheet
South Londonderry Campbelltown East STP**

NPDES Permit No. PA0087700

| | | | | | | | | | | | | |
|---|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| TSS (lbs/day) Raw Sewage Influent Daily Maximum | 418 | 1410 | 930 | 583 | 555 | 481 | 651 | 547 | 546 | 762 | 446 | 295 |
| TSS (lbs/day) Weekly Average | 474.00 | 45.33 | < 8.67 | 14.31 | 8.17 | 14.85 | 17.41 | 21.90 | 13.85 | 13.88 | 16.51 | 20.39 |
| TSS (mg/L) Average Monthly | < 83.75 | < 8.80 | < 5.00 | < 6.20 | < 5.50 | 7.00 | < 7.60 | < 9.00 | < 7.75 | < 6.80 | 9.00 | < 7.80 |
| TSS (mg/L) Raw Sewage Influent Ave. Monthly | 208 | 483 | 500 | 349 | 302 | 281 | 251 | 263 | 387 | 301 | 276 | 156 |
| TSS (mg/L) Weekly Average | 316.00 | 18.00 | < 5.00 | 11.00 | 7.00 | 10.00 | 12.00 | 13.00 | 11.00 | 10.00 | 12.00 | 15.00 |
| Fecal Coliform (CFU/100 ml) Geometric Mean | 538 | 253 | 176 | 87 | 44 | 61 | 108 | 162 | 43 | 21 | 26 | 62 |
| Fecal Coliform (CFU/100 ml) Instant Maximum | 12600 | 5400 | 10300 | 240 | 55 | 79 | 260 | 627 | 122 | 54 | 69 | 883 |
| Nitrate-Nitrite (mg/L) Average Monthly | 22.65 | 32.04 | 38.68 | 35.14 | 43.88 | 40.48 | 41.04 | 35.25 | 41.23 | 29.36 | 33.63 | 35.20 |
| Total Nitrogen (mg/L) Average Monthly | < 32.17 | < 33.04 | < 39.68 | < 36.14 | < 44.88 | < 41.48 | < 42.14 | < 37.90 | < 42.23 | < 30.50 | < 34.75 | < 36.20 |
| Total Nitrogen (lbs) Total Monthly | < 1243.20 | < 1639.59 | < 1798.00 | < 1393.80 | < 1703.76 | < 1776.00 | < 1981.21 | < 1481.80 | < 1642.80 | < 1338.27 | < 1389.00 | < 1589.37 |
| Ammonia (lbs/day) Average Monthly | < 7.329 | 0.296 | 0.294 | < 0.171 | < 0.137 | 0.223 | < 0.665 | 4.360 | < 0.340 | 1.568 | 0.649 | < 0.210 |
| Ammonia (mg/L) Average Monthly | < 4.891 | 0.176 | 0.199 | < 0.133 | < 0.112 | 0.158 | < 0.466 | 2.730 | < 0.261 | 1.133 | 0.481 | < 0.145 |
| Ammonia (lbs) Total Monthly | < 205.212 | 9.176 | 9.114 | < 5.130 | < 4.247 | 6.690 | < 20.62 | 135.052 | < 10.200 | 48.608 | 19.470 | < 6.510 |
| TKN (mg/L) Average Monthly | < 9.53 | < 1.00 | < 1.00 | < 1.00 | < 1.00 | < 1.00 | < 1.10 | < 2.65 | < 1.00 | < 1.14 | < 1.13 | < 1.00 |
| TKN (lbs) Total Monthly | < 395.36 | < 50.22 | < 45.57 | < 38.70 | < 37.82 | < 42.90 | < 52.39 | < 126.17 | < 39.00 | < 49.91 | < 45.00 | < 44.33 |
| Total Phosphorus (lbs/day)Ave. Monthly | 1.89 | < 0.55 | 1.04 | 0.75 | 0.62 | < 1.41 | 1.07 | 1.30 | 0.62 | 1.46 | 1.07 | 0.48 |
| Total Phosphorus (mg/L) Ave. Monthly | 1.29 | < 0.31 | 0.72 | 0.59 | 0.51 | < 0.99 | 0.69 | 0.92 | 0.48 | 1.03 | 0.79 | 0.35 |
| Total Phosphorus (lbs) Total Monthly | 52.92 | < 17.05 | 32.24 | 22.50 | 19.22 | < 42.30 | 33.17 | 40.30 | 18.60 | 45.26 | 32.10 | 14.88 |
| Total Phosphorus (lbs) Effluent Total Annual | | | | | | < 366.66 | | | | | | |

3.2 Effluent Violations for Outfall 001, from: April 1, 2018 To: February 28, 2019

| Parameter | Date | SBC | DMR Value | Units | Limit Value | Units |
|----------------|----------|----------|-----------|------------|-------------|------------|
| DO | 08/31/18 | Min | 4.99 | mg/L | 5.0 | mg/L |
| DO | 07/31/18 | Min | 4.36 | mg/L | 5.0 | mg/L |
| CBOD5 | 02/28/19 | Wkly Avg | 126.00 | lbs/day | 70 | lbs/day |
| CBOD5 | 02/28/19 | Wkly Avg | 84.20 | mg/L | 40 | mg/L |
| TSS | 02/28/19 | Avg Mo | < 124.80 | lbs/day | 52 | lbs/day |
| TSS | 02/28/19 | Wkly Avg | 474.00 | lbs/day | 78 | lbs/day |
| TSS | 02/28/19 | Avg Mo | < 83.75 | mg/L | 30 | mg/L |
| TSS | 02/28/19 | Wkly Avg | 316.00 | mg/L | 45 | mg/L |
| Fecal Coliform | 02/28/19 | IMAX | 12600 | CFU/100 ml | 10000 | CFU/100 ml |
| Fecal Coliform | 12/31/18 | IMAX | 10300 | CFU/100 ml | 10000 | CFU/100 ml |
| Ammonia | 07/31/18 | Avg Mo | 2.730 | mg/L | 2.5 | mg/L |

Eleven effluent violations were noted on DMR during the past 12 months of operations as shown on the table above. CBOD5, TSS and Fecal Coliform violation that occurred in February 2019 was attributed to electrical fuse blowing which cut off power to the blowers. No reason was given for the Ammonia, DO and Fecal Coliform violations which occurred in 2018. The four violations noted in 2018 appear to be operation related. The facility's compliance record is satisfactory.

3.3 Summary of Inspections:

The facility has been inspected 7 times during the past permit cycle. Two effluent violations were noted during plant inspections. A notice of violation was sent on... **No major issues noted during facility inspections.**

4.0 Development of Effluent Limitations

| | | | |
|---|-----------------------|--------------------------|------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>.21</u> |
| Latitude | <u>40° 17' 18.85"</u> | Longitude | <u>-76° 33' 43.25"</u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |

4.1 Basis for Effluent Limitations

In general, the Clean Water Act (AWA) requires that the effluent limits for a particular pollutant be the more stringent of either technology-based limits or water quality-based limits. Technology-based limits are set according to the level of treatment that is achievable using available technology. A water quality-based effluent limit is designed to ensure that the water quality standards applicable to a waterbody are being met and may be more stringent than technology-based effluent limits.

4.1.1 Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

4.2 Mass-Based Limits

The federal regulation at 40 CFR 122.45(f) requires that effluent limits be expressed in terms of mass, if possible. The regulation at 40 CFR 122.45(b) requires that effluent limitations for POTWs be calculated based on the design flow of the facility. The mass based limits are expressed in pounds per day and are calculated as follows:

$$\text{Mass based limit (lb/day)} = \text{concentration limit (mg/L)} \times \text{design flow (mgd)} \times 8.34$$

4.3 Water Quality-Based Limitations

4.3.1 Receiving Stream

The receiving stream is the Killinger Creek. According to 25 PA § 93.9o, this stream is protected for Trout Stocking Fishery (TSF). It is located in Drainage List o and State Watershed 7-D. It has been assigned stream code 09705. According to the Department's Integrated Water Quality Monitoring and Assessment Report, Killinger Creek is impaired for pathogens and nutrients. Source is unknown and agriculture, respectively. TMDL is completed and approved by EPA in 2001. See 303d listed streams section of the report for further discussion.

The Technical Support Document for Water Quality-Based Toxics Control (TSD) (EPA, 1991) and the Pennsylvania Water Quality Standards PA WQS) recommend the flow conditions for use in calculating water quality-based effluent limits (WQBELs) using steady-state modeling. The TSD and the PA WQS state that WQBELs intended to protect aquatic life uses

should be based on the lowest seven-day average flow rate expected to occur once every ten years (Q_{7-10}) for chronic criteria and the lowest one-day average flow rate expected to occur once every ten years (Q_{1-10}) for acute criteria. However, because the chronic criterion for ammonia is a 30-day average concentration not to be exceeded more than once every three years, EPA has used the Q_{30-10} for the chronic ammonia criterion instead of the Q_{7-10} . The Q_{30-10} is a biologically-based design flow intended to ensure an excursion frequency of once every three years for a 30-day average flow rate. These flows were determined by correlating with the yield of USGS gage No. 01573560 on Swatara Creek near Hershey. The Q_{7-10} and drainage area at the gage is 67.7ft³/s and 483mi² respectively. The resulting yields are as follows:

- $Q_{7-10} = (67.7\text{ft}^3/\text{s})/483 \text{ mi}^2 = 0.14\text{ft}^3/\text{s}/\text{mi}^2$
- $Q_{30-10} / Q_{7-10} = 0.89$
- $Q_{1-10} / Q_{7-10} = 1.23$

The drainage area at the point of discharge calculated using StreamStats = 2.01 mi².

The summer Q_{7-10} at discharge = 2.01 mi² x 0.14 ft³/s/mi² = 0.28 ft³/s.

4.3.2 NH₃N Calculations

NH₃N calculations will be based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the instream NH₃N criteria used in the attached computer model of the stream:

- Discharge pH = 6.6 (July to Sep. DMR median)
- Discharge Temperature = 25 ° C (Default)
- Stream pH = 7.8 (WQN Station on Quittapahilla Creek)
- Stream Temperature = 19 °C (WQN Station on Quittapahilla Creek)
- Background NH₃-N = 0.0 (default)
- Discharge flow = 0.02MGD

4.3.3 CBOD₅ & NH₃-N

Due to their proximities, Campbelltown East STP and Vanderhomes STP discharges were modeled together as two reaches. The attached WQM 7.0 stream model results presented in attachment B indicates a limit of 25 mg/l for CBOD₅ for Campbelltown East STP discharge is adequate to protect the water quality of the stream. This limit is consistent with the existing permit and the STP has been consistently achieving below this limitation. Therefore, a limit of 25 mg/l AML, 40mg/l average weekly limit (AWL) and 50 mg/l IMAX are recommended for this permit cycle.

Mass limits are calculated as follows:

$$\text{Mass based AML (lb/day)} = 25 \text{ (mg/L)} \times 0.21(\text{mgd}) \times 8.34 = 43$$

$$\text{Mass based AWL (lb/day)} = 40 \text{ (mg/L)} \times 0.21 \text{ (mgd)} \times 8.34 = 70$$

The attached WQM 7.0 stream model results (attachment B) also indicates that, for the Campbelltown East STP discharge, a summer limit of 2.5 mg/l for NH₃-N is necessary to protect aquatic life from toxicity effects. The limit for winter months is 3 times the summer limit (7.5 mg/l NH₃-N).

$$\text{Mass based AML (lb/day) for summer months} = 2.5 \text{ (mg/L)} \times 0.21(\text{mgd}) \times 8.34 = 4.4$$

$$\text{Mass based AML (lb/day) for winter months} = 7.5 \text{ (mg/L)} \times 0.21 \text{ (mgd)} \times 8.34 = 13.1$$

4.3.4 Dissolved Oxygen

The existing permit contains a limit of 5 mg/l for Dissolved Oxygen (DO). DEP's Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001, 10/97) suggests that either the adopted minimum stream D.O. criteria for the receiving stream or the effluent level determined through water quality modeling be used for the limit. Since the WQM 7.0 model was run using a minimum D.O. of 5.0 mg/l as well, this limit will be continued in the renewed permit with a daily monitoring requirement per DEP guidance.

4.3.5 Total Suspended Solids(TSS):

There is no water quality criterion for TSS. The existing limit of 30 mg/l AML based on the minimum level of effluent quality attainable by secondary treatment as defined in 40 CFR 133.102b(1), 40 CFR 133.102b(1), 25 PA § 92a.47(a)(1) and 92a.47(a)(2) will remain in the permit.

$$\text{Mass based AML (lb/day)} = 30 \text{ (mg/L)} \times 0.21 \text{ (mgd)} \times 8.34 = 52$$

$$\text{Mass based AWL (lb/day)} = 45 \text{ (mg/L)} \times 0.21 \text{ (mgd)} \times 8.34 = 78$$

4.3.6 Chesapeake Bay Strategy:

The Department formulated a strategy in April 2007, to comply with the EPA and Chesapeake Bay Foundation requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5(below 0.2mdg) will be required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001). Any facility in Phases 4 and 5 that undergoes expansion is subjected to cap load right away.

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011 and Phase 2 in March 2012. In accordance with the Phase 2 WIP and its supplement, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal. This facility is, classified as a phase 4, and had been monitoring and reporting Nitrate-Nitrite as N, Total Kjeldahl Nitrogen and Total Nitrogen monthly and will continue during this permit cycle. There is limitation on Total Phosphorus in the permit, no monitoring is required.

4.3.7 Phosphorus

The average monthly limit of 2mg/l phosphorus in the existing permit was required due to nutrient impairment of the stream prior to TMDL development for the Quittapahilla Creek watershed. The TMDL allocated a wasteload of 1,128.5lbs/year of Total Phosphorus to Killingier Creek. A Total Phosphorus wasteload of 974lbs/year was allocated from a total wasteload of 1,128.5lbs/yr to this facility and the rest of the wasteload of 154.5lbs/yr. was allocated to Vanderhomes STP downstream of the facility.

4.3.8 Total Residual Chlorine:

The attached computer printout presented in attachment C utilizes the equations and calculations as presented in the Department's 2003 Implementation Guidance for Residual Chlorine (TRC) (ID # 391-2000-015) for developing chlorine limitations. The results presented in attachment C indicates that a water quality limit of 0.13 mg/l monthly average and IMAX of 0.44 mg/l would be needed to prevent toxicity concerns. However, the existing limits of 0.12mg/l monthly average and IMAX of 0.40mg/l will remain in the permit due to anti-backsliding restrictions. DMR and inspection reports indicate the facility is meeting the permit requirement.

4.3.9 Toxics

A reasonable potential (RP) analysis was done for pollutants submitted with the application. All pollutants were entered into a Toxics Screening Analysis spreadsheet to determine if any pollutants are parameters of concern that require PENTOXSD modeling. All pollutants above the most stringent Chapter 93 criteria are considered parameters of concern. This also includes samples that resulted in non-detect, but the method detection limit that was used is higher than DEP's target quantitation limit (QL). All pollutants that were determined to be candidates for PENTOXSD modeling were entered into the PENTOXSD model. The most stringent WQBELs recommended by the PENTOXSD model were then entered into the

same Toxics Screening Analysis spreadsheet in order to determine which parameters of concern needs limitation or monitoring. Total Copper was determined to be parameter of concern and was analyzed with the PENTOXSD Model. The permit was amended during previous permit cycle and Total Copper limitation was dropped based on two WER tests conducted on June 5th and July 31 in 2013 using Ceriodaphnia dubia as test species. The tests were conducted using 55% effluent and 45% stream water. In addition, laboratory water was constituted with various spiked copper concentration to complete the tests. The study covers Dissolved Copper as well as Total Copper. The summary of the final results approved by the Department and EPA is shown on the tables A. and B. below.

Table A: Total Copper

| Test1 | EC 50 | EC 50 (Normalized | Normalized Table | WER |
|------------------|-----------|-------------------|------------------|-------|
| June 2013 | | | SMAV | |
| Lab water | 9.22 | 9.98ppb | 24.0ppb | NA |
| Effluent | 157.37 | 98.18 | NA | 4.09 |
| Test 2 | | | | |
| July/August 2013 | | | | |
| Lab water | 20.01ppb | 23.16ppb | 24.41 | NA |
| Effluent | 129.05ppb | 84.88ppb | NA | 3.54 |
| Final Site WER | | | | 3.80* |

Table B: Dissolved Copper

| Test 1 | EC 50 | EC 50 (Normalized | Normalized Table | WER |
|------------------|-----------|-------------------|------------------|-------|
| June 2013 | | | SMAV | |
| Lab water | 9.04 | 9.79ppb | 22.11ppb | NA |
| Effluent | 137.17 | 84.33 | NA | 3.81 |
| Test 2 | | | | |
| July/August 2013 | | | | |
| Lab water | 19.36ppb | 22.41ppb | 22.11ppb | NA |
| Effluent | 107.21ppb | 70.51ppb | NA | 3.15 |
| Final Site WER | | | | 3.46* |

*Final site WER is the geometric mean of the two WER results

PENTOXSD modeling was conducted with the approved WER for Total Copper entered into PENTOXSD model under the criterion modifier tab. The most stringent WQBELs recommended by the PENTOXSD model presented in attachment C was then entered into the same Toxics Screening Analysis spreadsheet in order to determine if limitation or monitoring was necessary. Monitoring of Total Copper was recommended. See the Toxic screenings spreadsheet presented in attachment E for details.

The recommended monitoring follows the logic presented in DEPs SOP, to establish limits in the permit where the maximum reported concentration exceeds 50% of the WQBEL, or for non-conservative pollutants to establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL, or to establish monitoring requirements for conservative pollutants where the maximum reported concentration is between 10% - 50% of the WQBEL.

4.3.10 TDS, Sulfate, Chloride, Bromide & 1,4-Dioxane

Under the authority of §92a.61, DEP has determined it should implement increased monitoring in NPDES permits for TDS, sulfate, chloride, bromide, and 1,4-dioxane. The following approach will be implemented for point source discharges upon issuance or reissuance of an individual NPDES permit:

- Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.

- Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.
- Where the concentration of 1,4-dioxane (CAS 123-91-1) in a discharge exceeds 10 µg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for 1,4-dioxane. Discharges of 0.1 MGD or less should monitor and report for 1,4-dioxane if the concentration of 1,4-dioxane in the discharge exceeds 100 µg/L.

The maximum daily TDS discharge submitted with the application is 540 mg/L which is equivalent to 946lbs/day based on the permitted flow of 0.21 MGD. The discharge level for TDS is below the minimum 1000 mg/l and 20,000lbs/day, to require monitoring, therefore no monitoring of TDS, Chloride, Sulfate, and Bromide will be required in the permit. There is no data for 1,4-dioxane, therefore no monitoring is required for 1,4-dioxane

4.3.11 Influent BOD and TSS Monitoring

The permit will include influent BOD5 and TSS monitoring at the same frequency as is done for effluent in order to implement Chapter 94.12 and assess percent removal requirements.

4.3.12 Pretreatment Requirements

The design annual average flow of the treatment plant is 0.21 MGD and the facility receives flow from no significant Industrial users. There is no approved pretreatment program for the facility, however, the permit contains standard conditions requiring the permittee to monitor and control industrial users if applicable.

5.0 Other Requirements

5.1 Anti-backsliding

Not applicable to this permit

5.2 Stormwater:

No storm water outfall is associated with this facility

5.3 Special Permit Conditions

The permit will contain the following special conditions:

Stormwater Prohibition, Approval Contingencies, Proper Waste/solids Management, Restriction on receipt of hauled in waste under certain conditions and Chlorine minimization.

5.4 Biosolids Management

Digested sludge is land applied under biosolid permit number PAG083520 or hauled to North Londonderry Township STP during winter months.

5.5 Anti-Degradation (93.4)

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

5.6 Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

5.7 303d Listed Streams:

The discharge is located on a stream segment that is designated on the 303(d) list as impaired, and the impairment is due to nutrients from agricultural activities in the watershed. TMDL for Quittapahilla Creek Watershed was approved in 2001. The wasteload allocation (WLA) for phosphorus in the Killinger creek watershed was set at 1128.5lbs/year based on Campbelltown East plant discharge. The document explained that average monthly discharge of 2mg/l at waste flow of 0.21mgd will account for less than 1% total phosphorus loading to Killinger Creek and limits Campbelltown East plant discharge to the existing NPDES permit limit of 2mg/l at 0.21mgd, however Vanderhomes formerly Palm City Mobile Home Park was not included in the WLA. The WLA was divided between this facility and Vanderhomes STP downstream of the this discharge. A Total Phosphorus wasteload of 974lbs/year was allocated from a total load of 1,128.5lbs/yr to this facility and the rest of the wasteload of 154.5lbs/yr was allocated to Vanderhomes downstream of the facility.

5.8 Basis for Effluent and Surface Water Monitoring

Section 308 of the CWA and federal regulation 40 CFR 122.44(i) require monitoring in permits to determine compliance with effluent limitations. Monitoring may also be required to gather effluent and surface water data to determine if additional effluent limitations are required and/or to monitor effluent impacts on receiving water quality. The permittee is responsible for conducting the monitoring and for reporting results on Discharge Monitoring Reports (DMRs).

5.9 Effluent Monitoring

Monitoring frequencies are based on the nature and effect of the pollutant, as well as a determination of the minimum sampling necessary to adequately monitor the facility's performance. Permittees have the option of taking more frequent samples than are required under the permit. These samples can be used for averaging if they are conducted using EPA-approved test methods (generally found in 40 CFR 136) and if the Method Detection Limits are less than the effluent limits. The sampling location must be after the last treatment unit and prior to discharge to the receiving water. If no discharge occurs during the reporting period, "no discharge" shall be reported on the DMR.

6.0 Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--|-------------------------------------|------------------|-----------------------|-----------------|----------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Daily Min | XXX | 9.0 Daily Max | XXX | 1/day | Grab |
| DO | XXX | XXX | 5.0 Daily Min | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.12 | XXX | 0.40 | 1/day | Grab |
| CBOD5 | 43 | 70 | XXX | 25 | 40 | 50 | 1/week | 24-Hr Composite |
| BOD5 Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| TSS | 52 | 78 | XXX | 30 | 45 | 60 | 1/week | 24-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 1/week | Grab |
| Ammonia Nov 1 - Apr 30 | 13.1 | XXX | XXX | 7.5 | XXX | 15 | 1/week | 24-Hr Composite |
| Ammonia May 1 - Oct 31 | 4.4 | XXX | XXX | 2.5 | XXX | 5 | 1/week | 24-Hr Composite |
| Total Phosphorus | 3.5 | XXX | XXX | 2.0 | XXX | 4 | 1/week | 24-Hr Composite |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)


| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------|-------------------------------------|---------------------|-----------------------|--------------------|-------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Total Copper | XXX | XXX | XXX | Report | XXX | XXX | 1/month | 24-Hr Composite |
| Nitrate-Nitrite | XXX | XXX | XXX | Report | XXX | XXX | 1/month | 24-Hr Composite |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 1/month | Calculation |
| TKN | XXX | XXX | XXX | Report | XXX | XXX | 1/month | 24-Hr Composite |
| Total Phosphorus (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Phosphorus (lbs) | XXX | 974 Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |

Compliance Sampling Location: At Outfall 001

| 7.0 Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment B) |
| <input checked="" type="checkbox"/> | PENTOXSD for Windows Model (see Attachment C) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment D) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment) |
| <input checked="" type="checkbox"/> | Toxics Screening Analysis Spreadsheet (see Attachment E) |
| <input checked="" type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input checked="" type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 385-2000-011, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97. |
| <input checked="" type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97. |
| <input checked="" type="checkbox"/> | Implementation Guidance Design Conditions, 391-2000-006, 9/97. |
| <input checked="" type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09. |
| <input checked="" type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input checked="" type="checkbox"/> | Design Stream Flows, 391-2000-023, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97. |
| <input checked="" type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input checked="" type="checkbox"/> | SOP: 1. Establishing effluent limitation for individual sewage permit, |
| <input checked="" type="checkbox"/> | Other: WIP 2 Supplement |

8.0 Attachments

A. Topographical Map



B. WQM Model Results

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--------------------|--------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 07D | 9705 | KILLINGER CREEK | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 4.050 | Camp. East Pit | PA0087700 | 0.210 | CBOD5 | 25 | | |
| | | | | NH3-N | 2.88 | 5.76 | |
| | | | | Dissolved Oxygen | | | 5 |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 3.800 | Vanderhomes MHP | PA0033065 | 0.036 | CBOD5 | 25 | | |
| | | | | NH3-N | 8.51 | 17.02 | |
| | | | | Dissolved Oxygen | | | 5 |

Permit No. PA0087700

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-----------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 07D | 9705 | KILLINGER CREEK | 4.050 | 423.00 | 2.01 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfs) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | pH | Stream Temp (°C) | pH |
|--------------|-----------|-----------------|-------------------|----------------------|--------------------|----------|----------------|----------------|---------------------|------|------------------|------|
| Q7-10 | 0.140 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 19.00 | 7.80 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Camp. East Plt | PA0087700 | 0.2100 | 0.2100 | 0.2100 | 0.000 | 25.00 | 6.60 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Permit No. PA0087700

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-----------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 07D | 9705 | KILLINGER CREEK | 3.800 | 420.00 | 2.20 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|-------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfs) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.140 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 19.00 | 7.80 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Vanderhomes MHP | PA0033065 | 0.0360 | 0.0360 | 0.0360 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Permit No. PA0087700

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-----------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 07D | 9705 | KILLINGER CREEK | 3.420 | 415.00 | 2.21 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.140 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 19.00 | 7.80 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|------------------|------------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 0.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | | |
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 | | | |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 | | | |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 | | | |

Permit No. PA0087700

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | | <u>Stream Name</u> | | | | | | |
|--------------------|-------------|--------------------|-----------------|--------------------|-------------|--------------------|-------|-----------|----------|-----------------|---------------|-------------|
| 07D | | 9705 | | | | KILLINGER CREEK | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | (cfs) | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 4.050 | 0.28 | 0.00 | 0.28 | .3249 | 0.00227 | .476 | 9.98 | 20.95 | 0.13 | 0.120 | 22.22 | 6.85 |
| 3.800 | 0.31 | 0.00 | 0.31 | .3806 | 0.00249 | .484 | 10.52 | 21.73 | 0.14 | 0.172 | 22.32 | 6.87 |
| Q1-10 Flow | | | | | | | | | | | | |
| 4.050 | 0.25 | 0.00 | 0.25 | .3249 | 0.00227 | NA | NA | NA | 0.12 | 0.123 | 22.39 | 6.83 |
| 3.800 | 0.27 | 0.00 | 0.27 | .3806 | 0.00249 | NA | NA | NA | 0.13 | 0.177 | 22.49 | 6.85 |
| Q30-10 Flow | | | | | | | | | | | | |
| 4.050 | 0.35 | 0.00 | 0.35 | .3249 | 0.00227 | NA | NA | NA | 0.13 | 0.113 | 21.90 | 6.89 |
| 3.800 | 0.38 | 0.00 | 0.38 | .3806 | 0.00249 | NA | NA | NA | 0.14 | 0.163 | 22.01 | 6.91 |

Permit No. PA0087700

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.89 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.23 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

Permit No. PA0087700

WQM 7.0 Wasteload Allocations

| | | |
|------------------|--------------------|--------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
| 07D | 9705 | KILLINGER CREEK |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 4.050 | Camp. East Pit | 8.99 | 15.93 | 8.99 | 14.06 | 2 | 12 |
| 3.800 | Vanderhomes M | 5.68 | 33.62 | 8.81 | 29.67 | 2 | 12 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 4.050 | Camp. East Pit | 1.79 | 3.69 | 1.79 | 2.88 | 2 | 22 |
| 3.800 | Vanderhomes M | 1.4 | 10.9 | 1.75 | 8.51 | 2 | 22 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|------|-----------------|--------------------|--------------------|--------------------|--------------------|-------------------------|--------------------|-------------------|----------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 4.05 | Camp. East Pit | 25 | 25 | 2.88 | 2.88 | 5 | 5 | 0 | 0 |
| 3.80 | Vanderhomes MHP | 25 | 25 | 8.51 | 8.51 | 5 | 5 | 0 | 0 |

Permit No. PA0087700

WQM 7.0 D.O. Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|--------------------|
| 07D | 9705 | KILLINGER CREEK | | |
| <hr/> | | | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | |
| 4.050 | 0.210 | 22.215 | 6.848 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | |
| 9.981 | 0.476 | 20.953 | 0.128 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | |
| 14.32 | 1.393 | 1.54 | 0.830 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | |
| 6.505 | 22.691 | Owens | 6 | |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u> | | | |
| 0.120 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> |
| | 0.012 | 14.06 | 1.53 | 6.64 |
| | 0.024 | 13.80 | 1.51 | 6.76 |
| | 0.036 | 13.55 | 1.50 | 6.85 |
| | 0.048 | 13.30 | 1.48 | 6.93 |
| | 0.060 | 13.06 | 1.47 | 6.99 |
| | 0.072 | 12.82 | 1.45 | 7.05 |
| | 0.084 | 12.59 | 1.44 | 7.10 |
| | 0.096 | 12.36 | 1.42 | 7.14 |
| | 0.108 | 12.13 | 1.41 | 7.18 |
| | 0.120 | 11.91 | 1.40 | 7.22 |
| <hr/> | | | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | |
| 3.800 | 0.246 | 22.316 | 6.874 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | |
| 10.518 | 0.484 | 21.735 | 0.135 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | |
| 12.58 | 1.378 | 1.92 | 0.837 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | |
| 7.080 | 22.982 | Owens | 6 | |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u> | | | |
| 0.172 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> |
| | 0.017 | 12.26 | 1.89 | 7.13 |
| | 0.034 | 11.94 | 1.86 | 7.17 |
| | 0.051 | 11.63 | 1.84 | 7.21 |
| | 0.069 | 11.33 | 1.81 | 7.25 |
| | 0.086 | 11.03 | 1.78 | 7.29 |
| | 0.103 | 10.75 | 1.76 | 7.32 |
| | 0.120 | 10.47 | 1.73 | 7.36 |
| | 0.137 | 10.20 | 1.71 | 7.39 |
| | 0.154 | 9.93 | 1.69 | 7.42 |
| | 0.172 | 9.67 | 1.66 | 7.45 |

Permit No. PA0087700

C. PENTOXSD Model Results

PENTOXSD Analysis Results

Recommended Effluent Limitations

| <u>SWP Basin</u> | <u>Stream Code:</u> | <u>Stream Name:</u> | | | |
|------------------|-----------------------|---------------------|-------------------------|----------------|-----------------|
| 07D | 9705 | KILLINGER CREEK | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | | |
| 4.05 | Camp. East Pit | PA0087700 | 0.2100 | | |
| Parameter | Effluent Limit (µg/L) | Governing Criterion | Max. Daily Limit (µg/L) | Most Stringent | |
| COPPER | 97.445 | CFC | 152.03 | WQBEL (µg/L) | WQBEL Criterion |
| | | | | 97.445 | CFC |
| RMI | Name | Permit Number | Disc Flow (mgd) | | |
| 3.80 | Vanderhomes MHP | PA0033065 | 0.0360 | | |

Permit No. PA0087700

PENTOXSD

Modeling Input Data

| Stream Code | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope | PWS With (mgd) | Apply FC |
|-------------|------|----------------|-----------------------|---------|----------------|-------------------------------------|
| 9705 | 4.05 | 423.00 | 2.01 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| LFY | Trib Flow | Stream Flow | WD Ratio | Rch Width | Rch Depth | Rch Velocity | Rch Trav Time | Tributary Hard | pH | Stream Hard | pH | Analysis Hard | pH |
|--------|-----------|-------------|----------|-----------|-----------|--------------|---------------|----------------|-----|-------------|----|---------------|----|
| (cfsm) | (cfs) | (cfs) | | (ft) | (ft) | (fps) | (days) | (mg/L) | | (mg/L) | | (mg/L) | |
| Q7-10 | 0.14 | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7.8 | 100 | 0 | 0 | 0 |
| Qh | | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7 | 0 | 0 | 0 | 0 |

Discharge Data

| Name | Permit Number | Existing Disc Flow | Permitted Disc Flow | Design Disc Flow | Reserve Factor | AFC PMF | CFC PMF | THH PMF | CRL PMF | Disc Hard | Disc pH |
|----------------|---------------|--------------------|---------------------|------------------|----------------|---------|---------|---------|---------|-----------|---------|
| | | (mgd) | (mgd) | (mgd) | | | | | | (mg/L) | |
| Camp. East Pit | PA0087700 | 0.21 | 0.21 | 0.21 | 0 | 0 | 0 | 0 | 0 | 207 | 6.6 |

Parameter Data

| Parameter Name | Disc Conc | Trib Conc | Disc Daily CV | Disc Hourly CV | Steam Conc | Stream CV | Fate Coef | FOS | Crit Mod | Max Disc Conc |
|----------------|-----------|-----------|---------------|----------------|------------|-----------|-----------|-----|----------|---------------|
| | (µg/L) | (µg/L) | | | (µg/L) | | | | | (µg/L) |
| COPPER | 1000000 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 3.8 | 0 |

| Stream Code | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope | PWS With (mgd) | Apply FC |
|-------------|------|----------------|-----------------------|---------|----------------|-------------------------------------|
| 9705 | 3.80 | 420.00 | 2.20 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| LFY | Trib Flow | Stream Flow | WD Ratio | Rch Width | Rch Depth | Rch Velocity | Rch Trav Time | Tributary Hard | pH | Stream Hard | pH | Analysis Hard | pH |
|--------|-----------|-------------|----------|-----------|-----------|--------------|---------------|----------------|-----|-------------|----|---------------|----|
| (cfsm) | (cfs) | (cfs) | | (ft) | (ft) | (fps) | (days) | (mg/L) | | (mg/L) | | (mg/L) | |
| Q7-10 | 0.14 | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7.8 | 100 | 0 | 0 | 0 |
| Qh | | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7 | 0 | 0 | 0 | 0 |

Discharge Data

| Name | Permit Number | Existing Disc Flow | Permitted Disc Flow | Design Disc Flow | Reserve Factor | AFC PMF | CFC PMF | THH PMF | CRL PMF | Disc Hard | Disc pH |
|-----------------|---------------|--------------------|---------------------|------------------|----------------|---------|---------|---------|---------|-----------|---------|
| | | (mgd) | (mgd) | (mgd) | | | | | | (mg/L) | |
| Vanderhomes MHP | PA0033065 | 0.036 | 0.036 | 0.036 | 0 | 0 | 0 | 0 | 0 | 100 | 7 |

Parameter Data

| Parameter Name | Disc Conc | Trib Conc | Disc Daily CV | Disc Hourly CV | Steam Conc | Stream CV | Fate Coef | FOS | Crit Mod | Max Disc Conc |
|----------------|-----------|-----------|---------------|----------------|------------|-----------|-----------|-----|----------|---------------|
| | (µg/L) | (µg/L) | | | (µg/L) | | | | | (µg/L) |
| COPPER | 0 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |

Permit No. PA0087700

PENTOXSD Analysis Results

Hydrodynamics

| <u>SWP Basin</u> | | <u>Stream Code:</u> | | | <u>Stream Name:</u> | | | | | | |
|----------------------------|----------------------|---------------------|--------------------------|-----------------------------|---------------------|---------------|---------------|----------|-------------------|---------------------------|--------------|
| 07D | | 9705 | | | KILLINGER CREEK | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope | Depth (ft) | Width (ft) | WD Ratio | Velocity (fps) | Reach Trav Time (days) | CMT (min) |
| Q7-10 Hydrodynamics | | | | | | | | | | | |
| 4.050 | 0.2814 | 0 | 0.2814 | 0.32486 | 0.0023 | 0.4763 | 9.9807 | 20.953 | 0.1275 | 0.1198 | 1.876 |
| 3.800 | 0.308 | 0 | 0.308 | 0.05569 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Qh Hydrodynamics | | | | | | | | | | | |
| 4.050 | 2.4530 | 0 | 2.4530 | 0.32486 | 0.0023 | 0.9306 | 9.9807 | 10.725 | 0.2991 | 0.0511 | 2.487 |
| 3.800 | 2.6545 | 0 | 2.6545 | 0.05569 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Permit No. PA0087700

PENTOXSD Analysis Results

Wasteload Allocations

| RMI | Name | Permit Number | | | | | | |
|---|----------------|--------------------|-----------|------------------|-------------|------------|-------------------|------------|
| 4.05 | Camp. East Pit | PA0087700 | | | | | | |
| AFC | | | | | | | | |
| Q7-10: | CCT (min) | 1.876 | PMF | 1 | Analysis pH | 6.847 | Analysis Hardness | 157.335 |
| Parameter | | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) |
| COPPER | | 0 | 0 | 0 | 0 | 78.272 | 81.533 | 152.157 |
| Criteria Modifier of 3.8 applied. Dissolved WQC. Chemical translator of 0.96 applied. | | | | | | | | |
| CFC | | | | | | | | |
| Q7-10: | CCT (min) | 1.876 | PMF | 1 | Analysis pH | 6.847 | Analysis Hardness | 157.335 |
| Parameter | | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) |
| COPPER | | 0 | 0 | 0 | 0 | 50.127 | 52.216 | 97.445 |
| Criteria Modifier of 3.8 applied. Dissolved WQC. Chemical translator of 0.96 applied. | | | | | | | | |
| THH | | | | | | | | |
| Q7-10: | CCT (min) | 1.876 | PMF | NA | Analysis pH | NA | Analysis Hardness | NA |
| Parameter | | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) |
| COPPER | | 0 | 0 | 0 | 0 | NA | NA | NA |
| CRL | | | | | | | | |
| Qh: | CCT (min) | 2.487 | PMF | 1 | | | | |
| Parameter | | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) |
| COPPER | | 0 | 0 | 0 | 0 | NA | NA | NA |

Permit No. PA0087700

D. Total Residual Chlorine Calculations

Copy of TRC_CALC1

| TRC EVALUATION | | | | | |
|---|---|-------------------------------|---------------------|-----------|--------------------------------------|
| Input appropriate values in A3:A9 and D3:D9 | | | | | |
| 0.28 | = Q stream (cfs) | | | 0.5 | = CV Daily |
| 0.21 | = Q discharge (MGD) | | | 0.5 | = CV Hourly |
| 30 | = no. samples | | | 1 | = AFC_Partial Mix Factor |
| 0.3 | = Chlorine Demand of Stream | | | 1 | = CFC_Partial Mix Factor |
| 0 | = Chlorine Demand of Discharge | | | 15 | = AFC_Criteria Compliance Time (min) |
| 0.5 | = BAT/BPJ Value | | | 720 | = CFC_Criteria Compliance Time (min) |
| 0 | = % Factor of Safety (FOS) | | | 0 | = Decay Coefficient (K) |
| Source | Reference | AFC Calculations | | Reference | CFC Calculations |
| TRC | 1.3.2.iii | | WLA_afc = 0.294 | 1.3.2.iii | WLA_cfc = 0.279 |
| PENTOXSD TRG | 5.1a | | LTAMULT_afc = 0.373 | 5.1c | LTAMULT_cfc = 0.581 |
| PENTOXSD TRG | 5.1b | | LTA_afc = 0.110 | 5.1d | LTA_cfc = 0.162 |
| Source | Effluent Limit Calculations | | | | |
| PENTOXSD TRG | 5.1f | AML_MULT = 1.231 | | | |
| PENTOXSD TRG | 5.1g | AVG_MON_LIMIT (mg/l) = 0.135 | | AFC | |
| | | INST_MAX_LIMIT (mg/l) = 0.441 | | | |
| WLA_afc | $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | | |
| LTAMULT_afc | $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$ | | | | |
| LTA_afc | wla_afc * LTAMULT_afc | | | | |
| WLA_cfc | $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | | |
| LTAMULT_cfc | $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$ | | | | |
| LTA_cfc | wla_cfc * LTAMULT_cfc | | | | |
| AML_MULT | $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$ | | | | |
| AVG_MON_LIMIT | MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT) | | | | |
| INST_MAX_LIMIT | 1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc) | | | | |

Permit No. PA0087700

E. Toxic Screening Analysis Spreadsheet

WATER QUALITY POLLUTANTS OF CONCERN
VERSION 2.5

Facility: **Cambeltown East STP**
Analysis Hardness (mg/L): **100**

NPDES Permit No.: **PA0087700**
Discharge Flow (MGD): **0.21**

Outfall: **001**
Analysis pH (SU): **7**

| Parameter | Maximum Concentration in Application or DMRs (µg/L) | Most Stringent Criterion (µg/L) | Candidate for PENTOXSD Modeling? | Most Stringent WQBEL (µg/L) | Screening Recommendation |
|---------------------------|---|---------------------------------|----------------------------------|-----------------------------|--------------------------|
| Total Dissolved Solids | 5400000 | 500000 | Yes | | Monitor |
| Chloride | 164000 | 250000 | No | | Monitor |
| Bromide | 0.5 | N/A | No | | Monitor |
| Sulfate | 64500 | 250000 | No | | Monitor |
| Total Aluminum | | 750 | | | |
| Total Antimony | | 5.6 | | | |
| Total Arsenic | | 10 | | | |
| Total Barium | | 2400 | | | |
| Total Beryllium | | N/A | | | |
| Total Boron | | 1600 | | | |
| Total Cadmium | | 0.271 | | | |
| Total Chromium | | N/A | | | |
| Hexavalent Chromium | | 10.4 | | | |
| Total Cobalt | | 19 | | | |
| Total Copper | 18 | 9.3 | Yes | 97 | Monitor |
| Free Available Cyanide | | 5.2 | | | |
| Total Cyanide | | N/A | | | |
| Dissolved Iron | | 300 | | | |
| Total Iron | | 1500 | | | |
| Total Lead | | 3.2 | | | |
| Total Manganese | | 1000 | | | |
| Total Mercury | | 0.05 | | | |
| Total Nickel | | 52.2 | | | |
| Total Phenols (Phenolics) | | 5 | | | |
| Total Selenium | | 5.0 | | | |
| Total Silver | | 3.8 | | | |
| Total Thallium | | 0.24 | | | |
| Total Zinc | 91 | 119.8 | No | | |
| Total Molybdenum | | N/A | | | |