

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0088277
 APS ID 619241
 Authorization ID 1476115

Applicant and Facility Information

Applicant Name	<u>Summit Ridge Homeowners Assoc</u>	Facility Name	<u>Summit Ridge STP</u>
Applicant Address	<u>2950 Lewisberry Road</u> <u>York, PA 17404-8376</u>	Facility Address	<u>1235 Abbottstown Pike</u> <u>Hanover, PA 17331-8237</u>
Applicant Contact	<u>Lindsey Thomas</u>	Facility Contact	<u>Lindsey Thomas</u>
Applicant Phone	<u>(717) 848-1579</u>	Facility Phone	<u>(717) 848-1579</u>
Client ID	<u>257538</u>	Site ID	<u>503328</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Berwick Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Adams</u>
Date Application Received	<u>March 7, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 8, 2024</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

Summit Ridge Homeowners Associates (Authority/Permittee), applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The permit was reissued on May 21, 2019 and became effective on June 1, 2019. The permit expires on May 31, 2024.

The average annual design flow and hydraulic design capacity is 0.02555 MGD. The treated effluent is discharged to UNT to Beaver Creek. The 2024 application states that there are no industrial users.

WQM Part II Permit No. 0100406 was issued on 2/9/2001, and 0100406 T-1 ownership transfer was issued on 8/16/2007.

Sludge use and disposal description and location(s): N/A because sludge is hauled by Smiths Sanitary Septic Service LLC.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the proposed permit. The TRC limits will change to 0.14 mg/L for AML & 0.45 mg/L for IMAX.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	May 3, 2024
X		<i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	May 22, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.02555
Latitude	39° 51' 38.00"	Longitude	-76° 58' 60.00"
Quad Name	Hanover	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Beaver Creek	Stream Code	8768
NHD Com ID	57473183	RMI	2.05
Drainage Area	0.69 mi. ²	Yield (cfs/mi ²)	0.05
Q ₇₋₁₀ Flow (cfs)	0.035	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	645	Slope (ft/ft)	
Watershed No.	7-F	Chapter 93 Class.	WWF & MF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s), & assessment ID 18596 is also impaired for recreational purposes.		
Cause(s) of Impairment	Pathogens		
Source(s) of Impairment	Unknown source		
TMDL Status	Not applicable	Name	
Nearest Downstream Public Water Supply Intake	PP & L Bruner Island		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	54.0 miles	Distance from Outfall (mi)	Approximate 41.0 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to UNT to beaver Creek at RMI 2.05 miles. A drainage area upstream of the discharge is estimated to be 0.69 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

According to StreamStats, the discharge point on Conewago Creek has a Q₇₋₁₀ of 0.035 cfs and a drainage area of 0.69 mi.², which results in a Q₇₋₁₀ low flow yield of 0.05 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 0.035 \text{ cfs} \\
 \text{Low Flow Yield} &= 0.035 \text{ cfs} / 0.69 \text{ mi.}^2 = 0.05 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 0.035 \text{ cfs} = 0.048 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.035 \text{ cfs} = 0.022 \text{ cfs}
 \end{aligned}$$

Receiving Water Characteristics

Under 25 Pa Code §93.9o, UNT to Beaver Creek is designated as Warm Water Fishes and Migratory Fishes (WWF & MF). The discharge is located within a stream segment listed as attaining uses.

303d Listed Streams

Based on the 2024 Integrated Report, Beaver Creek, assessment unit IDs 11748 is not impaired, & 18596 is impaired for pathogens from an unknown source. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Public Water Supply

The nearest downstream public water supply intake is for PPL Brunner Island on Susquehanna River, approximately 41.0 miles downstream of this discharge. Considering distance and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Summit Ridge STP				
WQM Permit No.		Issuance Date		
0100406		2/9/2001		
0100406 T-1		8/16/2007		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage			Hypochlorite	0.0255
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0256		Not Overloaded		

Changes Since Last Permit Issuance: none

Other Comments:

The WWTP train is as follows:

Bar Screen (1) ⇒ Equalization Tank (2) ⇒ Aeration tank (4) ⇒ Clarifier Tank (1) ⇒ Polishing Clarifier Tank (1)
⇒ Chlorine disinfection contact Tank (1) ⇒ Sludge Holding Tank (1) ⇒ Discharge to UNT to Beaver Creek

Chemical used:

Calcium hypochlorite is used for disinfection at a rate of 4 tablets/day. Sodium sulfite is used for dechlorination at a rate of 10 tablets/day. Sodium carbonate is used for pH control at a rated 5 bls/day. Aluminum sulfate is used for settling at a 5 bls/day.

Industrial/Commercial Users:

The permit application indicated there are no commercial or industrial contributors to the treatment plant.

Biosolids:

The total sewage sludge/biosolids production within the facility for the previous year was 2.902 dry tons.

Compliance History	
Summary of DMRs:	A summary of past 12-month DMRs is presented on the pages 4-5.
Summary of Inspections:	<p>2/02/23: Mr. Hoy, DEP WQS, conducted a compliance evaluation inspection. There were violations noted during inspection. The field test results were within permit limits. Recommendations were evaluating the influent screening process, since failure to properly screen out rags and debris contributes to pump malfunction and having a dumpster present at the facility to dispose of screenings and other facility wastes.</p> <p>4/30/21: Mr. Bettinger, DEP WQS, conducted an administrative inspection to follow up with the facility regarding reported effluent violations. There were no violations noted during inspection. The cause of the TSS exceedance is unclear at this time, but the facility is closely monitoring the effluent.</p>
Other Comments:	<p>There are 3 violations against the permittee or applicant.</p> <ul style="list-style-type: none"> - 2/2/2023: two violations such as 1. Failure to retain records required by the permit. 2. Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance. - 1/5/2024: one violation: failure to submit NPDES renewal application at least 180 days prior to expiration or later approved date.

Compliance History

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

Parameter	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23
Flow (MGD) Average Monthly	0.0099	0.0093	0.0124	0.0113	0.0095	0.0089	0.0096	0.0080	0.0089	0.0102	0.0118	0.0088
Flow (MGD) Daily Maximum	0.0186	0.0286	0.0229	0.0210	0.0165	0.0181	0.0161	0.0127	0.0125	0.0172	0.0300	0.0116
pH (S.U.) Instantaneous Minimum	8.09	8.11	7.78	7.80	7.89	7.85	7.91	7.57	7.46	7.28	7.31	7.68
pH (S.U.) Instantaneous Maximum	8.61	8.56	8.55	8.59	8.49	8.40	8.31	8.37	8.39	8.57	8.27	8.51
DO (mg/L) Instantaneous Minimum	10.1	10.4	10.2	10.1	9.8	8.5	8.7	8.1	8.1	8.7	9.5	9.1
TRC (mg/L) Average Monthly	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.003	0.02	0.02	0.01	0.03
CBOD5 (mg/L) Average Monthly	< 3.10	< 2.4	3.1	< 2.4	4.3	< 2.4	< 2.4	< 4.10	< 3.0	< 4.65	4.1	< 2.65
TSS (mg/L) Average Monthly	11.0	6.0	10.5	4.0	3.0	2.5	4.0	4.0	11	10.0	< 7.0	< 3.5
Fecal Coliform (No./100 ml) Average Monthly	74	8	333	3	< 4	< 2	51	7	16	< 8	18	15
Fecal Coliform (No./100 ml) Instantaneous Maximum	104	29	517	11	16	5	57	28	18	62	23	52.9
Nitrate-Nitrite (lbs/day) Annual Average				< 3.45								
Nitrate-Nitrite (mg/L) Annual Average				< 50.40								
Total Nitrogen (lbs/day) Annual Average				< 3.48								
Total Nitrogen (mg/L) Annual Average				< 50.90								
Ammonia (mg/L) Average Monthly	0.35	1.66	< 0.14	< 0.17	< 0.40	< 0.11	< 0.10	< 0.10	< 0.10	< 0.22	0.29	< 0.22
TKN (lbs/day) Annual Average				< 0.03								

NPDES Permit Fact Sheet
Summit Ridge STP

NPDES Permit No. PA0088277

TKN (mg/L) Annual Average				< 0.50								
Total Phosphorus (lbs/day) Annual Average				0.16								
Total Phosphorus (mg/L) Annual Average				2.30								

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.02555</u>
Latitude <u>39° 51' 38.00"</u>	Longitude <u>-76° 58' 60.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

- * Discharge pH = 7.0 (Default)
- * Discharge Temperature = 20°C (Default)
- * Stream pH = 7.0 (Default)
- * Stream Temperature = 20°C (Default)
- * Background NH₃-N = 0 mg/L (Default)

The screenshot shows the 'Effluent Limitations' tab in the WQM 7.0 software. The main window displays a table with the following data:

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	4.12	8.24	
Dissolved Oxygen			5

At the top of the window, there are fields for RMI (2.05), Discharge Name (Summit Ridge), Permit Number (PA0088277), and Disc Flow (0.0256). The interface includes a search bar at the bottom with 'No Filter' selected and a 'Search' button. Navigation buttons for 'Print', '< Back', 'Next >', 'Archive', and 'Cancel' are also present.

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 4.12 mg/L as a monthly average and 8.24 mg/L instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects at the point of discharge. However, the existing limits of 2.5 mg/L monthly average & 5.0 mg/L IMAX are more stringent and will remain in the proposed permit. Per anti-backsliding policy, the existing winter average monthly limit of 75 mg/L & IMAX limit of 15.0 mg/L will remain in place. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing permit 20.0 mg/L as AML, & 50.0 mg/L as IMAX will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has typically been achieving concentrations below this limit.

Dissolved Oxygen (D.O.):

The D.O. goal is 6.0 mg/L. However, a minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be replaced in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BCW-PMT-033, version 2.0 revised February 5, 2024, and has been applied to other point source dischargers throughout the state.

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

Total Suspended Solids (TSS):

The existing technology-based limits of 30.0 mg/L average monthly, and 60.0 mg/L IMAX will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Total Phosphorus:

The existing permit reporting the average monthly TP concentration & mass will remain in the proposed permit.

Stormwater:

There is no known stormwater outfall associated with this facility

Chesapeake Bay Strategy:

Phase 2 WIP identifies Cassville WWTP as a non-significant Phase 5 facility. DEP's SOP mentioned that for facilities with design flows >0.002 MGD and <0.2 MGD will include monitoring, at a minimum, for Total Nitrogen and Total Phosphorus, with a monitoring frequency specified in DEP's technical guidance. Therefore, 1/year TN species (such as Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, and Total Nitrogen). The yearly calculation "report" for Nitrate-Nitrite, TKN, & TN will remain in the proposed permit.

Toxics

This is a minor sewage facility receiving domestic wastewater only and the current application does not require sampling of toxic pollutants (or heavy metals) for those facilities with design flows less than 0.1 MGD. Therefore, no reasonable potential analysis for toxic pollutants has been performed for this permit renewal.

Total Residual Chlorine (TRC):

Based on the attached TRC Excel spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), the facility's

discharge must meet a monthly average limit of 0.138 mg/L and an instantaneous maximum limit of 0.45 mg/L. These limits are more stringent and will be replaced in the proposed permit.

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.035	= Q stream (cfs)	0.5	= CV Daily		
0.0256	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)		
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.301		1.3.2.iii	WLA_cfc = 0.286
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.112		5.1d	LTA_cfc = 0.166
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.138		AFC	
		INST MAX LIMIT (mg/l) = 0.451			
WLA_afc	(.019/e ^(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e ^(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_afc	EXP((0.5*LN(cvh ² +1))-2.326*LN(cvh ² +1) ^{0.5})				
LTA_afc	wla_afc*LTAMULT_afc				
WLA_cfc	(.011/e ^(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e ^(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_cfc	EXP((0.5*LN(cvd ² /no_samples+1))-2.326*LN(cvd ² /no_samples+1) ^{0.5})				
LTA_cfc	wla_cfc*LTAMULT_cfc				
AML_MULT	EXP(2.326*LN((cvd ² /no_samples+1) ^{0.5})-0.5*LN(cvd ² /no_samples+1))				
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)				

WETT:

Minor facilities and facilities without a formal EPA approved pretreatment program are exempted from WETT.

Anti-Backsliding:

The proposed limits are at least as stringent as are in existing permit; therefore, anti-backsliding is not applicable

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

WQM 7.0:

The following data were used in the attached computer model (WQM 7.0) of the stream:

- * Discharge pH = 7.0 (Default)
- * Discharge Temperature = 25°C (Default)
- * Stream pH = 7.0 (Default)
- * Stream Temperature = 20°C (Default)
- * Background NH₃-N = 0 mg/L (Default)

Node 1: Outfall 001 UNT to Beaver Creek (08768)

- Elevation: 645 ft (USGS National Map Viewer)
- Drainage Area: 0.69 mi² (USGS PA StreamStats)
- River Mile Index: 2.05 (PA DEP eMapPA)
- Low Flow Yield: 0.05 cfs/mi²
- Discharge Flow: 0.0256 MGD (NPDES PA0088277 Application)

Node 2: Just after confluence of Beaver Creek (08760)

- Elevation: 488 ft (USGS National Map Viewer)
- Drainage Area: 2.91 mi² (USGS PA StreamStats)
- River Mile Index: 0.001 (PA DEP eMapPA)
- Low Flow Yield: 0.05 cfs/mi²
- Discharge Flow: 0.000 MGD

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation **Effluent Limitations**

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
2.05	Summit Ridge	PA0088277	0.0256

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25	8.24	5
NH3-N	4.12	8.24	5
Dissolved Oxygen	5	8.24	5

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name
07F	0760	Trib 00760 to Beaver Creek

RMI	Name	Permit Number	Disc. Flow (mgd)	Parameter	CFL Limit 30-day Ave. (mg/L)	Dfl. Limit Maximum (mg/L)	CFL Limit Minimum (mg/L)
2.050	Summit Ridge	PA0088277	0.024	CBDOS	25		
				NH4-N	4.12	0.24	
				Dissolved Oxygen			5

Thursday, May 2, 2024 Version 1.1 Page 1 of 1

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
07F	0760	Trib 00760 to Beaver Creek

NHS-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.050	Summit Ridge	16.76	26.1	16.76	26.1	0	0

NHS-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.050	Summit Ridge	1.89	4.12	1.89	4.12	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBDOS		NH4-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.05	Summit Ridge	25	25	4.12	4.12	5	5	0	0

Thursday, May 2, 2024 Version 1.1 Page 1 of 1

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name
07F	0760	Trib 00760 to Beaver Creek

RMI	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
2.050	0.026	20.000	7.000

Reach Width (ft)	Reach Depth (ft)	Reach W:Q Ratio	Reach Velocity (ft/s)
3.839	0.333	11.533	0.059

Reach CBOD5 (mg/L)	Reach K1 (1/day)	Reach NH4-N (mg/L)	Reach NH4-N (mg/L)
14.28	0.911	2.00	0.700

Reach DO (mg/L)	Reach K1 (1/day)	K1 Equation	Reach DO Goal (mg/L)
6.510	24.645	Owens	5

Reach Travel Time (days)	Subreach Results
2.159	Travel Time
	CBOD5 (mg/L)
	NH4-N (mg/L)
	D.O. (mg/L)
	0.216 11.74 1.89 0.22
	0.432 9.64 1.63 0.24
	0.648 7.82 1.40 0.24
	0.864 6.51 1.20 0.24
	1.080 5.35 1.03 0.24
	1.296 4.39 0.89 0.24
	1.511 3.61 0.76 0.24
	1.727 2.86 0.66 0.24
	1.943 2.43 0.57 0.24
	2.159 2.00 0.49 0.24

Thursday, May 2, 2024 Version 1.1 Page 1 of 1

WQM 7.0 Modeling Specifications

Parameter	Value	Use Inputted 0-10 and Q50-10 Flows
WLA Method	EMPR	<input type="checkbox"/>
Q1-10Q74:Q Ratio	0.64	<input type="checkbox"/>
Q50-10Q7:10 Ratio	1.36	<input type="checkbox"/>
D.O. Saturation	90.0%	<input checked="" type="checkbox"/>
D.O. Goal	5	<input checked="" type="checkbox"/>
		Use Inputted W:D Ratio <input type="checkbox"/>
		Use Inputted Reach Travel Times <input type="checkbox"/>
		Temperature Adjust K1 <input checked="" type="checkbox"/>
		Use Balanced Technology <input checked="" type="checkbox"/>

Thursday, May 2, 2024 Version 1.1 Page 1 of 1

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
OTF	8768	Trib 08768 to Beaver Creek										
R88	Stream Flow With (cfs)	PWS Flow (cfs)	Net Stream Flow (cfs)	Disc. Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	WD Ratio	Velocity (ft/s)	Reach Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
2.050	0.03	0.00	0.03	0.036	0.01451	.333	3.84	11.53	0.06	2.158	20.00	7.00
Q1-10 Flow												
2.050	0.02	0.00	0.02	0.036	0.01451	NA	NA	NA	0.05	2.383	20.00	7.00
Q30-10 Flow												
2.050	0.05	0.00	0.05	0.036	0.01451	NA	NA	NA	0.06	1.980	20.00	7.00

Thursday May 2, 2024 Version 1.1 Page 1 of 1

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	R88	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
OTF	8768	Trib 08768 to Beaver Creek	2.050	64.500	0.68	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (ft/yr)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (ft/s)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.050	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10	0.00	0.00	0.00	0.000	0.000							
Q30-10	0.00	0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc. Flow (mgd)	Permitted Disc. Flow (mgd)	Design Disc. Flow (mgd)	Reserve Factor	Disc. Temp (°C)	Disc. pH
Summit Ridge	PA0088277	0.0256	0.0256	0.0256	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib Conc. (mg/L)	Stream Conc. (mg/L)	Fate Coef. (1/day)
CBOD5	25.00	2.00	0.00	1.00
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Thursday May 2, 2024 Version 1.1 Page 1 of 2

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	R88	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
OTF	8768	Trib 08768 to Beaver Creek	0.001	48.600	2.91	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (ft/yr)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (ft/s)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.00	0.00	0.000	0.000	0.0	0.00	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10	0.00	0.00	0.000	0.000								
Q30-10	0.00	0.00	0.000	0.000								


Discharge Data

Name	Permit Number	Existing Disc. Flow (mgd)	Permitted Disc. Flow (mgd)	Design Disc. Flow (mgd)	Reserve Factor	Disc. Temp (°C)	Disc. pH
Summit Ridge	PA0088277	0.0000	0.0000	0.0000	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib Conc. (mg/L)	Stream Conc. (mg/L)	Fate Coef. (1/day)
CBOD5	25.00	2.00	0.00	1.00
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Thursday May 2, 2024 Version 1.1 Page 2 of 2



USGS StreamStats
science for a changing world

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS
Accessibility FOIA Privacy Policy & Notices

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	6.1233	degrees
DRNAREA	Area that drains to a point on a stream	0.69	square miles
ROCKDEP	Depth to rock	4	feet
URBAN	Percentage of basin with urban development	0.1521	percent

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.69	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	6.1233	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4	feet	4.13	5.21
URBAN	Percent Urban	0.1521	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0914	ft ³ /s
30 Day 2 Year Low Flow	0.126	ft ³ /s
7 Day 10 Year Low Flow	0.0352	ft ³ /s
30 Day 10 Year Low Flow	0.0521	ft ³ /s
90 Day 10 Year Low Flow	0.0836	ft ³ /s

Batch Processor Report About ? Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

The screenshot displays the USGS StreamStats web application interface. The top left shows the USGS logo and 'StreamStats' text. Below it, navigation options include 'SELECT A STATE / REGION' (Pennsylvania), 'IDENTIFY A STUDY AREA' (Basin Delineated), and 'SELECT SCENARIOS'. A 'BUILD A REPORT' button is visible, along with a 'Report Built' indicator. A sidebar on the left contains instructions for Step 1 and a 'Show Basin Characteristics' section with checkboxes for 'Basin Characteristics Report' and 'Scenario Flow Reports', and an 'Open Report' button. The main content area is divided into two sections: 'Basin Characteristics' and 'Low-Flow Statistics'. The 'Basin Characteristics' section contains a table with the following data:

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	6.0373	degrees
DRNAREA	Area that drains to a point on a stream	2.91	square miles
ROCKDEP	Depth to rock	4.7	feet
URBAN	Percentage of basin with urban development	0.525	percent

The 'Low-Flow Statistics' section includes a table for 'Low-Flow Statistics Parameters [Low Flow Region 1]':

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	2.91	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	6.0373	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.7	feet	4.13	5.21
URBAN	Percent Urban	0.525	percent	0	89

Below this table is a 'Low-Flow Statistics Disclaimers [Low Flow Region 1]' section with a yellow warning box: 'One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.' The final section is the 'Low-Flow Statistics Flow Report [Low Flow Region 1]':

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.768	ft ³ /s
30 Day 2 Year Low Flow	0.952	ft ³ /s
7 Day 10 Year Low Flow	0.366	ft ³ /s
30 Day 10 Year Low Flow	0.472	ft ³ /s
90 Day 10 Year Low Flow	0.664	ft ³ /s

The interface also features a map on the right side showing the study area with a 'Layers' panel on the right edge.

Existing Effluent Limitations and Monitoring Requirements

Outfall 001.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.2	XXX	0.7	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.5	XXX	5.0	2/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	7.5	XXX	15.0	2/month	24-Hr Composite
Nitrate-Nitrite	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
TKN	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.14	XXX	0.45	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.5	XXX	5.0	2/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	7.5	XXX	15.0	2/month	24-Hr Composite
Nitrate-Nitrite	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
TKN	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite

Compliance Sampling Location:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input checked="" type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [redacted]