



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0088439

APS ID

636767

Authorization ID

1487301

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Applicant and Facility Information

Applicant Name **School House Village Wastewater Division**
Applicant Address **4774 Olde Pump Street, Unit 26,
PO Box 128
Walnut Creek, OH 44687**
Applicant Contact **Lee Mummau**
Applicant Phone **(301) 831-7624**
Client ID **261657**
Ch 94 Load Status **Not Overloaded**
Connection Status **No Limitations**
Date Application Received **June 3, 2024**
Date Application Accepted **June 5, 2024**
Purpose of Application **NPDES permit renewal.**

Facility Name

School House Village

Facility Address

23 Kennys Lane

Facility Contact

Lee Mummau

Facility Phone

(301) 831-7624

Site ID

532866

Municipality

Licking Creek Township

County

Fulton

EPA Waived?

Yes

If No, Reason

Summary of Review

School House Village Wastewater Division (Authority/Permittee), applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The permit was reissued on November 15, 2019 and became effective on December 1, 2019. The permit expires on November 30, 2024.

The average annual design flow and hydraulic design capacity is 0.01 MGD. The treated effluent is discharged to Sindeldecker Branch. The 2024 application states that there are no industrial users.

WQM Part II Permit No. 2900401 original & 2900401 T-1 ownership transfer was issued on 10/25/2000 & 3/20/2008.

Sludge use and disposal description and location(s): N/A because sludge is hauled by County Septic contractor.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the proposed permit. The summer NH₃-N monthly average limit changed to 14.0 mg/L in the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

| Approve | Deny | Signatures | Date |
|---------|------|--|--------------------|
| X | | <i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist | September 20, 2024 |
| X | | <i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager | September 30, 2024 |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|---------------------------|------------------------------|------------------------|
| Outfall No. | 001 | Design Flow (MGD) | 0.01 |
| Latitude | 39° 59' 44.56" | Longitude | -78° 5' 43.59" |
| Quad Name | Meadow Grounds | Quad Code | 1921 |
| Wastewater Description: | Sewage Effluent | | |
| Receiving Waters | Sindeldecker Branch (CWF) | Stream Code | 60751 |
| NHD Com ID | 49478724 | RMI | 3.26 |
| Drainage Area | 4.16 mi. ² | Yield (cfs/mi ²) | 0.018 |
| Q ₇₋₁₀ Flow (cfs) | 0.076 | Q ₇₋₁₀ Basis | USGS StreamStats |
| Elevation (ft) | 905.21 | Slope (ft/ft) | |
| Watershed No. | 13-B | Chapter 93 Class. | CWF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Attaining Use(s) | | |
| Cause(s) of Impairment | | | |
| Source(s) of Impairment | | | |
| TMDL Status | Name | | |
| Nearest Downstream Public Water Supply Intake | Hagerstown, MD | | |
| PWS Waters | Potomac River | Flow at Intake (cfs) | |
| PWS RMI | | Distance from Outfall (mi) | Approximate 75.0 miles |

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Sindeldecker Branch at RMI 3.26. The drainage area upstream of the point of discharge is 4.16 sq.mi, according to USGS PA StreamStats (<https://water.usgs.gov/osw/streamstats/pennsylvania.html>).

Streamflow

According to StreamStats, the discharge point on Sindeldecker Branch has a Q₇₋₁₀ of 0.076 cfs and a drainage area of 4.16 mi.², which results in a Q₇₋₁₀ low flow yield of 0.018 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 0.076 \text{ cfs} \\
 \text{Low Flow Yield} &= 0.076 \text{ cfs} / 4.16 \text{ mi.}^2 = 0.018 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 0.076 \text{ cfs} = 0.10 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.076 \text{ cfs} = 0.049 \text{ cfs}
 \end{aligned}$$

Sindeldecker Branch

25 Pa Code §93.9z classified the Sindeldecker Branch basin as cold-water fishes and migratory fishes. No Class A Wild Trout Fishery is impacted by this discharge. DEP's 2024 integrated water quality report indicates that the discharge is located in a stream segment listed as attaining use(s).

PWS Intake

The nearest downstream public water supply is Hagerstown, MD on Potomac River. It is approximately 75.0 miles downstream of the discharge. Due to the distance, dilution, and effluent limits the discharge is not expected to impact the water supply.

| Treatment Facility Summary | | | | |
|---|-----------------------------------|----------------------|------------------------------|-------------------------------|
| Treatment Facility Name: School House Village - WWTP | | | | |
| WQM Permit No. | | Issuance Date | | |
| 2900401 | | 10/25/2000 | | |
| 2900401 T-1 | | 3/20/2008 | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Extended Aeration | Chlorine With Dechlorination | 0.01 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.01 | | Not Overloaded | Aerobic Digestion | Other WWTP |

Changes Since Last Permit Issuance:

Other Comments:

Per DEP's recent visit to the site on February 16, 2023, the treatment facility consists of the following units:

- One bar screen
- One equalization tank
- Two aeration tanks
- One clarifier
- One chlorine contact tank
- One dechlorination tank
- One post aeration tank
- One sludge holding tank
- Two blowers

Plant uses chlorine and dechlorination tablets for disinfection & reduce chlorine at the effluent discharge.

Industrial/Commercial Users:

There are no industrial/commercial users contributing to this treatment plant.

Biosolids Management:

Liquid biosolids are hauled off site by County Septic.

| Compliance History | |
|--------------------------------|--|
| Summary of DMRs: | A summary of past 12-month DMRs is presented on the next page. |
| Summary of Inspections: | <p>3/14/24: Mr. Clark, DEP WQS, conducted a routine compliance inspection. The field test results were within permit limits. There were violations noted during inspection. Recommendations were to make repairs to the air piping and valves to allow for proper air distribution and adjustments to all treatment tanks, perform process control testing of mixed liquor, and reseed plant if necessary.</p> <p>2/16/23: Mr. Clark, DEP WQS, conducted a compliance evaluation inspection. The field test results were within permit limits. The cooling water looked clear. No sludge has been removed from the treatment plant since 2019.</p> |
| Other Comments: | <p>There were two violations against the permittee or applicant.</p> <ul style="list-style-type: none"> - 1/28/2022: Biosolids – permittee violated the record keeping requirements. - 3/14/2024: NPDES- Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance. |

Compliance History

DMR Data for Outfall 001 (from August 1, 2023 to July 31, 2024)

| Parameter | JUL-24 | JUN-24 | MAY-24 | APR-24 | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 | OCT-23 | SEP-23 | AUG-23 |
|--|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Flow (MGD) Average Monthly | 0.00169 8 | 0.00226 3 | 0.00213 2 | 0.00295 4 | 0.00177 6 | 0.00152 9 | 0.00167 6 | 0.00150 2 | 0.00153 0 | 0.00150 2 | 0.00150 2 | 0.00150 2 |
| Flow (MGD) Daily Maximum | 0.00425 | 0.00537 0 | 0.00518 | 0.00489 | 0.00912 | 0.00348 | 0.00554 0 | 0.00451 0 | 0.00485 | 0.00451 0 | 0.00451 0 | 0.00451 0 |
| pH (S.U.) Daily Minimum | 6.60 | 6.40 | 7.0 | 7.04 | 7.20 | 8.0 | 6.76 | 6.93 | 6.68 | 6.59 | 6.46 | 6.54 |
| pH (S.U.) Daily Maximum | 7.30 | 7.60 | 7.70 | 7.51 | 8.10 | 8.3 | 8.60 | 7.69 | 7.69 | 6.98 | 7.03 | 7.94 |
| DO (mg/L) Daily Minimum | 6.88 | 6.10 | 8.0 | 8.11 | 8.21 | 10.4 | 10.11 | 9.48 | 6.45 | 8.69 | 7.97 | 7.01 |
| TRC (mg/L) Average Monthly | 0.10 | 0.10 | 0.13 | 0.05 | 0.07 | 0.14 | 0.22 | 0.09 | 0.06 | 0.06 | 0.04 | 0.07 |
| TRC (mg/L) Instantaneous Maximum | 0.32 | 0.26 | 0.80 | 0.07 | 0.13 | 0.20 | 0.42 | 0.13 | 0.11 | 0.09 | 0.07 | 0.13 |
| CBOD5 (mg/L) Average Monthly | 2.39 | 6.42 | 2.58 | 3.26 | 7.16 | 4.62 | 3.41 | 2.60 | 2.0 | 3.0 | 2.48 | 2.0 |
| TSS (mg/L) Average Monthly | 2.75 | 3.0 | 2.75 | 2.00 | 3.75 | 3.75 | 2.50 | 5.50 | 4.50 | 4.25 | 3.25 | 7.50 |
| Fecal Coliform (No./100 ml) Geometric Mean | 6.0 | 6.0 | 3.0 | 22 | 9.0 | 3.0 | 1.0 | 3.0 | 3.0 | 26 | 1.0 | 3.0 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 18.0 | 37.0 | 7.0 | 52 | 85.0 | 4.0 | 1.0 | 7.0 | 12.0 | 62 | 1.0 | 3.0 |
| Nitrate-Nitrite (mg/L) Average Quarterly | | 10.90 | | | 9.30 | | | 12.40 | | | 10.20 | |
| Nitrate-Nitrite (lbs) Total Quarterly | | 6.68 | | | 1.382 | | | 3.08 | | | 4.333 | |
| Total Nitrogen (mg/L) Average Quarterly | | 12.49 | | | 10.00 | | | 12.90 | | | 11.20 | |
| Total Nitrogen (lbs) Total Quarterly | | 7.66 | | | 1.49 | | | 3.21 | | | 4.76 | |
| Total Nitrogen (lbs) Total Annual | | | | | | | | 11.0 | | | | |
| Ammonia (mg/L) Average Monthly | 0.50 | 5.35 | 0.61 | 0.50 | 0.50 | 0.50 | 1.41 | 0.50 | < 0.50 | 0.50 | 0.50 | 0.50 |

NPDES Permit Fact Sheet**School House Village****NPDES Permit No. PA0088439**

| | | | | | | | | | | | | |
|-------------------------|--|------|--|--|--------|--|--|--------|--|--|---------|--|
| Ammonia (mg/L) | | | | | | | | | | | | |
| Average Quarterly | | 3.81 | | | 1.41 | | | 0.50 | | | 0.50 | |
| Ammonia (lbs) | | | | | | | | | | | | |
| Total Quarterly | | 1.08 | | | 0.1654 | | | 0.0931 | | | 0.48522 | |
| Ammonia (lbs) | | | | | | | | 15.0 | | | | |
| Total Annual | | | | | | | | | | | | |
| TKN (mg/L) | | | | | 0.70 | | | 0.50 | | | 1.0 | |
| Average Quarterly | | 1.59 | | | | | | | | | | |
| TKN (lbs) | | | | | 0.10 | | | 0.12 | | | 0.42 | |
| Total Phosphorus (mg/L) | | | | | | | | | | | | |
| Average Quarterly | | 0.44 | | | 0.15 | | | 0.29 | | | 0.32 | |
| Total Phosphorus (lbs) | | | | | 0.02 | | | 0.07 | | | 0.13 | |
| Total Phosphorus (lbs) | | | | | | | | 1.0 | | | | |
| Total Annual | | | | | | | | | | | | |

Existing Effluent Limitations and Monitoring Requirements

Outfall 001.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------------|-----------------------|---------------------|------------------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Daily Min | XXX | 9.0 Daily Max | XXX | 1/day | Grab |
| DO | XXX | XXX | 5.0 Daily Min | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD5 | XXX | XXX | XXX | 25.0 | XXX | 50 | 2/month | 8-Hr Composite |
| TSS | XXX | XXX | XXX | 30.0 | XXX | 60 | 2/month | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 2/month | Grab |
| Ammonia Nov 1 - Apr 30 | XXX | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Ammonia May 1 - Oct 31 | XXX | XXX | XXX | 15.0 | XXX | XXX | 2/month | 8-Hr Composite |
| Ammonia | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 8-Hr Composite |
| Ammonia (lbs) | Report Total Qrtly | XXX | XXX | XXX | XXX | XXX | 1/quarter | Calculation |
| Ammonia (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| TKN | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 8-Hr Composite |
| TKN (lbs) | Report Total Qrtly | XXX | XXX | XXX | XXX | XXX | 1/quarter | Calculation |
| Nitrate-Nitrite | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 8-Hr Composite |
| Nitrate-Nitrite (lbs) | Report Total Qrtly | XXX | XXX | XXX | XXX | XXX | 1/quarter | Calculation |

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------|-------------------------------------|---------------------|-----------------------|------------------|---------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Total Nitrogen | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | Calculation |
| Total Nitrogen (lbs) | Report Total Qrtly | XXX | XXX | XXX | XXX | XXX | 1/quarter | Calculation |
| Total Nitrogen (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Total Phosphorus | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 8-Hr Composite |
| Total Phosphorus (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Total Phosphorus (lbs) | Report Total Qrtly | XXX | XXX | XXX | XXX | XXX | 1/quarter | Calculation |

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 59' 44.56"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.01
Longitude -78° 5' 43.59"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Comments: [redacted]

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

* Discharge pH = 7.0 (Default)
 * Discharge Temperature = 20°C (Default)
 * Stream pH = 7.0 (Default)
 * Stream Temperature = 20°C (Default)
 * Background NH₃-N = 0 mg/L (Default)

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

| RMI | Discharge Name | Permit Number | Disc Flow (mgd) |
|------------------|--------------------------------------|-------------------------------|-------------------------------|
| 3.26 | School House | PA.0088439 | 0.0100 |
| Parameter | Effluent Limit 30 Day Average (mg/L) | Effluent Limit Maximum (mg/L) | Effluent Limit Minimum (mg/L) |
| CBOD5 | 25 | | |
| NH3-N | 14.31 | 28.62 | |
| Dissolved Oxygen | | | 5 |

Record: 1 of 1 < Back Next > No Filter Search

Print Archive Cancel

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 14.31 mg/L as a monthly average and 28.62 mg/L instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects at the point of discharge. Therefore, the existing summer limits of 15.0 mg/L monthly average will be replaced with 14.0 mg/L because it is more stringent. The existing winter monitoring and reporting will remain in place. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Minimum monitoring frequency will be 2/month and sampling type will be 8-hr composite.

Dissolved Oxygen (D.O.):

The minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BCW-PMT-033, version 2.0 revised February 5, 2024, and has been applied to other point source dischargers throughout the state.

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing permit 25.0 mg/L as AML will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has typically been achieving concentrations below this limit. The minimum monitoring frequency will remain the same as 2/month.

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

Total Suspended Solids (TSS):

The existing technology-based limits of 30.0 mg/L average monthly, and 60.0 mg/L IMAX will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Toxics:

Any minor sewage facilities designed less than 0.1 MGD are not required to collect samples for toxics.

Total Phosphorus:

The receiving stream is in Potomac river basin, which is outside of Lower Susquehanna River Basin. Therefore, per DEP guidance No. 391-2000-018, no local phosphorus limits will be applied to this facility at this time.

Stormwater:

There is no known stormwater outfall associated with this facility.

Total Residual Chlorine (TRC):

Based on the attached TRC Excel spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), the facility's discharge must meet a monthly average limit of 0.5 mg/L and an instantaneous maximum limit of 1.6 mg/L. These limits are the same as in existing permit and will be carried over. The minimum monitoring frequency is 1/day.

| TRC EVALUATION | | | | |
|---|--------------------------------------|--|-----------|---------------------|
| Input appropriate values in A3:A9 and D3:D9 | | | | |
| 0.076 | = Q stream (cfs) | | | |
| 0.01 | = Q discharge (MGD) | | | |
| 30 | = no. samples | | | |
| 0.3 | = Chlorine Demand of Stream | | | |
| 0 | = Chlorine Demand of Discharge | | | |
| 0.5 | = BAT/BPJ Value | | | |
| 0 | = % Factor of Safety (FOS) | | | |
| 0.5 | = CV Daily | | | |
| 0.5 | = CV Hourly | | | |
| 1 | = AFC_Partial Mix Factor | | | |
| 1 | = CFC_Partial Mix Factor | | | |
| 15 | = AFC_Criteria Compliance Time (min) | | | |
| 720 | = CFC_Criteria Compliance Time (min) | | | |
| | = Decay Coefficient (K) | | | |
| Source | Reference | AFC Calculations | Reference | CFC Calculations |
| TRC | 1.3.2.iii | WLA_afc = 1.586 | 1.3.2.iii | WLA_cfc = 1.539 |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | 5.1c | LTAMULT_cfc = 0.581 |
| PENTOXSD TRG | 5.1b | LTA_afc = 0.591 | 5.1d | LTA_cfc = 0.895 |
| Source | | Effluent Limit Calculations | | |
| PENTOXSD TRG | 5.1f | AML MULT = 1.231 | | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | | BAT/BPJ |
| | | INST MAX LIMIT (mg/l) = 1.635 | | |
| WLA_afc | | (.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) | | |
| LTAMULT_afc | | EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5) | | |
| LTA_afc | | wla_afc*LTAMULT_afc | | |
| WLA_cfc | | (.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) | | |
| LTAMULT_cfc | | EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5) | | |
| LTA_cfc | | wla_cfc*LTAMULT_cfc | | |
| AML MULT | | EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1)) | | |
| AVG MON LIMIT | | MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT) | | |
| INST MAX LIMIT | | 1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc) | | |

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Chesapeake Bay TMDL & TN/TP SOP Monitoring Requirement

The discharge is located within the Chesapeake Bay watershed and is considered under the Supplement to Phase II Watershed Implementation Plan a Phase 5 facility designed to treat between 0.002 MGD and 0.2 MGD. The requirement to monitor for Total Phosphorus and Total Nitrogen is recommended. This approach is also consistent with DEP's Standard Operating Procedure (SOP) no. BCW-PMT-033 in which the SOP recommends a routine monitoring of Total Phosphorus and Total Nitrogen for any sewage facilities greater than 0.002 MGD regardless of the discharge location. The facility has already been monitoring for Total Phosphorus; no change is therefore recommended for Total Phosphorus. For Total Nitrogen, 1/quarter 8-hr composite monitoring is recommended for all TN species.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-Degradation Requirements

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as permit requirements specified in the existing permit renewal in accordance with 40 CFR §122.44(l)(1).

WETT

Minor facilities and facilities without a formal EPA approved pretreatment program are exempted from WETT.

Anti-Backsliding

The proposed limits are at least as stringent as are in existing permit; therefore, anti-backsliding is not applicable.

School House Village

WQM 7.0:

The following data were used in the attached computer model (WQM 7.0) of the stream:


- Discharge pH 7.0 (Default)
- Discharge Temperature 20°C (Default per 391-2000-013)
- Stream pH 7.0 (391-2000-007)
- Stream Temperature 20°C (Default per 391-2000-013)

Node 1: Outfall 001 at Sindeldecker Branch (60751)

Elevation: 905.21 ft. (USGS National Map)
 Drainage Area: 4.16 mi² (USGS StreamStats)
 River Mile Index: 3.26 (PA DEP eMapPA)
 Low Flow Yield: 0.018 cfs/mi²
 Discharge Flow: 0.01 MGD

Node 2: At the confluence with Sipes Branch (60753)

Elevation: 804.53 ft (USGS National Map)
 Drainage Area: 5.38 mi² (StreamStats)
 River Mile Index: 0.001 (PA DEP eMapPA)
 Low Flow Yield: 0.018 cfs/mi²
 Discharge Flow: 0.00 MGD



NPDES Permit Fact Sheet

School House Village

NPDES Permit No. PA0088439

USGS StreamStats

SELECT A STATE / REGION Pennsylvania

IDENTIFY A STUDY AREA Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the 'Build Report' button.

Show Basin Characteristics

Select available reports to display:

- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|-------|-----------------------|
| CARBON | Percentage of area of carbonate rock | 0 | percent |
| DRNAREA | Area that drains to a point on a stream | 4.16 | square miles |
| PRECIP | Mean Annual Precipitation | 39 | inches |
| ROCKDEP | Depth to rock | 4.1 | feet |
| STRDEN | Stream Density -- total length of streams divided by drainage area | 2.41 | miles per square mile |

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| DRNAREA | Drainage Area | 4.16 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 39 | inches | 35 | 50.4 |
| STRDEN | Stream Density | 2.41 | miles per square mile | 0.51 | 3.1 |
| ROCKDEP | Depth to Rock | 4.1 | feet | 3.32 | 5.65 |
| CARBON | Percent Carbonate | 0 | percent | 0 | 99 |

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

| Statistic | Value | Unit |
|-------------------------|-------|--------|
| 7 Day 2 Year Low Flow | 0.205 | ft^3/s |
| 30 Day 2 Year Low Flow | 0.304 | ft^3/s |
| 7 Day 10 Year Low Flow | 0.076 | ft^3/s |
| 30 Day 10 Year Low Flow | 0.114 | ft^3/s |
| 90 Day 10 Year Low Flow | 0.207 | ft^3/s |



USGS StreamStats

SELECT A STATE / REGION Pennsylvania

IDENTIFY A STUDY AREA Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the 'Build Report' button.

Show Basin Characteristics

Select available reports to display:

- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Zoom Level: Map Scale: Lat: 40.000000 Long: -77.000000

Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|-------|-----------------------|
| CARBON | Percentage of area of carbonate rock | 0 | percent |
| DRNAREA | Area that drains to a point on a stream | 5.38 | square miles |
| PRECIP | Mean Annual Precipitation | 39 | inches |
| ROCKDEP | Depth to rock | 3.9 | feet |
| STRDEN | Stream Density -- total length of streams divided by drainage area | 2.24 | miles per square mile |

Low-Flow Statistics


Low-Flow Statistics Parameters [Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|-------|-----------------------|-----------|-----------|
| DRNAREA | Drainage Area | 5.38 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 39 | inches | 35 | 50.4 |
| STRDEN | Stream Density | 2.24 | miles per square mile | 0.51 | 3.1 |
| ROCKDEP | Depth to Rock | 3.9 | feet | 3.32 | 5.65 |
| CARBON | Percent Carbonate | 0 | percent | 0 | 99 |

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

| Statistic | Value | Unit | SE | ASEp |
|-------------------------|--------|--------|----|------|
| 7 Day 2 Year Low Flow | 0.265 | ft^3/s | 38 | 38 |
| 30 Day 2 Year Low Flow | 0.398 | ft^3/s | 33 | 33 |
| 7 Day 10 Year Low Flow | 0.0944 | ft^3/s | 51 | 51 |
| 30 Day 10 Year Low Flow | 0.146 | ft^3/s | 46 | 46 |
| 90 Day 10 Year Low Flow | 0.27 | ft^3/s | 36 | 36 |



NPDES Permit Fact Sheet
School House Village

NPDES Permit No. PA0088439

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

| RMI | Discharge Name | Permit Number | Disc. Flow (mgd) |
|------------------|--------------------------------------|-------------------------------|-------------------------------|
| 3.26 | School House | PA0088439 | 0.0100 |
| Parameter | Effluent Limit 30 Day Average (mg/L) | Effluent Limit Maximum (mg/L) | Effluent Limit Minimum (mg/L) |
| CBOD5 | 25 | | |
| NH3-N | 14.31 | 28.62 | |
| Dissolved Oxygen | | | 5 |

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

rptEffLimits

WQM 7.0 Effluent Limits

| SWP Basin | Stream Code | Stream Name | | | | | |
|-----------|--------------|---------------------|------------------|------------------|-------------------------------|--------------------------|---------------------------|
| 13B | 60731 | SINDELDECKER BRANCH | | | | | |
| RMI | Name | Permit Number | Disc. Flow (mgd) | Parameter | Eff. Limit 30-day Ave. (mg/L) | RH. Limit Maximum (mg/L) | Eff. Limit Minimum (mg/L) |
| 3260 | School House | PA0088439 | 0.010 | CBOD5 | 25 | | |
| | | | | NH3-N | 14.31 | 28.62 | |
| | | | | Dissolved Oxygen | | | 5 |

Tuesday, September 17, 2024 Version 1.1 Page 1 of 1

rpt_WLA

WQM 7.0 Wasteload Allocations

| SWP Basin | Stream Code | Stream Name | | | | | |
|------------------------------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 13B | 60731 | SINDELDECKER BRANCH | | | | | |
| NH3-N Acute Allocations | | | | | | | |
| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
| 3260 | School House | 16.76 | 50 | 16.76 | 50 | 0 | 0 |
| NH3-N Chronic Allocations | | | | | | | |
| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
| 3260 | School House | 1.89 | 14.31 | 1.89 | 14.31 | 0 | 0 |
| Dissolved Oxygen Allocations | | | | | | | |
| RMI | Discharge Name | CBOD5 | NH3-N | Dissolved Oxygen | Percent Reduction | | |
| 3260 | School House | 25 | 25 | 14.31 | 0 | | |

Tuesday, September 17, 2024 Version 1.1 Page 1 of 1

Page: 1 No Filter

NPDES Permit Fact Sheet
School House Village

NPDES Permit No. PA0088439

rptDOSim

WQM 7.0 D.O. Simulation

| SWP Basin | Stream Code | Stream Name |
|--------------------------|------------------|-----------------------|
| 13B | 60751 | SINDELDECKER BRANCH |
| Reach 1:000 | | |
| Reach W (ft) | Reach Depth (ft) | Reach W:Depth |
| 6,332 | 0.352 | 17,965 |
| Reach (ft/day) | Reach (ft/day) | Reach Velocity (ft/s) |
| 6.94 | 0.221 | 0.040 |
| Reach DO (mg/L) | Reach K (1/day) | Reach DO Saturation |
| 7.40 | 17.400 | 90.00% |
| Reach Travel Time (days) | TravTime (days) | D.O. (mg/L) |
| 4,900 | 5.35 | 8.24 |
| 0.964 | 4.78 | 8.24 |
| 1.476 | 4.28 | 8.24 |
| 1.988 | 3.78 | 8.24 |
| 2.400 | 3.45 | 8.24 |
| 2.852 | 3.09 | 8.24 |
| 3.444 | 2.77 | 8.24 |
| 3.856 | 2.45 | 8.24 |
| 4.208 | 2.23 | 8.24 |
| 4.820 | 2.00 | 8.24 |

Tuesday, September 17, 2024 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

| Parameters | Value | Notes |
|--------------------|--------|-------------------------------------|
| WLA Method | EMPR | Use Inputted Q1-10 and Q30-10 Flows |
| Q1-10:Q7-10 Ratio | 0.64 | Use Inputted W:D Ratio |
| Q30-10:Q7-10 Ratio | 1.36 | Temperature Adjust K |
| D.O. Saturation | 90.00% | Use Balanced Technology |
| D.O. Goal | 5 | |

Tuesday, September 17, 2024 Version 1.1 Page 1 of 1

rptHydro

WQM 7.0 Hydrodynamic Outputs

| SWP Basin | Stream Code | Stream Name | | | | | | | | | | |
|-------------|-------------------|--------------------------------|--------------------------|---------------------|------------------|------------|-----------|-----------------|-------------------|--------------------|-------------|------|
| 13B | 60751 | SINDELDECKER BRANCH | | | | | | | | | | |
| RM | Stream Flow (cfs) | PWS With Net Annual Flow (cfs) | Net Discharge Flow (cfs) | Reach Slope (ft/ft) | Reach Depth (ft) | Width (ft) | W:D Ratio | Velocity (ft/s) | Reach Time (days) | Analytic Temp (°C) | Analytic pH | |
| Q1-10 Flow | 3.260 | 0.07 | 0.07 | 0.155 | 0.00565 | .352 | 6.33 | 17.96 | 0.04 | 4.900 | 20.00 | 7.00 |
| Q1-10 Flow | 3.260 | 0.05 | 0.05 | 0.155 | 0.00565 | NA | NA | NA | 0.03 | 6.000 | 20.00 | 7.00 |
| Q30-10 Flow | 3.260 | 0.10 | 0.00 | 0.10 | 0.00565 | NA | NA | NA | 0.05 | 4.251 | 20.00 | 7.00 |

Tuesday, September 17, 2024 Version 1.1 Page 1 of 1

rptGeneral

Input Data WQM 7.0

| SWP Basin | Streams Code | Stream Name | RM | Elevation (ft) | Drainage Area (sq mi) | Slope (ft) | PWS Velocity (mg/d) | Apply FC |
|-----------|--------------|---------------------|-------|----------------|-----------------------|------------|---------------------|-------------------------------------|
| 13B | 60751 | SINDELDECKER BRANCH | 3.260 | 90.521 | 6.16 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfs) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Velocity (ft/s) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tribuary pH | Temp pH | Streams pH |
|--------------|-----------|-----------------|-------------------|---------------------|----------|----------------|----------------|-------------|---------|------------|
| Q1-10 | 0.018 | 0.00 | 0.0000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 |
| Q1-10 | 0.00 | 0.00 | 0.0000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 |
| Q30-10 | 0.00 | 0.00 | 0.0000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 |

Discharge Data

| Name | Permit Number | Existing Discharge Flow (mg/d) | Permitted Discharge Flow (mg/d) | Design Discharge Flow (mg/d) | Reserve Factor | Discharge Temp (°C) |
|--------------|---------------|--------------------------------|---------------------------------|------------------------------|----------------|---------------------|
| School House | PA0088439 | 0.0100 | 0.0100 | 0.0100 | 0.000 | 20.00 |

Parameter Data

| Parameter Name | Discharge Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Flow (1/day) |
|------------------|-----------------------|------------------|--------------------|--------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Tuesday, September 17, 2024 Version 1.1 Page 1 of 2

rptGeneral

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMS | Elevation | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (inpt) | Apply FC |
|-----------|-------------|---------------------|-------|-----------|-----------------------|---------------|-----------------------|-------------------------------------|
| 13B | 60751 | SINDELDECKER BRANCH | 0.001 | 604.53 | 5.38 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rich Time | Rich Velocity | WD Ratio | Rich Width | Rich Depth | Tributary Temp | Stream pH |
|--------------|-------|-----------|-------------|-----------|---------------|----------|------------|------------|----------------|-----------|
| | (cfs) | (cfs) | (cfs) | (days) | (ft/s) | (ft) | (ft) | (ft) | (°C) | (°C) |
| QT-10 | 0.018 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 |
| Q1-10 | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | |
| Q30-10 | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | |

Discharge Data

| Name | Permit Number | Eating Flow (mgd) | Premitted Flow (mgd) | Design Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|--------------|---------------|-------------------|----------------------|-------------------|----------------|----------------|---------|
| School House | PA0088439 | 0.0000 | 0.0000 | 0.0000 | 0.000 | 20.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/day) |
|------------------|------------------|------------------|--------------------|-------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.00 |
| Dissolved Oxygen | 5.00 | 0.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Tuesday, September 17, 2024

Version 1.1

Page 2 of 2

Page: 14

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|---------------------|-----------------------|-------------------|------------------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Daily Min | XXX | 9.0 Daily Max | XXX | 1/day | Grab |
| DO | XXX | XXX | 5.0 Daily Min | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD5 | XXX | XXX | XXX | 25.0 | XXX | 50.0 | 2/month | 8-Hr Composite |
| TSS | XXX | XXX | XXX | 30.0 | XXX | 60.0 | 2/month | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 2/month | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/year | Grab |
| Ammonia Nov 1 - Apr 30 | XXX | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Ammonia May 1 - Oct 31 | XXX | XXX | XXX | 14.0 | XXX | XXX | 2/month | 8-Hr Composite |
| Ammonia | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 8-Hr Composite |
| Ammonia (lbs) | Report Total Qrtly | XXX | XXX | XXX | XXX | XXX | 1/quarter | Calculation |
| Ammonia (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| TKN | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 8-Hr Composite |

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------|-------------------------------------|---------------------|-----------------------|------------------|---------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| TKN (lbs) | Report Total Qrtly | XXX | XXX | XXX | XXX | XXX | 1/quarter | Calculation |
| Nitrate-Nitrite | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 8-Hr Composite |
| Nitrate-Nitrite (lbs) | Report Total Qrtly | XXX | XXX | XXX | XXX | XXX | 1/quarter | Calculation |
| Total Nitrogen | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | Calculation |
| Total Nitrogen (lbs) | Report Total Qrtly | XXX | XXX | XXX | XXX | XXX | 1/quarter | Calculation |
| Total Nitrogen (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Total Phosphorus | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 8-Hr Composite |
| Total Phosphorus (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Total Phosphorus (lbs) | Report Total Qrtly | XXX | XXX | XXX | XXX | XXX | 1/quarter | Calculation |

Compliance Sampling Location: 

Other Comments: 

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [REDACTED]) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input checked="" type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input checked="" type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input checked="" type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input checked="" type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input checked="" type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input checked="" type="checkbox"/> | SOP: BCW-PMT-033 |
| <input type="checkbox"/> | Other: [REDACTED] |