

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

**PA0088536**

APS ID

**328845**

Authorization ID

**1461789**

## NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

### Applicant and Facility Information

Applicant Name	<b>Camp Hebron</b>	Facility Name	<b>Camp Hebron Retreat</b>
Applicant Address	957 Camp Hebron Road	Facility Address	957 Camp Hebron Road
	Halifax, PA 17032-9574		Halifax, PA 17032-9520
Applicant Contact	Deke Rider	Facility Contact	Daniel Sheeler
Applicant Phone	(717) 896-3441	Facility Phone	(717) 896-3441
Client ID	144786	Site ID	533921
Ch 94 Load Status	Not Overloaded	Municipality	Halifax Township
Connection Status	No Limitations	County	Dauphin
Date Application Received	November 14, 2023	EPA Waived?	Yes
Date Application Accepted	November 29, 2023	If No, Reason	
Purpose of Application	NPDES permit renewal		

### Summary of Review

#### **1.0 General Discussion**

This fact sheet supports the renewal of an existing NPDES permit for discharge of treated domestic wastewater from Camp Hebron wastewater treatment plant located in Halifax Township, Dauphin County. The treatment plant has a hydraulic design capacity of 0.0206MGD. Camp Hebron owns, and operates the wastewater treatment plant, which has a design flow of 0.0206 MGD and provides sanitary services for a church, camp and a retreat center. The discharge goes to Powell Creek which is classified for Trout Stocking (STF) and Migratory Fishes (MF). The existing NPDES permit was issued on May 30, 2019 with an effective date of June 1, 2019 and expiration date of May 31, 2024. The applicant submitted a timely permit renewal application to the Department and is currently operating under the terms and conditions in the existing permit under administrative extension provisions pending Department action on the renewal application. A topographic map showing the discharge location is presented in attachment A

#### **1.1 Sludge use and disposal description and location(s):**

Sludge is hold up in a sludge holding tank and hauled out by a licensed hauler periodically.

#### **1.2 Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*,

Approve	Deny	Signatures	Date
X		<i>J. Pascal Kwedza</i> J. Pascal Kwedza, P.E. / Environmental Engineer	November 8, 2024
X		<i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	November 8, 2024
X		<i>Maria D. Bebenek</i> Maria D. Bebenek, P.E. / Program Manager	November 8, 2024

### Summary of Review

DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**1.3.0 Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.0206
Latitude	40° 26' 3.11"	Longitude	-76° 53' 57.93"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Powell Creek (TSF)	Stream Code	16691
NHD Com ID	54975115	RMI	7.26
Drainage Area	30.2	Yield (cfs/mi <sup>2</sup> )	USGS Gage Station
Q <sub>7-10</sub> Flow (cfs)	3.02	Q <sub>7-10</sub> Basis	
Elevation (ft)		Slope (ft/ft)	
Watershed No.	6-C	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Background/Ambient Data	Data Source		
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake	Veolia Water PA		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	15

Changes Since Last Permit Issuance: None

**1.3.1 Water Supply Intake**

The nearest downstream water supply intake is approximately 15 miles downstream for Veolia Water PA on the Susquehanna River in Susquehanna Township Dauphin County. No impact is expected from this discharge on the intake

2.0 Treatment Facility Summary				
<b>Treatment Facility Name:</b> Camp Hebron				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
2201401	2/27/2001			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Hypochlorite	0.0206
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0206	25	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None

## **2.1 Treatment Facility**

The treatment plant is a 0.0206 MGD facility with 2 aerated Equalization tanks in series. Flow is pumped from the 2<sup>nd</sup> EQ tank to the 2 Chromaglass treatment trains consisting of Aeration and Clarification and a common Chlorine Contact Tank and sludge holding tank. Effluent is disinfected with chlorine tabs with a batch discharge to Powell Creek.

3.0 Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	24-Hr Composite
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	Calculation
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
TKN	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	24-Hr Composite

**3.1 Compliance History**

**3.1.1 DMR Data for Outfall 001 (from September 1, 2023 to August 31, 2024)**

Parameter	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23
Flow (MGD) Average Monthly	0.00608	0.1271	0.00642	0.00465	0.00308	0.00302	0.00304	0.00271	0.00221	0.00316	0.00282	0.00343
Flow (MGD) Daily Maximum	0.01289	0.02490	0.01057	0.01078	0.00824	0.00624	0.00755	0.01009	0.00466	0.00887	0.00776	0.01116
pH (S.U.) Daily Minimum	6.8	6.8	6.9	6.7	6.6	6.6	6.8	7.3	7.0	6.5	6.7	6.6
pH (S.U.) Daily Maximum	7.9	7.8	7.7	7.6	7.8	7.7	7.7	7.9	7.7	7.8	7.7	7.7
DO (mg/L) Daily Minimum	5.5	6.7	7.0	7.1	7.2	7.7	7.9	8.2	8.1	6.9	7.5	7.7
TRC (mg/L) Average Monthly	0.26	0.25	0.21	0.16	0.27	0.24	0.23	0.22	0.17	0.20	0.15	0.16
TRC (mg/L) Instantaneous Maximum	0.75	0.65	0.65	0.38	0.73	0.61	1.27	0.51	0.48	0.62	0.41	0.56
CBOD5 (mg/L) Average Monthly	4.7	< 3	5.2	4	2.7	6.4	5	3	3.1	3.5	< 2.2	4.1
TSS (mg/L) Average Monthly	13	8.5	10.5	12	9	9.5	16	15	13.5	24.5	< 18	13.5
Fecal Coliform (No./100 ml) Geometric Mean	< 1	63	49.2	17	22.8	< 3.6	18	21	1313	< 5.2	18.7	73.5
Fecal Coliform (No./100 ml) Instantaneous Maximum	1	166	> 2419.6	39	38	13	54	64	1990	27	50	108
Nitrate-Nitrite (mg/L) Daily Maximum			49.8						37.4			
Total Nitrogen (mg/L) Daily Maximum			< 50.8						< 37.8			
Ammonia (mg/L) Average Monthly	0.17	< 0.10	0.17	< 0.12	< 0.115	0.135	0.19	< 0.07	0.23	0.215	0.165	0.56
TKN (mg/L) Daily Maximum			< 1						< 0.4			
Total Phosphorus (mg/L) Daily Maximum			7.4						7.9			

**3.1.2 Effluent Violations for Outfall 001, from: September 1, 2023 To: July 31, 2024**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	06/30/24	IMAX	> 2419.6	No./100 ml	1000	No./100 ml

**3.1.3 Summary of DMRs:**

Discharge Monitoring Reports (DMRs) review for the facility for the last 12 months of operation presented on the table above in section 3.1.1 indicate permit limits have been met most of the time. One permit limit violation for Fecal Coliform was noted on DMRs during the period reviewed presented in section 3.1.2. The violation appears to be a one-time occurrence.

**3.1.4 Summary of Inspections:**

The facility was inspected a couple of times during the past permit cycle. Inspection reports review for the facility during the period indicate permit limits have been met most of the time. The facility has good operation and maintenance record.

#### **4.0 Development of Effluent Limitations**

Outfall No. 001  
Latitude 40° 26' 3.13"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .0206  
Longitude -76° 53' 57.93"

#### **4.1 Basis for Effluent Limitations**

In general, the Clean Water Act (CWA) requires that the effluent limits for a particular pollutant be the more stringent of either technology-based limits or water quality-based limits. Technology-based limits are set according to the level of treatment that is achievable using available technology. A water quality-based effluent limit is designed to ensure that the water quality standards applicable to a waterbody are being met and may be more stringent than technology-based effluent limits.

##### **4.1.1 Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Average weekly limitations are not applicable to this discharge

#### **4.2 Water Quality-Based Limitations**

##### **4.2.1 Receiving Stream**

The receiving stream is the Powell Creek. According to 25 PA § 93.9m, this stream is protected for Trout Stocking (TSF) and Migratory Fishes (MF). It is located in Drainage List m and State Watershed 6-C. It has been assigned stream code 16691. According to the Department's Integrated Water Quality Monitoring and Assessment Report, this stream is attaining its designated uses.

##### **4.2.2 Streamflows**

Streamflows for the water quality analysis were determined by correlating with the yield of USGS gauging station No. 01570500 on Susquehanna River in Harrisburg. The Q<sub>7-10</sub> and drainage area at the gage is 2610 ft<sup>3</sup>/s and 24100 mi<sup>2</sup> respectively. The resulting yields are as follows:

- Q<sub>7-10</sub> = (2610 ft<sup>3</sup>/s) / 24100 mi<sup>2</sup> = 0.10 ft<sup>3</sup>/s / mi<sup>2</sup>
- Q<sub>30-10</sub> / Q<sub>7-10</sub> = 1.17
- Q<sub>1-10</sub> / Q<sub>7-10</sub> = 0.95

The drainage area at discharge taken from previous report = 30.2 mi<sup>2</sup>

The Q<sub>7-10</sub> at discharge = 30.2 mi<sup>2</sup> x 0.10 ft<sup>3</sup>/s/mi<sup>2</sup> = 3.02 ft<sup>3</sup>/s.

#### **4.2.3 NH<sub>3</sub>N Calculations**

NH<sub>3</sub>N calculations will be based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the instream NH<sub>3</sub>N criteria used in modelling of the stream:

• Discharge pH	= 7.0 (DMR median from Jul. to Sept.)
• Discharge Temperature	= 25 ° C (Default)
* Stream pH	= 8.2 (Taken from WQN station at Harrisburg)
* Stream Temperature	= 23.5°C (Taken from WQN station at Harrisburg)
• Background NH <sub>3</sub> -N	= 0.0 (default)

#### **4.2.4 CBOD<sub>5</sub> :**

The attached results of the WQM 7.0 stream model (attachment B) also indicates that, for Camp Hebron's discharge of 0.0206MGD, a limitation of 25 mg/l CBOD<sub>5</sub> as a monthly average limit (AML) and 50 mg/l as instantaneous maximum (IMAX) is adequate to protect the water quality of the stream. This limit is consistent with the existing permit and the STP has been complying with this limitation. Therefore, a limit of 25mg/l AML, and 50 mg/l IMAX is again recommended for this permit cycle.

#### **4.2.5 NH<sub>3</sub>-N:**

The attached results of the WQM 7.0 stream model (attachment B) indicates that no limitation on NH<sub>3</sub> as a monthly average is necessary to protect the aquatic life from toxicity effects. Monitoring of Ammonia will be required in the permit to evaluate treatment plant's performance.

#### **4.2.6 Dissolved Oxygen**

The existing permit contains a limit of 5 mg/l for Dissolved Oxygen (DO). DEP's Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001, 10/97) suggests that either the adopted minimum stream D.O. criteria for the receiving stream or the effluent level determined through water quality modeling be used for the limit. Since the WQM 7.0 model was run using a minimum D.O. of 5.0 mg/l, this limit will be continued in the renewed permit with a daily monitoring requirement.

#### **4.2.7 Total Suspended Solids (TSS):**

There is no water quality criterion for TSS. A limit of 30 mg/l AML in the existing permit based on the minimum level of effluent quality attainable by secondary treatment as defined in 40 CFR 133.102b(1) and 25 PA § 92a.47(a)(1) will remain in the permit.

#### **4.2.8 Total Residual Chlorine:**

The attached computer printout presented in attachment C utilizes the equations and calculations as presented in the Department's 2003 Implementation Guidance for Residual Chlorine (TRC) (ID # 391-2000-015) for developing chlorine limitations. The results presented in attachment C indicates that a water quality limit of 0.5 mg/l monthly average and IMAX of 1.6 mg/l would be needed to prevent toxicity concerns. The limitation recommended is consistent with the existing. DMR and inspection report indicate the facility is meeting the permit requirement.

#### **4.2.9 Toxics**

A reasonable potential (RP) analysis was done for pollutants in the discharge. The discharge consists entirely of domestic wastewater with no pollutants of concern that need further analysis.

#### **4.2.10 Chesapeake Bay Strategy:**

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized based on their delivered TN and TP loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets if approved by DEP. Phase 4 (0.2 -0.4mgd) and Phase 5(below 0.2mdg) will be required to monitor and report TN and TP during permit renewal. Any facility in Phases 4 and 5 that undergoes expansion is subjected to cap load right away. This facility is, classified as a phase 5, and has been monitoring Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, Total Nitrogen and Total Phosphorus semi-annually and will continue during the current permit cycle.

#### **4.2.11 Fecal Coliform and E. Coli**

The existing Fecal Coliform limit is consistent with the technology limits recommended in 92a.47(a)(4) and (a)(5) and will remain in the permit. In March of 2021, EPA approved DEP's Triennial Review of Water Quality Standards, which included a new swimming season criterion for E. coli. As a result, DEP is including monitoring requirements for E. Coli in new and renewed sewage permits above 2000gpd. Monitoring frequency is based on annual average flow as follows: 1/month for design flows  $\geq$  1 MGD, 1/quarter for design flows  $\geq$  0.05 and  $<$  1 MGD and 1/year for design flows of 0.002 – 0.05 MGD. Your discharge of 0.0206 MGD requires 1/year monitoring as included in the permit

#### **4.2.12 Special Permit Conditions**

The permit will contain the following special conditions:

Stormwater Prohibition, Approval Contingencies, Management of collected screenings, slurries, sludges and other solids, Requirement to connect if a public sewer becomes available in the area, Chlorine minimization and Solids Management.

### **5.0 Other Requirements**

#### **5.1 Anti-backsliding**

Not applicable to this permit

#### **5.2 Stormwater:**

No storm water outfall is associated with this facility

#### **5.6 Special Permit Conditions**

The permit will contain the following special conditions:

Stormwater Prohibition, Approval Contingencies, Management of collected screenings, slurries, sludges and other solids, Requirement to connect if a public sewer becomes available in the area, Chlorine minimization and Solids Management.

### **5.3 Anti-Degradation (93.4)**

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

### **5.4 Class A Wild Trout Fisheries**

No Class A Wild Trout Fisheries are impacted by this discharge.

### **5.5 303d Listed Streams:**

The discharge is not located on a 303d listed stream segment.

### **5.6 Basis for Effluent and Surface Water Monitoring**

Section 308 of the CWA and federal regulation 40 CFR 122.44(i) require monitoring in permits to determine compliance with effluent limitations. Monitoring may also be required to gather effluent and surface water data to determine if additional effluent limitations are required and/or to monitor effluent impacts on receiving water quality. The permittee is responsible for conducting the monitoring and for reporting results on Discharge Monitoring Reports (DMRs).

### **5.7 Effluent Monitoring**

Monitoring frequencies are based on the nature and effect of the pollutant, as well as a determination of the minimum sampling necessary to adequately monitor the facility's performance. Permittees have the option of taking more frequent samples than are required under the permit. These samples can be used for averaging if they are conducted using EPA-approved test methods (generally found in 40 CFR 136) and if the Method Detection Limits are less than the effluent limits. The sampling location must be after the last treatment unit and prior to discharge to the receiving water. If no discharge occurs during the reporting period, "no discharge" shall be reported on the DMR.

**6.0 Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Nitrate-Nitrite	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	24-Hr Composite
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	Calculation
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
TKN	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/6 months	24-Hr Composite

Compliance Sampling Location: At Outfall 001

7.0 Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment <b>B</b> )
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment <b>C</b> )
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing effluent limitation for individual sewage permit.
<input type="checkbox"/>	Other: [REDACTED]

**8. Attachment**

**A. Topographical**



**B. WQM**

**WQM 7.0 Effluent Limits**

SWP Basin	Stream Code	Stream Name					
		06C	16691	POWELL CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
7.260	Camp Hebron	PA0088536	0.021	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5

Input Data WQM 7.0

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Camp Hebron	PA0088536	0.0206	0.0206	0.0206	0.000	25.00	6.70

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
06C	16691	POWELL CREEK	6.800	410.00	39.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp (°C)	Disc pH
		(mgd)	(mgd)	(mgd)			
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin			Stream Code			Stream Name						
06C			16691			POWELL CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
7.260	3.02	0.00	3.02	.0319 0.02059		.657	22.26	33.87	0.21	0.135	20.05	7.00
<b>Q1-10 Flow</b>												
7.260	2.87	0.00	2.87	.0319 0.02059		NA	NA	NA	0.20	0.139	20.05	7.00
<b>Q30-10 Flow</b>												
7.260	3.53	0.00	3.53	.0319 0.02059		NA	NA	NA	0.23	0.124	20.04	7.00

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.95	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.17	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
06C	16691	POWELL CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.260	Camp Hebron	16.75	50	16.75	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.260	Camp Hebron	1.88	25	1.88	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
7.26	Camp Hebron	25	25	25	25	5	5	0	0

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
06C	16691	POWELL CREEK		
<u>RMI</u> 7.260	<u>Total Discharge Flow (mgd)</u> 0.021	<u>Analysis Temperature (°C)</u> 20.052	<u>Analysis pH</u> 6.996	
<u>Reach Width (ft)</u> 22.263	<u>Reach Depth (ft)</u> 0.657	<u>Reach WDRatio</u> 33.867	<u>Reach Velocity (fps)</u> 0.209	
<u>Reach CBOD5 (mg/L)</u> 2.24	<u>Reach Kc (1/days)</u> 0.160	<u>Reach NH3-N (mg/L)</u> 0.26	<u>Reach Kn (1/days)</u> 0.703	
<u>Reach DO (mg/L)</u> 8.209	<u>Reach Kr (1/days)</u> 40.842	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5	
<u>Reach Travel Time (days)</u> 0.135	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.013	2.24	0.26	8.23
	0.027	2.23	0.26	8.23
	0.040	2.23	0.25	8.23
	0.054	2.22	0.25	8.23
	0.067	2.22	0.25	8.23
	0.081	2.21	0.25	8.23
	0.094	2.21	0.24	8.23
	0.108	2.20	0.24	8.23
	0.121	2.20	0.24	8.23
	0.135	2.19	0.24	8.23

C. TRC Calculations Results

TRC EVALUATION									
Input appropriate values in A3:A9 and D3:D9									
Source	Reference	AFC Calculations		Reference	CFC Calculations				
TRC	1.3.2.iii	WLA_afc = 3.042		1.3.2.iii	WLA_cfc = 2.958				
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581				
PENTOXSD TRG	5.1b	LTA_afc = 1.134		5.1d	LTA_cfc = 1.720				
Source									
Effluent Limit Calculations									
PENTOXSD TRG	5.1f	AML MULT = 1.231		BAT/BPJ					
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		INST MAX LIMIT (mg/l) = 1.635					
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
LTAMULT_afc	$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^{0.5})$								
LTA_afc	wla_afc*LTAMULT_afc								
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
LTAMULT_cfc	$\text{EXP}((0.5*\text{LN}(cvd^2/no\_samples+1))-2.326*\text{LN}(cvd^2/no\_samples+1)^{0.5})$								
LTA_cfc	wla_cfc*LTAMULT_cfc								
AML MULT	$\text{EXP}(2.326*\text{LN}((cvd^2/no\_samples+1)^{0.5})-0.5*\text{LN}(cvd^2/no\_samples+1))$								
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)								
INST MAX LIMIT	$1.5*((\text{av\_mon\_limit}/\text{AML\_MULT})/\text{LTAMULT\_afc})$								