

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0088579
 APS ID 988356
 Authorization ID 1434649

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|---|
| Applicant Name | <u>The York Water Co.</u> | Facility Name | <u>Felton Borough STP</u> |
| Applicant Address | <u>130 E Market Street</u> <u>York, PA 17401-1219</u> | Facility Address | <u>70 Water Street</u> <u>Felton, PA 17322</u> |
| Applicant Contact | <u>Vaughn Wenger</u> | Facility Contact | <u>Vaughn Wenger</u> |
| Applicant Phone | <u>(717) 718-7544</u> | Facility Phone | <u>(717) 845-3601</u> |
| Client ID | <u>69800</u> | Site ID | <u>459500</u> |
| Ch 94 Load Status | <u>Existing Hydraulic and Organic Overload</u> | Municipality | <u>Felton Borough</u> |
| Connection Status | <u>Dept. Imposed Connection Prohibitions</u> | County | <u>York</u> |
| Date Application Received | <u>March 31, 2023</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>April 14, 2023</u> | If No, Reason | <u></u> |
| Purpose of Application | <u>Renewal of Existing NPDES Permit</u> | | |

Summary of Review

The York Water Company (YWC) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of a NPDES permit for the Delta Borough STP. The permit was last reissued to Felton Borough on September 28, 2018 before being transferred to YWC on February 22, 2021. The permit expired on September 30, 2023 but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days. A file review of documents associated with the discharge or permittee may be available at the PA DEP southcentral regional office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file reviews, contact the SCRO file review coordinator at 717.705.4700.

Sludge use and disposal description and location(s): Smith Disposal Facility and Berstine Farm (Adams County)

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|---|--------------|
| x | | Aaron Baar Aaron Baar / Project Manager | May 18, 2024 |
| x | | Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager | May 22, 2024 |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|---|------------------------------|-------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>.04</u> |
| Latitude | <u>39° 51' 12.47"</u> | Longitude | <u>-76° 33' 50.50"</u> |
| Quad Name | <u>Stewartstown</u> | Quad Code | <u>2033</u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |
| Receiving Waters | <u>North Branch Muddy Creek (CWF)</u> | Stream Code | <u>07367</u> |
| NHD Com ID | <u>57470951</u> | RMI | <u>7.99</u> |
| Drainage Area | <u>16.5 sq. mi.</u> | Yield (cfs/mi ²) | <u>0.265</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>4.38</u> | Q ₇₋₁₀ Basis | <u>USGS StreamStats</u> |
| Elevation (ft) | <u>522.89</u> | Slope (ft/ft) | <u></u> |
| Watershed No. | <u>7-I</u> | Chapter 93 Class. | <u>CWF</u> |
| Existing Use | <u></u> | Existing Use Qualifier | <u></u> |
| Exceptions to Use | <u></u> | Exceptions to Criteria | <u></u> |
| Assessment Status | <u>Attaining Use(s)</u> | | |
| Cause(s) of Impairment | <u></u> | | |
| Source(s) of Impairment | <u></u> | | |
| TMDL Status | <u>Name</u> | | |
| Nearest Downstream Public Water Supply Intake | <u>Exelon Peach Bottom Atomic Power Station</u> | | |
| PWS Waters | <u>Susquehanna River</u> | Flow at Intake (cfs) | <u></u> |
| PWS RMI | <u>4.33</u> | Distance from Outfall (mi) | <u>28</u> |

Drainage Area

The discharge is to North Branch Muddy Creek at RMI 7.99. A drainage area upstream of the discharge is determined to be 16.5 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, the watershed has a Q₇₋₁₀ of 4.38 cfs. This information was used to obtain a LFY, a chronic 30-day (Q₃₀₋₁₀) and acute (Q₁₋₁₀) exposure stream flows for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned}
 Q_{7-10} &= 4.38 \text{ cfs} \\
 Q_{30-10} &= 1.36 * 4.38 \text{ cfs} = 5.96 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 4.38 \text{ cfs} = 2.80 \text{ cfs} \\
 LFY &= 4.38 \text{ cfs}/16.5 \text{ mi}^2 = 0.265 \text{ cfs/mi}^2
 \end{aligned}$$

North Branch Muddy Creek

25 Pa Code §93.9 classifies the receiving water, North Branch Muddy Creek, with a CWF Existing Use designation. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed attaining use.

Local Watershed Total Maximum Daily Loads (TMDLs)

According to PA's 2024 integrated water quality monitoring and assessment report, North Branch Muddy Creek in the vicinity of the proposed point of discharge is supporting aquatic life. The creek is listed as Category 2 in the 2024 integrated report, indicating that some but not all uses are met. The assessment status of the remaining uses may be unknown because data are insufficient to assess the water, or it may be impaired. No TMDL has been developed

for North Branch Muddy Creek to date, so no local watershed TMDL has been taken into consideration during this review.

Public Water Supply Intake

The nearest downstream public water supply intake is the Exelon Peach Bottom Atomic Power Plant intake located on the Susquehanna River approximately 28 miles from the discharge. Considering the distance and nature, the discharge is not expected to significantly affect the water supply.

Class A Wild Trout Streams

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

| Treatment Facility Summary | | | | |
|--|-----------------------------------|----------------------|---|-------------------------------|
| Treatment Facility Name: Felton STP | | | | |
| WQM Permit No. | | Issuance Date | | |
| 6700417 A05-1 | | January 20, 2005 | | |
| | | | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Extended Aeration | Ultraviolet | 0.04 |
| Hydraulic Capacity (MGD) | | | | |
| 0.04 | Organic Capacity (lbs/day) | | Load Status | Biosolids Treatment |
| | 80 | | Existing Hydraulic and Organic Overload | Aerobic Digestion |
| | | | | Biosolids Use/Disposal |
| | | | | Other WWTP |

The York Water Company owns and operates the sanitary wastewater treatment facility located in Felton Borough, York County. This NPDES permit covers discharges of sewage treated by the Felton Borough STP. The facility only serves portions of Felton Borough; all sewer systems are 100% separated. With an annual average design flow 0.040 MGD and a hydraulic design capacity of 0.040 MGD, this facility utilizes an extended aeration system consisting of:

Comminutor (1) ⇒ Screening (1) ⇒ EQ Tank (2) ⇒ Aeration Tank (6) ⇒ Clarifier (2) ⇒ Ultraviolet Unit (1) ⇒ Post Aeration Tank (1) ⇒ Discharge

The system incorporates chemical addition in the form of soda ash (to control pH) and alum (for settleability). As a precaution for the failure of the ultraviolet treatment unit, calcium hypochlorite and sodium bisulfite are kept on site for chlorination and dechlorination. Three sludge holding tanks are used for solids storage.

| Compliance History | |
|--------------------------------|---|
| Summary of DMRs: | DMR results for the past year are presented below. |
| Summary of Inspections: | <p>Since the last renewal of the facility's NPDES permit, the following inspections have been logged:</p> <p>June 21, 2018: A routine CEI was conducted by Michael Benham. No violations were noted. Recommendations were made regarding build up of solids in the aeration tank, restoring skimmer function to the clarifiers, hauling accumulated sludge, records management, and repairing the effluent sampler.</p> |

Other Comments: As of May 18, 2024, there are two open violations associated YWC (facility unknown):

| CLIENT ID | CLIENT | FF ID | FACILITY | FF KIND | FF STATUS | INSP PROGRAM | PROGRAM SPECIFIC ID | INSP ID | VIOLATION ID | INSPECTION CATEGORY | VIOLATION DATE | VIOLATION CODE | VIOLATION | FF INSPECTOR | INSP REGION |
|-----------|-------------------|-------|----------|---------|-----------|-----------------------------------|---------------------|---------|--------------|---------------------|----------------|----------------|--|--------------|-------------|
| 68800 | THE YORK WATER CO | | | | | WPC State Water Pollution Control | 68800 | 3418993 | 967146 | Chit | 08/20/2022 | 91.33(A) | CSL - Failure to immediately report to DEP a pollution incident | | SCRO |
| 68800 | THE YORK WATER CO | | | | | WPC State Water Pollution Control | 68800 | 3418993 | 967147 | Chit | 08/20/2022 | CSL401 | CSL - Unauthorized, unpermitted discharge of polluting substances to waters of the Commonwealth resulting in pollution | | SCRO |

The draft permit letter will indicate that the permit may not be finalized until all pending violations are resolved or closed.

Existing Effluent Limitations and Monitoring Requirements

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------|-------------------------------------|------------------------|-----------------------|-----------------|---------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Monthly | Annual | Monthly | Monthly Average | Maximum | Instant. Maximum | | |
| Total Nitrogen (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Ammonia (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Total Phosphorus (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |

Compliance Sampling Location: Outfall 001

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|---------------------|-----------------------|------------------|------------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Instantaneous Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Daily Min | XXX | 9.0 Daily Max | XXX | 1/day | Grab |
| DO | XXX | XXX | 5.0 Daily Min | XXX | XXX | XXX | 1/day | Grab |
| CBOD5 | 8.3 | 13.0 | XXX | 25.0 | 40.0 | 50 | 2/month | 8-Hr Composite |
| BOD5 Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 2/month | 24-Hr Composite |
| TSS | 10.0 | 15.0 | XXX | 30.0 | 45.0 | 60 | 2/month | 8-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 2/month | 24-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 2/month | Grab |
| Nitrate-Nitrite | XXX | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------|-------------------------------------|----------------|-----------------------|-----------------|----------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Instantaneous Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Nitrate-Nitrite (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 1/month | Calculation |
| Total Nitrogen (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Ammonia Nov 1 - Apr 30 | Report | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Ammonia May 1 - Oct 31 | Report | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Ammonia (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| TKN | XXX | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| TKN (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | Report | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Total Phosphorus (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 2/month | Calculation |

Compliance Sampling Location: Outfall 001

Compliance History

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

| Parameter | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 | OCT-23 | SEP-23 | AUG-23 | JUL-23 | JUN-23 | MAY-23 | APR-23 |
|---------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.006 | 0.008 | 0.028 | 0.017 | 0.004 | 0.004 | 0.003 | 0.004 | 0.005 | 0.005 | 0.004 | 0.006 |
| Flow (MGD) Daily Maximum | 0.014 | 0.020 | 0.115 | 0.081 | 0.008 | 0.006 | 0.007 | 0.015 | 0.007 | 0.008 | 0.008 | 0.011 |
| pH (S.U.) Instantaneous Minimum | 6.92 | 6.83 | 6.57 | 6.88 | 7.25 | 6.72 | 6.79 | 6.57 | 6.55 | 6.48 | 6.77 | 6.61 |

**NPDES Permit Fact Sheet
York Water Felton Borough STP**

NPDES Permit No. PA0088579

| | | | | | | | | | | | | |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|-------|-------|
| pH (S.U.) Instantaneous Maximum | 8.31 | 7.55 | 7.6 | 8.04 | 8.27 | 8.23 | 7.64 | 7.46 | 7.55 | 7.34 | 7.34 | 7.48 |
| DO (mg/L) Instantaneous Minimum | 9.73 | 10.27 | 9.85 | 9.71 | 9.63 | 8.97 | 8.37 | 7.95 | 7.85 | 7.58 | 9.28 | 9.44 |
| CBOD5 (lbs/day) Average Monthly | < 0.10 | < 0.14 | < 0.91 | < 0.59 | < 0.05 | < 1.9 | < 0.04 | < 0.06 | < 0.08 | < 0.07 | < 0.1 | < 0.1 |
| CBOD5 (lbs/day) Weekly Average | < 0.12 | < 0.16 | 1.62 | 1.08 | 0.05 | < 0.08 | < 0.06 | < 0.06 | < 0.1 | < 0.08 | < 0.1 | 0.5 |
| CBOD5 (mg/L) Average Monthly | < 2.4 | < 2.4 | < 5.3 | < 3.1 | < 2.6 | < 2.4 | < 2.4 | < 2.0 | < 2.0 | < 3.0 | < 2.0 | < 2.0 |
| CBOD5 (mg/L) Weekly Average | < 2.4 | < 2.4 | 8.1 | 3.7 | 2.7 | < 2.4 | < 2.4 | 3.0 | < 2.0 | 3.0 | < 2.0 | < 2.0 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 12 | 15 | 24 | 29 | 7 | 7 | 2 | 8.0 | 5.0 | 5.0 | 8.0 | 8.0 |
| BOD5 (lbs/day) Raw Sewage Influent Daily Maximum | 15 | 16 | 25 | 31 | 7 | 11 | 3 | 9.0 | 5.0 | 5.0 | 10.0 | 8.0 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 260 | 264 | 207 | 415 | 397 | 227 | 118 | 303 | 143 | 170 | 169 | 172.0 |
| TSS (lbs/day) Average Monthly | 0.09 | 0.16 | 0.49 | 1.36 | 0.07 | 0.08 | 0.03 | 0.06 | 0.03 | 0.2 | 0.05 | 0.2 |
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 14 | 23 | 22 | 29 | 9 | 7 | 2 | 8.0 | 4.0 | 5.0 | 10.0 | 5.0 |
| TSS (lbs/day) Raw Sewage Influent Daily Maximum | 19 | 27 | 22 | 33 | 9 | 13 | 2 | 13.0 | 4.0 | 6.0 | 17.0 | 7.0 |
| TSS (lbs/day) Weekly Average | 0.10 | 0.25 | 0.80 | 2.63 | 0.12 | 0.13 | 0.03 | 0.08 | 0.04 | 0.3 | 0.05 | 0.4 |
| TSS (mg/L) Average Monthly | 2.0 | 3.0 | 3.0 | 5.5 | 4.0 | 3.0 | 2.0 | 3.0 | 1.0 | 8.0 | 1.0 | 5.0 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 326 | 398 | 188 | 338 | 518 | 240 | 98 | 302 | 122 | 158 | 200 | 96.0 |
| TSS (mg/L) Weekly Average | 2.0 | 5.0 | 4.0 | 9.0 | 7.0 | 4.0 | 3.0 | 3.0 | 1.0 | 10.0 | 1.0 | 7.0 |

**NPDES Permit Fact Sheet
York Water Felton Borough STP**

NPDES Permit No. PA0088579

| | | | | | | | | | | | | |
|--|---------|---------|--------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Fecal Coliform (No./100 ml) Geometric Mean | < 1 | < 1 | < 1 | < 1 | < 1 | < 1 | < 8 | < 1 | < 1.0 | < 1 | < 1 | < 1 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | < 1 | < 1 | < 1 | 2 | 6 | 2 | 59 | 2.0 | < 1.0 | < 1 | < 1 | < 1 |
| Nitrate-Nitrite (mg/L) Average Monthly | 31 | 30 | 18 | 29 | 58 | 45 | 56.0 | 64.0 | 56.0 | 50.0 | 45.0 | 47 |
| Nitrate-Nitrite (lbs) Total Monthly | 41 | 49 | 62 | 96 | < 29 | 36 | 28 | 49 | 58.0 | 43.0 | 63.0 | 65.0 |
| Total Nitrogen (mg/L) Average Monthly | < 31.9 | < 30.0 | < 21.8 | < 29.5 | < 58.5 | < 45.5 | < 56.5 | < 64 | < 56.0 | < 50.5 | < 45.0 | < 47.5 |
| Total Nitrogen (lbs) Total Monthly | < 42 | < 50 | < 87 | < 98 | < 29 | < 36 | < 29 | < 50.0 | < 58.0 | < 43 | < 63 | < 66 |
| Total Nitrogen (lbs) Total Annual | | | | | | | 893 | | | | | |
| Ammonia (lbs/day) Average Monthly | < 0.004 | < 0.006 | 0.587 | < 0.017 | < 0.002 | < 0.003 | < 0.002 | < 0.003 | < 0.003 | < 0.003 | < 0.005 | < 0.005 |
| Ammonia (mg/L) Average Monthly | < 0.1 | < 0.1 | 3.0 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 |
| Ammonia (lbs) Total Monthly | < 0.12 | < 0.17 | 18.2 | < 0.53 | < 0.06 | < 0.09 | < 0.05 | < 0.08 | < 0.1 | < 0.09 | < 0.1 | < 0.1 |
| Ammonia (lbs) Total Annual | | | | | | | 2 | | | | | |
| TKN (mg/L) Average Monthly | < 0.9 | < 0.5 | < 4.2 | < 0.5 | < 0.5 | < 0.5 | < 0.5 | < 0.5 | < 0.5 | < 0.5 | < 0.5 | < 0.5 |
| TKN (lbs) Total Monthly | < 1.2 | < 0.9 | < 24.8 | < 2.8 | < 0.3 | < 0.6 | < 0.3 | < 0.4 | < 0.5 | < 43 | < 0.7 | < 0.7 |
| Total Phosphorus (lbs/day) Average Monthly | 0.2 | 0.2 | 0.4 | 0.3 | 0.1 | 0.2 | 0.1 | 0.2 | 0.3 | 0.3 | 0.3 | 0.1 |
| Total Phosphorus (mg/L) Average Monthly | 4.0 | 3.8 | 2.9 | 3.2 | 6.8 | 6.3 | 7.0 | 9.0 | 7.8 | 8.8 | 6.8 | 2.1 |
| Total Phosphorus (lbs) Total Monthly | 5 | 6 | 11 | 9 | 4 | 5 | 4 | 7.0 | 8.0 | 8.0 | 10.0 | 3.0 |
| Total Phosphorus (lbs) Total Annual | | | | | | | 99 | | | | | |

Development of Effluent Limitations

| | | | |
|---|----------------------|--------------------------|------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>.04</u> |
| Latitude | <u>39° 51' 4.00"</u> | Longitude | <u>-76° 33' 44.00"</u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

Water Quality-Based Limitations

CBOD₅, NH₃-N and Dissolved Oxygen (DO)

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD₅, NH₃-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. The model was utilized using data derived by USGS StreamStats and the model output indicated that existing WQBELs for ammonia and CBOD₅ are still protective of water quality

The model also determined that the facility's existing DO limits of 5 mg/L are still protective of water quality.

Toxics

DEP's NPDES permit application for minor sewages (less than 0.1 MGD) does not require sampling for heavy metals including Total Copper, Total Lead, and Total Zinc.

E. Coli Monitoring

In conformity with the Department's *Establishing Effluent Limitations for Individual Sewage Permits* (SOP No. BCW-PMT-033) and as authorized by § 92a.61 of the PA Code, quarterly E. Coli monitoring has been proposed in this permit. The collection method will be via grab sample.

Best Professional Judgment (BPJ) Limitations

Dissolved Oxygen

A minimum of 5.0 mg/L for DO is an existing effluent limit and will remain unchanged in the draft permit as recommended by DEP's SOP. This requirement has also been assigned to other sewage facilities in the region. 5.0 mg/L is taken directly from 25 Pa. Code § 93.7(a) and it is also determined to be appropriate according to water quality modeling.

Ultraviolet Disinfection

Based on inspection reports, it appears that the existing UV system is equipped with an intensity sensor; therefore, UV intensity is proposed to be added to the permit as the monitoring parameter for disinfection in accordance with SOP No. BCW-PMT-033 (Establishing Effluent Limitations for Individual Sewage Permits), Section 1(A), Note 4.

Total Phosphorus & Total Nitrogen

DEP's SOP no. BPNPSM-PMT-033 (Establishing Effluent Limitations for Individual Sewage Permits) recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, routine monitoring for TKN, Nitrate-Nitrite, and TN are recommended to be continued in this permit. Sampling frequency for TKN, Nitrate-Nitrite, TN, and TP are currently required 2/month, which is consistent with Table 6.3 in Guidance Doc. 362-0400-001, which recommends the testing of conventional pollutants bimonthly for facilities with flows between 0.01 mgd to 0.1 mgd. No change is proposed in this permit renewal.

Historically, an average monthly Total Phosphorus limit of 2.0 mg/L was recommended in NPDES permits, per DEP phosphorus guidance 391-2000-018, to control phosphorus effluent levels for any facilities that are expected to contribute 0.25% or more of the total phosphorus loading of the entire basin. DEP has previously determined that this facility does not meet this criterion and a bimonthly monitoring requirement has been continuously imposed instead. It is recommended to maintain this monitoring requirement in the draft permit.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Chesapeake Bay TMDL

The Department formulated a strategy in April 2007, to comply with the EPA's and Chesapeake Bay Foundation's requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011, Phase 2 in March 2012 and Phase 3 in December 2019. In accordance with the Phase 3 WIP, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 3 WIP categorizes this facility as a phase 5 non-significant sewage facility that has a design flow less than 0.2 MGD but greater than 0.002 MGD. The WIP recommends monitoring and reporting for Total Nitrogen and Total Phosphorus throughout the permit term at a frequency no less than annual. As discussed previously, twice monthly testing of these pollutants is proposed in this permit.

Monitoring Frequency and Sample Type

Unless discussed otherwise above, the permit's monitoring frequency and sample type for all parameters will remain unchanged from the last permit renewal.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-backsliding Requirement

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal unless noted otherwise above. This approach is in accordance with 40 CFR §122.44(l)(1).

Annual Fees

An annual fee clause was added to the permit in accordance with 25 Pa. Code § 92a.62. The facility covered by the permit is classified in the Minor Sewage Facility <0.05 MGD, which has an annual fee of \$500.

Mass Loading Limitations

Unless stated otherwise in this fact sheet, mass loading effluent limits are calculated based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------|-------------------------------------|------------------------|-----------------------|--------------------|---------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Monthly | Annual | Monthly | Monthly Average | Maximum | Instant. Maximum | | |
| Total Nitrogen (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Ammonia (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Total Phosphorus (lbs) | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/year | Calculation |

Compliance Sampling Location: Outfall 001

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--|-------------------------------------|------------------|-----------------------|-----------------|----------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Instantaneous Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Daily Min | XXX | 9.0 Daily Max | XXX | 1/day | Grab |
| DO | XXX | XXX | 5.0 Daily Min | XXX | XXX | XXX | 1/day | Grab |
| CBOD5 | 8.3 | 13.0 | XXX | 25.0 | 40.0 | 50 | 2/month | 8-Hr Composite |
| BOD5 Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 2/month | 24-Hr Composite |
| TSS | 10.0 | 15.0 | XXX | 30.0 | 45.0 | 60 | 2/month | 8-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 2/month | 24-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 2/month | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/quarter | Grab |
| UV Intensity (mW/cm ²) | XXX | XXX | Report | XXX | XXX | XXX | 1/day | Recorded |
| Nitrate-Nitrite | XXX | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Nitrate-Nitrite (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---------------------------|-------------------------------------|-------------------|--------------------------|--------------------|-------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Instantaneous Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 1/month | Calculation |
| Total Nitrogen (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Ammonia Nov 1 - Apr 30 | Report | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Ammonia May 1 - Oct 31 | Report | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Ammonia (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| TKN | XXX | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| TKN (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | Report | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Total Phosphorus (lbs) | Report Total Mo | XXX | XXX | XXX | XXX | XXX | 2/month | Calculation |


Compliance Sampling Location: Outfall 001

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment [redacted]) |
| <input type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | TRC Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input checked="" type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input checked="" type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: [redacted] |
| <input type="checkbox"/> | Other: [redacted] |



StreamStats Report

Region ID: PA
 Workspace ID: PA20240517130833116000
 Clicked Point (Latitude, Longitude): 39.85126, -76.56194
 Time: 2024-05-17 09:08:56 -0400



Collapse All

Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|--------|--------------|
| BSLOPD | Mean basin slope measured in degrees | 7.2271 | degrees |
| DRNAREA | Area that drains to a point on a stream | 16.5 | square miles |
| ROCKDEP | Depth to rock | 5 | feet |
| URBAN | Percentage of basin with urban development | 2.1761 | percent |

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|--------------------------|--------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 16.5 | square miles | 4.78 | 1150 |
| BSLOPD | Mean Basin Slope degrees | 7.2271 | degrees | 1.7 | 6.4 |
| ROCKDEP | Depth to Rock | 5 | feet | 4.13 | 5.21 |
| URBAN | Percent Urban | 2.1761 | percent | 0 | 89 |

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

| Statistic | Value | Unit |
|-------------------------|-------|--------------------|
| 7 Day 2 Year Low Flow | 7.45 | ft ³ /s |
| 30 Day 2 Year Low Flow | 8.44 | ft ³ /s |
| 7 Day 10 Year Low Flow | 4.38 | ft ³ /s |
| 30 Day 10 Year Low Flow | 5.01 | ft ³ /s |
| 90 Day 10 Year Low Flow | 5.99 | ft ³ /s |

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)


USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

StreamStats Report

Region ID: PA
 Workspace ID: PA20240517131839961000
 Clicked Point (Latitude, Longitude): 39.84545, -76.54128
 Time: 2024-05-17 09:19:03 -0400



[-] Collapse All

Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|--------|--------------|
| BSLOPD | Mean basin slope measured in degrees | 7.4291 | degrees |
| DRNAREA | Area that drains to a point on a stream | 17 | square miles |
| ROCKDEP | Depth to rock | 5 | feet |
| URBAN | Percentage of basin with urban development | 2.1136 | percent |

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|--------------------------|--------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 17 | square miles | 4.78 | 1150 |
| BSLOPD | Mean Basin Slope degrees | 7.4291 | degrees | 1.7 | 6.4 |
| ROCKDEP | Depth to Rock | 5 | feet | 4.13 | 5.21 |
| URBAN | Percent Urban | 2.1136 | percent | 0 | 89 |

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

| Statistic | Value | Unit |
|-------------------------|-------|--------------------|
| 7 Day 2 Year Low Flow | 7.94 | ft ³ /s |
| 30 Day 2 Year Low Flow | 8.94 | ft ³ /s |
| 7 Day 10 Year Low Flow | 4.72 | ft ³ /s |
| 30 Day 10 Year Low Flow | 5.36 | ft ³ /s |
| 90 Day 10 Year Low Flow | 6.32 | ft ³ /s |

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--------------------|--------------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 071 | 7367 | NORTH BRANCH MUDDY CREEK | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 1.420 | Felton STP | PA0088579 | 0.040 | CBOD5 | 25 | | |
| | | | | NH3-N | 25 | 50 | |
| | | | | Dissolved Oxygen | | | 5 |

WQM 7.0 Wasteload Allocations

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
|------------------|--------------------|--------------------------|
| 071 | 7367 | NORTH BRANCH MUDDY CREEK |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-----|------------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| | 1.420 Felton STP | 16.61 | 50 | 16.61 | 50 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-----|------------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| | 1.420 Felton STP | 1.88 | 25 | 1.88 | 25 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|-----|-----------------|-----------------|-----------------|-----------------|-----------------|-------------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| | 1.42 Felton STP | 25 | 25 | 25 | 25 | 5 | 5 | 0 | 0 |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|--------------------|
| 07I | 7367 | NORTH BRANCH MUDDY CREEK | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | |
| 1.420 | 0.040 | 20.070 | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | |
| 26.653 | 0.637 | 41.823 | 0.262 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | |
| 2.32 | 0.183 | 0.35 | 0.704 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | |
| 8.198 | 12.540 | Tsivoglou | 6 | |
| <u>Reach Travel Time (days)</u> | Subreach Results | | | |
| 0.332 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> |
| | 0.033 | 2.31 | 0.34 | 8.23 |
| | 0.066 | 2.29 | 0.33 | 8.23 |
| | 0.099 | 2.28 | 0.32 | 8.23 |
| | 0.133 | 2.26 | 0.32 | 8.23 |
| | 0.166 | 2.25 | 0.31 | 8.23 |
| | 0.199 | 2.24 | 0.30 | 8.23 |
| | 0.232 | 2.22 | 0.30 | 8.23 |
| | 0.265 | 2.21 | 0.29 | 8.23 |
| | 0.298 | 2.20 | 0.28 | 8.23 |
| | 0.332 | 2.18 | 0.28 | 8.23 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | | <u>Stream Name</u> | | | | | | |
|--------------------|----------------------|--------------------|--------------------------|-----------------------------|------------------------|--------------------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| 071 | | 7367 | | | | NORTH BRANCH MUDDY CREEK | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 1.420 | 4.38 | 0.00 | 4.38 | .0619 | 0.00504 | .637 | 26.65 | 41.82 | 0.26 | 0.332 | 20.07 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 1.420 | 2.80 | 0.00 | 2.80 | .0619 | 0.00504 | NA | NA | NA | 0.20 | 0.424 | 20.11 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 1.420 | 5.96 | 0.00 | 5.96 | .0619 | 0.00504 | NA | NA | NA | 0.31 | 0.280 | 20.05 | 7.00 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|--------------------------|--------------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 07I | 7367 | NORTH BRANCH MUDDY CREEK | 1.420 | 522.89 | 16.50 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|---------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.100 | 0.00 | 4.38 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Felton STP | PA0088579 | 0.0400 | 0.0400 | 0.0400 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|--------------------------|--------------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 07I | 7367 | NORTH BRANCH MUDDY CREEK | 0.001 | 485.14 | 17.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|---------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.100 | 0.00 | 4.72 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |