



Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. **PA0240125**
APS ID **1101655**
Authorization ID **1463192**

Applicant and Facility Information

Applicant Name	<u>Pulaski Township Municipal Authority</u>	Facility Name	<u>New Bedford STP</u>
Applicant Address	<u>1172 State Route 208</u>	Facility Address	<u>1172 State Route 208</u>
Applicant Contact	<u>Pulaski, PA 16143</u>	Facility Contact	<u>Pulaski, PA 16143</u>
Applicant Phone	<u>(724) 964-8891</u>	Facility Phone	<u>(724) 964-8891</u>
Client ID	<u>202480</u>	Site ID	<u>701511</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Pulaski Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lawrence</u>
Date Application Received	<u>November 6, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>NPDES Renewal.</u>		

Summary of Review

An application was submitted for an NPDES permit renewal for an existing minor sewage facility discharge. The New Bedford STP consists of a grinder/influent flow splitter, two sequencing batch reactors, chlorine contact tanks, de-chlorination, and Outfall 001 to Deer Creek. The sludge is pumped to an aerated sludge holding tank, and then pumped to a belt press.

Changes to the permit: E. Coli monitoring has been added to the permit. Total Copper and Total Zinc monitoring have been added to the permit. A more stringent TRC limit has been imposed. A 1-year compliance schedule for TRC has been added to the permit.

There are no open violations for the Applicant.

Sludge use and disposal description and locations: Aerated sludge holding and belt press, disposed of at landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	May 28, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	June 2, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	.28
Latitude	41° 6' 25"	Longitude	80° 28' 6"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Deer Creek (WWF)	Stream Code	35888
NHD Com ID	130025407	RMI	2.4
Drainage Area	11 mi ²	Yield (cfs/mi ²)	0.013
Q ₇₋₁₀ Flow (cfs)	0.147	Q ₇₋₁₀ Basis	USGS PA StreamStats
Elevation (ft)	1054	Slope (ft/ft)	
Watershed No.	20-A	Chapter 93 Class.	WWF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	N/A		
Source(s) of Impairment	N/A		
TMDL Status	N/A	Name	N/A
Nearest Downstream Public Water Supply Intake		PA American Water Company - New Castle	
PWS Waters	Shenango River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	12.0

Changes Since Last Permit Issuance: None

Treatment Facility Summary				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Chlorine With Dechlorination	0.28
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.28	376	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: None

Compliance History	
Summary of DMRs:	There were no violations in the past year DMR data.
Summary of Inspections:	2/16/2022: A routine inspection was conducted. No issues were reported.

Other Comments: There are currently no open violations for this Applicant

Compliance History

DMR Data for Outfall 001 (from April 1, 2024 to March 31, 2025)

Parameter	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24
Flow (MGD) Average Monthly	0.186	0.199	0.125	0.144	0.113	0.090	0.103	0.114	0.103	0.108	0.132	0.271
Flow (MGD) Weekly Average	0.222	0.256	0.184	0.186	0.144	0.101	0.132	0.170	0.125	0.114	0.155	0.591
pH (S.U.) Daily Minimum	7.2	7.0	7.0	7.0	7.2	7.1	7.2	6.9	7.0	6.9	7.0	6.7
pH (S.U.) Daily Maximum	7.8	7.8	7.7	7.9	7.7	7.9	8.0	8.2	7.9	7.7	7.6	7.3
DO (mg/L) Daily Minimum	8.8	8.0	7.3	8.5	8.0	6.9	6.7	6.2	6.0	6.8	6.2	6.2
TRC (mg/L) Average Monthly	0.1	< 0.1	0.1	< 0.1	0.1	0.1	0.1	< 0.1	0.1	0.1	0.1	0.1
TRC (mg/L) Instantaneous Maximum	0.09	0.06	0.05	0.10	0.19	0.09	0.11	0.10	0.40	0.10	0.30	0.18
CBOD5 (lbs/day) Average Monthly	< 4.8	< 3.2	< 2.6	< 5.8	2.7	2.7	< 4.5	9.1	< 2.9	5.9	6.5	< 6.6
CBOD5 (lbs/day) Weekly Average	8.4	4.3	4.0	9.4	4.6	3.9	10.0	23.2	5.5	7.7	8.2	13.1
CBOD5 (mg/L) Average Monthly	< 3.1	< 2.0	< 2.8	< 4.8	2.8	3.2	< 4.8	5.6	< 3.4	6.6	6.6	< 4.4
CBOD5 (mg/L) Weekly Average	4.9	2.1	3.9	10.0	3.1	4.0	6.6	6.3	5.9	8.3	7.6	6.3
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	131	213	120	86	107	63	87	131	75	124	106	116
BOD5 (mg/L) Raw Sewage Influent Average Monthly	89	144	131	80	121	77	98	86	89	136	108	88
TSS (lbs/day) Average Monthly	< 7.6	< 7.9	< 4.6	< 7.6	< 4.8	< 4.6	< 4.5	< 7.9	< 4.2	< 4.5	< 5.5	< 7.3
TSS (lbs/day) Raw Sewage Influent Average Monthly	116	141	109	68	46	35	37	62	37	67	76	103

NPDES Permit Fact Sheet
New Bedford STP

NPDES Permit No. PA0240125

TSS (lbs/day) Weekly Average	< 8.6	< 10.1	< 5.0	< 9.4	< 7.7	6.1	< 7.5	< 19.3	< 4.6	< 4.8	6.9	< 10.4
TSS (mg/L) Average Monthly	< 5.0	< 5.0	< 5.0	< 5.8	< 5.0	< 5.5	< 5.0	< 5.0	< 5.0	< 5.0	< 5.8	< 5.0
TSS (mg/L) Raw Sewage Influent Average Monthly	77	90	121	61	51	43	44	46	44	74	80	81
TSS (mg/L) Weekly Average	< 5.0	< 5.0	< 5.0	8.0	< 5.0	7.0	< 5.0	< 5.0	< 5.0	< 5.0	8.0	< 5.0
Fecal Coliform (No./100 ml) Geometric Mean	< 9	152	392	41	8	< 11	< 29	17	33	142	138	94
Fecal Coliform (No./100 ml) Instantaneous Maximum	26	1302	3635	67	32	16	120	134	214	494	581	687
Total Nitrogen (mg/L) Average Quarterly	10.6			10.3			8.62			4.92		
Ammonia (lbs/day) Average Monthly	< 0.3	< 0.3	< 0.1	< 0.3	< 0.1	< 0.3	0.5	< 1.2	< 0.3	< 0.2	< 0.5	< 2.7
Ammonia (mg/L) Average Monthly	< 0.2	< 0.2	< 0.2	< 0.2	0.1	< 0.3	0.4	< 0.5	< 0.3	< 0.2	< 0.5	< 2.0
Total Phosphorus (mg/L) Average Quarterly	2.5				2.1			< 1.0			0.9	

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	.28	
Latitude	41° 6' 25"	Longitude	80° 28' 6"	
Wastewater Description:	Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: E. Coli monitoring has been added per Chapter 92 requirements.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
NH3-N	2.21	Avg. Mo.	WQM 7.0
CBOD ₅	25	Avg. Mo.	WQM 7.0
Total Copper	Report	Avg. Mo.	Toxics Management Spreadsheet 1.4
Total Zinc	Report	Avg. Mo.	Toxics Management Spreadsheet 1.4

Comments: The existing CBOD₅ limit of 15 mg/l is more stringent than the WQM Model output, and will remain in the permit. The existing NH₃-N limit of 2.0 mg/l is more stringent, and will remain in the permit. DEP's Toxics Management Spreadsheet was used to evaluate toxic parameters. The spreadsheet recommended monitoring for Total Copper and Total Zinc. These parameters have been added to the renewal permit with a monitoring requirement.

Additional Considerations

This facility is a POTW, therefore, the requirement to sample raw sewage BOD and TSS has been incorporated into the permit.

DEP's TRC Evaluation Spreadsheet was used, which provided an average monthly limit of 0.06 mg/l. This is more stringent than the existing permit limit; therefore, an average monthly limit of 0.06 mg/l and an instantaneous maximum limit of 0.19 mg/l will be imposed in the permit. Based on a review of the DMR data, the more stringent limits may not be attainable so a 1 year compliance schedule was added to the NPDES permit.

Total Nitrogen and Total Phosphorus will be monitored 1/quarter per the Departments' SOP.

The previous Dissolved Oxygen minimum technology-based limit of 5.0 mg/l will be retained with this renewal.

Anti-Backsliding

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through One Year from Permit Effective Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.2	XXX	0.65	1/day	Grab
CBOD5 Nov 1 - Apr 30	58.0	93.0	XXX	25.0	40.0	50	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	35.0	54.0	XXX	15.0	23.0	30	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	70.0	105.0	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Ammonia Nov 1 - Apr 30	14.0	XXX	XXX	6.0	XXX	12	1/week	8-Hr Composite

Outfall 001, Continued (from Permit Effective Date through One Year from Permit Effective Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia May 1 - Oct 31	4.7	XXX	XXX	2.0	XXX	4	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Copper	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/month	8-Hr Composite
Total Zinc	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/month	8-Hr Composite

Compliance Sampling Location: Outfall 001, after chlorination/de-chlorination

Other Comments: None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: One Year From Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.06	XXX	0.19	1/day	Grab
CBOD5 Nov 1 - Apr 30	58.0	93.0	XXX	25.0	40.0	50	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	35.0	54.0	XXX	15.0	23.0	30	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	70.0	105.0	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Ammonia Nov 1 - Apr 30	14.0	XXX	XXX	6.0	XXX	12	1/week	8-Hr Composite

Outfall 001, Continued (from One Year From Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia May 1 - Oct 31	4.7	XXX	XXX	2.0	XXX	4	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Copper	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/month	8-Hr Composite
Total Zinc	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/month	8-Hr Composite

Compliance Sampling Location: Outfall 001, after chlorination/de-chlorination

Other Comments: None


New Bedford STP PA0240125 Outfall 001

Region ID: PA

Workspace ID: PA20250509014622025000

Clicked Point (Latitude, Longitude): 41.10686, -80.46857

Time: 2025-05-08 21:46:56 -0400



[Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	11	square miles
ELEV	Mean Basin Elevation	1054	feet

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	11	square miles	2.26	1400
ELEV	Mean Basin Elevation	1054	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.387	ft ³ /s	43	43
30 Day 2 Year Low Flow	0.662	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.147	ft ³ /s	66	66
30 Day 10 Year Low Flow	0.26	ft ³ /s	54	54
90 Day 10 Year Low Flow	0.459	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.


New Bedford STP PA0240125 RMI = 0.0

Region ID: PA

Workspace ID: PA20250509015039774000

Clicked Point (Latitude, Longitude): 41.10335, -80.43550

Time: 2025-05-08 21:51:13 -0400



 [Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	13.6	square miles
ELEV	Mean Basin Elevation	1043	feet

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	13.6	square miles	2.26	1400
ELEV	Mean Basin Elevation	1043	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.489	ft^3/s
30 Day 2 Year Low Flow	0.828	ft^3/s
7 Day 10 Year Low Flow	0.19	ft^3/s
30 Day 10 Year Low Flow	0.33	ft^3/s
90 Day 10 Year Low Flow	0.576	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

TRC_CALC

1A	B	C	D	E	F	G			
2	TRC EVALUATION								
3	Input appropriate values in B4:B8 and E4:E7								
4	0.147	= Q stream (cfs)		0.5	= CV Daily				
5	0.28	= Q discharge (MGD)		0.5	= CV Hourly				
6	30	= no. samples		1	= AFC_Partial Mix Factor				
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor				
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)				
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)				
	0	= % Factor of Safety (FOS)			= Decay Coefficient (K)				
10	Source	Reference	AFC Calculations	Reference	CFC Calculations				
11	TRC	1.3.2.iii	WLA_afc = 0.127	1.3.2.iii	WLA_cfc = 0.117				
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581				
13	PENTOXSD TRG	5.1b	LTA_afc = 0.047	5.1d	LTA_cfc = 0.068				
14									
15	Source	Effluent Limit Calculations							
16	PENTOXSD TRG	5.1f	AML MULT = 1.231						
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.058	AFC					
18			INST MAX LIMIT (mg/l) = 0.191						
19									
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ ... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$								
LTA_afc	$wla_afc*LTAMULT_afc$								
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ ... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$								
LTA_cfc	$wla_cfc*LTAMULT_cfc$								
AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$								
AVG MON LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$								
INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$								

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC																																	
20A	35888 DEER CREEK				2.400	1054.00	11.00	0.00000	0.00	<input checked="" type="checkbox"/>																																	
Stream Data																																											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)																																	
<table> <tr> <td>Q7-10</td><td>0.100</td><td>0.00</td><td>0.15</td><td>0.000</td><td>0.000</td><td>0.0</td><td>0.00</td><td>0.00</td><td>20.00</td><td>7.00</td></tr> <tr> <td>Q1-10</td><td></td><td>0.00</td><td>0.00</td><td>0.000</td><td></td><td>0.000</td><td></td><td></td><td></td><td></td></tr> <tr> <td>Q30-10</td><td></td><td>0.00</td><td>0.00</td><td>0.000</td><td></td><td>0.000</td><td></td><td></td><td></td><td></td></tr> </table>											Q7-10	0.100	0.00	0.15	0.000	0.000	0.0	0.00	0.00	20.00	7.00	Q1-10		0.00	0.00	0.000		0.000					Q30-10		0.00	0.00	0.000		0.000				
Q7-10	0.100	0.00	0.15	0.000	0.000	0.0	0.00	0.00	20.00	7.00																																	
Q1-10		0.00	0.00	0.000		0.000																																					
Q30-10		0.00	0.00	0.000		0.000																																					
Discharge Data																																											
				Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)																																	
New Bedford STP		PA0240125			0.2800	0.2800	0.2800	0.000	25.00	7.00																																	
Parameter Data																																											
						Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)																																		
				CBOD5		25.00	2.00	0.00	1.50																																		
				Dissolved Oxygen		4.00	8.24	0.00	0.00																																		
				NH3-N		25.00	0.00	0.00	0.70																																		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35888 DEER CREEK				0.000	1043.00	13.60	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)
Q7-10	0.100	0.00	0.19	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
Discharge Data										
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH			
		0.0000	0.0000	0.0000	0.000	0.00	7.00			
Parameter Data										
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)						
CBOD5	25.00	2.00	0.00	1.50						
Dissolved Oxygen	3.00	8.24	0.00	0.00						
NH3-N	25.00	0.00	0.00	0.70						

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
20A			35888			DEER CREEK						
RMI	Stream Flow	PWS Wth	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
2.400	0.15	0.00	0.15	.4332 0.00087	.505	14.54	28.81	0.08	1.856	23.73	7.00	
Q1-10 Flow												
2.400	0.09	0.00	0.09	.4332 0.00087	NA	NA	NA	0.07	1.958	24.11	7.00	
Q30-10 Flow												
2.400	0.20	0.00	0.20	.4332 0.00087	NA	NA	NA	0.08	1.767	23.42	7.00	

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
20A	35888	DEER CREEK					
NH3-N Acute Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.400	New Bedford STP	11.92	14.51	11.92	14.51	0	0
NH3-N Chronic Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.400	New Bedford STP	1.51	2.21	1.51	2.21	1	0
Dissolved Oxygen Allocations							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
2.40	New Bedford STP	25	25	2.21	2.21	4	4
						0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	35888	DEER CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.400	0.280	23.733	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
14.544	0.505	28.813	0.079	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
19.17	1.026	1.65	0.933	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
5.075	15.336	Owens	5	
<u>Reach Travel Time (days)</u>	Subreach Results			
1.856	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.186	15.29	1.39	6.14
	0.371	12.20	1.17	6.64
	0.557	9.73	0.98	7.01
	0.742	7.76	0.83	7.31
	0.928	6.19	0.69	7.55
	1.114	4.94	0.58	7.71
	1.299	3.94	0.49	7.71
	1.485	3.14	0.41	7.71
	1.670	2.51	0.35	7.71
	1.856	2.00	0.29	7.71

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20A	35888	DEER CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Efl. Limit 30-day Ave. (mg/L)	Efl. Limit Maximum (mg/L)	Efl. Limit Minimum (mg/L)
2.400	New Bedford STP	PA0240125	0.280	CBOD5	25		
				NH3-N	2.21	4.42	
				Dissolved Oxygen			4



Discharge Information

Instructions Discharge Stream

Facility: New Bedford STP NPDES Permit No.: PA0240125 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated sewage

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q_{7-10}	Q_h
0.28	100	7						

		Discharge Pollutant	Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L											
	Chloride (PWS)	mg/L		181									
	Bromide	mg/L		0.112									
	Sulfate (PWS)	mg/L		55.2									
	Fluoride (PWS)	mg/L	<										
Group 2	Total Aluminum	mg/L											
	Total Antimony	µg/L	<										
	Total Arsenic	µg/L											
	Total Barium	µg/L											
	Total Beryllium	µg/L	<										
	Total Boron	µg/L											
	Total Cadmium	µg/L	<										
	Total Chromium (III)	µg/L	<										
	Hexavalent Chromium	µg/L	<										
	Total Cobalt	µg/L	<										
	Total Copper	mg/L		0.004									
	Free Cyanide	µg/L											
	Total Cyanide	µg/L	<										
	Dissolved Iron	µg/L											
	Total Iron	mg/L		0.0004									
	Total Lead	µg/L	<										
	Total Manganese	mg/L											
	Total Mercury	µg/L											
	Total Nickel	µg/L	<										
	Total Phenols (Phenolics) (PWS)	µg/L	<										
	Total Selenium	µg/L	<										
	Total Silver	µg/L	<										
	Total Thallium	µg/L	<										
	Total Zinc	mg/L		0.029									
	Total Molybdenum	µg/L											
	Acrolein	µg/L	<										
	Acrylamide	µg/L	<										
	Acrylonitrile	µg/L	<										
	Benzene	µg/L	<										
	Bromoform	µg/L	<										



Stream / Surface Water Information

Toxics Management Spreadsheet
Version 1.4, May 2023

Instructions **Discharge** Stream

New Bedford STP, NPDES Permit No. PA0240125, Outfall 001

Receiving Surface Water Name: Deer Creek

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	035888	2.4	1054	11			Yes
End of Reach 1	035888	0	1043	13.6			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream
		Stream	Tributary						Hardness	pH
Point of Discharge	2.4	0.1	0.147							
End of Reach 1	0	0.1	0.19						100	7

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream
		Stream	Tributary						Hardness	pH
Point of Discharge	2.4									
End of Reach 1	0									

Model Results

New Bedford STP, NPDES Permit No. PA0240125, Outfall 001

Instructions

RETURN TO INPUTS

SAVE AS PDF

PRINT

● All ○ Inputs ○ Results ○ Limits

□ *Hydrodynamics*

Wasteload Allocations

AFC

CCCT (min):	1.762	PMF:	1	Analysis Hardness (mg):	100	Analysis pH:	7.00
-------------	-------	------	---	-------------------------	-----	--------------	------

Pollutants	Stream			Trib Conc ($\mu\text{g/L}$)	Fate Coef	WQC ($\mu\text{g/L}$)	WQA Obj ($\mu\text{g/L}$)	Comments
	Stream Conc ($\mu\text{g/L}$)	Stream CV	WLA ($\mu\text{g/L}$)					
Chloride (PWS)	0	0	N/A	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	N/A	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	13.439	14.0	18.7	Chem Translator of 0.96 applied
Total Iron	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	117.180	120	160	Chem Translator of 0.978 applied

CFCC	1.762	CCT (min):	1	PMF:	100	Analysis Hardness (mgf):	7.00	Analysis pH:	7.00
------	-------	------------	---	------	-----	--------------------------	------	--------------	------

CCCT (min): 1.762 PMF: 1

Analysis pH: 7.00

Pollutants	Stream			Trib Conc ($\mu\text{g/L}$)	Fate Coeff	WQC ($\mu\text{g/L}$)	WLA ($\mu\text{g/L}$)	Comments
	Conc ($\mu\text{g/L}$)	Stream CV	WQ Obj ($\mu\text{g/L}$)					
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	8.956	9.33	12.5	Chem Translator of 0.96 applied
Total Iron	0	0	0	0	1,500	1,500	2,009	WQC = 30 day average; PMF = 1
Total Zinc	0	0	0	0	118.139	120	160	Chem Translator of 0.986 applied

CRL

CCT (min): 7.491

PMF: 1

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments	
								WQC	WLA
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A		
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A		
Total Copper	0	0	0	0	N/A	N/A	N/A		
Total Iron	0	0	0	0	N/A	N/A	N/A		
Total Zinc	0	0	0	0	N/A	N/A	N/A		

✓ Recommended WQBELs & Monitoring Requirements

No Samples/Month:

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).