

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0091791
 APS ID 1012563
 Authorization ID 1307532

Applicant and Facility Information

Applicant Name	<u>DRBITTNER, LLC</u>	Facility Name	<u>Countryside Estates MHP STP</u>
Applicant Address	<u>339 Breakiron Road</u> <u>Connellsville, PA 15425</u>	Facility Address	<u>320 Breakneck Road</u> <u>Connellsville, PA 15425-9701</u>
Applicant Contact	<u>Donald Bittner</u>	Facility Contact	<u>Donald Bittner</u>
Applicant Phone	<u>(724) 502-0268</u>	Facility Phone	<u>(724) 502-0268</u>
Client ID	<u>329422</u>	Site ID	<u>253521</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Bullskin Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Fayette</u>
Date Application Received	<u>March 3, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 4, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit for an existing discharge of treated sewage</u>		

Summary of Review

The subject facility is a sewage treatment plant serving a Mobile Home Park in Bullskin Township, Fayette County.

Sludge use and disposal description and location(s): The facility's sludge is transferred to other sewage treatment facilities for further processing. According to the application, 0.03 tons of sludge was removed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		<i>Keith C. Allison</i> Keith C. Allison, E.I.T. / Project Manager	February 1, 2021
✓		<i>Christopher Kriley</i> Christopher Kriley, P.E. / Program Manager	February 5, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.026</u>
Latitude	<u>40° 2' 22.68"</u>	Longitude	<u>-79° 32' 42.86"</u>
Quad Name	<u>Connellsville, PA</u>	Quad Code	<u>1809</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Breakneck Run (WWF)</u>	Stream Code	<u>38100</u>
NHD Com ID	<u>69917193</u>	RMI	<u>1.29</u>
Drainage Area	<u>5.31</u>	Yield (cfs/mi ²)	<u>0.0152</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.0805</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>1100</u>	Slope (ft/ft)	<u>0.02</u>
Watershed No.	<u>19-D</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Nearest Downstream Public Water Supply Intake	<u>Westmoreland County Municipal Authority - McKeesport</u>		
PWS Waters	<u>Youghiogheny River</u>	Distance from Outfall (mi)	<u>Approx. 48</u>

Changes Since Last Permit Issuance: Stream flow was updated using the USGS StreamStats web application. Other stream and drainage characteristics were determined by interpolation of USGS topographic maps.

Other Comments: No downstream water supply is expected to be affected by the discharge at this time with the limitations and monitoring proposed.

Treatment Facility Summary				
Treatment Facility Name: Countryside Estates MHP STP				
WQM Permit No.		Issuance Date		
2681401		Transfer - 2/10/17		
		Amendment - 10/29/01		
		Original - 10/29/81		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Chlorine With Dechlorination	0.026
Hydraulic Capacity (MGD)				
0.026	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
	53	Not Overloaded	Dewatering	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: Treatment, as approved by WQM permit No 2681401, consists of extended aeration, final clarification, sand filtration, and chlorination.

Compliance History

DMR Data for Outfall 001 (from December 1, 2019 to November 30, 2020)

Parameter	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20	DEC-19
Flow (MGD) Average Monthly	0.0006	0.0007	0.000480	0.0006	0.001	0.006	0.0008	0.001	0.0005	0.0004	0.0007	0.0006
pH (S.U.) Minimum	6.3	6.5	6.3	6.0	6.0	7.2	7.3	7.4	7.2	6.1	7.1	7.0
pH (S.U.) Maximum	6.6	6.7	6.9	6.9	6.0	7.5	7.5	7.8	7.5	7.7	7.2	7.1
DO (mg/L) Minimum	5.6	5.3	4.5	4.5	4.0	5.4	5.4	8.0	8.7	8.0	5.7	5.9
TRC (mg/L) Average Monthly	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.5	0.5	0.38	0.5	0.49
TRC (mg/L) Instantaneous Maximum	0.05	0.05	0.05	0.05	0.05	0.07	0.05	0.5	0.6	0.50	0.5	0.60
CBOD5 (mg/L) Average Monthly	2.0	2.0	2.0	3.4	2.0	2.0	3.3	2.0	2.0	2.0	2.0	3.5
CBOD5 (mg/L) Instantaneous Maximum	2.0	2.0	2.0	4.7	2.0	2.0	4.6	2.0	2.0	2.0	2.0	4.7
TSS (mg/L) Average Monthly	13.5	5.0	7.5	8.5	5.0	9.5	5.0	7.5	6.5	5.0	7.5	10.0
TSS (mg/L) Instantaneous Maximum	14.0	5.0	10.0	12.0	5.0	13.0	5.0	10.0	8.0	5.0	8.0	13.0
Fecal Coliform (CFU/100 ml) Geometric Mean	2	1	1	4	1	4	1	3	19	5	35	169
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	3	1	1	7	1	14	1	4	182	14	41	298
Total Nitrogen (mg/L) Daily Maximum												19.8
Ammonia (mg/L) Average Monthly	4.3	0.2	0.1	0.9	0.4	0.1	0.8	0.5	1.9	2.3	4.3	13.1
Ammonia (mg/L) Instantaneous Maximum	6.2	0.2	0.1	1.5	0.4	0.1	1.0	0.6	3.1	2.9	6.3	14.4
Total Phosphorus (mg/L) Daily Maximum												4.8

Compliance History, Cont'd

Compliance History, Cont'd	
Summary of DMRs:	The above DMR data shows compliance with effluent limitations for the past year.
Summary of Inspections:	The facility has been inspected periodically over the past permit term. The most recent inspection by the Department on December 27, 2018 noted ongoing effluent violations at the time.
Other Comments:	A WMS query in eFACTS found no open violations for DRBITTNER, LLC in eFACTS.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.026	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/day	Grab
DO	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	19.5	XXX	39.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	6.0	XXX	13.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.026</u>
Latitude <u>40° 7' 1.00"</u>	Longitude <u>-79° 33' 58.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and included in the existing permit and will remain except a more stringent water quality-based TRC limit is necessary as discussed below.

Water Quality-Based Limitations

DO, CBOD₅ and NH₃-N

The discharge has existing water quality-based limits for ammonia-nitrogen and a BPJ-based limitation for Dissolved Oxygen.

The Department uses the WQM7.0 model to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. WQM7.0 modeling was performed and found that the Secondary limits for CBOD₅ and the existing BPJ limit for DO are adequate but the ammonia limitations should be reduced by a small margin from 6.5 mg/L to 6.49 mg/L as a monthly average. As in previous approvals, the winter (November through April) ammonia limitation was determined by a factor of three times the summer (May through October) limit.

Total Residual Chlorine

The Department uses a modeling spreadsheet to determine appropriate limitations for TRC based on available instream criteria, dilution, and other factors. The attached modeling shows that a new water quality-based limit of 0.30 mg/L is necessary to protect the receiving stream. The new limit is primarily the result of a different stream flow used compared to the previous review of the discharge. The existing DMR data as shown on page 4 of this Fact Sheet indicates that the limit is achievable.

Toxics Management

No further "Reasonable Potential Analysis" was conducted to determine additional toxic parameters for this minor treatment facility with no industrial contributors.

Nutrient Requirements

Annual nutrient monitoring was included in the existing permit. The Total Nitrogen was found to average 22 mg/L and the Total Phosphorus averaged 4.8 mg/L over the past five years. The existing annual monitoring for Total Nitrogen and Total Phosphorus is adequate and will continue.

Best Professional Judgment (BPJ) Limitations

Comments: No other BPJ limitations are necessary beyond the water quality and technology-based limitations noted above other than the existing BPJ limit for DO.

Anti-Backsliding

No limitations have been made less stringent consistent with the anti-backsliding requirements of the Clean Water Act and 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.026	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/day	Grab
DO	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.3	XXX	0.98	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	19.47	XXX	38.94	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	6.49	XXX	12.98	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab


Compliance Sampling Location: Outfall 001

Other Comments: The above limitations and monitoring are unchanged from the existing permit except for a modest reduction in the Ammonia-nitrogen limits and a more stringent TRC limit as mentioned above.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 8/23/13
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Modeling
- C. TRC Spreadsheet Model



Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19D	38100	BREAKNECK RUN	1.290	1200.00	5.31	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.015	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
DrBitner	PA0091791	0.0260	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NHG-N	6.50	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19D	38100	BREAKNECK RUN	0.290	1100.00	6.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.015	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NHG-N	25.00	0.00	0.00	0.70

Permit No. PA0091791

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
19D		38100				BREAKNECK RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
1.290	0.08	0.00	0.08	.0402	0.01894	.374	6.5	17.38	0.05	1.227	21.66	7.00
Q1-10 Flow												
1.290	0.05	0.00	0.05	.0402	0.01894	NA	NA	NA	0.04	1.432	22.19	7.00
Q30-10 Flow												
1.290	0.11	0.00	0.11	.0402	0.01894	NA	NA	NA	0.06	1.088	21.34	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Permit No. PA0091791

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19D	38100	BREAKNECK RUN		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
1.290	0.026	21.663		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
6.498	0.374	17.383		0.050
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
9.65	1.027	2.16		0.796
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
6.832	18.675	O wens		5
<u>Reach Travel Time (days)</u>	Subreach Results			
1.227	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.123	8.42	1.96	7.62
	0.245	7.35	1.78	7.82
	0.368	6.42	1.61	7.95
	0.491	5.60	1.46	7.99
	0.614	4.89	1.32	7.99
	0.736	4.26	1.20	7.99
	0.859	3.72	1.09	7.99
	0.982	3.25	0.99	7.99
	1.105	2.84	0.90	7.99
	1.227	2.47	0.81	7.99

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>							
19D	38100	BREAKNECK RUN							
<hr/>									
NH3-N Acute Allocations									
<u>RMI</u>	<u>Discharge Name</u>	<u>Baseline Criterion (mg/L)</u>	<u>Baseline WLA (mg/L)</u>	<u>Multiple Criterion (mg/L)</u>	<u>Multiple WLA (mg/L)</u>	<u>Critical Reach</u>	<u>Percent Reduction</u>		
1.290	DrBittner	8.26	13	8.26	13	0	0		
<hr/>									
NH3-N Chronic Allocations									
<u>RMI</u>	<u>Discharge Name</u>	<u>Baseline Criterion (mg/L)</u>	<u>Baseline WLA (mg/L)</u>	<u>Multiple Criterion (mg/L)</u>	<u>Multiple WLA (mg/L)</u>	<u>Critical Reach</u>	<u>Percent Reduction</u>		
1.290	DrBittner	1.74	6.49	1.74	6.49	0	0		
<hr/>									
Dissolved Oxygen Allocations									
<u>RMI</u>	<u>Discharge Name</u>	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		<u>Critical Reach</u>	<u>Percent Reduction</u>
		<u>Baseline (mg/L)</u>	<u>Multiple (mg/L)</u>	<u>Baseline (mg/L)</u>	<u>Multiple (mg/L)</u>	<u>Baseline (mg/L)</u>	<u>Multiple (mg/L)</u>		
1.29	DrBittner	25	25	6.49	6.49	4	4	0	0

Permit No. PA0091791

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19D	38100	BREAKNECK RUN

RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	E fl. Limit 30-day Ave. (mg/L)	E fl. Limit Maximum (mg/L)	E fl. Limit Minimum (mg/L)
1.290	DrBittner	PA0091791	0.026	CBOD5	25		
				NH3-N	6.49	12.98	
				Dissolved Oxygen			4

Source		Reference	AFC Calculations	Reference	CFC Calculations
TRC		1.3.2.iii	WLA_afc = 0.657	1.3.2.iii	WLA_cfc = 0.633
PENTOXSD TRG		5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG		5.1b	LTA_afc = 0.245	5.1d	LTA_cfc = 0.368
Source		Effluent Limit Calculations			
PENTOXSD TRG		5.1f	AML MULT = 1.231		
PENTOXSD TRG		5.1g	AVG MON LIMIT (mg/l) = 0.302		AFC
			INST MAX LIMIT (mg/l) = 0.986		
WLA_afc	(.019/e ^(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd ^e (-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_afc	EXP((0.5*LN(cvh ² +1)))-2.326*LN(cvh ² +1) ^{0.5}				
LTA_afc	wla_afc*LTAMULT_afc				
WLA_cfc	(.011/e ^(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd ^e (-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_cfc	EXP((0.5*LN(cvd ² /no_samples+1)))-2.326*LN(cvd ² /no_samples+1) ^{0.5}				
LTA_cfc	wla_cfc*LTAMULT_cfc				
AML MULT	EXP(2.326*LN((cvd ² /no_samples+1) ^{0.5})-0.5*LN(cvd ² /no_samples+1))				
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)				