

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0093157
 APS ID 1018896
 Authorization ID 1318926

Applicant and Facility Information

Applicant Name	<u>Moraine Camplands Association Inc.</u>	Facility Name	<u>Moraine Camplands</u>
Applicant Address	<u>281 Staff Road</u> <u>Slippery Rock, PA 16057-5327</u>	Facility Address	<u>281 Staff Road</u> <u>Slippery Rock, PA 16057-5327</u>
Applicant Contact	<u>Jonathan Bluedorn</u>	Facility Contact	<u>Jonathon Bluedorn</u>
Applicant Phone	<u>(724) 794-6242</u>	Facility Phone	<u>(724) 794-6242</u>
Applicant E Mail	<u>Bluedorn3@yahoo.com</u>	Facility E Mail	<u></u>
Client ID	<u>37526</u>	Site ID	<u>270128</u>
Municipality	<u>Brady Township</u>	County	<u>Butler</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No Limitations</u>
Application Received	<u>June 3, 2020</u>	EPA Waived?	<u>Yes</u>
Application Accepted	<u>July 2, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES discharge permit renewal/</u>		

Summary of Review

No violations on file.

Sludge use and disposal description and location(s): 0.57-dry tons hauled to the New Castle STP.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	December 8, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	December 9, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.05</u>
Latitude DP	<u>41° 0' 4.20"</u>	Longitude DP	<u>-80° 0' 9.00"</u>
Latitude NHD	<u>41° 0' 3.81"</u>	Longitude NHD	<u>-80° 0' 8.16"</u>
Quad Name	<u>Slippery Rock</u>	Quad Code	<u>1005</u>
Wastewater:	<u>Treated campground domestic wastes</u>		
Receiving Waters	<u>Unnamed Tributary to Big Run</u>	Stream Code	<u>34431</u>
NHD Com ID	<u>126222104</u>	RMI	<u>0.31</u>
Drainage Area	<u>0.91</u>	Yield (cfs/mi ²)	<u>Intermittent stream</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>Muddy Creek at Isle</u>
Elevation (ft)	<u>1282.73</u>	Slope (ft/ft)	<u>0.02</u>
Watershed No.	<u>20-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>Big Run 34427 RMI 2.37 Drainage 3.77 sq mi Elevation 1225.98 feet</u>		
Low Flow	<u>Muddy Creek at Isle 03106200 0.4 cfs 29.3 square mile yield 0.014 cfs/square mile²</u>		
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Siltation, Metals</u>		
Source(s) of Impairment	<u>Abandoned Mine Drainage</u>		
TMDL Status	<u>pending</u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	<u>default</u>	
Temperature (°C)	<u>20</u>	<u>default</u>	
Hardness (mg/L)	<u></u>	<u></u>	
Other:	<u>7.1</u>	<u>Discharge pH median 1987-1993</u>	
Nearest Downstream Public Water Supply Intake	<u>Pa American Water</u>		
PWS Waters	<u>Connoquenessing Creek</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>0.01</u>	Distance from Outfall (mi)	<u>34.5</u>

Changes Since Last Permit Issuance: Water intake shifted from mouth of Slippery Rock to mouth of Connoquenessing.

Other Comments:

Formerly the downstream water supply evaluated was the Slippery Rock Creek at the Salvation Army Camp Allegheny. This water supply is no longer used

Treatment Facility Summary				
Treatment Facility Name: Moraine Camplands				
WQM Permit No.	Issuance Date			
1074405	3/15/1974			
1074405 A1	3/25/2011			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Septic Tank Sand Filter	Hypochlorite	0.05
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.05	100	Not Overloaded	Aerobic Digestion	Offsite

Changes Since Last Permit Issuance: none

WQM 1074405

Comminution, flow splitting, parallel aeration tanks with clarifiers, sand filtration, disinfection and aerated sludge holding. This permit is as modified below with all special conditions superseded.

WQM 107445 A1, November 20, 2010 application date, revised on February 17, 2011 and issued on March 25, 2011 for: Chemical feed installation, air lift pump replacement, aeration coarse bubble diffuser replacement with fine bubble diffusers, and old plate settler conversion to aerated sludge holding.

	Ave	Ave	
	MGD	PPD	
Annual Average Design	0.05		
Hydraulic Design Capacity	0.005-		
Organic Design Capacity		100	
Annual Average	2017	0.0250	
	2018	0.0235	
	2019	0.0240	
Peak Monthly Mean June		0.0680	
pH			6.3
TRC			7.5
F coliform			0.06
CBOD5			22
TSS			2
Amm			6
N			0.25
P			8.20
			0.89

Compliance History

DMR Data for Outfall 001 (from May 1, 2020 to April 30, 2021)

Parameter	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20
Flow (MGD) Average Monthly	0.017	0.022	0.094	0.0172	0.021	0.008	0.012	0.018	0.021	0.021	0.011	0.023
pH (S.U.) Minimum	8.10	7.80	7.6	7.7	7.1	7.1	6.7	6.6	6.60	6.60	7.10	6.8
pH (S.U.) Maximum	8.40	8.30	8.9	8.8	8.4	7.8	7.8	7.3	7.40	7.40	7.50	7.8
DO (mg/L) Daily Minimum	6.90	7.08	7.4	8.0	5.40	5.95	5.1	3.40	3.50	3.40	3.14	3.0
TRC (mg/L) Average Monthly	0.23	0.03	0.7	0.5	0.40	0.40	0.30	0.27	0.20	0.14	0.40	0.24
CBOD5 (mg/L) Average Monthly	6.50	6.25	2.0	5.0	5.60	3.75	6.45	4.45	6.55	8.35	5.75	3.95
TSS (mg/L) Average Monthly	1.0	1.0	1.0	1.0	3.50	3.50	4.50	3.50	7.0	7.0	6.0	1.0
Fecal Coliform (CFU/100 ml) Geometric Mean	1.0	1.0	1.0	1.0	3.0	1.0	1.73	3.87	3.31	12.0	3.31	2.82
Total Nitrogen (mg/L) Average Monthly	5.23	1.83	3.03	2.98	2.90	9.52	22.6	23.45	31.5	37.0	14.3	13.0
Ammonia (mg/L) Average Monthly	0.30	0.30	0.30	0.30	0.30	1.78	0.30	0.90	3.0	1.07	1.30	0.17
Total Phosphorus (mg/L) Average Monthly	0.565	0.40	0.51	0.46	0.635	1.73	2.54	2.08	2.65	2.30	1.80	0.98

Median pH 7.5 SU Summer pH median 6.95 SU

Effluent Violations for Outfall 001, from: June 1, 2020 To: April 30, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	02/28/21	Avg Mo	0.7	mg/L	0.5	mg/L

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) .05
 Latitude 41° 0' 4.20" Longitude -80° 0' 9.00"
 Wastewater Description: Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4.0	Daily Minimum		BPJ

Comments: *Monitoring was added for E. Coli at a frequency of 1/year. The basis for this monitoring is the application of Chapter 92a.61 as recommended by the SOP for flows between 0.002 MGD and 0.05 MGD. JCD*

Water Quality-Based Limitations

CBOD₅, TSS, P, TRC, DO, and pH were evaluated.

Secondary treatment with ammonia reduction is recommended. No TRC requirements are necessary in the primary dry receiving waters to protect aquatic life.

Previously the discharge was considered remote and not a nuisance. The receiving waters were classified as a dry stream and evaluated for dissolved oxygen. The resulting stream quality was then evaluated at the first point of use on Big Run. Modelling recommended a 3.0-mg/L minimum daily dissolved oxygen limit and a 3.5-mg/L summer ammonia limit. As the facility was achieving a 3.0-mg/L summer ammonia limit, the existing 3.0-mg/L summer limit was retained (no backsliding).

The current ammonia criteria does not change the ammonia requirements and anti-backsliding allows the 3.0-mg/L summer ammonia limitation to be retained.

Retention of the existing 3.0-mg/L minimum daily dissolved oxygen limitation is recommended based on remote operation and septic tank/sand filter treatment without aeration. The cold-water fish criteria is not appropriate as the receiving stream is a dry channel with no flowing water.

Three WQM 7.0 runs were done. A two-node run less the fish criteria and with a 5.0-mg/L in stream dissolved oxygen level relaxed the ammonia requirements to 4.03-mg/L and recommended a 5.0-mg/L minimum daily dissolved oxygen. A second run without fish criteria and with a 3.0-mg/L in stream dissolved oxygen level recommended 2.98-mg/L ammonia and 3.0-mg/L minimum daily dissolved oxygen. A two-stage run with 3.0-mg/L dry stream and 5.0-mg/L perennial stream dissolved oxygen recommended a 3.08-mg/L perennial stream ammonia and 3.0-mg/L dry stream dissolved oxygen limitations.

Best Professional Judgment (BPJ) Limitations

Comments: No change in the DO requirements is proposed as no aeration facilities are present.

Anti-Backsliding

The revised criteria relaxed the ammonia requirements. As the facility is achieving compliance with the existing limitations no change is proposed.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	3.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	XXX	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location Outfall 001 after disinfection.

E. Coli monitoring added per the SOP. jcd

Discharger Site Moraine Camplands STP
Municipality Moraine Camplands
County Brady Township
NPDES Permit Butler
0.5 PA0093157

Monday, November 29, 2021
 Revised Wednesday, December 8, 2021

TRC EVALUATION

Input appropriate values in B4:B8 and E4:E7

0.0515	= Q stream (cfs)	0.5	= CV Daily
0.0500	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.4	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0	= BAT/BJP Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.298	1.3.2.iii	WLA_cfc = 0.284
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.111	5.1d	LTA_cfc = 0.165

Source	Effluent Limit Calculations	
PENTOXSD TRG	5.1f	AML MULT = 1.231
PENTOXSD TRG	5.1g	LIMIT (mg/l) = 0.137
		X LIMIT (mg/l) = 0.447

WLA_afc $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$
 LTAMULT_afc $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1) \cdot 0.5)$
 LTA_afc $wla_afc \cdot LTAMULT_afc$
 WLA_cfc $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$
 LTAMULT_cfc $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1) \cdot 0.5)$
 LTA_cfc $wla_cfc \cdot LTAMULT_cfc$
 AML_MULT $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1) \cdot 0.5) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$
 AVG_MON_LIMIT $MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$
 INST_MAX_LIMIT $1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$

$(0.011 / EXP(-K \cdot CFC_tc / 1440)) + ((CFC_Yc \cdot Qs \cdot 0.011) / (1.547 \cdot Qd)) \dots$
 $\dots \cdot EXP(-K \cdot CFC_tc / 1440)) + Xd + (CFC_Yc \cdot Qs \cdot Xs / 1.547 \cdot Qd) \cdot (1 - FOS / 100)$

Stream	Chlorine Required	=	perennial	Chlorine Demand	+	Chlorine Residual
Stream	Reach/Node		2	1		2
Stream	Flow	Conditions		intermittent		perennial
Stream	Code			34431		34427
Stream	Function					
Samples			30	30		
reach	outfall	RMI	0.31	2.37		
reach	Reach End	RMI	0	0		
reach		feet	1636.8	12513.6		
drainage		sq miles	0.91	3.77		
TRC	limitation	average	mg/L	0.049		0.137
		maximum	mg/L	0.129		0.447
elevation	modelled	feet	1282.73	1225.98		
elevation	modelled	feet	1225.98	1182.43		
slope	modelled	foot/foot	0.035	0.003		
low flow		cfs/sq mi	0.014	0.014		
discharge		mgd	0.0500	0.0500		
Runoff	Period	hours	24.000	24.000		

Intermittent stream discharge. TRC revised at outfall and estimated perennial stream conditions. Stream chlorine is expected to naturally abate prior to reaching perennial flow conditions.

stream	flow	cfs	0.01242	0.05147
stream	flow	MGD	0.008029	0.033264
stream	flow	total	0.058029	0.083264
stream	chlorine	demand	mg/L	0.4
discharge	discharge	demand	mg/L	0.4
stream	Total Stream/Waste	ratio	1.2	1.7
permitted	TRC	mean	BAT	0.5
permitted	TRC	maximum	BAT	1.6

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	34431	Trib 34431 to Big Run	3.080	1282.73	0.91	0.00000	0.00	<input type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.014	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Moraine Camp	PA0093157A	0.0500	0.0500	0.0500	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	34431 Trib	34431 to Big Run	2.770	1225.98	3.77	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.014	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	34431 Trib	34431 to Big Run	0.000	1182.43	293.56	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.014	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		34431				Trib 34431 to Big Run						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
3.080	0.01	0.00	0.01	.0773	0.03467	.353	3.9	11.03	0.07	0.289	24.29	7.00
2.770	0.05	0.00	0.05	.0773	0.00298	.377	7.19	19.05	0.05	3.529	22.97	7.00
Q1-10 Flow												
3.080	0.01	0.00	0.01	.0773	0.03467	NA	NA	NA	0.06	0.298	24.52	7.00
2.770	0.03	0.00	0.03	.0773	0.00298	NA	NA	NA	0.04	3.855	23.48	7.00
Q30-10 Flow												
3.080	0.02	0.00	0.02	.0773	0.03467	NA	NA	NA	0.07	0.282	24.08	7.00
2.770	0.07	0.00	0.07	.0773	0.00298	NA	NA	NA	0.05	3.269	22.59	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20C	34431	Trib 34431 to Big Run

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.080	Moraine Camp	NA	50	11.52	24.25	2	51
2.770		NA	NA	12.56	NA	NA	NA

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.080	Moraine Camp	NA	25	1.45	4.03	2	84
2.770		NA	NA	1.6	NA	NA	NA

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
3.08	Moraine Camp	25	25	4.03	4.03	5	5	0	0
2.77		NA	NA	NA	NA	NA	NA	NA	NA

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
20C	34431	Trib 34431 to Big Run			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
3.080	0.050	24.293		7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
3.897	0.353	11.034		0.065	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
21.75	1.474	3.48		0.974	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
5.459	26.510	Owens		NA	
<u>Reach Travel Time (days)</u>	Subreach Results				
0.289	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.029	20.65	3.38	5.62	
	0.058	19.60	3.29	5.76	
	0.087	18.61	3.19	5.89	
	0.116	17.66	3.10	6.01	
	0.145	16.77	3.02	6.12	
	0.174	15.92	2.93	6.23	
	0.203	15.11	2.85	6.33	
	0.232	14.35	2.77	6.43	
	0.261	13.62	2.70	6.52	
	0.289	12.93	2.62	6.61	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
2.770	0.050	22.972		7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
7.189	0.377	19.052		0.048	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
9.57	0.387	1.81		0.880	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
7.114	18.467	Owens		5	
<u>Reach Travel Time (days)</u>	Subreach Results				
3.529	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.353	8.18	1.32	8.07	
	0.706	7.00	0.97	8.20	
	1.059	5.98	0.71	8.24	
	1.411	5.12	0.52	8.24	
	1.764	4.37	0.38	8.24	
	2.117	3.74	0.28	8.24	
	2.470	3.20	0.21	8.24	
	2.823	2.74	0.15	8.24	
	3.176	2.34	0.11	8.24	
	3.529	2.00	0.08	8.24	

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20C	34431	Trib 34431 to Big Run					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.080	Moraine Camp	PA0093157A	0.050	CBOD5	25		
				NH3-N	4.03	8.06	
				Dissolved Oxygen			5

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	34431	Trib 34431 to Big Run	3.080	1282.73	0.91	0.00000	0.00	<input type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.014	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
Moraine Camp	PA0093157A	0.0500	0.0500	0.0500	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	34431 Trib	34431 to Big Run	2.770	1225.98	3.77	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.014	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		34431				Trib 34431 to Big Run						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
3.080	0.01	0.00	0.01	.0773	0.03467	.353	3.9	11.03	0.07	0.289	24.29	7.00
Q1-10 Flow												
3.080	0.01	0.00	0.00	.0773	0.03467	NA	NA	NA	0.00	0.000	0.00	0.00
Q30-10 Flow												
3.080	0.02	0.00	0.00	.0773	0.03467	NA	NA	NA	0.00	0.000	0.00	0.00

WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	3		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20C	34431	Trib 34431 to Big Run

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	3.08 Moraine Camp	25	25	25	25	3	3	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	34431	Trib 34431 to Big Run		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
3.080	0.050	24.293		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
3.897	0.353	11.034		0.065
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
21.75	1.474	21.48		0.974
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
3.741	26.510	Owens		NA
<u>Reach Travel Time (days)</u>	Subreach Results			
0.289	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.029	20.65	20.88	3.23
	0.058	19.60	20.30	3.10
	0.087	18.61	19.74	3.15
	0.116	17.66	19.19	3.27
	0.145	16.77	18.65	3.43
	0.174	15.92	18.14	3.60
	0.203	15.11	17.63	3.76
	0.232	14.35	17.14	3.93
	0.261	13.62	16.66	4.09
	0.289	12.93	16.20	4.25

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
20C		34431		Trib 34431 to Big Run			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.080	Moraine Camp	PA0093157A	0.050	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	34431 Trib	34431 to Big Run	2.770	1225.98	3.77	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.014	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
Morain	PA	0.0500	0.0500	0.0500	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	12.93	2.00	0.00	1.50
Dissolved Oxygen	4.25	8.24	0.00	0.00
NH3-N	162.00	0.00	0.00	0.70

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	34431 Trib	34431 to Big Run	0.000	1182.43	293.56	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.014	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		34431				Trib 34431 to Big Run						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
2.770	0.05	0.00	0.05	.0773	0.00298	.377	7.19	19.05	0.05	3.529	22.97	7.00
Q1-10 Flow												
2.770	0.03	0.00	0.03	.0773	0.00298	NA	NA	NA	0.04	3.855	23.48	7.00
Q30-10 Flow												
2.770	0.07	0.00	0.07	.0773	0.00298	NA	NA	NA	0.05	3.269	22.59	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20C	34431	Trib 34431 to Big Run

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.770	Morain	12.56	18.05	12.56	18.05	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.770	Morain	1.6	3.08	1.6	3.08	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.77	Morain	12.93	12.93	3.08	3.08	4.25	4.25	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	34431	Trib 34431 to Big Run		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
2.770	0.050	22.972		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
7.189	0.377	19.052		0.048
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
8.50	0.358	1.83		0.880
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
5.870	18.467	Owens		5
<u>Reach Travel Time (days)</u>	Subreach Results			
3.529	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>
	(days)	(mg/L)	(mg/L)	(mg/L)
	0.353	7.35	1.34	8.12
	0.706	6.36	0.98	8.24
	1.059	5.51	0.72	8.24
	1.411	4.76	0.53	8.24
	1.764	4.12	0.39	8.24
	2.117	3.57	0.28	8.24
	2.470	3.09	0.21	8.24
	2.823	2.67	0.15	8.24
	3.176	2.31	0.11	8.24
	3.529	2.00	0.08	8.24

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
20C		34431		Trib 34431 to Big Run			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.770	Morain	PA	0.050	CBOD5	12.93		
				NH3-N	3.08	6.16	
				Dissolved Oxygen			4.25

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	34431	Trib 34431 to Big Run	3.080	1282.73	0.91	0.00000	0.00	<input type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.014	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Moraine Camp	PA0093157A	0.0500	0.0500	0.0500	0.000	25.00	7.50

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	34431 Trib	34431 to Big Run	2.770	1225.98	3.77	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.014	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	34431 Trib	34431 to Big Run	0.000	1182.43	293.56	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.014	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		34431				Trib 34431 to Big Run						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
3.080	0.01	0.00	0.01	.0773	0.03467	.353	3.9	11.03	0.07	0.289	24.29	7.50
2.770	0.05	0.00	0.05	.0773	0.00298	.377	7.19	19.05	0.05	3.529	22.97	7.50
Q1-10 Flow												
3.080	0.01	0.00	0.01	.0773	0.03467	NA	NA	NA	0.06	0.298	24.52	7.50
2.770	0.03	0.00	0.03	.0773	0.00298	NA	NA	NA	0.04	3.855	23.48	7.50
Q30-10 Flow												
3.080	0.02	0.00	0.02	.0773	0.03467	NA	NA	NA	0.07	0.282	24.08	7.50
2.770	0.07	0.00	0.07	.0773	0.00298	NA	NA	NA	0.05	3.269	22.59	7.50

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	3		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20C	34431	Trib 34431 to Big Run

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.080	Moraine Camp	NA	50	6.35	13.36	2	73
2.770		NA	NA	6.92	NA	NA	NA

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.080	Moraine Camp	NA	25	1.07	2.98	2	88
2.770		NA	NA	1.18	NA	NA	NA

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
3.08	Moraine Camp	25	25	2.98	2.98	3	3	0	0
2.77		NA	NA	NA	NA	NA	NA	NA	NA

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
20C	34431	Trib 34431 to Big Run			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
3.080	0.050	24.293		7.500	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
3.897	0.353	11.034		0.065	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
21.75	1.474	2.57		0.974	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
3.741	26.510	Owens		NA	
<u>Reach Travel Time (days)</u>	Subreach Results				
0.289	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.029	20.65	2.50	4.90	
	0.058	19.60	2.43	5.51	
	0.087	18.61	2.36	5.85	
	0.116	17.66	2.30	6.06	
	0.145	16.77	2.23	6.22	
	0.174	15.92	2.17	6.35	
	0.203	15.11	2.11	6.45	
	0.232	14.35	2.05	6.55	
	0.261	13.62	1.99	6.64	
	0.289	12.93	1.94	6.73	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
2.770	0.050	22.972		7.500	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
7.189	0.377	19.052		0.048	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
9.57	0.387	1.33		0.880	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
7.196	18.467	Owens		3	
<u>Reach Travel Time (days)</u>	Subreach Results				
3.529	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.353	8.18	0.98	8.15	
	0.706	7.00	0.72	8.24	
	1.059	5.98	0.52	8.24	
	1.411	5.12	0.38	8.24	
	1.764	4.37	0.28	8.24	
	2.117	3.74	0.21	8.24	
	2.470	3.20	0.15	8.24	
	2.823	2.74	0.11	8.24	
	3.176	2.34	0.08	8.24	
	3.529	2.00	0.06	8.24	

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20C	34431	Trib 34431 to Big Run					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.080	Moraine Camp	PA0093157A	0.050	CBOD5	25		
				NH3-N	2.98	5.96	
				Dissolved Oxygen			3