

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0093254  
 APS ID 1070066  
 Authorization ID 1407706

**Applicant and Facility Information**

Applicant Name	<u>Sugar Creek Rest, Inc.</u>	Facility Name	<u>Sugar Creek Rest Home</u>
Applicant Address	<u>120 Lakeside Drive</u> <u>Worthington, PA 16262-5102</u>	Facility Address	<u>120 Lakeside Drive</u> <u>Worthington, PA 16262-5102</u>
Applicant Contact	<u>Dee Hillberry</u> <u>(dhillberry@qualitylifeservices.com)</u>	Facility Contact	<u>Dee Hillberry</u> <u>(dhillberry@qualitylifeservices.com)</u>
Applicant Phone	<u>(724) 445-3000, ext. 2846</u>	Facility Phone	<u>(724) 445-3000, ext. 2846</u>
Client ID	<u>280</u>	Site ID	<u>250139</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Sugarcreek Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Armstrong</u>
Date Application Received	<u>August 22, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 26, 2022</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater.</u>		

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The Permittee should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling
- D. Public Sewerage Availability
- E. Effluent Chlorine Optimization and Minimization
- F. Little Assimilative Capacity

SPECIAL CONDITIONS:

- II. Solids Management

There are no open violations in efacts for Client ID (280) as of 12/27/2023. [CWY 12/27/2023](#)

Approve	Return	Deny	Signatures	Date
X			Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	12/27/2023
X			Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	12/27/2023

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.02</u>
Latitude	<u>40° 53' 40.00"</u>	Longitude	<u>-79° 40' 6.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to the Patterson Creek (HQ-TSF)</u>	Stream Code	<u>UNT to 42695</u>
NHD Com ID	<u>123970867</u>	RMI	<u>0.05</u>
Drainage Area	<u>0.12</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1 (default)</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.012</u>	Q <sub>7-10</sub> Basis	<u>calculated</u>
Elevation (ft)	<u>1322</u>	Slope (ft/ft)	<u>0.03179</u>
Watershed No.	<u>18-F</u>	Chapter 93 Class.	<u>HQ-TSF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Buffalo Township Municipal Water Authority - Freeport</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>2576</u>
PWS RMI	<u>30.0</u>	Distance from Outfall (mi)	<u>26.0</u>

Sludge use and disposal description and location(s): Sludge is hauled by CWM Environmental to the AVJSA WWTP, where it is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.02 MGD of treated sewage from a non-municipal STP in Sugarcreek Township, Armstrong County.

Existing treatment consists of: Comminutor with bypass bar screen, an equalization tank, aeration tanks, a clarifier, tablet chlorination with a contact tank, tablet dechlorination, and post aeration.  
(WQM Permit no. 0377406)

**1. Streamflow:**

Unnamed Tributary to the Patterson Creek:

Drainage Area: 0.12 sq. mi. (from StreamStats)  
Yieldrate: 0.1 cfsm (Default)  
% of stream allocated: 100% Basis: no nearby discharges  
Q<sub>7-10</sub>: 0.012 cfs (Calculated)

**2. Wasteflow:**

Maximum discharge: 0.02 MGD = 0.03 cfs

Runoff flow period: 24 hours Basis: Runoff flow with flow equalization

The calculated stream flow (Q<sub>7-10</sub>) is greater than 3 times the permitted discharge flow. In accordance with the SOP, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were not evaluated for this facility.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

**3. Parameters:**

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, Phosphorus, NH<sub>3</sub>-N, CBOD<sub>5</sub>, Dissolved Oxygen, and Disinfection.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: The previous limits are more restrictive. Based on the eDMR data, the previous, more restrictive limits of 25.0 mg/l as a monthly average and 50.0 as an instantaneous maximum are attainable so they will be retained.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)  
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)  
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a.47 technology-based limits.

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows between 0.002 MGD and 0.05 MGD.

e. Total Phosphorus

Monitoring for Total Phosphorus will be retained with this renewal in accordance with the SOP, based on Chapter 92a.61.

f. Total Nitrogen

Monitoring for Total Nitrogen will be retained with this renewal in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH<sub>3</sub>-N)

Median discharge pH to be used: 7.4 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: Default value used in the absence of data

Stream Temperature: 25°C (default value used for HQ/TSF modeling)

Background NH<sub>3</sub>-N concentration: 0.1 mg/l

Basis: Default value used in the absence of data

calculated summer NH<sub>3</sub>-N limits: 2.3 mg/l (monthly average)  
4.6 mg/l (instantaneous maximum)

calculated winter NH<sub>3</sub>-N limits: 6.9 mg/l (monthly average)  
13.8 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 1), which are slightly more restrictive than in the previous NPDES Permit. The winter limits are calculated as three times the summer limits. Based on the eDMR data, the more restrictive limits are attainable so a compliance schedule will not be necessary.

h. CBOD<sub>5</sub>

Median discharge pH to be used: 7.4 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used in the absence of data)  
Median stream pH to be used: 7.0 Standard Units (S.U.)  
Basis: Default value used in the absence of data

Stream Temperature: 25°C (default value used for HQ/TSF modeling)  
Background CBOD<sub>5</sub> concentration: 2.0 mg/l  
Basis: Default value used in the absence of data

calculated CBOD<sub>5</sub> limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated CBOD<sub>5</sub> limits above (see Attachment 1), which are less restrictive than the previous NPDES Permit. Based on the eDMR data, the previous, more restrictive limits of 20.0 mg/l as a monthly average and 40.0 as an instantaneous maximum are attainable so they will be retained.

i. Dissolved Oxygen (DO)

The technology-based minimum of 5.0 mg/l is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61. However, the previous Dissolved Oxygen minimum requirement was set as 6.0 mg/l. Based on the eDMR data, the previous, more restrictive limits are attainable so they will be retained.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

j. Disinfection

- Ultraviolet (UV) light monitoring
- Total Residual Chlorine (TRC): 0.06 mg/l (monthly average)  
0.21 mg/l (instantaneous maximum)

Basis: The TRC limits above were calculated using the Department's TRC Calculation Spreadsheet (see Attachment 2). The limits are less restrictive than in the previous NPDES Permit. Based on the eDMR data, the previous, more restrictive limits are attainable so they will be retained.

The measurement frequency will be set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

**4. Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was not performed in accordance with State practices using the Department's Toxics Management Spreadsheet since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

**5. Reasonable Potential for Downstream Public Water Supply (PWS):**

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no sample data was provided, mass-balance calculations were not performed.

Nearest Downstream potable water supply (PWS): Buffalo Township Municipal Water Authority - Freeport  
Distance downstream from the point of discharge: 26.0 miles (approximate)

Result: No limits are necessary as significant dilution is available

**6. Anti-Backsliding:**

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

**7. Attachment List:**

- Attachment 1 - WQ Modeling Printouts
- Attachment 2 - TRC\_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from November 1, 2022 to October 31, 2023)

Parameter	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22
Flow (MGD) Average Monthly	0.020	0.00264	0.020	0.0200	0.01854	0.01621	0.01593	0.01583	0.01589	0.0154	0.01534	0.01528
Flow (MGD) Daily Maximum	0.02702	0.02126	0.02345	0.06865	0.02151	0.01977	0.02736	0.01892	0.02354	0.023	0.02221	0.01566
pH (S.U.) Minimum	7.1	7.1	7.3	6.8	7.1	7.2	7.2	7.2	7.2	7.2	7.3	7.1
pH (S.U.) Maximum	7.6	7.8	8.2	7.8	8.2	7.6	7.7	7.7	7.8	8.0	7.8	7.8
DO (mg/L) Minimum	6.4	6.9	6.5	6.8	6.4	6.3	6.3	6.1	6.1	6.1	6.0	6.0
TRC (mg/L) Average Monthly	0.03	0.02	0.02	0.02	0.02	0.02	0.03	0.03	0.02	0.02	0.02	0.02
TRC (mg/L) Instantaneous Maximum	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.12	0.03	0.03	0.03	0.03
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.0	< 3.7	< 3.0	4.4	6.5	< 3.7	< 3.0	< 3.0	< 3.0	< 3.0
CBOD5 (mg/L) Instantaneous Maximum	< 3.0	< 3.0	< 3.0	4.4	< 3.0	5.5	7.8	4.4	< 3.0	3.0	< 3.0	< 3.0
TSS (mg/L) Average Monthly	7.0	< 5.0	9.0	< 4.0	< 3.0	< 3.0	< 3.0	< 3.0	4.0	4.0	< 3.0	3.5
TSS (mg/L) Instantaneous Maximum	10.0	6.0	9.0	5.0	< 3.0	< 3.0	3.0	< 3.0	5.0	4.0	3.0	4.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 1.0	90.0	< 1.0	< 1.0	< 1.0	< 146	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0
Fecal Coliform (No./100 ml) Maximum	< 1.0	< 1.0	462	< 1.0	< 1.0	< 1.0	291	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0
Total Nitrogen (mg/L) Daily Maximum											4.04	
Ammonia (mg/L) Average Monthly	2.77	4.17	0.97	0.27	1.62	6.61	< 1.7	0.81	< 0.21	0.20	0.20	0.14
Ammonia (mg/L) Instantaneous Maximum	5.07	5.13	1.73	0.33	2.5	7.97	3.3	1.50	0.32	0.26	0.29	0.49
Total Phosphorus (mg/L) Daily Maximum											0.48	

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	6.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.04	XXX	0.13	1/day	Grab
CBOD5	XXX	XXX	XXX	20.0	XXX	40.0	2/month	Grab
TSS	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	6.9	XXX	13.8	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.3	XXX	4.6	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are water quality-based on Chapter 93.7. The limits for CBOD<sub>5</sub>, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7.



Attachment 1

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18F		42695		PATTERSON CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.400	Sugar Creek	PA0093254	0.020	CBOD5	25		
				NH3-N	2.33	4.66	
				Dissolved Oxygen			5

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
18F	42695	PATTERSON CREEK	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
1.400	0.020	21.397	7.247
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
1.961	0.327	5.998	0.067
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
18.57	1.365	1.68	0.779
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
5.710	29.021	Owens	5
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>		
1.277	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.128	15.42	1.52
	0.255	12.81	1.38
	0.383	10.63	1.24
	0.511	8.83	1.13
	0.638	7.33	1.02
	0.766	6.09	0.92
	0.894	5.06	0.84
	1.022	4.20	0.76
	1.149	3.49	0.69
	1.277	2.90	0.62

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42695	PATTERSON CREEK	1.400	1322.00	0.12	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Sugar Creek	PA0093254	0.0200	0.0000	0.0000	0.000	20.00	7.40

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42695	PATTERSON CREEK	0.000	1087.00	1.51	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18F		42695				PATTERSON CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
1.400	0.01	0.00	0.01	.0309	0.03179	.327	1.96	6	0.07	1.277	21.40	7.25
<b>Q1-10 Flow</b>												
1.400	0.01	0.00	0.01	.0309	0.03179	NA	NA	NA	0.06	1.355	20.99	7.29
<b>Q30-10 Flow</b>												
1.400	0.02	0.00	0.02	.0309	0.03179	NA	NA	NA	0.07	1.210	21.73	7.22

**WQM 7.0 Wasteload Allocations**

SWP Basin      Stream Code                      Stream Name  
 18F                      42695                                      PATTERSON CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.400	Sugar Creek	11.41	14.24	11.41	14.24	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.400	Sugar Creek	1.52	2.33	1.52	2.33	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.40	Sugar Creek	25	25	2.33	2.33	5	5	0	0

Attachment 2

<b>TRC EVALUATION</b>				
Input appropriate values in A3:A9 and D3:D9				
0.012	= Q stream (cfs)		0.5	= CV Daily
0.02	= Q discharge (MGD)		0.5	= CV Hourly
30	= no. samples		1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 0.143		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.053		5.1d
		WLA_cfc = 0.132		
		LTAMULT_cfc = 0.581		
		LTA_cfc = 0.077		
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.065		AFC
		INST_MAX_LIMIT (mg/l) = 0.214		
WLA_afc	$(.019/e(-k*AFC\_tc)) + [(AFC\_Yc*Qs*.019/Qd*e(-k*AFC\_tc))... \\ ...+ Xd + (AFC\_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$			
LTA_afc	$wla\_afc*LTAMULT\_afc$			
WLA_cfc	$(.011/e(-k*CFC\_tc)) + [(CFC\_Yc*Qs*.011/Qd*e(-k*CFC\_tc))... \\ ...+ Xd + (CFC\_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no\_samples+1))-2.326*LN(cvd^2/no\_samples+1)^0.5)$			
LTA_cfc	$wla\_cfc*LTAMULT\_cfc$			
AML_MULT	$EXP(2.326*LN((cvd^2/no\_samples+1)^0.5)-0.5*LN(cvd^2/no\_samples+1))$			
AVG_MON_LIMIT	$MIN(BAT\_BPJ,MIN(LTA\_afc,LTA\_cfc)*AML\_MULT)$			
INST_MAX_LIMIT	$1.5*((av\_mon\_limit/AML\_MULT)/LTAMULT\_afc)$			